

DOMESTIC WATER VALVES

- D1 MAINLINE ISOLATION
- D2 DIALYSIS DOMESTIC & FIRE SHUT-OFF
- D3 MAINLINE ISOLATION
- D4 MAINLINE ISOLATION-SOUTHWEST LOOP
- D5 MAINLINE ISOLATION-SOUTHEAST LOOP
- D6 MAINLINE ISOLATION
- D7 FIRE HYDRANT #1 SHUT-OFF
- D8 EMERGENCY ROOM DOMESTIC SHUT-OFF
- D9 MAINLINE ISOLATION
- D10 EMERGENCY ROOM FIRE SHUT-OFF
- D11 FUTURE CONNECTION
- D12 MAINLINE ISOLATION
- D13 FIRE HYDRANT #2 SHUT-OFF
- D14 FINANCE BUILDING DOMESTIC & FIRE SHUT-OFF
- D15 FIRE HYDRANT #3 SHUT-OFF
- D16 FINANCE BUILDING DOMESTIC SHUT-OFF
- D17 SECURITY TRAILER DOMESTIC SHUT-OFF
- D18 FINANCE BUILDING FIRE SHUT-OFF
- D19 MAINLINE ISOLATION-WEST SPLITTER
- D20 ANCILLARY DOMESTIC SHUT-OFF
- D21 WOMEN'S CENTER DOMESTIC SHUT-OFF
- D22 MAINLINE ISOLATION
- D23 ANCILLARY FIRE SHUT-OFF
- D24 FIRE HYDRANT #4 SHUT-OFF
- D25 WOMEN'S CENTER FIRE SHUT-OFF
- D26 MENTAL HEALTH UNIT FIRE SHUT-OFF
- D27 MENTAL HEALTH UNIT DOMESTIC SHUT-OFF
- D28 MAINLINE ISOLATION
- D29 FIRE HYDRANT #5 SHUT-OFF
- D30 NORTH WING/OB FIRE SHUT-OFF
- D31 NORTH WING/OB FIRE & HYDRANT #6 SHUT-OFF
- D32 FIRE HYDRANT #6 SHUT-OFF
- D33 MAINLINE ISOLATION
- D34 FIRE HYDRANT #7 SHUT-OFF
- D35 MRI DOMESTIC SHUT-OFF
- D36 MAINLINE ISOLATION
- D37 PAVILION DOMESTIC SHUT-OFF
- D38 PAVILION FIRE SHUT-OFF
- D39 FIRE HYDRANT #8 SHUT-OFF
- D40 MAINLINE ISOLATION-NORTH LOOP
- D41 MAINLINE ISOLATION FROM THUNDER DRIVE METER
- D42 MAINLINE ISOLATION-SOUTH LOOP
- D43 MAINLINE ISOLATION
- D44 NORTH WING/OB DOMESTIC SHUT-OFF
- D45 FIRE HYDRANT #9 SHUT-OFF
- D46 MAINLINE ISOLATION
- D47 SURGERY DOMESTIC SHUT-OFF
- D48 SURGERY DOMESTIC SHUT-OFF
- D49 MAINLINE ISOLATION
- D50 SURGERY FIRE SHUT-OFF
- D51 MAINLINE ISOLATION
- D52 FIRE HYDRANT #10 SHUT-OFF
- D53 MAINLINE ISOLATION
- D54 CENTER BUILDING & GENERATOR FIRE SHUT-OFF
- D55 GENERATOR BUILDING FIRE SHUT-OFF
- D56 CENTER BUILDING DOMESTIC SHUT-OFF
- D57 MAINLINE ISOLATION
- D58 FIRE HYDRANT #12 SHUT-OFF
- D59 FIRE HYDRANT SHUT-OFF
- D60 SOUTH TOWER DOMESTIC SHUT-OFF
- D61 CENTER BUILDING DOMESTIC SHUT-OFF
- D62 FIRE HYDRANT #13 SHUT-OFF
- D63 MAINLINE ISOLATION FROM THUNDER DRIVE METER
- D64 CENTRAL PLANT FIRE SHUT-OFF
- D65 CENTRAL PLANT DOMESTIC SHUT-OFF
- D66 CENTRAL PLANT DOMESTIC BLOWOFF

IRRIGATION VALVES

- V1 MAINLINE ISOLATION
- V2 CENTRAL PLANT AREA FEED
- V3 MAINLINE ISOLATION
- V4 MAINLINE ISOLATION
- V5 EMERGENCY & PORTION OF WEST PARKING LOT
- V6 MAINLINE ISOLATION
- V7 FINANCE BUILDING AREA FEED
- V8 MAINLINE ISOLATION
- V9 WOMEN'S CENTER AREA FEED
- V10 WEST PARKING LOT AREA FEED
- V11 MAINLINE ISOLATION
- V12 MAINLINE ISOLATION
- V13 MAINLINE ISOLATION
- V14 MAINLINE ISOLATION
- V15 MAINLINE ISOLATION

FIRE HYDRANTS

- FH1 FEED FOR PIV1, EMERGENCY
- FH2 GENERAL USE
- FH3 FEED FOR PIV2, FINANCE BUILDING
- FH4 FEED FOR PIV3, PIV4, & PIV5, ANCILLARY WOMEN'S CENTER, & MENTAL HEALT UNIT
- FH5 GENERAL USE
- FH6 FEED FOR PIV6, NORTH WING/OB
- FH7 FEED FOR PIV7, PAVILION
- FH8 GENERAL USE
- FH9 GENERAL USE
- FH10 GENERAL USE
- FH11 FEED FOR PIV9, CENTER BUILDING
- FH12 GENERAL USE
- FH13 FEED FOR PIV10, CENTRAL PLANT

POST INDICATOR VALVES

- PIV1 EMERGENCY
- PIV2 FINANCE BUILDING
- PIV3 ANCILLARY
- PIV4 WOMEN'S CENTER
- PIV5 MENTAL HEALTH UNIT
- PIV6 NORTH WING/OB
- PIV7 PAVILION
- PIV8 SURGERY
- PIV9 CENTER & GENERATOR BUILDING
- PIV10 CENTRAL PLANT
- PIV11 DIALYSIS

THIS WATER METER HAS BEEN CONSTRUCTED WITHIN AN EASEMENT GRANTED TO THE CITY OF OCEANSIDE PER DOCUMENT #99-69953, RECORDED 12/27/89. THE ADJACENT REDUCED PRESSURE BACKFLOW DEVICE IS OUTSIDE OF THE EASEMENT.

BOTH THE THUNDER DRIVE AND VISTA WAY 10" WATER METERS ARE MAINTAINED BY THE CITY OF OCEANSIDE WATER UTILITIES DEPARTMENT. THE 4" WATER METER ON THUNDER DRIVE IS MAINTAINED BY THE VISTA IRRIGATION DISTRICT.

ABBREVIATIONS

- A ASBESTOS CEMENT PIPE
- ARV 1" AIR RELEASE VALVE
- BO 2" BLOW OFF
- C9 C-900 PVC CLASS 150 PIPE
- CU COPPER PIPE
- GV GATE VALVE
- FDC FIRE DEPARTMENT CONNECTION
- FH FIRE HYDRANT
- FH1 FIRE INDICATOR VALVE
- PIV POST INDICATOR VALVE
- PVC POLYVINYL CHLORIDE, GRADE OF PIPE UNKNOWN
- RP REDUCED PRESSURE BACKFLOW PREVENTER
- S4 SCHEDULED 40 PIPE
- VID VISTA IRRIGATION DISTRICT
- WM WATER METER


EMERGENCY NUMBERS

CITY OF OCEANSIDE	966-4900
VISTA IRRIGATION DISTRICT	724-8811

DOMESTIC WATER CONNECTIONS WILL NOT BE PERMITTED TO THE IRRIGATION SYSTEM. THE IRRIGATION SYSTEM WILL BE CONNECTED TO THE CITY RECLAIMED WATER MAIN WHEN AVAILABLE.

LEGEND

- DOMESTIC WATER MAIN
- IRRIGATION WATER MAIN
- ⊗ GATE VALVE
- ⊕ FIRE HYDRANT
- ▬ 1" AIR RELEASE VALVE
- 2" BLOW OFF
- ⊠ WATER METER
- ⊞ REDUCED PRESSURE BACKFLOW PREVENTER
- ⊙ POST INDICATOR VALVE
- ⊕ FIRE DEPARTMENT CONNECTION



Tri-City Medical Center
4002 Vista Way, Oceanside, California 92056 (619) 724-8411

MASTER WATER SYSTEM MAP