Tri City Medical Center Air Handler Filter Listing

Unit ID#	Location	Qty.	Туре	Size	Efficiency
AHU#1	South Tower	3	Primary	24×24×2	MERV 8
AHU#1	South Tower	3	Primary	12x24x2	MERV 8
AHU#1	South Tower	3	Secondary	24x24x12	MERV 12
AHU#1	South Tower	3	Secondary	12x24x12	MERV 12
AHU#2	South Tower	8	Primary	24x24x4	MERV 8
AHU#2	South Tower	8	Secondary	24x24x12	MERV 15
AHU#3	South Tower	3	Primary	24x24x2	MERV 8
AHU#3	South Tower	3	Secondary	24x24x12	MERV 15
AHU#4	South Tower Roof	5	Primary	24x24x2	MERV 8
AHU#4	South Tower Roof	5	Primary	12x24x2	MERV 8
AHU#4	South Tower Roof	5	Secondary	24x24x12	MERV 11
AHU#4	South Tower Roof	5	Secondary	12x24x12	MERV 11
AHU#7	Mech. Rm. 5	10	Primary	24x24x2	MERV 8
AHU#7	Mech. Rm. 5	10	Secondary	24x24x12	MERV 14
AHU#8	Mech. Rm 5	10	Primary	24x24x2	MERV 8
AHU#8	Mech. Rm 5	10	Secondary	24x24x12	MERV 14
AHU#9	Mech. Rm. 5	8	Primary	24x24x2	MERV 8
AHU#9	Mech. Rm. 5	8	Secondary	24x24x12	MERV 14
AHU#10	Lab Roof	10	Primary	24x24x2	MERV 8
AHU#10	Lab Roof	10	Secondary	24x24x12	MERV 14
AHU#11	Mech. Rm. 1	6	Primary	24x24x2	MERV 8
AHU#11	Mech. Rm. 1	6	Pre-Pri	24x24x12	MERV 15
AHU#11	Mech. Rm. 1	9	Secondary	24x24x12	MERV 12
AHU#12	Mech. Rm. 1	8	Primary	16x25x2	MERV 8
AHU#12	Mech. Rm. 1	12	Primary	16x20x2	MERV 8
AHU#12	Mech. Rm. 1	1	Secondary	12x24x12	MERV 15
AHU#12	Mech. Rm. 1	13	Secondary	24x24x12	MERV 15
AHU#14	Mech. Rm. 1	2	Primary	24x24x2	MERV 8
AHU#14	Mech. Rm. 1	2	Secondary	24x24x12	MERV 15

Unit ID#	Location	Qty.	Туре	Size	Efficiency
AHU#15	Mech. Rm. 1	8	Primary	24x24x2	MERV 8
AHU#15	Mech. Rm. 1	2	Primary	12x24x2	MERV 8
AHU#15	Mech. Rm. 1	8	Pre-Sec	24x24x12	MERV 15
AHU#15	Mech. Rm. 1	2	Pre-Sec	12x24x12	MERV 12
AHU#15	Mech. Rm. 1	12	Secondary	24x24x12	MERV 14
71101123	Wicelli Will 2		Secondary	Z IXZ IXZZ	WERT I
AHU#16	X-Ray Well	2	Primary	24x24x2	MERV 8
AHU#16	X-Ray Well	2	Primary	12x24x2	MERV 8
AHU#16	X-Ray Well	2	Secondary	12x24x12	MERV 14
AHU#16	X-Ray Well	2	Secondary	24x24x12	MERV 14
74101120	A Hay Well	_	Secondary	Z IXZ IXZZ	WERT I
AHU#17	X-Ray Well	2	Primary	24x24x2	MERV 8
AHU#17	X-Ray Well	2	Secondary	24x24x12	MERV 14
7410#17	X Ray Well		Secondary	ZHXZHXIZ	IVILITY IT
AHU#18	RCU Roof	3	Primary	24x24x4	MERV 11
AHU#18	RCU Roof	2	Primary	24x12x4	MERV 11
AHU#18	RCU Roof	8	Secondary	24x24x12	MERV 14
Allowio	NCO NOO!	8	Secondary	24724712	IVILITY 14
AHU#19	RCU Roof	3	Primary	24x12x4	MERV 11
AHU#19	RCU Roof	3	Primary	24x24x12	MERV 11
AHU#19	RCU Roof	6	Secondary	24x24x12	MERV 14
Allowin	NCO NOO!	U	Secondary	24724712	IVILITY 14
AHU#20	RCU Roof	1	Primary	24x24x2	MERV 8
AHU#20	RCU Roof	1	Secondary	24x24x12	MERV 14
74101120	Nee nee		Secondary	Z IAZ IAIZ	WEW IT
AHU#21	Women's Center	10	Primary	24x24x4	MERV 8
	Roof		,		
AHU#21	Women's Center	5	Primary	12x24x4	MERV 8
	Roof		,		
AHU#21	Women's Center	20	Secondary	24x24x12	MERV 14
	Roof				
AHU#22	Women's Center	12	Primary	24x24x4	MERV 8
	Roof				
AHU#22	Women's Center	8	Primary	12x24x4	MERV 8
	Roof				
AHU#22	Women's Center	20	Secondary	24x24x12	MERV 16 Biocel
	Roof			1	
AHU#22	Women's Center	8	Secondary	12x24x12	MERV 16 Biocel
	Roof				
A11111122	District Time 5	2	Dita	24.24.2	AAEDV (O
AHU#23	Physical Therapy Roof	2	Primary	24x24x2	MERV 8
AHU#23	Physical Therapy Roof	2	Secondary	24x24x12	MERV 15

Unit ID#	Location	Qty.	Туре	Size	Efficiency
AHU#24	Employee Health	1	Primary	24x24x2	MERV 8
AHU#24	Employee Health	1	Primary	12x24x2	MERV 8
AHU#24	Employee Health	1	Secondary	24x24x12	MERV 15
AHU#24	Employee Health	1	Secondary	12x24x12	MERV 15
74101121	zmproyee medicin	_	Secondary	TEXE IXIE	WEITT 15
Unit ID#	Location	Qty.	Туре	Size	Efficiency
AHU#25	BHU Roof	3	Primary	24x24x2	MERV 8
AHU#25	BHU Roof	3	Primary	12x24x2	MERV 8
AHU#25	BHU Roof	3	Secondary	24x24x12	MERV 14
AHU#25	BHU Roof	3	Secondary	12x24x12	MERV 14
74101125	BITO NOOT	3	Secondary	ΙΖΑΣΨΑΙΣ	WILKV 14
AHU#26	BHU Roof	6	Primary	24x24x4	MERV 8
AHU#26	BHU Roof	3	Primary	12x24x4	MERV 8
AHU#26	BHU Roof	6	Secondary	24x24x12	MERV 14
AHU#26	BHU Roof	3	Secondary	12x24x12	MERV 14
Allowed	BHO NOOF	3	Secondary	12/24/12	IVILITY 14
AHU#28	Ancillary Roof	12	Primary	24x24x2	MERV 8
AHU#28	Ancillary Roof	4	Primary	20x24x2	MERV 8
AHU#28	Ancillary Roof	8	Secondary	24x24x12	95%
AHU#28	Ancillary Roof	4	Secondary	20x24x12	95%
AITO#20	Ancillary Noor	4	Secondary	20,24,12	3370
AHU#29	Pavilion Basement	30	Primary	20x25x2	MERV 8
AHU#29	Pavilion Basement	20	Secondary	24x24x12	MERV 15
AIIO#25	r aviiion basement	20	Secondary	24724712	WILKV 13
AHU#30	Pavilion Roof	36	Primary	20x25x2	MERV 8
AHU#30	Pav. Roof (Optional)	36	New Prim	20x25x2	MERV 8 Megapleat
AHU#30	Pavilion Roof	25	Secondary	24x24x12	MERV 15
74101130	T d v III O I T T O O I	23	Secondary	ΣπλΣπλίΣ	WIERV 15
AHU#31	CT Scan Roof	2	Primary	24x24x4	MERV 8
AHU#31	CT Scan Roof	2	Secondary	24x24x12	MERV 14
7(10/131	CT Scarritoor		Secondary	ΣπλΣπλίΣ	WILKV 14
AHU#38	Lab Roof	2	Primary	20x20x2	MERV 8
AHU#38	Lab Roof	2	Primary	20x24x2	MERV 8
AHU#38	Lab Roof	1	Secondary	24x12x12	MERV 14
AHU#38	Lab Roof	1	Secondary	24x24x12	MERV 14
7.1.01130	200 NOO!		Secondary	= 175-1715	WILITY IT
AHU#39	Mail Room	3	Primary	24x24x2	MERV 8
AHU#39	Mail Room	3	Secondary	24x12x12	MERV 14
	THAI NOOM	3	Secondary	- 1/175/175	1412114 I
AHU#40	RCU TUB ROOM	1	Primary	20x16x2	MERV 8
AHU#40	RCU TUB ROOM	1	Primary	16x16x2	MERV 8
7110#40	ACC TOD ROOM	-	7 Tillial y	10/10/2	IVILITY O

Unit ID#	Location	Qty.	Type	Size	Efficiency
AHU#41	ER MECH RM	12	Primary	24x24x4	MERV 8
AHU#41	ER MECH RM	3	Primary	24x12x4	MERV 8
AHU#41	ER MECH RM	12	Secondary	24x24x12	MERV 14
AHU#41	ER MECH RM	3	Secondary	24x12x12	MERV 14
71101141	ER WEET RIVI	,	Secondary	ZHAIZAIZ	IVILITY IT
AHU#42	Cath Lab Roof	4	Primary	24x24x4	MERV 8
AHU#42	Cath Lab Roof	4	Secondary	24x24x12	MERV 12
71101142	Cath Lab Noor	7	Secondary	24724712	IVILITY IZ
Unit ID#	Location	Qty.	Type	Size	Efficiency
AHU#43	Lobby Roof	2	Primary	24x24x4	MERV 8
AHU#43	Lobby Roof	1	Secondary	12x24x12	MERV 14
AHU#43	Lobby Roof	1	Secondary	24x24x12	MERV 14
71511 15	-555, 11001	<u> </u>	Jecondary	- 1/12 1/12	
AHU#44	Lab Roof	2	Primary	24x24x4	MERV 8
AHU#44	Lab Roof	1	Primary	12x24x4	MERV 8
AHU#44	Lab Roof	2	Secondary	24x24x6	MERV 14
AHU#44	Lab Roof	1	Secondary	12x24x6	MERV 14
71101144	Lab Noor		Secondary	12/24/0	IVILITY IT
AHU#45	ER Penthouse	8	Primary	24x24x4	MERV 8
AHU#45	ER Penthouse	4	Primary	24x12x4	MERV 8
AHU#45	ER Penthouse	8	Secondary	24x24x12	MERV 14
AHU#45	ER Penthouse	4	Secondary	12x24x12	MERV 14
Allon45	Livi entilouse	4	Secondary	12,24,12	IVILITY 14
AHU#46	WC Mechanical Room	6	Primary	24x24x4	MERV 8
AHU#46	WC Mechanical Room	3	Primary	12x24x4	MERV 8
AHU#46	WC Mechanical Room	6	Secondary	24x24x12	MERV 15
AHU#46	WC Mechanical Room	3	Secondary	12x24x12	MERV 15
71101140	W C WiceHarlical Noolii	,	Secondary	12/2-//12	WILKV 13
AHU#47	WC Mechanical Room	6	Primary	24x24x4	MERV 8
AHU#47	WC Mechanical Room	3	Primary	12x24x4	MERV 8
AHU#47	WC Mechanical Room	6	Secondary	24x24x12	MERV 15
AHU#47	WC Mechanical Room	3	Secondary	12x24x12	MERV 15
/(10π4/	VV C IVICCITATIICAI NOOIII	,	Secondary	12727712	IVILIA IJ
UAHU#1/48	Surgery	12	Primary	24x24x4	MERV 8
UAHU#1/48	Surgery	3	Primary	12x24x4	MERV 8
UAHU#1/48	Surgery	12	Secondary	24x24x12	99.97% HEPA
UAHU#1/48	Surgery	3	Secondary	12x24x12	99.97% HEPA
5/115/11/40		,	Secondary		33.3770112171
UAHU-2/49	Surgery	12	Primary	24x24x4	MERV 8
UAHU-2/49	Surgery	3	Primary	24x12x4	MERV 8
UAHU-2/49	Surgery	12	Secondary	24x24x12	99.97% HEPA
UAHU-2/49	Surgery	3	Secondary	12x24x12	99.97% HEPA
5,110 2,45		,	Secondary		33.3770112171

Unit ID#	Location	Qty.	Туре	Size	Efficiency
UAHU-50	Surgery	12	Primary	24x24x4	MERV 8
UAHU-50	Surgery	3	Primary	12x24x4	MERV 8
UAHU-50	Surgery	12	Secondary	24x24x11.5	99.97% HEPA
UAHU-50	Surgery	3	Secondary	12x24x11.5	99.97% HEPA
UAHU-51	Surgery	12	Primary	24x24x4	MERV 8
UAHU-51	Surgery	12	Secondary	24x24x12	99.97% HEPA
AHU-53	Lab Roof	12	Primary	24x24x2	Merv 8
AHU-53	Lab Roof	12	Secondary	24x24x12	Merv 12
AHU-54	BHU Roof	2	Pre-filter	24x24x2	MERV 8
AHU-54	BHU Roof	2	Pre-filter	12x24x2	MERV 8
AHU-54	BHU Roof	2	Primary	24x24x4	MERV 8
AHU-54	BHU Roof	2	Primary	12x24x4	MERV 8
AHU-54	BHU Roof	2	Secondary	24x24x12	MERV 14
AHU-54	BHU Roof	2	Secondary	12x24x12	MERV 14
CP AHU-1	Central Plant	2	Primary	20x25x2	MERV 8
CP AHU-1	Central Plant	6	Primary	16x25x2	MERV 8
CP AHU-1	Central Plant	4	Primary	20x20x2	MERV 8