

### TCMC USP 800 Upgrade 07/25/2018 ADDENDUM #1

The following items are issued as part of this Addendum:

- 1. OSHPD Approved documents:
  - a. Plan Set
  - b. TIO
  - c. Specifications

MEP:

P2S

9665 Chesapeake, suite 230 San Diego, CA 92123 P: 619-618-2347

# TCMC PHARMACY USP 800 UPGRADE

# TRI-CITY MEDICAL CENTER

4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056

CONSTRUCTION DOCUMENTS: 07/27/2017

 $\wedge$ OSHPD COMMENTS: 10/09/2017

<u>/2</u> DESIGN CHANGES: 10/09/2017  $\sqrt{3}$ 

OSHPD COMMENTS: 12/11/2017

 $\land$ DESIGN CHANGES: 12/11/2017

<u>∕</u>5√ OSHPD COMMENTS: 05/15/2018

DESIGN CHANGES: 06/05/2018

\_\_\_\_\_

### ARCHITECTURE:

R S F ARCHITECTS

5151 Shoreham Pl., Suite 100 San Diego, CA 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

6



**OSHPD PROJECT NUMBER:** S171641-37-00

STRUCTURAL:

SUN Structural Engineering, Inc.

2091 Las Palmas Dr., Ste. D Carlsbad, California 92011 760–438–1188 Fax: 760–438–1188





BE ON THE JOBSITE PRIOR TO STARTING THE INSTALLATION OF HANGERS AND/OR BRACES a) IT IS THE CONTRACTOR'S RESPONSIBILITY TO OBTAIN COPIES OF OPM AND FURNISH THE IOR WITH ONE COPY OF EACH. F. COMPONENTS OF TWO OR MORE PRE-APPROVED BRACING SYSTEMS SHALL NOT BE MIXED. a) ONLY ONE PRE-APPROVED BRACING SYSTEM MAY BE USED FOR A RUN OF PIPE, DUCT OR CONDUIT. b) ANY SUBSTITUTION OF COMPONENT OF A PRE-APPROVED BRACING SYSTEM SHALL REQUIRE OSHPD REVIEW AND APPROVAL. REFERENCE: 2016 CAC SECTIONS 7-115, 7-126, 7-153, AND CBC 2016 SECTION 107. REQUIREMENTS FOR ACCESSIBILITY STANDARDS IN ADDITION TO ALL LOCAL REQUIREMENTS AND THE AMERICANS WITH DISABILITIES ACT DRAWINGS (ADA), ACCESSIBLE FEATURES SHALL COMPLY WITH THE STATE OF CALIFORNIA ADMINISTRATIVE CODE OF REGULATIONS, BUILDING CODE, TITLE 24, PART 2 . DURING ALL HOURS THE BUILDING IS OPEN TO THE PUBLIC, ALL PRIMARY ENTRANCES TO THE BUILDING. THE PRIMARY PATH OF TRAVEL FROM THE ENTRANCES TO ALL PORTIONS OF THE BUILDING INCLUDING SANITARY FACILITIES, DRINKING FOUNTAINS AND PUBLIC TELEPHONES SERVING THE BUILDING MUST BE ACCESSIBLE TO THE DISARI ED ALL BUILDING ENTRANCES SHALL BE IDENTIFIED WITH AT LEAST ONE STANDARD SIGN AND WITH ADDITIONAL DIRECTIONAL SIGNS, AS REQUIRED, TO BE VISIBLE TO PERSONS ALONG APPROACHING PEDESTRIAN WAYS. SUBCONTRACTORS HAND-ACTIVATED DOOR OPENING HARDWARE SHALL BE 34" MIN. AND 44 INCHES MAX. ABOVE THE FINISH FLOOR OR GROUND. LATCHING AND LOCKING DOORS THAT ARE HAND-ACTIVATED AND WHICH ARE IN A PATH OF TRAVEL SHALL BE OPERABLE WITH A SINGLE EFFORT BY LEVER-TYPE HARDWARE, PANIC BARS, PUSH-PULL ACTIVATING BARS OR OTHER HARDWARE DESIGNED TO PROVIDE PASSAGE WITHOUT REQUIRING THE ABILITY TO GRASP THE OPENING HARDWARE. LOCKED EXIT DOORS SHALL OPERATE AS ABOVE IN EGRESS DIRECTION. (CBC SECTION 11B-404.2.7) MAXIMUM EFFORT TO OPERATE DOORS SHALL NOT EXCEED 5 POUNDS FOR EXTERIOR DOORS AND 5 POUNDS FOR INTERIOR DOORS, SUCH PULL OR PUSH EFFORT BEING APPLIED AT RIGHT ANGLES TO HINGED DOORS AND AT THE CENTER PLANE OF SLIDING OR FOLDING DOORS. COMPENSATING DEVICES OR AUTOMATIC DOOR ASSEMBLY. OPERATORS MAY BE UTILIZED TO MEET THE ABOVE STANDARDS. WHEN FIRE DOORS ARE REQUIRED. THE MAXIMUM EFFORT TO OPERATE THE DOOR MAY BE INCREASED TO THE MINIMUM ALLOWABLE BY THE APPROPRIATE ADMINISTRATIVE AUTHORITY, NOT TO EXCEED 15 POUNDS. (CBC SECTION 11B-404.2.9) THE BOTTOM 10 INCHES OF ALL DOORS EXCEPT AUTOMATIC AND SLIDING SHALL HAVE A SMOOTH. UNINTERRUPTED SURFACE TO ALLOW THE DOOR TO BE OPENED BY A WHEELCHAIR FOOTREST WITHOUT CREATING A TRAP OR HAZARDOUS CONDITION. WHERE NARROW FRAME DOORS ARE USED, A 10-INCH HIGH SMOOTH PANEL SHALL BE INSTALLED ON THE PUSH SIDE OF THE DOOR, WHICH WILL ALLOW THE DOOR TO BE OPENED BY A WHEELCHAIR FOOTREST WITHOUT CREATING A TRAP OR HAZARDOUS CONDITION. (CBC SECTION 11b-404.2.10) FOR HINGED DOORS, THE OPENING WIDTH SHALL BE MEASURED WITH THE DOOR POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION. AT LEAST ONE OF A PAIR OF DOORS SHALL MEET THIS OPENING WIDTH REQUIREMENT. (CBC SECTION 11B-404.2.2 & 11B-404.2.3) MANUALLY OPERATED EDGE OR SURFACE MOUNTED FLUSH BOLTS ARE NOT ALLOWED. WHEN EXIT DOORS ARE USED IN PAIRS AND APPROVED FLUSH BOITS ARE USED. THE DOOR LEAF HAVING THE AUTOMATIC FLUSH BOLTS CONSTRUCTION. SHALL HAVE NO DOOR KNOB OR SURFACE-MOUNTED HARDWARE. THE UNLATCHING OF ANY LEAF SHALL NOT REQUIRE MORE THAN ONE OPERATION. THERE SHALL BE A LEVEL AND CLEAR FLOOR OR LANDING ON EACH SIDE OF A DOOR. THE LEVEL AREA SHALL HAVE A LENGTH IN THE DIRECTION OF DOOR SWING OF A LEAST 60 INCHES AND THE LENGTH OPPOSITE THE DIRECTION OF THE DOOR SWING OF 48 INCHES AS MEASURED AT RIGHT ANGLES TO THE PLANE OF THE DOOR IN ITS CLOSED POSITION. THE WIDTH OF THE LEVEL AREA ON THE SIDE TO WHICH THE DOOR SWINGS SHALL EXTEND 24 INCHES PAST THE STRIKE EDGE OF THE DOOR FOR EXTERIOR DOORS AND 18 INCHES PAST THE STRIKE EDGE FOR INTERIOR DOORS. THE WIDTH OF THE AREA ON THE SIDE OPPOSITE THE SWING SHALL EXTEND 12 INCHES PAST THE STRIKE EDGE OF THE DOOR WHEN THE DOOR IS EQUIPPED WITH BOTH A CLOSER AND A LATCHSET. ABRUPT CHANGES IN LEVEL ALONG ANY ACCESSIBLE ROUTE SHALL NOT EXCEED 1/2 INCH. WHEN CHANGES IN LEVEL DO OCCUR, THEY SHALL BE BEVELED WITH A SLOPE NO GREATER THAN 1:2 EXCEPT THAT LEVEL CHANGES NOT EXCEEDING 1/4 INCH MAY BE VERTICAL. WHEN CHANGES IN LEVELS GREATER THAN 1/2 INCH ARE NECESSARY THEY SHALL COMPLY WITH THE REQUIREMENTS. 12. FOR RAMPS. MINIMUM WIDTH SHALL BE 48". 13. SIDE REACH MOUNTING HEIGHTS: IF THE CLEAR FLOOR SPACE ALLOWS PARALLEL APPROACH BY A PERSON IN A WHEELCHAIR, THE MAXIMUM HEIGHT FOR HIGH SIDE REACH SHALL BE 44 INCHES AND THE LOW SIDE REACH SHALL BE 15 INCHES ABOVE THE FINISHED FLOOR. 14. FORWARD REACH MOUNTING HEIGHTS: IF THE CLEAR SPACE ONLY ALLOWS FORWARD APPROACH BY A PERSON IN A WHEELCHAIR, THE MAXIMUM HEIGHT FOR HIGH SIDE REACH SHALL BE 48 INCHES AND THE LOW SIDE REACH SHALL BE 15 INCHES ABOVE THE FINISHED FLOOR. 15. DOORS LEADING TO MEN'S SANITARY FACILITIES SHALL BE IDENTIFIED BY AN EQUILATERAL TRIANGLE 1/4" THICK, WITH EDGES 12" LONG AND A VERTEX POINTING UPWARD. WOMEN'S SANITARY FACILITIES SHALL BE IDENTIFIED BY A CIRCLE 1/4" THICK AND 12" IN DIAMETER. 16. UNISEX SANITARY FACILITIES SHALL BE IDENTIFIED BY A CIRCLE 1/4" THICK, 12" DIAMETER, WITH A 1/4" THICK TRIANGLE SUPERIMPOSED ON THE CIRCLE AND WITHIN THE 12" DIAMETER.

E. A COPY OF THE CHOSEN BRACING SYSTEM(S) INSTALLATION GUIDE/OPM MANUAL SHALL

- 17. GEOMETRIC (CIRCLE AND TRIANGLE) SYMBOLS SHALL BE CENTERED ON THE DOOR AT A HEIGHT OF 60" ABOVE FINISHED FLOOR AND THEIR COLOR AND CONTRAST SHALL BE DISTINCTLY DIFFERENT FROM THE COLOR AND CONTRAST OF THE DOOR.
- 18. ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 11B-703. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE, INCLUDING DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL AND SIGNS SHALL BE MOUNTED 48" MINIMUM ABOVE FINISH FLOOR, MEASURED FROM THE BASELINE OF THE LOWEST LINE OF BRAILLE AND 60" MAXIMUM ABOVE THE FINISH FLOOR, MEASURED FROM THE BASELINE OF THE HIGHEST LINE OF RAISED CHARACTERS. CBC 11B-703.4.1

### VICINITY MAP:



### GENERAL NOTES

- THE GENERAL CONTRACTOR IS RESPONSIBLE FOR CHECKING CONTRACT DOCUMENTS FIELD CONDITIONS AND DIMENSIONS FOR ACCURACY, AND CONFIRMING THAT WORK BUILDABLE AS SHOWN BEFORE PROCEEDING WITH CONSTRUCTION. IF THERE ARE AN QUESTIONS REGARDING THESE OR OTHER COORDINATION ISSUES, THE GENERAL CONTRACTOR IS RESPONSIBLE FOR OBTAINING A CLARIFICATION FROM THE OWNERS REPRESENTATIVE BEFORE PROCEEDING WITH WORK IN QUESTION OR RELATED WORK.
- THE GENERAL CONTRACTOR SHALL INFORM THE OWNERS' REPRESENTATIVE, PRIOR TO CONSTRUCTION, OF ANY CONFLICTS THAT EXIST IN ANY AND ALL MECHANICAL, TELEPHONE, ELECTRICAL, LIGHTING, PLUMBING AND SPRINKLER EQUIPMENT LOCATION INCLUDING ALL PIPING, DUCTWORK AND CONDUIT, AND INSURE THAT ALL REQUIRED CLEARANCES FOR INSTALLATION AND MAINTENANCE ARE PROVIDED.
- THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ALL WORK AND MATERIALS IN ACCORDANCE WITH ALL CODES AND REQUIREMENTS OF STATE AND LOCAL REGULATORY AGENCIES.
- ALL WORK NOT SPECIFICALLY COVERED IN THE CONTRACT DOCUMENTS SHALL BE FURNISHED AND INSTALLED IN ACCORDANCE WITH CONSTRUCTION INDUSTRY
- DRAWINGS, THOUGH NOTED TO SCALE, ARE DIAGRAMMATICAL. DO NOT SCALE
- ALL HEIGHTS ARE DIMENSIONED FROM TOP OF SLAB UNLESS OTHERWISE NOTED.
- THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR DOCUMENTING ALL CHANGES TO THE CONSTRUCTION DOCUMENTS, NO MATTER HOW MINOR, FOR AS-BUILT RECORD DOCUMENTS. THESE DOCUMENTS ARE TO BE GIVEN TO THE OWNERS' REPRESENTATIVE WITHIN 2 WEEKS AFTER FINAL COMPLETION.
- THE GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL UTILITIES INDICATED ON THE INTERIOR ELEVATIONS WITH THE ELECTRICAL AND PLUMBING
- 9. IN THE CASE OF CONFLICTS OR AMBIGUITIES NOT CLARIFIED PRIOR TO THE BIDDING DEADLINE, USE THE MOST COSTLY ALTERNATIVE (BETTER QUALITY, GREATER QUANTITY AND LARGER SIZE) IN PREPARING THE BID.
- 10. ALL PENETRATIONS THROUGH FIRE RESISTIVE PARTITION AND SLAB, INCLUDING CONDUITS AND PIPING, SHALL BE CONSTRUCTED TO MEET APPROVED U.L. SYSTEM.
- ALL PENETRATIONS INTO SOUND RATED PARTITIONS, INSULATED PARTITIONS OR CEILING ASSEMBLIES SHALL BE SEALED WITH APPROVED PERMANENT RESILIENT SEALANT. OR OTHERWISE TREATED TO MAINTAIN INTEGRITY OF THE ACOUSTICAL
- CONTRACTOR TO PREVENT GALVANIC ACTION AND OTHER FORMS OF CORROSION BY INSULATING METALS AND OTHER MATERIALS FROM DIRECT CONTACT WITH INCOMPATIBLE MATERIALS.
- THE CONTRACTOR SHALL PERFORM ALL CUTTING, PATCHING, AND FINISHING NECESSARY TO RESTORE THE ORIGINAL CONDITION OF THE BUILDING TO ALL EXISTING PORTIONS OF THE BUILDING AFFECTED BY HIS WORK, TO THE SATISFACTION OF THE OWNER'S REPRESENTATIVE.
- WHEN INSTALLING DRILLED-IN ANCHORS AND OR POWDER DRIVEN PINS IN EXISTING NON-PRESTRESSED REINFORCED CONCRETE, USE CARE AND CAUTION TO AVOID CUTTING OR DAMAGING THE EXISTING REINFORCING STEEL MAINTAIN A MINIMUM CLEARANCE OF ONE INCH BETWEEN THE REINFORCEMENT STEEL AND THE DRILLED-IN ANCHOR AND OR PIN.
- 15. THE CONTRACTOR SHALL COORDINATE ALL PHASING, ACCESS, DEBRIS, STAGING AREAS, AND HOURS OF CONSTRUCTION WITH OWNERS PRIOR TO START OF
- CONTRACTOR TO PROVIDE REQUIRED DUST AND INFECTION CONTROL PROTECTION SYSTEM. MEANS AND METHODS TO BE COORDINATED WITH OWNER.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SECURITY OF THE AREA OF THE PROJECT WORK AND SHALL ALSO BE RESPONSIBLE FOR THE DISCIPLINE OF ALL CONSTRUCTION WORKERS ON THE PROJECT
- THE GENERAL CONTRACTOR SHALL COORDINATE WITH STRUCTURAL, MEP, FIRE ALARM FIRE PROTECTION, NURSE CALL, INTERIORS AND EQUIPMENT DRAWINGS PRIOR TO STARTING CONSTRUCTION. THE PROJECT MANUAL AND ALL DRAWINGS IN THE CONSTRUCTION DRAWINGS SHALL BE PART OF THE CONSTRUCTION DOCUMENTS
- 19. THE GENERAL CONTRACTOR SHALL SEPARATE DISSIMILAR METALS WITH BUILDING PAPER OR PLASTIC SHIM.
- THE GENERAL CONTRACTOR SHALL X-RAY AND/OR ULTRASOUND THE EXISTING CONCRETE FLOORS AND STRUCTURAL SLAB FOR ANY POSSIBLE EMBEDDED CONDUITS, STRUCTURAL REBAR UNFORESEEN CONDITION THAT IS OUTSIDE THE SCOPE OF WORK AND MIGHT IMPEDE THE ANCHORING OF EQUIPMENT OR CONFLICT WITH TRENCHING PRIOR TO CONSTRUCTION.
- CONTRACTOR STAGING TO BE IN THE ROOMS UNDER REMODEL.
- 22. CONTRACTOR PARKING TO BE IN CONTRACTOR DESIGNATED PARKING AREA.
- THE CONTRACTOR SHALL ENSURE THAT THE AREA UNDER REMODEL IS LOCKED AND OTHERWISE SECURED AFTER HOURS.
- 24. THE GENERAL CONTRACTOR IS RESPONSIBLE TO CUT & PATCH TO MATCH ALL EXISTING PARTITIONS WHERE NEW FIRE ALARM AND ELECTRICAL DEVICES ARE REQUIRED AS SPECIFIED IN THE FIRE ALARM DRAWINGS.
- CONTRACTOR SHALL FURNISH AND APPLY CRETESEAL 2000 CONCRETE SEALER OR APPROVED EQUAL ON SLAB ON GRADE.

### **PROJECT INFORMATION:**

### SCOPE OF WORK:

UPGRADE AND REMODEL OF THE EXISTING INPATIENT PHARMACY TO UNITED STATES PHARMACOPEIA CHAPTER 800. THE FULL EXTENT OF WORK IS INDICATED IN THE CONSTRUCTION DOCUMENTS PREPARED BY SFEIR ARCHITECTS.

### BUILDING DESCRIPTION:

NUMBER OF STORIES: 1 STORY + 1 BASEMENT OCCUPANCY GROUP: I-2 (NO CHAMGE IN EXISTING OCCUPANCY LOAD) TYPE OF CONSTRUCTION: I-A FIRE SPRINKLERS: ENTIRE BUILDING

### CONSTRUCTION CLASSIFICATION:

SEISMIC ZONE 4 3HR STRUCTURAL FRAME. 2HR FLOOR-CEILING/ROOF 1 1/2 HR ROOF

### AREA OF REMODEL

ANTE ROOM = 339 SQ. FT. BSC ROOM = 94 SQ. FT. IV PREP. ROOM = 139 SQ. FT. TOTAL COMBINED AREA = 572 SQ. FT.

### INDEX OF DRAWINGS

ARCHITECTUR	COVER SHEET AL:
A0-00	
A1-00	SITE ACCESSIBILITY AND EGRESS PATH OF TRAVEL
A1-01 A1-02	CODE COMPLIANCE FIRST FLOOR PLAN
A1-03	PHARMACY FLOOR PLAN
A1-04 A4-00	ADA CODE COMPLIANCE DETAILS PHASING PLAN
A4-01	DEMOLITION FLOOR PLAN
A4-10	NEW FLOOR PLAN
A4-30	REFLECTED CEILING PLAN
A4-40	INTERIOR ELEVATIONS
A5-00	FIRE RATED ASSEMBLIES
A5-10	TYPICAL RATED PARTITION ASSEMBLIES
$\bigwedge^{A5-60}$	GYPSUM CEILING DETAILS
A5-70	LAY IN CEILING DETAILS
A6-00	DOOR AND INTERIOR OPENINGS SCHEDULE
A6-20	PROPOSED EQUIPMENT FLOOR PLAN
ID-1 ID-2	FINISHES, NOTES & DETAILS
STRUCTURAL:	
S–1	GENERAL NOTES TYPICAL DETAILS
S-2	PARTIAL FLOOR PLAN, PARTIAL PENTHOUSE ROOF PLAN
SD2	DETAILS
SD3	DETAILS
MECHANICAL:	
M0-01 M0-02	SCHEDULES
M1-10	ZONING PLAN
M2-10 M2-11	PARTIAL RENOVATION HEATING HOT WATER FLOOR PLAN
M5-10	DIAGRAMS
MD2-10	PARTIAL DEMOLITION FIRST FLOOR AND ROOF PLAN
MD2-11	PARTIAL DEMOLITION HEATING HOT WATER FLOOR PLAN
PLUMBING:	
P0-01	GENERAL NOTES, LEGEND, SYMBOLS, AND SHEET INDEX
P0-02 P2-10	SCHEDULES AND DETAILS PARTIAL RENOVATION FLOOR PLAN
PD2-10	PARTIAL DEMOLITION FLOOR PLAN
ELECTRICAL:	
E0.1	GENERAL NOTES, LEGEND, SYMBOLS AND SHEET INDEX
E0.2 ED2.1	PARTIAL SINGLE LINE DIAGRAM, SCHEDULES, & LOAD SUMMARY PARTIAL DEMOLITION FLOOR PLANS
5 E2.1	PARTIAL RENOVATION FLOOR PLANS
E0.3	PANEL SCHEDULES & LOAD SUMMARIES
DEFERR	ED APPROVALS
-FIRE ALA -FIRE PRC	RM ITECTION
-SIGNAGE	
APPLICA	BLE CODES AND REGULATIONS:
2016 C.	ALIFORNIA ADMINISTRATIVE CODE (CAC) PART 1, TITLE 24. CCR)
2016 C.	·, ·····,
(F	ALIFORNIA BUILDING CODE (CBC)
	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR)
2016 C. (F	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR)
2016 C. (F 2016 C.	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC)
2016 C. (F 2016 C. (F	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC) PART 4, TITLE 24, CCR)
2016 C. (F 2016 C. (F 2016 C. (F	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC) PART 4, TITLE 24, CCR) ALIFORNIA PLUMBING CODE (CPC) PART 5, TITLE 24, CCR)
2016 C. (F 2016 C. (F 2016 C. (F 2016 C.	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC) PART 4, TITLE 24, CCR) ALIFORNIA PLUMBING CODE (CPC) PART 5, TITLE 24, CCR) ALIFORNIA FIRE CODE (CFC)
2016 C. (F 2016 C. 2016 C. 2016 C. (F 2016 C. (F	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC) PART 4, TITLE 24, CCR) ALIFORNIA PLUMBING CODE (CPC) PART 5, TITLE 24, CCR) ALIFORNIA FIRE CODE (CFC) PART 9, TITLE 24, CCR)
2016 C. (F 2016 C. (F 2016 C. (F 2016 C. (F 2016 C.	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC) PART 4, TITLE 24, CCR) ALIFORNIA PLUMBING CODE (CPC) PART 5, TITLE 24, CCR) ALIFORNIA FIRE CODE (CFC) PART 9, TITLE 24, CCR) DINTENT STATEMENT
2016 C. (F 2016 C. 2016 C. (F 2016 C. (F 2016 C. (F 2016 C. (F	ALIFORNIA BUILDING CODE (CBC) PART 2, TITLE 24, CCR) ALIFORNIA ELECTRICAL CODE (CEC) PART 3, TITLE 24, CCR) ALIFORNIA MECHANICAL CODE (CMC) PART 4, TITLE 24, CCR) ALIFORNIA PLUMBING CODE (CPC) PART 5, TITLE 24, CCR) ALIFORNIA FIRE CODE (CFC) PART 9, TITLE 24, CCR) DINTENT STATEMENT DF THE DRAWINGS AND SPECIFICATIONS IS TO BUILD IN ACCORDANCE WITH

### **OSHPD APPROVAL:**

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or information and retrieval systems without written permission of the ARCHII

APPLICATION NUMBER: S171641-37-00

OSHPD PRIOR TO PROCEEDING WITH THE WORK.

AND SPECIFYING THE REQUIRED WORK SHALL BE SUBMITTED TO AND APPROVED BY

CHECKED BY

DATE:

AS SHOWN

07/31/17

S A R 5151 Sho San Diegu P: 619-2 Www.sfeir TC PH US US	F c H oreham Place, o, Ca 92122 299-3917 299-5084 arch.com CMC AR BAR BAR BAR BAR BAR	E I T Suite 100	I E	R T S
Tri-(	City N	/ledio	cal C	Center
4002 V Ocean	∕ista Way side, Califo	ornia 920	056	
OWNER:	TRI-CIT 4002 V OCEANS	Y MEDICAL ISTA WAY SIDE, CALIFO	CENTER RNIA 9205	56
ARCHITEC	T: SFEIR A 5151 SH SAN DII TEL(619	RCHITECTS HOREHAM PI EGO, CALIFO )299–3917	_ACE, SUIT RNIA 9212 FAX(619)	E 100 2 299-5084
MEP:	P2S EN 9665 C SAN DIE TEL(619	GINEERING, HESAPEAKE EGO, CA 92 )618–2347	INC. DRIVE, SU 123	IITE 230
STRUCTUF	RAL: SUN ST 2091 L/ CARLSB TEL(760	RUCTURAL I AS PALMAS AD, CA 920 ))438–1188	ENGINEERIN DRIVE, SU 11	IG ITE D
11/11/2 N 10/2 1/1/2	D AP NICHI 0. C 28543 7 0. 1-31-19 OF CALFOR			
	SHPD COMMENTS			- <u>10-09-17</u> - <u>10-09-17</u>
$ \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \begin{array}{c} \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \end{array}{}\\ \end{array}{}$	SHPD COMMENTS			12-11-17 12-11-17 12-11-17
	SHPD COMMENTS SIGN CHANGES		~~~~~ ~~~~~	5-15-18 6-05-18
	SCRIPTION:			 
CONSULTANT				
OSHPD APPRO	) #: S171	641–37	-00	
	REVIEWED THE REQU AP wit	IN ACCORDAN IREMENTS OF PROVI h comme	ice with 124, cor ED nts	
	KC Huang, Office of Sta	Sr. Archit tewide Healt	ect h	
FA	Planning & CILITIES DEVEL	OPMENT DIV	t ISION	]
Sheet Title:	#[ S1710	641-37-00 ]		
P IN	ROJEC NFORM	T ATION	١	
PROJECT TITLE TCMC US	፰ SP 800			
PROJECT #: DRAWN BY:	01667.00 LN	SHEET NUMBER	:	



- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### PARTITION LEGEND:

ACCESSIBLE PATH OF TRAVEL. EGRESS PATH OF TRAVEL. ONE-HOUR RATED CORRIDOR. \_\_\_\_ INDICATES AN EXISTING MEMBRANE OF PARTITION OR \_\_\_\_ PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS. INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS. <u>/1</u> 3 SP SP SP SP SP INDICATES AN EXISTING 1 HOUR SMOKE PARTITION BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB - FB - FB - INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. INDICATES A NEW 1 HOUR SMOKE PARTITION **FP FP FP FP FP FP FP INDICATES A NEW ONE HOUR RATED FIRE PARTITION** EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FFB FFF FFF FFF INDICATES A NEW ONE HOUR RATED FIRE BARRIER EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. THICK LINE INDICATES NEW SURFACE FINISH. INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING.

 $\prec x$ WALL TYPE REFERENCE REFER TO SHEET A5-10.

PARTITION NOTES:

1. ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND REQUIREMENTS FOR PARTITIONS.

2. EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

al systems without written permission of the ARCH

### R S F F A R C H I T E C T S 5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619–299–3917 F: 619–299–5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

	e, California 92000	
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92	2056
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, S SAN DIEGO, CALIFORNIA 92 TEL(619)299–3917 FAX(6	UITE 100 2122 19)299–508
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SAN DIEGO, CA 92123 TEL(619)618–2347	SUITE 230
STRUCTURAL:	SUN STRUCTURAL ENGINEE 2091 LAS PALMAS DRIVE, CARLSBAD, CA 92011 TEL(760)438–1188	ring Suite d
STATE OF	-31-19 CALFORNIT	
	COMMENTS	10-09-17
	CHANGES	10-09-17
	COMMENTS	12-11-17
	CHANGES	12-11-17
5 OSHPD	COMMENTS	5–15–18 <del>××××××</del>
	CHANGES	6-05-18 

### OSHPD APPROVAL STAMP:

OSHPD	#: S171	641-37-0	0	
	REVIEWED THE REQU AP wit	IN ACCORDANCE V IREMENTS OF T24, PROVED h comments	VITH COR	
К	C Huang,	Sr. Architect		
	Office of Sta	tewide Health		
TA CI	Planning &	Development		
FAUL	ITTES DEVEL		NN IN	
	07/23/2018 <b>#[ S171</b> 0	3 08:10:09 AM 6 <b>41-37-00 ]</b>		
Sheet title:				
SI <sup>-</sup> AN OF	TE AC ID EG TRA	CESSIE RESS P VEL	BILIT	Y I
PROJECT TITLE:	000			
	000			
PROJECT #:	01667.00	SHEET NUMBER:		
DRAWN BY:	JD			
CHECKED BY:	JS	Λ	1	$\land \land$
SCALE: A	S SHOWN	A		UU
DATE:				$\mathbf{\nabla}$

07/31/17

DATE:



CODE COMPLIANCE FIRST FLOOR PLAN SCALE: 1/32" : 1'-0"



NORTH

### **GENERAL NOTES:**

- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### PARTITION LEGEND:

ACCESSIBLE PATH OF TRAVEL. EGRESS PATH OF TRAVEL. ONE-HOUR RATED CORRIDOR. \_\_\_\_ INDICATES AN EXISTING MEMBRANE OF PARTITION OR \_\_\_\_\_ PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS. INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS.  $\sqrt{1}$ SB SB SB SB SB INDICATES AN EXISTING 1 HOUR SMOKE BARRIER 3 SP SP SP SP SP INDICATES AN EXISTING 1 HOUR SMOKE PARTITION BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB IINDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. SB SB SB SB SB SB INDICATES A NEW 1 HOUR SMOKE BARRIER INDICATES A NEW 1 HOUR SMOKE PARTITION **FP FP FP FP FP FP FP INDICATES A NEW ONE HOUR RATED FIRE PARTITION** EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. THICK LINE INDICATES NEW SURFACE FINISH. INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING.

WALL TYPE REFERENCE REFER TO SHEET A5-10.  $\prec x$ 

PARTITION NOTES:

- 1. ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND REQUIREMENTS FOR PARTITIONS.
- 2. EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or informatic

### R S F F A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619–299–3917 F: 619–299–5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

Oceansid		
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 9	2056
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, S SAN DIEGO, CALIFORNIA 9 TEL(619)299–3917 FAX(6	SUITE 100 2122 S19)299–508
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SAN DIEGO, CA 92123 TEL(619)618–2347	SUITE 230
STRUCTURAL:	SUN STRUCTURAL ENGINEE 2091 LAS PALMAS DRIVE, CARLSBAD, CA 92011 TEL(760)438–1188	ering Suite D
THE NIC	28543 TO *	· · · · . · · ·
SAPACE OF	28543 70 * -31-19	· · · · · · · · · · · · · · · · · · ·
No. C	28543 70 * -31-19 CALIFORTINE CALIFORTINE COMMENTS	<u>10–09–17</u>
No. C SATURE OF CONTRACTOR	28543 70 * 28543 70 * CALFORNIT CALFORNITS CHANGES	<u> </u>
No. C STATE OF OSHPD A OSHPD	28543 7 + 28543 7 + CALFORM CA	<u>10–09–17</u> 10–09–17 12–11–17
No. C Shy Correction No. C Shy Correction Shy Correction	28543 TO THE CALIFORNIA CALIFORNIA CALIFORNIA CALIFORNIA CHANGES COMMENTS CHANGES	<u> </u>
No. C STATE OF OSHPD A DESIGN S S S S S S S S S S S S S	COMMENTS CHANGES COMMENTS CHANGES	10-09-17 10-09-17 12-11-17 12-11-17 5-15-18 6-05-18
A DESIGN	COMMENTS CHANGES COMMENTS CHANGES COMMENTS CHANGES	10-09-17 10-09-17 12-11-17 12-11-17 5-15-18 6-05-18
A DESIGN	COMMENTS CHANGES COMMENTS CHANGES COMMENTS CHANGES COMMENTS CHANGES	10-09-17 10-09-17 12-11-17 12-11-17 5-15-18 6-05-18
× SED V C No. C S S No. C S S No. C S S S S S S S S S S S S S S S S S S S	28543 70 * 28543 70 * CALFORITS CHANGES COMMENTS CHANGES COMMENTS CHANGES COMMENTS CHANGES COMMENTS CHANGES	10-09-17 10-09-17 12-11-17 12-11-17 5-15-18 6-05-18

### OSHPD APPROVAL STAMP:

OSHPD #: S171641-37-00	
REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR APPROVED with comments	
KC Huang, Sr. Architect	
Office of Statewide Health Planning & Development FACILITIES DEVELOPMENT DIVISION	
07/23/2018 08:10:09 AM <b>#[ \$171641-37-00 ]</b>	
SHEET TITLE:	
CODE COMPLIANCE FIRST FLOOR PLAN	
PROJECT TITLE: TCMC USP 800	
PROJECT # 01667.00 SHEET NUMBER:	
DRAWN BY: LN	
DRAWN BY: LN CHECKED BY: JS	

07/31/17

DATE:



- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### PARTITION LEGEND:

ACCESSIBLE PATH OF TRAVEL. EGRESS PATH OF TRAVEL. ONE-HOUR RATED CORRIDOR. \_\_\_\_\_ INDICATES AN EXISTING MEMBRANE OF PARTITION OR \_\_\_\_\_ PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS. INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS.  $\sqrt{1}$ SB SB SB SB SB INDICATES AN EXISTING 1 HOUR SMOKE BARRIER 3 SP SP SP SP SP INDICATES AN EXISTING 1 HOUR SMOKE PARTITION PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB IINDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. SB SB SB SB INDICATES A NEW 1 HOUR SMOKE BARRIER INDICATES A NEW 1 HOUR SMOKE PARTITION FP ------ INDICATES A NEW ONE HOUR RATED FIRE PARTITION EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. THICK LINE INDICATES NEW SURFACE FINISH. INDICATES AN EXISTING STRUCTURE CONCLUDE WALL TO REMAIN. LOCATE REINFORCING STEEL AND

 $\prec x$ WALL TYPE REFERENCE REFER TO SHEET A5-10. PARTITION NOTES:

ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, <u>-</u>1. TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND REQUIREMENTS FOR PARTITIONS.

OBTAIN APPROVAL FROM STRUCTURAL ENGINEER

PRIOR TO CORING AND/ OR CUTTING.

EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR 2. CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

![](_page_5_Figure_11.jpeg)

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

	e, California 92056	
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 920	56
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUI SAN DIEGO, CALIFORNIA 921 TEL(619)299–3917 FAX(619	TE 100 22 9)299–508
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, S SAN DIEGO, CA 92123 TEL(619)618–2347	UITE 230
STRUCTURAL:	SUN STRUCTURAL ENGINEERI 2091 LAS PALMAS DRIVE, SU CARLSBAD, CA 92011 TEL(760)438–1188	NG JITE D
SATE OF	-31-19 CALIFORNIT	
	COMMENTS	 10–09–17
	CHANGES	 10–09–17
	COMMENTS	12-11-17
	COMMENTS CHANGES	<u>12–11–17</u> <u>12–11–17</u>
	COMMENTS CHANGES COMMENTS	12-11-17 12-11-17 5-15-18
DESIGN (	COMMENTS CHANGES COMMENTS CHANGES	12-11-17 12-11-17 5-15-18 6-05-18
2     DESIGN       3     OSHPD       4     DESIGN       5     OSHPD       6     DESIGN	COMMENTS CHANGES COMMENTS CHANGES	12-11-17 12-11-17 5-15-18 6-05-18
2     DESIGN (       3     OSHPD (       4     DESIGN (       5     OSHPD (       6     DESIGN (	COMMENTS CHANGES COMMENTS CHANGES	

### OSHPD APPROVAL STAMP:

![](_page_5_Picture_18.jpeg)

07/31/17

DATE:

PATIE

BIO-ME

![](_page_5_Figure_22.jpeg)

PREP AI

![](_page_5_Figure_24.jpeg)

![](_page_6_Figure_0.jpeg)

3

 $\Lambda$ 

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or infor

### S F R **GENERAL NOTES:** 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS A R C H I T E C T S AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION. 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET. 5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917 F: 619-299-5084 PARTITION LEGEND: www.sfeirarch.com TCMC ACCESSIBLE PATH OF TRAVEL. PHARMACY EGRESS PATH OF TRAVEL. USP 800 ONE-HOUR RATED CORRIDOR. UPGRADE \_\_\_\_ INDICATES AN EXISTING MEMBRANE OF PARTITION OR \_\_\_\_\_ PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS. INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS. <u>\_1</u> **Tri-City Medical Center** SB SB SB SB SB INDICATES AN EXISTING 1 HOUR SMOKE BARRIER SP SP SP SP SP INDICATES AN EXISTING 1 HOUR SMOKE PARTITION 4002 Vista Way PARTITION TO REMAIN. ALL PENETRATIONS SHALL Oceanside, California 92056 BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE TRI-CITY MEDICAL CENTER OWNER: PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 FB - FB - FB - INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SB SB SB SB SB INDICATES A NEW 1 HOUR SMOKE BARRIER SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084 INDICATES A NEW 1 HOUR SMOKE PARTITION MEP: P2S ENGINEERING, INC. FP ------ INDICATES A NEW ONE HOUR RATED FIRE PARTITION 9665 CHESAPEAKE DRIVE, SUITE 230 EXTENDING TO THE UNDERSIDE OF THE STRUCTURE SAN DIEGO, CA 92123 ABOVE. ALL PENETRATIONS SHALL BE PROTECTED TEL(619)618-2347 WITH A UL-LISTED FIRE STOP SYSTEM. STRUCTURAL: SUN STRUCTURAL ENGINEERING EXTENDING TO THE UNDERSIDE OF THE STRUCTURE 2091 LAS PALMAS DRIVE, SUITE D ABOVE. ALL PENETRATIONS SHALL BE PROTECTED CARLSBAD, CA 92011 WITH A UL-LISTED FIRE STOP SYSTEM. TEL(760)438-1188 THICK LINE INDICATES NEW SURFACE FINISH. INDICATES AN EXISTING STRUCTURAL CONSTRUCT WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING. WALL TYPE REFERENCE REFER TO SHEET A5-10. $\prec x >$ No. C 28543 🗖 PARTITION NOTES: 1-31-1. ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND, OF CALIF REQUIREMENTS FOR PARTITIONS. ••••• 2. EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR \_\_\_\_\_ 10-09-17 OSHPD COMMENTS CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET. 10-09-17 DESIGN CHANGES 12-11-17 OSHPD COMMENTS PHARMACY FLOOR PLAN KEYNOTES: DESIGN CHANGES 12-11-17 $\sim\sim\sim\sim$ 5-15-18 OSHPD COMMENTS 1 REMOVE EXISTING SIGNAGE AND ADD NEW SIGNAGE PER DETAIL 2/A1-04. 6-05-18 DESIGN CHANGES 3 (2) 60" WIDE BY 56" DEEP SPACE. DATE: REV: DESCRIPTION: CONSULTANT OSHPD APPROVAL STAMP: OSHPD #: S171641-37-00 REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR **APPROVED** with comments KC Huang, Sr. Architect Office of Statewide Health Planning & Development FACILITIES DEVELOPMENT DIVISION 07/23/2018 08:10:09 AM #[ \$171641-37-00 ] SHEET TITLE:

PHARMACY FLOOR PLAN

PROJECT TITLE: TCMC USP 800

Project #: 01667.00 DRAWN BY: CHECKED B  $\frac{1}{4"} = 1' - 0"$ DATE: 07/31/17

![](_page_7_Figure_0.jpeg)

![](_page_8_Figure_0.jpeg)

- THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### PARTITION LEGEND:

	$\rightarrow$	ACCESSIBLE PATH OF TRAVEL.
	>	EGRESS PATH OF TRAVEL.
		ONE-HOUR RATED CORRIDOR.
		INDICATES AN EXISTING MEMBRANE OF PARTITION OR PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS.
		INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS.
$\Lambda$	SB SB SB SB SB	INDICATES AN EXISTING 1 HOUR SMOKE BARRIER
<u>}</u>	SP SP SP SP SP	INDICATES AN EXISTING 1 HOUR SMOKE PARTITION
	FP FP FP	INDICATES AN EXISTING ONE HOUR FIRE RATED PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	FB FB FB FB FB FFB	INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	EFB FB FFB FFF FB FFF	INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	SB SB SB SB	INDICATES A NEW 1 HOUR SMOKE BARRIER
	SP SP SP SP SP	INDICATES A NEW 1 HOUR SMOKE PARTITION
		INDICATES A NEW ONE HOUR RATED FIRE PARTITION EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	FB FB FF FF FF FF	INDICATES A NEW ONE HOUR RATED FIRE BARRIER EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
		THICK LINE INDICATES NEW SURFACE FINISH.
		INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING.

WALL TYPE REFERENCE REFER TO SHEET A5-10.

PARTITION NOTES:

—( x )

- ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, 1. TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND REQUIREMENTS FOR PARTITIONS.
- 2. EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

# PHASING PLAN KEYNOTES:

- 1 INSTALL COMPOUNDING WORK STATION ISO 5 POSITIVE (EQUIPMENT 005) -REFRIGERATOR IN PHASE I AND MOVE IT TO PHASE II AFTER CONSTRUCTION COMPLETION.
- (2) INSTALL EQUIPMENT 032 ISOLATOR AND REMOVE AFTER CONSTRUCTION COMPLETION.
- (3) DEMARCATION LINE. FLOOR MARKING 2 " WIDE YELLOW TAPE.
- (4) TEMPORARY MOBILE EYE WASH STATION.
- (5) TEMPORARY MOBILE SCRUB SINK STATION.
- (6) LIMITS OF SEGREGATED AREA AROUND BUFFER AREA.
- (7) INSTALL FIRE RESISTIVE CORRUGATED BOARD COROPLAST® FIREWALL FRB CLASS 94V-2 ABOVE SEGREGATED STERILE COMPOUNDING AREA. SECURE CORRUGATED BOARD TO CEILING GRID WITH 16 GAGE WIRE TIE TO CEILING GRID @ 16" O.C. KEEP ALL CEILING FIXTURES OPEN AND ACCESSIBLE INCLUDING LIGHTS, FIRE PROTECTION, FIRE ALARM, AIR DIFFUSERS AND RETURN AND ALL OTHER EQUIPMENT.

(8) DONNING AND DOFFING AREA.

- (9) ADD SIGN INCLUDING FULL NAME OF TEMPORARY PHARMACY ROOM NAME PER PLAN SHOWN IN 1/A4-00 "SEGREGATED STERILE NON-HAZARDOUS COMPOUNDING AREA B.U.D. WILL NOT EXCEED 12 HOURS."
- (10) INSTALL TEMPORARY WALL AROUND TEMPORARY SEGREGATED STERILE COMPOUNDING AREA DURING PHASE I, TO BE REMOVED AT THE COMPLETION OF PHASE II. COMPOSED OF FIRE RESISTIVE CORRUGATED BOARD - COROPLAST® FIREWALL FRB CLASS 94V-2 ON 250S162-33 LIGHTWEIGHT METAL STUDS SPACED AT 16" O.C. FROM FLOOR TO CEILING.

S	S F		Ε			I		R	
A	R	C	H	1	T	Ε	C	T	S
				- ··					

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

4002 Vista Oceanside	a Way e, California  92056
OWNER:	TRI—CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
STRUCTURAL:	SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188
NSED	

![](_page_8_Picture_27.jpeg)

### OSHPD APPROVAL STAMP:

![](_page_8_Picture_29.jpeg)

![](_page_9_Figure_0.jpeg)

### **DEMOLITION GENERAL NOTES:**

- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING DEMOLITION.
- 2. THE GENERAL CONTRACTOR SHALL COORDINATE ALL PHASING, ACCESS, DEBRIS REMOVAL, STAGING AREAS AND HOURS OF CONSTRUCTION WITH
- 3. THE GENERAL CONTRACTOR SHALL COORDINATE WITH STRUCTURAL, MEP, FIRE ALARM, FIRE PROTECTION, NURSE CALL, INTERIORS AND EQUIPMENT DRAWINGS PRIOR TO STARTING DEMOLITION. THE PROJECT MANUAL AND ALL DRAWINGS IN THE CONSTRUCTION DRAWINGS SHALL BE PART OF THE
- 4. THE GENERAL CONTRACTOR SHALL SEPARATE DISSIMILAR METALS WITH
- THE GENERAL CONTRACTOR SHALL X-RAY AND/OR ULTRASOUND THE EXISTING CONCRETE FLOORS AND FLOOR ABOVE FOR ANY POSSIBLE EMBEDDED CONDUITS, STRUCTURAL REBAR OR UNFORESEEN CONDITION THAT MIGHT IMPEDE THE ANCHORING OF EQUIPMENT OR CONFLICT WITH
- 6. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT
- 7. CONTRACTOR STAGING TO BE IN THE ROOMS UNDER REMODEL
- 8. CONTRACTOR PARKING TO BE IN CONTRACTOR DESIGNATED PARKING
- 9. THE CONTRACTOR SHALL ENSURE THAT THE AREA UNDER REMODEL IS
- 10. UNLESS OTHERWISE NOTED, CONTRACTOR SHALL COORDINATE WITH THE OWNER THE REMOVAL OF EXISTING EQUIPMENT INDICATED ON
- 11. DASHED LINES INDICATE ITEMS TO BE DEMOLISHED OR REMOVED. REFER TO FLOOR PLAN, CEILING PLAN AND ROOM FINISH SCHEDULE ALONG WITH MECHANICAL, PLUMBING, ELECTRICAL, FIRE PROTECTION, AND FIRE ALARM
- 12. REFER TO DEMOLITION PLAN FOR NOTES INDICATING TYPE OF FINISHES
- 13. REFER TO RELATED PLANS FOR PORTIONS OF EXISTING CONSTRUCTION
- 14. PATCH NEW WORK TO MATCH AND ALIGN WITH THE EXISTING. COMPLETELY REMOVE EXISTING FINISHES WHERE NEW FINISHES ARE SCHEDULED.
- 15. CONTRACTOR SHALL PRESERVE AND PROTECT THE EXISTING AREA,
- 16. REFER TO NEW PLAN AND INTERIOR ELEVATIONS FOR LOCATION OF NEW WALL CONNECTIONS, OPENINGS, RECESSED ITEMS, BACKING PLATES, ETC. AT EXISTING WALLS. REMOVE GYPSUM BOARD WHERE NEEDED TO
- 17. CAP AND CLOSE ALL ABANDONED OPENINGS AT EXISTING SLAB. FILL AND PATCH TO LEVEL FLOOR. REFER TO STRUCTURAL DETAIL FOR INFILL OPENING DETAIL. NOTE THAT THE NUMBER OF EXISTING OPENINGS TO BE FILLED IS ONLY INDICATIVE, REFER TO MEP FOR MORE INFORMATION.
- 18. CONTRACTOR SHALL PRESERVE AND PROTECT THE PORTIONS OF THE EXISTING OVERHEAD PAGING, TELEPHONE, DATA AND ELECTRICAL LINES DURING THE COURSE OF CONSTRUCTION. MANY OF THE SYSTEMS ARE SCHEDULED FOR REUSE BY THE OWNER UNDER THIS OR SEPERATE
- AND FILTER THE AIR WITH HEPA FILTRATION AND EXHAUST FILTER AIR THROUGH EXHAUST SYSTEM. G.C. TO SECURE AN INFECTION CONTROL PERMIT FROM TRI-CITY MEDICAL CENTER PRIOR TO STARTING
- 20. EXISTING EQUIPMENT SHALL BE RELOCATED BY G.C. COORDINATE TEMPORARY LOCATION WITH OWNER. MOVE BACK EQUIPMENT FOR FINAL

AND BACKING PLATE PER DETAIL 10B/S-1. (28) SAW CUT SLAB PER DETAIL 6/SD3 AS NECESSARY TO INSTALL NEW SINK DRAIN PER PLUMBING PLANS (X-RAY OR 6 ÚLTŘAŠOUND CONČRĚTE BĚFORE START OF CONSTRUCTION TO AVOID CUTTING INTO STRUCTURAL CONCRETE FOUNDATION.

(29) PRESERVE AND PROTECT TOILET ACCESSORY DURING 

(30) PROVIDE TWO ZIPPER CURTAINS OF FIRE RESISTANT VISQUEEN. TEMPORARY EXITING PROVISIONS SHALL MEET THE REQUIREMENTS OF OSHPD CAN 9-3301 AND THAT CONSTRUCTION/INFECTION CONTROL BARRIER PLACEMENT SHALL BE COORDINATED WITH OSHPD FIELD FLSO.

(31) REMOVE GWB AS NECESSARY TO INSTALL NEW EYEWASH WATER

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, o

### GENERAL NOTES:

- THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

# **PARTITION LEGEND:**

ACCESSIBLE PATH OF TRAVEL. EGRESS PATH OF TRAVEL. \_\_\_\_\_ \_\_\_\_\_ FP FP FP FP SYSTEM. FB FB FB FB FB

FB FB FB	INDICAT BARRIE PROTEC
	INDICAT
	INDICAT
	INDICAT EXTENE ABOVE. WITH A
	INDICAT EXTENE ABOVE. WITH A
	THICK L

ONE-HOUR RATED CORRIDOR. INDICATES AN EXISTING MEMBRANE OF PARTITION OR PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS. INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS. SB - SB - SB - SB - INDICATES AN EXISTING 1 HOUR SMOKE BARRIER 3 = SP = SP = INDICATES AN EXISTING 1 HOUR SMOKE PARTITION INDICATES AN EXISTING ONE HOUR FIRE RATED PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. TES AN EXISTING TWO HOUR RATED FIRE ER TO REMAIN, ALL PENETRATIONS SHALL BE CTED WITH A UL-LISTED FIRE STOP SYSTEM. TES A NEW 1 HOUR SMOKE BARRIER TES A NEW 1 HOUR SMOKE PARTITION TES A NEW ONE HOUR RATED FIRE PARTITION DING TO THE UNDERSIDE OF THE STRUCTURE . ALL PENETRATIONS SHALL BE PROTECTED A UL-LISTED FIRE STOP SYSTEM.

> TES A NEW ONE HOUR RATED FIRE BARRIER IDING TO THE UNDERSIDE OF THE STRUCTURE E. ALL PENETRATIONS SHALL BE PROTECTED A UL-LISTED FIRE STOP SYSTEM.

LINE INDICATES NEW SURFACE FINISH.

INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING.

WALL TYPE REFERENCE REFER TO SHEET A5-10.  $\prec$  x >

PARTITION NOTES:

ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND REQUIREMENTS FOR PARTITIONS.

EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR 2. CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

### **DEMOLITION KEYNOTES:**

		$\left(1\right)$	REMOVE EXISTING PARTITION IN ITS ENTIRETY.
		2	REMOVE EXISTING DOOR AND FRAME.
	6	-3	REMOVE DOOR. FRAME TO REMAIN.
	6	4	REMOVE EXISTING BASE AND OVERHEAD CABINETS IN THEIR ENTIRETY INSIDE THE PHARMACY.
		5	REMOVE EXISTING EQUIPMENT. RETURN EQUIPMENT NOT TO BE RELOCATED TO OWNER.
		6	REMOVE EXISTING FLOOR FINISHES AND BASE.
		7	REMOVE EXISTING EQUIPMENT AND SALVAGE. SEE A6-20 FOR NEW LOCATIONS. RETURN EQUIPMENT NOT TO BE RELOCATED TO OWNER.
		8	CUT OPENING IN EXISTING WALL FOR NEW DOOR AND SLIDING WINDOW.
	$\wedge$	9	REMOVE EXISTING MILLWORK.
		10	FIRE RESISTIVE CORRUGATED BOARD – Coroplast®Firewall FRB Class 94V-2. TEMPORARY EXITING PROVISIONS SHALL MEET THE REQUIREMENTS OF OSHPD CAN 9-3301 AND THAT CONSTRUCTION/INFECTION CONTROL BARRIER PLACEMENT SHALL BE COORDINATED WITH OSHPD FIELD FLSO. SEPARATE CONSTRUCTION AREA FROM ADJACENT OCCUPIED SPACE ABOVE CEILING WITH FIRE RESISTIVE VISQUEEN.
Ş		(11)	REMOVE EXISTING GWB AS NEEDED TO INSTALL BACKING PLATE. $\bigtriangleup$
}		(12)	ERECT AND TIGHTLY SEAL FROM TOP OF PARTITION TO UNDERSIDE OF DECK WITH VISQUEEN. TAPE ALL EDGES TO STOP AIR LEAKAGE.
		13	SLIDING WINDOW & WALL FRAMING TO REMAIN. REMOVE CORIAN COUNTER TOP IN IV PREP ROM & REPLACE WITH STAINLESS STEEL COUNTER TOP. REMOVE PLASTIC LAMINATED SHELVING & COUNTER TOP & REPLACE WITH STAINLESS STEEL CABINET & COUNTER.
		(14)	REMOVE SINK & EYE WASH.
		(15)	SALVAGE DOOR OPERATOR & SENSOR PLATE TO REINSTALL.
	6	(16)	REMOVE DOOR. SALVAGE FRAME TO REINSTALL, PRIME & PAINT.
		(17)	REMOVE WALL MOUNTED BOARD TO TURN OVER TO OWNER.
		(18)	EXISTING DOOR OPERATOR TO REMAIN.
		(19)	REMOVE EXISTING EQUIPMENT & DISCARD.
Ŀ	2	20	REMOVE WALL PROTECTION.
		(21)	INFECTION CONTROL ANTEROOM.

# S A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800 UPGRADE**

# Tri-City Medical Center

4002 Vista V Oceanside, OWNER: 1 ARCHITECT: 5 MEP: 6 STRUCTURAL: 5 C	Way California 92056 TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 920 SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SU SAN DIEGO, CALIFORNIA 92 TEL(619)299–3917 FAX(61 P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, S SAN DIEGO, CA 92123 TEL(619)618–2347 SUN STRUCTURAL ENGINEER 2091 LAS PALMAS DRIVE, S CARLSBAD, CA 92011 TEL(760)438–1188	D56 IITE 100 122 9)299–5084 SUITE 230 RING SUITE D
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 920 SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SU SAN DIEGO, CALIFORNIA 92 TEL(619)299-3917 FAX(61 P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, S SAN DIEGO, CA 92123 TEL(619)618-2347 SUN STRUCTURAL ENGINEER 2091 LAS PALMAS DRIVE, S CARLSBAD, CA 92011 TEL(760)438-1188	D56 ITE 100 122 9)299–5084 SUITE 230
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SU SAN DIEGO, CALIFORNIA 92 TEL(619)299–3917 FAX(61 P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, S SAN DIEGO, CA 92123 TEL(619)618–2347 SUN STRUCTURAL ENGINEER 2091 LAS PALMAS DRIVE, S CARLSBAD, CA 92011 TEL(760)438–1188	NTE 100 122 9)299–5084 SUITE 230 NNG SUITE D
MEP: F	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, S SAN DIEGO, CA 92123 TEL(619)618–2347 SUN STRUCTURAL ENGINEER 2091 LAS PALMAS DRIVE, S CARLSBAD, CA 92011 TEL(760)438–1188	SUITE 230 RING SUITE D
STRUCTURAL: S	SUN STRUCTURAL ENGINEER 2091 LAS PALMAS DRIVE, S CARLSBAD, CA 92011 TEL(760)438–1188	RING SUITE D
ENSED A		
★ S No. C 285	543 TO T	
SHPD COM	MENTS	10-09-17
$\frac{1}{2}$ design char	NGES	10-09-17
$\frac{\sqrt{3}}{\sqrt{3}}$ Oshpd comm	MENTS	12–11–17
DESIGN CHAI	NGES	12-11-17
5 OSHPD COM	MENTS	5–15–18 ******

OSHPD	APPROVAL	ST

\_\_\_\_\_

CONSULTANT

REV: DESCRIPTION:

![](_page_9_Picture_49.jpeg)

DATE:

PROJECT TITLE: TCMC USP 800

PROJECT #: 01667.00 DRAWN BY: CHECKED BY

SCALE: 1/4" = 1'-0"

DATE:

SHEET NUME

100% CONSTRUCTION DOCUMENT

07/31/17

![](_page_10_Figure_0.jpeg)

G	ENERAL I	NOTES:	S F E I R
1.	THE GENERAL CONTRA AND MEASUREMENTS I	CTOR SHALL VERIFY ALL EXISTING CONDITIONS N THE FIELD PRIOR TO STARTING CONSTRUCTION.	A R C H I T E C T S
2.	REFER TO GENERAL NO INDICATED ON THIS SHE	DTES ON SHEET A0-00 FOR INFORMATION NOT EET.	5151 Shoreham Place, Suite 100 San Diego, Ca 92122
G	ENERAL FL	OOR PLAN NOTES:	P: 619–299–3917 F: 619–299–5084 www.sfeirarch.com
1.	THE GENERAL CONTRA MEASUREMENTS IN TH	CTOR SHALL VERIFY ALL EXISTING CONDITIONS AND E FIELD PRIOR TO STARTING CONSTRUCTION.	TCMC
2.	THE GENERAL CONTRA DEBRIS REMOVAL, STA OWNER PRIOR TO STAF	CTOR SHALL COORDINATE ALL PHASING, ACCESS, GING AREAS AND HOURS OF CONSTRUCTION WITH RT OF CONSTRUCTION.	PHARMACY
3.	THE GENERAL CONTRA FIRE ALARM, FIRE PRO DRAWINGS PRIOR TO S ALL DRAWINGS IN THE CONSTRUCTION DOCU	CTOR SHALL COORDINATE WITH STRUCTURAL, MEP, TECTION, NURSE CALL, INTERIORS AND EQUIPMENT TARTING CONSTRUCTION. THE PROJECT MANUAL AND CONSTRUCTION DRAWINGS SHALL BE PART OF THE MENTS.	USP 800 UPGRADE
4.	THE GENERAL CONTRA BUILDING PAPER OR PL	CTOR SHALL SEPARATE DISSIMILAR METALS WITH ASTIC SHIM.	
5.	THE GENERAL CONTRA CONCRETE FLOORS AN CONDUITS, STRUCTUR THE SCOPE OF WORK A CONFLICT WITH TRENC	Tri-City Medical Center	
6.	REFER TO GENERAL NO INDICATED ON THIS SH	DTES ON SHEET A0-00 FOR INFORMATION NOT EET.	4002 Vista Way Oceanside, California 92056
7.		G TO BE IN THE ROOMS UNDER REMODEL.	
8. 9.	CONTRACTOR PARKING TO BE IN CONTRACTOR DESIGNATED PARKING AREA. THE CONTRACTOR SHALL ENSURE THAT THE AREA UNDER REMODEL IS LOCKED AND OTHERWISE SECURED AFTER HOURS.		4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056
10.	VERIFY ALL DIMENSION CONSTRUCTION.	IS WITH EQUIPMENT SCHEDULE PRIOR TO START OF	ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100
11.	REFER TO EQUIPMENT PLAN, CEILING PLAN, INTERIOR ELEVATIONS AND ROOM FINISH SCHEDULE ALONG WITH MECHANICAL, ELECTRICAL, PLUMBING, FIRE PROTECTION, AND FIRE ALARM SECTIONS FOR FURTHER DESCRIPTION OF SCOPE OF WORK		SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084 MEP: P2S ENGINEERING, INC.
12.	REFER TO FINISH PLAN AND SCHEDULE AND INTERIOR DESIGN DOCUMENTS FOR TYPES OF FINISHES.		9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
13.	FOR DOOR INFORMATIO	DN REFER TO DOOR SCHEDULE, SHEET A6-00.	STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D
15.	PROVIDE ACOUSTICAL	INSULATION IN ALL NEW WALL ASSEMBLIES.	CARLSBAD, CA 92011 TEL(760)438–1188
16.	16. THE GENERAL CONTRACTOR SHALL VERIFY THE LEVELNESS OF THE SLAB AT ALL NEW DOOR LOCATIONS PRIOR TO CONSTRUCTION. APPLY LEVELING MATERIAL AS NECESSARY DURING CONSTRUCTION TO ACHIEVE MAX. OF 3/8" CLEARANCE FROM FINISH FLOOR TO UNDERSIDE OF NEW DOOR, REPLACE FINISHES TO MATCH EXISTING AS NEEDED.		ELISED R MICH
17.	THE GENERAL CONTRA NEW BUILDING SYSTEM DUCTWORK, ELECTRIC. PIPES, ETC, REFER TO	CTOR SHALL SEISMICALLY ANCHOR ALL EXISTING AND IS ABOVE CEILING INCLUDING BUT NOT LIMITED TO AL CONDUITS AND TRAYS, SPRINKLER PIPES, PLUMBING A0-00 FOR MORE INFORMATION.	★ S No. C 28543 元 ★
18.	PROVIDE GROMMET HO	DLE IN COUNTER ABOVE ALL POWER AND DATA DER NEW COUNTER.	NATE OF ONLE OF
P			
<u> </u>		ACCESSIBLE PATH OF TRAVEL.	$ \begin{array}{c c} \hline & \hline \\ \hline \\$
	>	EGRESS PATH OF TRAVEL.	$\begin{array}{c c} \hline 4 \\ \hline 5 \\ \hline 5$
		ONE-HOUR RATED CORRIDOR.	
		INDICATES AN EXISTING MEMBRANE OF PARTITION OR PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS.	
^		INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS.	
	SB SB SB	INDICATES AN EXISTING 1 HOUR SMOKE BARRIER	REV: DESCRIPTION: DATE: CONSULTANT
<u> </u>	SP SP SP FP	INDICATES AN EXISTING 1 HOUR SMOKE PARTITION	
		PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.	
	FB FB FB	INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.	OSHPD APPROVAL STAMP: OSHPD #: S171641-37-00
	FB FB FB FB	INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.	REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR APPROVED
		INDICATES A NEW 1 HOUR SMOKE BARRIER	with comments
	SP SP SP SP SP	INDICATES A NEW 1 HOUR SMOKE PARTITION	KC Huang, Sr. Architect Office of Statewide Health
		ADDIGATES A NEW ONE HOUR RATED FIRE PARTITION EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.	Planning & Development FACILITIES DEVELOPMENT DIVISION
	FB FB FB FB FB	INDICATES A NEW ONE HOUR RATED FIRE BARRIER EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.	07/23/2018 08:10:09 AM #[ S171641-37-00 ] SHEET TITLE:

NEW FLOOR PLAN

PROJECT TITLE: TCMC USP 800

PROJECT #: 01667.00 DRAWN BY: CHECKED BY: SCALE: 1/4" = 1'-6DATE: 07/31/17

- K - S - 0"	A4-10	)
7	OF	

SHEET NUMB

100% CONSTRUCTION DOCUMENT

PARTITION NOTES:

 $\prec x$ 

ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND REQUIREMENTS FOR PARTITIONS. 1

EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO 2 FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER

WALL TYPE REFERENCE REFER TO SHEET A5-10.

PRIOR TO CORING AND/ OR CUTTING.

THICK LINE INDICATES NEW SURFACE FINISH.

![](_page_11_Figure_0.jpeg)

### **RCP DEMOLITION KEYNOTES:**

- (1) REMOVE 24"X24" ACP CEILING.
- (2) GWB CEILING TO REMAIN
- 3 REMOVE LIGHT FIXTURE, REFER TO ELEC. DWGS.
- (4) REMOVE MECH. AIR REGISTER REFER TO MECH.
- DWGS. (5) REMOVE EXISTING GWB AND SOFFIT.
- (6) REMOVE EXISTING GYPSUM BOARD SOFFIT AND
- METAL FRAMING.
- (<sup>7</sup>) REMOVE SPRINKLER HEAD.
- 8 REMOVE EXISTING GWB CEILING.
- (9) REMOVE EXISTING CEILING DEVICE, SAVE TO REINSTALL.
- 10 NOT USED.
- 11) NOT USED.
- (12) ERECT AND TIGHTLY SEAL TO TOP OF PARTITION AND TO UNDERSIDE OF DECK WITH VISQUEEN. TAPE ALL EDGES TO STOP AIR LEAKAGE.
- (13) REMOVE EXISTING CEILING TILES, LIGHTS, HVAC GRILLS AS A NEEDED TO ERECT DUCTWORK ABOVE. PROVIDE TEMPORARY INFECTION CONTROL PARTITION WITH HEPA-FILTERED NEGATIVE AIR TO COVER AREA AS NEEDED.

![](_page_11_Picture_16.jpeg)

	NEGATIVE AIR TÔ ČÔVĚŘ AŘĚA AŠ ŇEĚDĚĎ.
)	SALVAGE OR PRESERVE AND PROTECT ALL CEILING EQUIPMENT AND TILES ALL TO BE REINSTALLED.
)	REMOVE EXISTING LIGHT FIXTURE, SAVE FOR REINSTALLATION.

\_\_\_\_\_

### MATERIAL LEGEND:

	2X2 ACOUSTICAL CEILING TILE
	SUSPENDED GYP. BOARD CEILING RECESSED LAY-IN LED LIGHT FIXTURE PROVIDE (2) SLACK SAFETY WIRES AT DIAGONAL CORNERS
	RECESSED "CAN" LIGHT PROVIDE (1) SLACK SAFETY WIRE
	RECESSED "CAN" LIGHT DIRECTED TOWARD WALL PROVIDE (1) SLACK SAFETY WIRE
$\bigotimes$	EXIT SIGN PROVIDE (1) SLACK SAFETY WIRE AT CLG MOUNTED FIXTURES
$\langle$	SMOKE DETECTOR PROVIDE (1) SLACK SAFETY WIRE
S	PAGING SPEAKER PROVIDE (1) SLACK SAFETY WIRE
R	2'-0' RETURN AIR
	RETURN AIR OR EXHAUST PROVIDE (2) SLACK SAFETY WIRES AT DIAGONAL CORNERS.
\$	3'-0" SUPPLY AIR DIFFUSER
	SUPPLY AIR DIFFUSER PROVIDE (2) SLACK SAFETY WIRES AT DIAGONAL CORNERS
	2' X 2' CEILING ACCESS PANEL
$\bigvee$	1' X 1' CEILING ACCESS PANEL
$\square$	1' X 1' CEILING EXHAUST
$\square$	1' X 1' CEILING HVAC SUPPLY
	1' X 1' CEILING HVAC RETURN
	1' X 4' FLOURESCENT CEILING LIGHT
C	CAMERA
$\textcircled{\bullet}$	SPRINKLER HEAD
$\ominus$	AUDIBLE NURSE CALL
	HEPA FILTER
$\land \diamond \diamond$	CHIME / STROBE
- S	STROBE
	BSC EXHAUST
	WI-FI
	All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, el

![](_page_11_Figure_20.jpeg)

![](_page_11_Picture_21.jpeg)

### **GENERAL NOTES:**

- THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

# RCP DEMOLITION NOTES:

- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING DEMOLITION.
- 2. THE GENERAL CONTRACTOR SHALL COORDINATE ALL PHASING, ACCESS, DEBRIS REMOVAL, STAGING AREAS AND HOURS OF CONSTRUCTION WITH OWNER PRIOR TO START OF DEMOLITION.
- 3. THE GENERAL CONTRACTOR SHALL COORDINATE WITH STRUCTURAL, MEP, FIRE ALARM, FIRE PROTECTION, NURSE CALL, INTERIORS AND EQUIPMENT DRAWINGS PRIOR TO STARTING DEMOLITION. THE PROJECT MANUAL AND ALL DRAWINGS IN THE CONSTRUCTION DRAWINGS SHALL BE PART OF THE CONSTRUCTION DOCUMENTS.
- 4. THE GENERAL CONTRACTOR SHALL SEPARATE DISSIMILAR METALS WITH BUILDING PAPER OR PLASTIC SHIM.
- 5. THE GENERAL CONTRACTOR SHALL X-RAY AND/OR ULTRASOUND THE EXISTING CONCRETE FLOORS FOR ANY POSSIBLE EMBEDDED CONDUITS, STRUCTURAL REBAR OR UNFORESEEN CONDITION THAT IS OUTSIDE THE SCOPE OF WORK AND MIGHT IMPEDE THE ANCHORING OF EQUIPMENT OR CONFLICT WITH TRENCHING PRIOR TO CONSTRUCTION.
- 6. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.
- 7. CONTRACTOR STAGING TO BE IN THE ROOMS UNDER REMODEL
- 8. CONTRACTOR PARKING TO BE IN CONTRACTOR DESIGNATED PARKING AREA.
- 9. THE CONTRACTOR SHALL ENSURE THAT THE AREA UNDER REMODEL IS LOCKED AND OTHERWISE SECURED AFTER HOURS.
- 10. UNLESS OTHERWISE NOTED, CONTRACTOR SHALL COORDINATE WITH THE OWNER THE REMOVAL OF EXISTING EQUIPMENT INDICATED ON DRAWINGS.
- 11. DASHED LINES INDICATE ITEMS TO BE DEMOLISHED OR REMOVED. REFER TO CEILING PLAN, ROOM FINISH SCHEDULE ALONG WITH MECHANICAL AND ELECTRICAL SECTIONS FOR FURTHER DESCRIPTION OF SCOPE OF WORK.
- 12. REFER TO DEMOLITION PLAN FOR NOTES INDICATING TYPE OF FINISHES WITHIN THE EXISTING SPACE TO BE REMOVED.
- 13. REFER TO RELATED PLANS FOR PORTIONS OF EXISTING CONSTRUCTION SCHEDULED TO REMAIN.
- 14. PATCH NEW WORK TO MATCH AND ALIGN WITH THE EXISTING. COMPLETELY REMOVE EXISTING FINISHES WHERE NEW FINISHES ARE SCHEDULED.
- 15. CONTRACTOR SHALL PRESERVE AND PROTECT THE EXISTING OVERHEAD EQUIPMENT, LIGHTING, FIRE ALARM, FIRE SPRINKLER, PAGING, PHONE, DATA, ELECTRICAL LINES, ETC. SCHEDULED TO REMAIN DURING THE COURSE OF DEMOLITION. MANY OF THE SYSTEMS ARE SCHEDULED FOR REUSE BY THE OWNER UNDER THIS OR SEPARATE CONTRACTS.
- 16. PROVIDE DUST CURTAIN ABOVE CEILING AND ISOLATE CONSTRUCTION AREA FROM THE REMAINDER OF THE FLOOR. PROVIDE A FLEX DUCT FROM SEALED AREA ABOVE CONSTRUCTION AREA, ROUTED AND EXHAUSTED INTO EXISTING EXHAUST SYSTEM.

# PARTITION LEGEND:

![](_page_11_Picture_43.jpeg)

ACCESSIBLE PATH OF TRAVEL.

EGRESS PATH OF TRAVEL.

ONE-HOUR RATED CORRIDOR.

\_\_\_\_\_ INDICATES AN EXISTING MEMBRANE OF PARTITION OR \_\_\_\_\_ PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS. INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS. 3 INDICATES AN EXISTING 1 HOUR SMOKE PARTITION PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB - FB - FB - INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB III INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. INDICATES A NEW 1 HOUR SMOKE PARTITION FP ------ FP ------ INDICATES A NEW ONE HOUR RATED FIRE PARTITION EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. THICK LINE INDICATES NEW SURFACE FINISH. INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING. WALL TYPE REFERENCE REFER TO SHEET A5-10.  $\prec x >$ PARTITION NOTES ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND

REQUIREMENTS FOR PARTITIONS.

WIDTH OF WALL TO BE SET.

;, electronic, or mechanical, including photocopying, recording, taping, or informati

2. EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR

CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE

![](_page_11_Picture_48.jpeg)

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

4002 Vista Way Oceanside, California 92056

OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347

STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188

11 × 110	SED (R) NICHA NO. C 28543 ₹ No. C 28543 ₹ TOT CN (C) NO. C 28543 ₹ NO. C 28543 ₹	
∧ <u> </u>		<sup></sup>
$\frac{1}{2}$	OSHPD COMMENTS	10-09-17
$\frac{2}{2}$	DESIGN CHANGES	10-09-17
$\frac{\sqrt{3}}{\sqrt{3}}$	OSHPD COMMENTS	12-11-17
	DESIGN CHANGES	12-11-17
5	OSHPD COMMENTS	5-15-18
	DESIGN CHANGES	6-05-18
REV:	DESCRIPTION:	DATE:

### OSHPD APPROVAL STAMP:

![](_page_11_Picture_58.jpeg)

PROJECT TITLE: TCMC USP 800

PROJECT # 01667.00 DRAWN BY: NI CHECKED BY: IS

Scale: 1/4" = 1'-0"

DATE:

A4-2	20

100% CONSTRUCTION DOCUMENT

07/31/17

![](_page_12_Figure_0.jpeg)

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or i

### GENERAL NOTES:

- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### **RCP GENERAL NOTES:**

- THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- THE GENERAL CONTRACTOR SHALL COORDINATE ALL PHASING, ACCESS, DEBRIS REMOVAL, STAGING AREAS AND HOURS OF CONSTRUCTION WITH 2. OWNER PRIOR TO START OF CONSTRUCTION.
- THE GENERAL CONTRACTOR SHALL COORDINATE WITH STRUCTURAL, MEP, 3. FIRE ALARM, FIRE PROTECTION, NURSE CALL, INTERIORS AND EQUIPMENT DRAWINGS PRIOR TO STARTING CONSTRUCTION. THE PROJECT MANUAL AND ALL DRAWINGS IN THE CONSTRUCTION DRAWINGS SHALL BE PART OF THE CONSTRUCTION DOCUMENTS.
- THE GENERAL CONTRACTOR SHALL SEPARATE DISSIMILAR METALS WITH BUILDING PAPER OR PLASTIC SHIM.
- THE GENERAL CONTRACTOR SHALL X-RAY AND/OR ULTRASOUND THE 5 EXISTING CONCRETE FLOORS FOR ANY POSSIBLE EMBEDDED CONDUITS, STRUCTURAL REBAR OR UNFORESEEN CONDITION THAT IS OUTSIDE THE SCOPE OF WORK AND MIGHT IMPEDE THE ANCHORING OF EQUIPMENT OR CONFLICT WITH TRENCHING PRIOR TO CONSTRUCTION.
- REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT 6. INDICATED ON THIS SHEET.
- 7. CONTRACTOR STAGING TO BE IN THE ROOMS UNDER REMODEL.
- CONTRACTOR PARKING TO BE IN CONTRACTOR DESIGNATED PARKING 8. AREA.
- THE CONTRACTOR SHALL ENSURE THAT THE AREA UNDER REMODEL IS 9. LOCKED AND OTHERWISE SECURED AFTER HOURS.
- 10. CEILING HEIGHTS TO MATCH EXISITNG UNLESS OTHERWISE NOTED (NOT LESS THAN 8'-0")
- 11. REFER TO SHEET A5-60 AND A5-70 FOR CEILING DETAILS. 12. REFER TO ELECTRICAL DRAWINGS FOR LIGHT FIXTURE TYPES.
- 13. FIRE SPRINKLER HEAD LAYOUT MUST BE APPROVED BY ARCHITECT PRIOR TO INSTALLATION, ALL EXPOSED SPRINKLER HEAD COMPONENTS SHALL BE WHITE.
- 14. REPLACE EXISTING LENSES FOR 2X2 AND 2X4 LIGHT FIXTURES.

### 15. REPLACE ALL GRILLES, DIFFUSERS AND REGISTERS WITH NEW. MATERIAL LEGEND:

		TEL(019)010-2347
	2X2 ACOUSTICAL CEILING TILE	STRUCTURAL: SUN STRUCTURAL ENGINEE 2091 LAS PALMAS DRIVE, CARLSBAD, CA 92011 TEL(760)438–1188
	SUSPENDED GYP. BOARD CEILING RECESSED LAY-IN LED LIGHT FIXTURE	CENSED AR CHINEAU CONNICAU No. C28543 TO T
	RECESSED "CAN" LIGHT PROVIDE (1) SLACK SAFETY WIRE RECESSED "CAN" LIGHT DIRECTED TOWARD WALL	OF CALIFORNIE
<ul> <li>∑</li> <li>∑</li> </ul>	EXIT SIGN PROVIDE (1) SLACK SAFETY WIRE AT CLG MOUNTED FIXTURES SMOKE DETECTOR PROVIDE (1) SLACK SAFETY WIRE	$ \begin{array}{c ccccccccccccccccccccccccccccccccccc$
	PAGING SPEAKER PROVIDE (1) SLACK SAFETY WIRE 2'0' RETURN AIR	
s s	RETURN AIR OR EXHAUST PROVIDE (2) SLACK SAFETY WIRES AT DIAGONAL CORNERS. 3'-0" SUPPLY AIR DIFFUSER	REV: DESCRIPTION:
	2' X 2' CEILING ACCESS PANEL	OSHPD APPROVAL STAMP: $OSHDD$ $\mu$ : $S171611 - 37 - 00$
	1 X 1 CEILING ACCESS PANEL 1' X 1' CEILING EXHAUST 1' X 1' CEILING HVAC SUPPLY	REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR APPROVED with comments
	1' X 1' CEILING HVAC RETURN 1' X 4' FLOURESCENT CEILING LIGHT	KC Huang, Sr. Architect Office of Statewide Health Planning & Development FACILITIES DEVELOPMENT DIVISION
	SPRINKLER HEAD AUDIBLE NURSE CALL	SHEET TITLE: REFLECTED CEILING PLAN
	HEPA FILTER CHIME / STROBE	PROJECT TITLE: TCMC USP 800
Š Ø	STROBE	PROJECT #: 01667.00 SHEET NUMBER: DRAWN BY: NI CHECKED BY: JS SCALE: DRAWN DATE: CHECKED BY: JS
	WI-FI	$\frac{1/4" = 1' - 0"}{DATE: 07/31/17}$

### S R F A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

4002 Vista Way

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

Oceanside	e, California 92056	
OWNER:	R: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056	
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUIT SAN DIEGO, CALIFORNIA 9212 TEL(619)299–3917 FAX(619)	E 100 2 299-508
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITI SAN DIEGO, CA 92123 TEL(619)618–2347	
STRUCTURAL:	SUN STRUCTURAL ENGINEERIN 2091 LAS PALMAS DRIVE, SU CARLSBAD, CA 92011 TEL(760)438–1188	ig Ite d
STATE OF	28543 5 *	
SHPD C	OMMENTS	10-09-17
$\frac{1}{2}$ design c	HANGES	10-09-17
$\frac{\sqrt{3}}{\sqrt{3}}$ Oshpd c	OMMENTS	12–11–17
	HANGES	12-11-17
6 DESIGN C	UMMEN IS 	0-15-18 2 6-05-18
		·
		•

OSHPD #:	S171641-37-00

![](_page_12_Picture_29.jpeg)

![](_page_13_Figure_0.jpeg)

6

			ר.			LEVA		NKEY	NOTES:
			D. FOLIIDMENT SCHEDUILE		$\langle 1 \rangle$	PAINT TO	MATCH EXI	STING.	
$\langle 11 \rangle$	/ /	NOTES	O EQUIFMENT SCHEDULE.		$\langle 2 \rangle$	WALL PRO	TECTION SH	EETING SEE	ID SHEET.
1'-6") 7"		FWOR	R IFCFND.		$\langle 3 \rangle$	° 6" VINYL E	BASE TO M	ATCH EXISTII	NG.
	<u>CASE</u>	ID NUM	<u>BER</u> <u>HEIGHT</u>		4	NEW STAIN	ILESS STEEI	L COUNTER	/BACKSPLASH WITH SINK AND
	D100G24			HEIGHT	$\sim$	EYEWASH.		~~~~~	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
		ASE WIDTH (IN ASE HEIGHT - ASE TYPE (RE	$\begin{array}{c} \text{CHES} ( = \text{ AS REQ'D.}) \\ \hline \\ \text{EFER TO W.I.C.} \\ \end{array} \qquad \qquad$	18" 24"	5	REINSTALL	(E) DOOR	FRAME, PRIN	ME AND PAINT, WITH NEW DOOR,
	S S M	PECIAL PREFIX = DOUBLE = MODIFY	C D	27" 30"	6	4" BACK S	SPLASH.		
	TASK24 =	24" TASK LI	GHT MODULE	30" 33" 36"		NEW LOW	AIR EXHAUS	ST GRILLE.	
	TASK36 = TASK48 =	36" TASK LIG	GHT MODULE H GHT MODULE J	39" 42"	8	NO LOWER	CABINETS.	ADD WALL	
"  <u> </u> -9"	FTPED =			48" 54"	9	REINSTALL	ED DOOR O	PERATOR SE	ENSOR PLATE.
	LOWER	<u>1 (U.U.N</u> CASE: 24'	. ON ELEVATIONS)     M       ' DEEP     U.O.N.	80" 86"		STAINLESS	STEEL SUF	PORT PANE	LS.
$\sqrt{2}$	UPPER TALL C	CASE: 14" ASE: 14"	DEEPU.O.N.QDEEPU.O.N.R	96" AS REQ'D.		NEW SOFFI	T. SEE DET	AIL 6/A5-1	0. <u> </u>
9/ 243	<u>OUTLE</u>	T DESC	RIPTION			LOWER ST	AINLESS ST		rs
	A – C – D –	MEDICAL CODE BLU DATA	COMPRESSED AIR NO – NITROU JE O – OXYGEN PS – NURSE	S OXIDE I CALL PULL STATIC			AIINLESS STEEL		13.
	DP - DS -	DICTAPHC DIMMER S	NE S – SWITCH T – TELEPH	ONE			STEEL EL		
	E – F –	DUPLEX E	ELECT. OUTLET TL – TASK L HINE TV – TELEVIS	IGHT ION		OPENING W	VITH STAINL	ESS STEEL I	
	J – J	JUNCTION	BOX VC – VACUU BOX VC – VOLUME ALL VS – VACUU	CONTROL SLIDE	16	EXISTING T	O REMAIN.	~~~~	
						NEW INFILL	. PARTITION		
						DONNING A	AND DOFFIN	G AREA.	
					19	WALL MOU	NTED CLEAN	NING SUPPLI	
					20	THERMOST	AT. MOUNTI	NG HEIGHT	
i l					21	REINSTALL	DOOR OPE	RATOR.	
					22	CORNER G	UARD.	$\sim$	
					<23	4"x4" GLA	ZED CERAM	IÇ TILE(.	~~~~~~ <sup>(</sup>
					24	SEMIGLOSS	PAINT. PR	IME AND PA	AINT TO MATCH EXISTING.
					25	REMOVE A	ND REINSTA	LL TOILET A	ACCESSORY.
< <u>009</u> < 017					26	1"x1"_CER4	MIC FLOOR	TILE.	
<u>DOM</u> WEST					27>		AND PROTE	ECT TOILET	ACCESSORY.
					· · · ·				
		OF0I : 0'	WNER FURNISHED, OWNER INSTALLED		28	TYPICAL C	OUNTER SU	PPORT SIMIL	AR TO DETAIL 8/A5-80.
		OFOI : 0 OFCI : 0 CFCI : C	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST	ALLED	28	TYPICAL C	ounter su	PPORT SIMIL	AR TO DETAIL 8/A5-80.
		OFOI : O' OFCI : O' CFCI : CO	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEI	ALLED	28	TYPICAL C	OUNTER SU	PPORT SIMIL	LAR TO DETAIL 8/A5-80.
23 27		OFOI : O' OFCI : O' CFCI : CO EQUIP #	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEI DESCRIPTION	ALLED DULE WEIGHT(APPROX.)	28 HEIGHT=h	TYPICAL C	OUNTER SU	PPORT SIMIL	AR TO DETAIL 8/A5-80.
23 27		OFOI : 0' OFCI : 0' CFCI : CC EQUIP # 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEI DESCRIPTION BSC WORKSTATION MONITOR	ALLED DULE WEIGHT(APPROX.) 800 LBS N/A	28 HEIGHT=h 90.5" 16"	WIDTH=b 52.5"	DEPTH=d 33.5" 7.5"	PPORT SIMIL ELEV/SHT -/A-9 -/-	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER
> 23 27		OFOI : 0' OFCI : 0' CFCI : CC EQUIP # 001 002 003	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU	ALLED DULE WEIGHT(APPROX.) 800 LBS N/A N/A	HEIGHT=h 90.5" 16" 18"	TYPICAL       C         WIDTH=b       52.5"         52.5"       15"         6"       6"	DEPTH=d 33.5" 7.5" 18"	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER
23 27		0F0I : 0' 0FCI : 0' CFCI : CC EQUIP # 001 002 003 004 005	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR	ALLED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS	HEIGHT=h 90.5" 16" 18" 3" 84"	TYPICAL       C         WIDTH=b       52.5"         52.5"       15"         6"       18"         56"       56"	DEPTH=d 33.5" 7.5" 18" 6" 35"	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30
		OFOI : 0' OFCI : 0' CFCI : C( EQUIP # 001 002 003 004 004 005 006	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR	ALLED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26"	TYPICAL       C         WIDTH=b       52.5"         52.5"       15"         6"       18"         56"       22"         10"       10"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21"	PPORT SIMIL	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56
		OFOI : 0 OFCI : 0 CFCI : C EQUIP # 001 002 003 004 004 005 006 007 008	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH	ALLED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70"	TYPICAL       C         WIDTH=b       52.5"         52.5"       15"         6"       18"         56"       22"         12"       50"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34"	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL
		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 006 006 007 008 009 009	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION	ALLED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1 000 LBS	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 78"	TYPICAL       C         WIDTH=b       52.5"         52.5"       15"         6"       18"         56"       22"         12"       50"         74"       52"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 34" 28"	PPORT SIMIL	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 008 009 009 010 011	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN	ALLED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 78" 78"	TYPICAL       C         WIDTH=b       52.5"         52.5"       15"         6"       18"         56"       22"         12"       50"         74"       52"         52"       52"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 34" 28" 28"	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 009 010 011 012 013	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED -	ALLED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 78" 78" 78" -	WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         -         -	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" - - -	PPORT SIMIL	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
23 27 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7		OFOI : 0 OFCI : 0 CFCI : C EQUIP # 001 002 003 004 004 005 006 006 007 006 007 006 007 008 009 009 009 009 009 009 009 009 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1	ALLED WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 78" 78" 78" - - 27"	TYPICAL       Clinical         WIDTH=b       52.5"         52.5"       15"         6"       18"         56"       22"         12"       50"         74"       52"         52"       -         -       -         22ø"       -	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" - - - -	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
23 27 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	_	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 009 010 010 011 012 013 014 015 016	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP	ALLED	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         78"         78"         27"         26"         13"	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         12"         12"         12"         50"         74"         52"         52"         52"         52"         13"         8"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" - - - 19" 10"	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
23 $27$ $1$ $27$ $1$ $27$ $27$ $27$ $27$ $27$ $27$ $27$ $27$	-	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 001 001 001 001 001 001 002 003 004 002 003 004 005 006 007 001 007 006 007 006 007 006 007 007	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL	ALLED	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 78" 78" 78" 78" 78" 78" 78" 78" 78" 78	WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52.5"         12"         50"         74"         52"         52"         13"         8"         -         10"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" - - 19" 10" - 10" - 10" - 10"	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
$\frac{23}{27}$	_	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 001 010 010 011 012 013 014 015 014 015 016 017 016 017 018 019 019	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT.	ALLED  VEIGHT(APPROX.)  WEIGHT(APPROX.)  800 LBS N/A N/A N/A N/A 1,470 LBS 100 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A N/A 25 LBS N/A 25 LBS N/A	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 78" 78" - 26" 70" 78" 78" - 26" 13" 13" 16"	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         13"         8"         -         10"         12ø	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" - - 19" 10" - 19" 10" - 19" - -	PPORT SIMIL	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
$\frac{23}{27}$		0F0I : 0 0FCI : 0 CFCI : CC EQUIP # 001 002 003 004 005 006 007 006 007 008 009 005 006 007 008 009 010 010 010 011 012 013 014 015 015 016 017 018 019 020 020 020 020 020 012 013 014 015 015 015 015 015 015 015 015	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED -	ALLED  VEIGHT(APPROX.)  WEIGHT(APPROX.)  800 LBS N/A N/A N/A N/A 1,470 LBS 100 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 70" 70" 70" 70" 70	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52.5"         12"         50"         74"         52"         -         220"         13"         8"         -         10"         120         11"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" - - 19" 10" - 19" 10" - 19" - 15" -	PPORT SIMIL	AR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
$\frac{23}{27}$		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 008 009 005 006 007 008 009 001 001 001 001 002 003 004 005 006 007 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 008 007 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 001 001 001 001 005 006 007 007 008 009 001 001 001 001 001 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE	ALLED	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         -         27"         26"         13"         -         13"         16"         18"         -         34"	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         74"         52"         74"         52"         12"         12"         12"         12"         12"         13"         8"         -         10"         12ø         11"         -         26"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 19" 19"	PPORT SIMIL	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 
25		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 001 001 001 002 003 004 002 003 004 005 006 007 006 007 008 009 001 001 002 003 004 005 006 007 007	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED -	ALLED	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         79         26"         13"         16"         <	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         74"         52"         12"         12"         12"         12"         13"         8"         -         10"         12ø         11"         -         26"         20"         -         20"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - - 19" 10" - 19" 10" - 19" 10" - 19" 17" - - 19" 17" -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252,
$\frac{23}{20}$	-	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 008 009 006 007 008 009 001 001 001 001 002 003 004 005 006 007 008 009 001 001 001 002 003 004 005 006 007 006 007 008 009 001 001 001 002 003 004 005 006 007 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 001 001 001 005 006 007 008 009 001 001 001 001 001 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE	ALLED	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         -         27"         26"         13"         -         13"         16"         18"         -         34"         24"         -         16"	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52.5"         12"         50"         74"         52"         -         220"         11"         -         26"         20"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16"	PPORT SIMIL ELEV/SHT -/A-9 -/- -/- -/- -/- -/- -/- -/- -	AR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STER KELVINATOR/MODEL BT30 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 
$\frac{23}{26}$		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 005 006 007 008 009 005 006 007 008 009 001 001 001 002 003 004 005 006 007 008 009 001 005 006 007 008 009 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 001 001 005 006 007 008 009 001 001 001 001 005 006 007 008 009 001 001 001 001 001 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - PRINTER - NOT USED - PRINTER - NOT USED -	ALLED	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 70" 70" 70" 70" 70	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         74"         52"         74"         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         74         74         74         74         74         74         74         74         75         74         75         74         75         74 <td>DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16" - 16" - 5" - 16" - 5" - - - - - - - - - - - - -</td> <td>PPORT SIMIL  ELEV/SHT -/A-9 -/////////</td> <td>AR TO DETAIL 8/A5-80.</td>	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16" - 16" - 5" - 16" - 5" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.
$\frac{23}{26}$		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 008 009 006 007 008 009 001 001 001 002 003 004 005 006 007 006 007 008 009 001 005 006 007 006 007 008 009 001 005 006 007 008 009 001 005 006 007 008 009 001 005 006 007 008 009 001 005 006 007 008 009 001 001 005 006 007 008 009 001 002 003 006 007 008 009 001 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 008 009 001 001 005 006 007 005 006 007 008 009 001 001 001 001 001 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHES DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - PRINTER - NOT USED - PRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD	ALLED	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 70" 70" 70" 70" 70	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"      7	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16" - 19" 10" - 16" - 19" 10" - 19" 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - - 10" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.
$\frac{23}{26}$	_	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 006 007 008 009 010 010 010 010 011 012 013 014 015 016 017 013 014 015 016 017 018 019 020 010 012 013 014 015 016 017 018 019 020 010 012 012 013 014 015 016 017 018 019 020 021 022 022 023 024 025 026 027 025 026 027 025 026 027 028 029 030 030 030 020 020 010 010 010 010 010 01	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHES DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - PRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTF	ALLED         WEIGHT(APPROX.)         800 LBS         N/A         N/A         N/A         N/A         1,470 LBS         100 LBS         100 LBS         100 LBS         100 LBS         100 LBS         N/A         440 LBS         680 LBS         1,000 LBS         1,000 LBS         N/A	HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 70" 70" 70" 70" 70	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"         74"      7	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16" - 16" - 6" N/A 30" -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.
$\frac{23}{26}$		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 006 007 008 009 010 010 010 010 010 010 011 012 013 014 015 016 017 018 019 010 017 018 019 020 010 011 012 013 014 015 016 017 018 019 020 021 022 022 023 024 025 026 027 026 027 028 029 030 031 031 031 031 031 031 031	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHES DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES	ALLED         WEIGHT(APPROX.)         800 LBS         N/A         N/A         N/A         N/A         N/A         1,470 LBS         100 LBS         N/A         1,470 LBS         100 LBS         N/A         1,000 LBS         1,000 LBS         1,000 LBS         N/A	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         70"         78"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         34"         24"         -         16"         18"         -         34"         24"         -         16"         -         16"         -         16"         -         18"         36"         79"         -         -         18"         36"         79"         -         -	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         74"         52"         74"         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         74         52"         74         74         74         74         74         74         74         74         74         74         74         74         74         74         74         74 <td>DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16" - 16" - 16" - 16" - - 16" - - - - - - - - - - - - -</td> <td>PPORT SIMIL  ELEV/SHT -/A-9 -/////////</td> <td>AR TO DETAIL 8/A5-80.</td>	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 16" - 16" - 16" - 16" - - 16" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.
23 27 4 4 5 26 26 26 26 26 26 26 26 26 26 26 26 26		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 006 007 008 009 001 010 010 010 011 012 013 014 015 016 017 018 019 010 011 012 013 014 015 016 017 018 019 020 010 010 010 011 012 013 014 015 016 017 018 019 020 021 022 023 024 025 026 027 028 029 030 031 032 030 031 032 030 031 032 030 031 032 031 032 033 031 032 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 031 032 033 033 031 032 033 033 033 033 035 035 035 035	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHES DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - FRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATOR - NOT USED -	ALLED         WEIGHT(APPROX.)         800 LBS         N/A         N/A         N/A         N/A         1,470 LBS         100 LBS         N/A         1,470 LBS         100 LBS         N/A         1,000 LBS         1,000 LBS         1,000 LBS         1,000 LBS         N/A         N/A </td <td>28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         70"         78"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         34"         24"         -         34"         24"         -         16"         -         34"         24"         -         18"         36"         79"         -         -         85"         -</td> <td>TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         13"         8"         -         120"         11"         -         20"         11"         -         26"         20"         -         20"         -         18"         24"         53"         -         51"</td> <td>DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" - 19" 10" - 10" - 19" 10" - 19" 10" - 15" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - - 10" - - 10" - - 10" - - 10" - - 10" - - 10" - - - 10" - - - 10" - - - - - - - - - - - - -</td> <td>PPORT SIMIL  ELEV/SHT -/A-9 -/////////</td> <td>AR TO DETAIL 8/A5-80.</td>	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         70"         78"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         34"         24"         -         34"         24"         -         16"         -         34"         24"         -         18"         36"         79"         -         -         85"         -	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         13"         8"         -         120"         11"         -         20"         11"         -         26"         20"         -         20"         -         18"         24"         53"         -         51"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" - 19" 10" - 10" - 19" 10" - 19" 10" - 15" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - - 10" - - 10" - - 10" - - 10" - - 10" - - 10" - - - 10" - - - 10" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.
23 27 4 4 5 26 26 26 26 26 26 26 26 26 26 26 26 26		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 006 007 008 009 010 010 010 011 012 013 014 015 016 017 013 014 015 016 017 018 019 020 021 022 023 024 025 026 027 022 022 023 024 025 026 027 022 022 023 024 025 026 027 022 023 024 025 026 027 022 023 024 025 026 027 022 023 024 025 026 027 026 027 026 027 026 027 026 027 028 029 030 031 032 033 034 034	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - FRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATÓR - NOT USED - NOT USED - NOT USED - NOT USED - NOT USED - MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES	ALLED         WEIGHT(APPROX.)         800 LBS         N/A         N/A         N/A         N/A         1,470 LBS         100 LBS         N/A         440 LBS         680 LBS         1,000 LBS         1,000 LBS         1,000 LBS         1,000 LBS         N/A         N/A <td>28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         13"         -         34"         24"         -         16"         -         36"         79"         -         85"         -         -         85"</td> <td>TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52.5"         12"         50"         74"         52"         -         220"         13"         8"         -         100"         120         11"         -         20"         -         20"         -         20"         -         20"         -         18"         24"         53"         -         51"</td> <td>DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 10" - - 15" - - 15" - - - - - - - - - - - - -</td> <td>PPORT SIMIL  ELEV/SHT  -/A-9  -/-  -/-  -/-  -/-  -/-  -/-  -</td> <td>AR TO DETAIL 8/A5-80.</td>	28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         13"         -         34"         24"         -         16"         -         36"         79"         -         85"         -         -         85"	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52.5"         12"         50"         74"         52"         -         220"         13"         8"         -         100"         120         11"         -         20"         -         20"         -         20"         -         20"         -         18"         24"         53"         -         51"	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 15" - 10" - - 15" - - 15" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT  -/A-9  -/-  -/-  -/-  -/-  -/-  -/-  -	AR TO DETAIL 8/A5-80.
23 27 4 4 5 26 1/4" = 1'-0"		0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 010 010 010 011 012 013 014 015 016 017 018 019 010 011 012 013 014 015 016 017 018 019 020 021 022 023 024 025 026 027 028 029 020 021 022 023 024 025 026 027 028 029 030 031 032 034 035 035 035 035 035 035 035 035	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHES DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - - NOT USED - (V STORAGE(MOBILE) IV STORAGE(MOBILE) INCINERATION WASTE	ALLED         WEIGHT(APPROX.)         800 LBS         N/A         N/A         N/A         N/A         1,470 LBS         100 LBS         100 LBS         100 LBS         1,000 LBS         1,000 LBS         1,000 LBS         1,000 LBS         N/A         N/A <td><math display="block"> \begin{array}{c} 28\\ \hline 16"  ^{\circ}\phantom</math></td> <td>TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"      7</td> <td>DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" 28" 28" - 19" 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - - 10" - - 10" - - 10" - - 10" - - - 10" - - - - 10" - - - - - - - - - - - - -</td> <td>PPORT SIMIL  ELEV/SHT -/A-9 -/////////</td> <td>AR TO DETAIL 8/A5-80.</td>	$ \begin{array}{c} 28\\ \hline 16"  ^{\circ}\phantom$	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"      7	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" 28" 28" - 19" 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - 10" - - 10" - - 10" - - 10" - - 10" - - - 10" - - - - 10" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.
23 27 10 26 26 26 1/4" = 1'-0"		0F0I ::       0         0FCI ::       C         EQUIP #         001         002         003         004         005         006         007         008         009         010         011         012         013         014         015         016         017         018         019         020         021         022         023         024         025         026         027         028         029         030         031         032         033         034         035         036         037	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED DNTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - FREGULAR WASTE CONTAINER - NOT USED - - NOT USED - - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATOR - NOT USED - IV STORAGE(MOBILE) INCINERATION WASTE REGULAR WASTE	ALLED         WEIGHT(APPROX.)         800 LBS         N/A         N/A         N/A         N/A         1,470 LBS         100 LBS         N/A         1,470 LBS         100 LBS         N/A         1,470 LBS         100 LBS         N/A	$ \begin{array}{c} 28\\ \hline 28\\ \hline 28\\ \hline 28\\ \hline 28\\ \hline 16'' 18'' 3'' 6'' 3'' 26'' 70'' 70'' 70'' 70'' 70'' 70'' 70'' 7$	TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         52"         74"         74"         13"         8"         -         20"         -         20"         -         20"         -         18"         24"         53"         -         -         51"         -         -         -         51"      -	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 15" - 16" - 18" - 14" 19" - 14" 19" - - 14" 19"	PPORT SIMIL ELEV/SHT -/A-9 -/- -/- -/- -/- -/- -/- -/- -	AR TO DETAIL 8/A5-80.
23 27 10 26 10 1/4" = 1'-0"		0F0I :: 0         0FCI :: 0         001         002         003         004         005         006         007         008         009         010         011         012         013         014         015         016         017         018         019         020         021         022         023         024         025         026         027         028         029         030         031         032         033         034         035         036         037	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INST EQUIPMENT SCHEE DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY NULTI-ADD PUMP - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATOR - NOT USED - IV STORAGE(MOBILE) INCINERATION WASTE REGULAR WASTE CLOCK TEMPORERY WASYL STATION	ALLED		TYPICAL C         WIDTH=b         52.5"         15"         6"         18"         56"         22"         12"         50"         74"         52"         52"         74"         52"         74"         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         52"         74         13"         8"         7         120"         7         7         7         7         7         7         7         7         7         7         7         7         7         7         7         7	DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 19" 10" - 15" - 15" - 16" - 18" - 16" - 19" 10" - 19" 10" - 10" - 19" 10" - 19" 10" - 10" - 10" - 10" - 10" - 10" - 11" 10" - 10" - 11" 10" - - 11" 10" - - 11" 10" - - 11" 11" - - 11" - - - - - - - - - - - - -	PPORT SIMIL  ELEV/SHT -/A-9 -/////////	AR TO DETAIL 8/A5-80.

GENERAL	NO	TE	S:									SFEIR
1. THE GENERAL CONTR AND MEASUREMENTS	ACTOR S	SHALL FIELD	VERIF PRIOR	Y ALL E TO ST	EXISTIN ARTINO	IG CO G CON	NDITIO ISTRUC	NS CTION.				ARCHITECTS
2. REFER TO GENERAL N INDICATED ON THIS S	NOTES O HEET.	N SHEI	ET A0-0	00 FOR		RMATIO	TON NO	Г				5151 Shoreham Place, Suite 100
		/Δ٦	ΓΙΟ	NI (	GEI		RΔ	IN		TES		P: 619-299-3917
1. NOT USED.	<u> </u>								10		÷	F: 619-299-5084 www.sfeirarch.com
2. NOT USED.												TCMC
3. NOT USED.												PHARMACY
4. NOT USED.												USP 800
5. IN CASES OF CABINET FIELD AND PROVIDE FIL WIDTH AS REQUIRED TO	INSTALL/ LER PAN D FIT SP	ATIONS NEL ST ACE A	S BETW RIPS A S INDI	ÆEN W AT ENE CATED	VALLS, DS OR	VERIF REDU	Y DIME CE ENI	NSION CABI	S IN INETS			UPGRADE
6. ALL CABINET DOORS A CABINET DOORS AND F VERTICALLY. DRAWERS	ND DRAV ULL HEI( SHALL F	WERS S GHT C/ HAVE F	SHALL ABINET IORIZO	HAVE S SHA NTAL	PULLS	. UP VE PU	PER AN LLS MO	ND LO' DUNTE	WER D			Tri-City Medical Cente
7. ALL FILE DRAWERS SHA RODS EXTENDING FRON	ALL BE S T TO BA	SIZED I VCK OF	FOR 8 DRAV	1/2"× VER UN	( 11" F NIT TYF	ORMS. PICAL.	PRO	VIDE F	ILE			4002 Vista Way
8. COORDINATE HEIGHT AN STUD FRAMING CONTRA ▲ FURTHER INFORMATION.	ND LOCA ACTOR. R	TION ( REF AL	OF BAO SO TO	CKING DETAI	PLATES	S FOR ON SH	CASE EET S-	WORK -1 FOF	WITH २			Oceanside, California 92056
2 9. REFER TO SHEET A5-8 ANCHORAGE/BACKING	30 FOR N TRACK C	NEW S' CONNEC	TAINLE CTION.	SS STI	EEL CC	UNTEI	२					OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056
10. GENERAL CONTRACTOR COORDINATE W/OWNER SHOP DRAWINGS AND F	SHALL FOR AL FABRICAT	VERIFY L EQUI TION.	ALL [ PMENT	DIMENS	SIONS ( RANCE	DF RO S PRI	UGH O OR TO	PENIN( PREP	GS AN ARING	D	-	ARCHITECT: SFEIR ARCHITECTS
												SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084
												MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123
3											_	STRUCTURAL: SUN STRUCTURAL ENGINEERING
												CARLSBAD, CA 92011 TEL(760)438–1188
												SED AR
									1			SU ON MICH OF THE
HUMIDITY MONITOR & PRES	SURE MO	NITOR.	MOUN		HEIGHT	TO C		WITH				★ > No. C 28543 7 ★
												OF CALIFOR
KS	EXIS.	NEW	OFOI	OFCI	CFCI	QNTY	HVAC	ELECT	DATA	SEISMIC		$\frac{1}{2} \frac{1}{2} \frac{1}$
ILGARD, CALCS BY SSE	x	X	X	X		1 4	X N/A	X N/A	N/A N/A	X N/A		$\begin{array}{c} 23\\ 4\\ 4\\ 5\\ 6\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\ 7\\$
	× ×		X X			2 4	N/A N/A	N/A N/A	X N/A	N/A N/A		5     0SHPD COMMENTS     5-15-18       6     DESIGN CHANGES     6-05-18
RG-4.1, CALCS BY SSE 64.9149510	X X			X X		1 1	X N/A	X N/A	N/A N/A	X N/A		
. EG4252, CALCS BY SSE	X X			X X		1	N/A X	N/A X	N/A N/A	N/A X		
CALCS BY SSE	X			X		1	X	X	N/A	X		
	×			×		1	X	X	X	X		REV: DESCRIPTION: DATE:
	x		x			1	N/A	N/A	N/A	N/A		
	X X		X X			1 2	N/A X	N/A X	N/A N/A	N/A N/A		OSHPD APPROVAL STAMP:
	X		X			9	N/A	N/A	N/A	N/A N/A	_	OSHPD #: S171641-37-00
	× ×		X			1	N/A	^ N/A	^ N/A	N/A		REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR
	X		X			1	N/A	N/A	N/A	N/A		APPROVED with comments
	× ×		X			1	N/A	X	N/A	N/A		KC Huang, Sr. Architect
	x		x			2	N/A	x	x	N/A		Planning & Development FACILITIES DEVELOPMENT DIVISION
												07/23/2018 08:10:09 AM <b>#[ S171641-37-00 ]</b>
	X X		X X			2 1	N/A N/A	N/A N/A	N/A N/A	N/A N/A		
ORG-3, CALCS BY SSE	X X			X								ELEVATIONS
	X											
		X				2						PROJECT TITLE: TCMC USP 800
	x											PROJECT #: 01667.00 SHEET NUMBER:
	X											DRAWN BY: NI
	X											$\frac{JS}{SCALE: 1/4" = 1'-0"}  A4-40$
		X										DATE: 07/31/17 OF

100% CC	ΝΙΟΤΟΙ	ICTION	DOCL	

![](_page_14_Figure_0.jpeg)

L	EGE	ND:		<u>/2</u>	ELEV	ATIC	N KE	YNOTES:
	** REFE	R TO EQUIPMENT SCHEDULE.		$\langle 1$		О МАТСН Е	XISTING.	
		ES		2	WALL PR	ROTECTION	SHEETING SE	E ID SHEET.
$\begin{array}{c c} \hline & 10 \\ \hline & A5-80 \\ \hline & 12 \\ \hline & C \\ \hline \end{array}$	ASEW(	<u> ORK LEGEND:</u>		3	>6" VINYL	BASE TO	MATCH EXIS	TING.
	<u>ASE ID N</u>	UMBER HEIGH		4	NEW STA	AINLESS ST	EEL COUNTER	R /BACKSPLASH WITH SINK AND
	CASE WID	TH (INCHES) ( = AS REQ'D.)	18"	5		_L (E) DOO	R FRAME, PF	RIME AND PAINT, WITH NEW DOOF
	CASE TYP SPECIAL P D = DOUE	E (REFER TO W.I.C.) B REFIX C BLE	24" 27"	6	>4" ВАСК	SPLASH.		
	M = MODI	FY D E	30" 30" 33"	$\langle 7 \rangle$	> NEW LOW	V AIR EXHA	UST GRILLE.	
	3624 = 24" TAS $3636 = 36" TAS3648 = 48" TAS$	SK LIGHT MODULE G SK LIGHT MODULE H	36" 39"	8	> NO LOWE	R CABINET	'S. ADD WALL	PROTECTION.
	2ED = SINK FC	DOT CONTROL PEDALS	42" 48"	9	> REINSTAL	LED DOOR	OPERATOR S	SENSOR PLATE.
	<u>epth (u.(</u>	D.N. ON ELEVATIONS)	54 <sup>°°</sup> 72" 80"			SS STEEL S	UPPORT PAN	IELS.
'-11" 3'-6" LC	WER CASE: PPER CASE:	24" DEEP U.O.N. P 14" DEEP U.O.N. Q	86" 96"	× 11	> NEW SOF	FIT. SEE D	ETAIL 6/A5-	-10.
	ILL CASE:	14" DEEP U.O.N. R	I AS REQ'D.	12	/ UPPER S	TAINLESS S	STEEL CABINI	ETS.
7 $4$ $45-80$ $4$ $4$ $45-80$ $4$ $4$ $4$ $4$	– MEDIC	<u>SCRIFTION</u> AL COMPRESSED AIR NO – NITRO	US OXIDE	13	LOWER S	TAINLESS S	steel cabini	ETS.
	– CODE – DATA ? – DICTAE	PLUE 0 - OXYGE PS - NURSI PHONE S - SWITC	≟n E CALL PULL ST H		NEW STA	) VINLESS STE	EEL TABLE.	٨
DS E	6 – DIMME – DUPLE	R SWITCH T – TELEP X ELECT. OUTLET TL – TASK	HONE LIGHT	15		SS STEEL F	ULL HEIGHT	CABINET. COORDINATE ROUGH
FIC	- FAX M - INTERC	IACHINETV - TELEVCOMV - VACUIVOVO	ISION JM	$\sim$		WITH STAI	NLESS STEEL	- MANUFACTURER.
J N	– JUNCT – NURSE	ION BOX VC - VOLUN I CALL VS - VACUN	JM SLIDE	<16 ×	EXISTING		N.	
				<17 ×	>NEW INFI	LL PARTITIC	ON.	
6 45-80 $12$ $19$				<18 X		AND DOFF	ING AREA.	
	7			<19 ×	WALL MC	OUNTED CLE	EANING SUPP	
				<20 ×	THERMOS	STAT. MOUN	iting height	TO COMPLY WITH DETAIL
				21	REINSTAL	L DOOR OF	PERATOR.	
				22		GUARD.	$\sim$	
3				23	5 4"x4" GL	AZED CERA	AMIC TILE.	
				24		SS PAINT. I	PRIME AND F	PAINT TO MATCH EXISTING.
				25		AND REINS	TALL TOILET	ACCESSORY.
1 Start H				26	> 1 <b>"</b> x1" CE	RAMIC FLO	OR TILE.	·····)
				$\sim$				
					<b>`</b>			
$\Delta$ $(10)$ $(28)$ $(6)$				27		E AND PRO	DTECT TOILET	T ACCESSORY.
$\begin{array}{cccccccccccccccccccccccccccccccccccc$	0F0I : 0 0FCI : 0	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED		27 28	> PRESERV	e and pro	DTECT TOILET	I ACCESSORY.
$\begin{array}{c} \Delta \\ 10 \\ 4 \end{array} \end{array} $	OFOI : O OFCI : O CFCI : C	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL		27	> PRESERV	E AND PRO	DTECT TOILET	ACCESSORY.
$\begin{array}{c} & & & & & \\ & & & & & \\ & & & & & \\ & & & & \\ & & & & \\ & & & & \\ & & & & \\ & & & & \\ & &$	OFOI : O OFCI : O CFCI : C E	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED				E AND PRO	SUPPORT SIM	ACCESSORY.
$\begin{array}{c} \Delta \\ 10 \\ 4 \end{array} \end{array} \xrightarrow{28} \\ 4 \end{array}$	OFOI : 0 OFCI : 0 CFCI : C EQUIP #	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION	LED DULE WEIGHT(APPROX.) 800 LBS	27 28 HEIGHT=h 90.5"	> PRESERV > TYPICAL WIDTH=b 52.5"	E AND PRO COUNTER S DEPTH=d 33.5"	DTECT TOILET SUPPORT SIM	T ACCESSORY. IILAR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STERI
$\Delta \qquad \underbrace{10}_{10}  \underbrace{28}_{4} \qquad \underbrace{76}_{4}$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR	LED DULE WEIGHT(APPROX.) 800 LBS N/A	27 28 HEIGHT=h 90.5" 16"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5"	DTECT TOILET SUPPORT SIM	T ACCESSORY. IILAR TO DETAIL 8/A5-80. 30 REMAR VBM SG404 BAKER STERI
$\Delta \qquad \underbrace{10}_{4} \qquad \underbrace{28}_{4} \qquad \underbrace{76}_{4}$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD	LED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A	27 28 HEIGHT=h 90.5" 16" 18" 3"	PRESERV TYPICAL WIDTH=b 52.5" 15" 6" 18"	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6"	DTECT TOILET SUPPORT SIM	ACCESSORY.
$\Delta \qquad \underbrace{10}_{10}  \underbrace{28}_{4} \qquad \underbrace{76\Delta}_{4}$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 004	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR	LED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS	27 28 HEIGHT=h 90.5" 16" 18" 3" 84"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35"	DTECT TOILET SUPPORT SIM	ACCESSORY. ACCESSORY. ALLAR TO DETAIL 8/A5-80. 30 30 30 30 30 30 30 30 30 30
$\Delta \qquad \underbrace{10}_{4} \qquad \underbrace{28}_{4} \qquad \underbrace{76\Delta}_{4}$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 004 005 006	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE	LED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A	27 28 HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18"	DTECT TOILET SUPPORT SIM ELEV/SHT -/A-9 -/- -/- -/- -/- -/- -/- -/-	ACCESSORY. ALLAR TO DETAIL 8/A5-80. ALLAR
$\Delta$ $(10)$ $(28)$ $(28)$ $(26)$ $(4)$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 003 004 004 005 006 007 008	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH	LED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS	27 28 HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34"	DTECT TOILET SUPPORT SIM ELEV/SHT -/A-9 -/- -/- -/- -/- -/- -/- -/- -/-	ACCESSORY. ACCESSORY. ALLAR TO DETAIL 8/A5-80. ALLAR TO DETAIL 8/A5-80. ALLAR REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT301 KENMORE 56 BAKER "EDGEGARD"/MODEL
$\Delta$ $(10)$ $(28)$ $(28)$ $(26)$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 004 005 006 006 007 008 009	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION	LED VULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS	27 28 HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 78"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 34" 28"	DTECT TOILET SUPPORT SIM ELEV/SHT -/A-9 -/- -/- -/- -/- -/- -/- -/- -/- -/- -	ACCESSORY. ACCESSORY. ALLAR TO DETAIL 8/A5-80. ALLAR TO DETAIL 8/A5-80. ALLAR TO DETAIL 8/A5-80. ALLAR REMARING ALLAR STERI ALLAR STERI ALLA
$\Delta$ $(10)$ $(28)$ $(28)$ $(26)$ $(4)$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 004 005 006 006 007 006 006 007 008 009 009 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY	LED DULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS	27 28 HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 78" 78"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 34" 28" 28"	DTECT TOILET SUPPORT SIM ELEV/SHT -/A-9 -/- -/- -/- -/- -/- -/- -/- -/- -/- -	ACCESSORY. ACCESSORY. ALLAR TO DETAIL 8/A5-80. ALLAR TO DETAIL 8/A5-80. ALLAR TO DETAIL 8/A5-80. ALLAR REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT301 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 0
$\Delta$ $(10)$ $(28)$ $(24)$ (4)	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 004 005 006 006 007 006 007 006 007 008 009 009 009 009 009	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED -	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A	27 28 HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 78" 78" 78" - -	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>-</li> <li>-</li> <li>-</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 34" 28" 28" 28" 28" - -	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>ACCESSORY. ALAR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT300 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 0</td>	ACCESSORY. ALAR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT300 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 0
$\Delta$ $(10)$ $(28)$ $(24)$ (4)	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 005 006 005 006 007 006 007 008 009 009 009 010 010 011 011 012 013 014	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1	LED ULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS N/A 440 LBS 680 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A	27 28 HEIGHT=h 90.5" 16" 18" 3" 84" 35" 26" 70" 70" 70" 70" 70" 78" 78" 78" - - 27"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li></li> <li></li> <li>22ø"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28"	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>ACCESSORY.</td>	ACCESSORY.
$\Delta$ $(10)$ $(28)$ $(24)$ $(24)$ $(26)$ $(26)$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 009 009 009 009 010 010 011 012 013 014 015 015	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         78"         -         27"         26"         13"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>-</li> <li>-</li> <li>22ø"</li> <li>13"</li> <li>9"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" - - - - 19" 10"	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>ACCESSORY. AILAR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT300 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 0</td>	ACCESSORY. AILAR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT300 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 0
$\Delta$ $(10)$ $(28)$ $(24)$ (4)	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 005 006 007 008 009 009 009 010 010 011 011 012 013 014 014 015 016 017	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         78"         -         27"         26"         13"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>13"</li> <li>8"</li> <li>–</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>ACCESSORY.</td>	ACCESSORY.
$\Delta$ $10$ $28$ $28$ $4$	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 009 009 009 010 011 012 013 014 015 016 017 018	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         78"         78"         78"         26"         13"         13"         13"         10"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>13"</li> <li>8"</li> <li>-</li> <li>10"</li> <li>10"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         -/A-9         -/-	ACCESSORY. ALAR TO DETAIL 8/A5-80. REMAR VBM SG404 BAKER STERI KELVINATOR/MODEL BT300 KENMORE 56 BAKER "EDGEGARD"/MODEL BAKER EG6252, 0
	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 008 009 005 006 007 008 009 010 010 011 012 013 014 011 012 013 014 015 016 015 016 017 018 019 020	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL <b>EQUIPMENT SCHED</b> DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         78"         78"         78"         78"         78"         710"         70"         78"         713"         16"         18"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>-</li> <li>-</li> <li>22ø"</li> <li>13"</li> <li>8"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>ACCESSORY.</td>	ACCESSORY.
	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 000 009 000 000 009 000 000 000	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED -	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         70"         78"         713"         16"         18"         7	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>13"</li> <li>8"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>ACCESSORY.</td>	ACCESSORY.
	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 008 009 000 000 000 000 001 001 001 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - - NOT USED - - NOT USED - TABLE MULTI-ADD PUMP	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         78"         78"         78"         78"         78"         710"         70"         70"         70"         70"         78"         -         26"         13"         -         13"         -         13"         16"         18"         -         34"         24"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>22"</li> <li>12"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>12"</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>IILAR TO DETAIL 8/A5-80.       29         IILAR TO DETAIL 8/A5-80.       30         REMAR       30         VBM SG404 BAKER STERI       30         KELVINATOR/MODEL BT30I       80         KELVINATOR/MODEL BT30I       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       9         III III III IIII IIII IIIIIIIIIIIIIII</td>	IILAR TO DETAIL 8/A5-80.       29         IILAR TO DETAIL 8/A5-80.       30         REMAR       30         VBM SG404 BAKER STERI       30         KELVINATOR/MODEL BT30I       80         KELVINATOR/MODEL BT30I       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       9         III III III IIII IIII IIIIIIIIIIIIIII
	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 006 007 006 007 008 009 000 000 000 001 001 002 003 004 005 006 007 008 009 001 001 002 003 004 005 006 007 005 006 007 005 006 007 005 006 007 005 006 007 001 002 003 001 002 003 004 005 005 006 007 005 006 007 005 006 007 005 006 007 005 006 007 001 002 003 000 005 006 007 001 002 003 000 001 002 000 005 005 006 007 000 007 001 000 000 000 000 000 000	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED -	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A 1,000 LBS N/A N/A N/A 1,000 LBS N/A 1,000 LBS N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         70"         78"         13"         16"         18"         74"         74"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>12"</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>T ACCESSORY.</td>	T ACCESSORY.
	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 000 001 001 001 001 001 001 001 001	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 100 LBS 1,000 LBS 680 LBS 1,000 LBS N/A 1,000 LBS N/A N/A N/A N/A N/A N/A 1,000 LBS N/A N/A N/A N/A 1,000 LBS N/A N/A N/A N/A 1,000 LBS N/A N/A N/A N/A 120 LBS N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         713"         16"         34"         24"         716"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>22"</li> <li>12"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>38"</li> <li>-</li> <li>220"</li> <li>11"</li> <li>-</li> <li>226"</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>20"</li> <li>-</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>IILAR TO DETAIL 8/A5-80.       29         IILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT301       KENMORE 56         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       90         BAKER       90</td>	IILAR TO DETAIL 8/A5-80.       29         IILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT301       KENMORE 56         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       90         BAKER       90
	0F0I : 0 0FCI : 0 CFCI : C EQUIP # 001 002 003 004 005 006 007 008 009 010 011 012 013 014 015 010 011 012 013 014 015 016 017 012 013 014 015 016 017 012 013 014 015 010 010 011 012 010 010 010 010 010 010	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 1,470 LBS 100 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         713"         16"         18"         74"         74"         74"         74"         74"         74"         74"         74"         75"         76"         76" <tr td=""></tr>	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>12"</li> <li>12"</li> <li>11"</li> <li>120</li> <li>11"</li> <li>26"</li> <li>20"</li> <li>-</li> <li>20"</li> <li>-</li> <li>18"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>IILAR TO DETAIL 8/A5-80.       30         REMARI       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI         KELVINATOR/MODEL BT30I         KELVINATOR/MODEL BT30I         BAKER "EDGEGARD"/MODEL         BAKER "EDGEGARD"/MODEL         BAKER EG6252, 0</td>	IILAR TO DETAIL 8/A5-80.       30         REMARI       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI         KELVINATOR/MODEL BT30I         KELVINATOR/MODEL BT30I         BAKER "EDGEGARD"/MODEL         BAKER "EDGEGARD"/MODEL         BAKER EG6252, 0
	0F0I :: 0 0FCI :: 0 CFCI :: C EQUIP # 001 002 003 004 005 006 007 008 009 010 011 012 013 014 015 016 017 013 014 015 016 017 018 019 020 021 022 023 024 025 026 027 026	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 680 LBS 1,000 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         70"         26"         13"         16"         18"         34"         24"         -         16"         18"         36"         70"	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>11"</li> <li>-</li> <li>220"</li> <li>11"</li> <li>-</li> <li>226"</li> <li>11"</li> <li>-</li> <li>226"</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>18"</li> <li>24"</li> <li>5"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIM         ELEV/SHT         -/A-9         -/- </td <td>F ACCESSORY.       29         MILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT301       KENMORE 56         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       0         State       0         KELVINATOR       0         BAKER "EDGEGARD"/MODEL       0         BAKER EG6252, 0       0         State       0         Stat</td>	F ACCESSORY.       29         MILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT301       KENMORE 56         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       0         State       0         KELVINATOR       0         BAKER "EDGEGARD"/MODEL       0         BAKER EG6252, 0       0         State       0         Stat
	0F0I :: 0 0FCI :: 0 CFCI :: C EQUIP # 001 002 003 004 005 006 007 008 009 001 010 010 010 010 010 011 012 013 014 015 016 017 018 019 010 017 018 019 020 010 010 010 010 010 010 010 010 010	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         70"         78"         78"         78"         78"         78"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         70"         78"         -         13"         16"         18"         36"         79"         -         18"         36"         79"         -	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li></li> <li>22ø"</li> <li>13"</li> <li>8"</li> <li></li> <li>20"</li> <li></li> <li>20"</li> <li></li> <li>20"</li> <li></li> <li>18"</li> <li>24"</li> <li>53"</li> <li></li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/- </td <td>F ACCESSORY.       29         MILAR TO DETAIL 8/A5-80.       30         REMAR       30         VBM SG404 BAKER STERI       30         KELVINATOR/MODEL BT301       KENMORE 56         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         KELVINATOR/MODEL BT301       KELVINATOR/MODEL BT301</td>	F ACCESSORY.       29         MILAR TO DETAIL 8/A5-80.       30         REMAR       30         VBM SG404 BAKER STERI       30         KELVINATOR/MODEL BT301       KENMORE 56         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         KELVINATOR/MODEL BT301       KELVINATOR/MODEL BT301
	0F0I :: 0 0FCI :: 0 CFCI :: C EQUIP # 001 002 003 004 005 006 007 008 009 010 011 012 013 014 015 016 017 014 015 016 017 018 019 020 021 022 023 024 025 026 027 028 029 030 030 031	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED BSC WORKSTATION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - PRINTER - NOT USED - PRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 680 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A 1,000 LBS N/A 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         78"         78"         78"         78"         78"         78"         70"         78"         79"         16"         18"         36"         79"         -         -         18"         36"         79"         -         -         -         16" <tr td=""></tr>	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>11"</li> <li>-</li> <li>220"</li> <li>11"</li> <li>-</li> <li>220"</li> <li>11"</li> <li>-</li> <li>226"</li> <li>11"</li> <li>-</li> <li>20"</li> <li>-</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>-</li> <li>-<!--</td--><td>E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28</td><td>DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/-     <!--</td--><td>F ACCESSORY.       29         AILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT30       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       0         KELVINATOR/MODEL BT30       0         KELVINATOR/MODEL BT30       0         KELVINATOR/MODEL BAKER EG6252, 0       0         KELVINATOR/MODEL BAKER EG6252, 0       0</td></td></li></ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/- </td <td>F ACCESSORY.       29         AILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT30       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       0         KELVINATOR/MODEL BT30       0         KELVINATOR/MODEL BT30       0         KELVINATOR/MODEL BAKER EG6252, 0       0         KELVINATOR/MODEL BAKER EG6252, 0       0</td>	F ACCESSORY.       29         AILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI       80         KELVINATOR/MODEL BT30       80         BAKER "EDGEGARD"/MODEL       80         BAKER "EDGEGARD"/MODEL       80         BAKER EG6252, 0       0         KELVINATOR/MODEL BT30       0         KELVINATOR/MODEL BT30       0         KELVINATOR/MODEL BAKER EG6252, 0       0         KELVINATOR/MODEL BAKER EG6252, 0       0
	0F0I :: 0 0FCI :: 0 CFCI :: C EQUIP # 001 002 003 004 005 006 007 008 009 010 011 012 013 014 015 016 017 018 019 020 010 010 010 010 010 010 010	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - PRINTER - NOT USED - PRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATOR - NOT USED -	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 1,470 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         79"         79"         79"         79"         79"         79"         70"         70"         70"      70" <td><ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>12"</li> <li>52"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>12"</li> <li>11"</li> <li>-</li> <li>220"</li> <li>13"</li> <li>8"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>-</li> <li>-</li> <li>51"</li> <li>-</li> </ul></td> <td>E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 10" 10" 10" 10" 10" 10" 10" 10</td> <td>DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/-     <!--</td--><td>r ACCESSORY.</td></td>	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>12"</li> <li>52"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>12"</li> <li>11"</li> <li>-</li> <li>220"</li> <li>13"</li> <li>8"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>-</li> <li>-</li> <li>51"</li> <li>-</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 10" 10" 10" 10" 10" 10" 10" 10	DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/- </td <td>r ACCESSORY.</td>	r ACCESSORY.
	0F0I :: 0         0FCI :: 0         0FCI :: 0         EQUIP #         001         002         003         004         005         006         007         008         009         010         011         012         013         014         015         016         017         018         019         020         021         022         023         024         025         026         027         028         030         031         032         033	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATOR - NOT USED - - NOT USED - - NOT USED -	LED ULE WEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 680 LBS 680 LBS 1,000 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	27         28         HEIGHT=h         90.5"         16"         18"         3"         84"         35"         26"         70"         78"         78"         -         27"         26"         70"         78"         -         27"         26"         13"         -         27"         26"         13"         -         27"         26"         13"         -         13"         -         34"         24"         -         16"         -         16"         -         16"         -         16"         -         16"         -         16"         -         18"         36"         79"         -         85"         -	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>53"</li> <li>-</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>-</li> <li>51"</li> <li>-</li> <li>51"</li> <li>-</li> <li>-</li> <li>51"</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/- </td <td>ILAR TO DETAIL 8/A5-80.       30         REMAR       30         VBM SG404 BAKER STERI       30         KELVINATOR/MODEL BT30I       KENMORE 56         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         KELVINATOR/MODEL BAKER EG6252, 0       50         KELVINATOR/MODEL BAKER EG6252, 0       50         KELVINATOR/MODEL BAKER EG6252, 0       50</td>	ILAR TO DETAIL 8/A5-80.       30         REMAR       30         VBM SG404 BAKER STERI       30         KELVINATOR/MODEL BT30I       KENMORE 56         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         BAKER "EDGEGARD"/MODEL       BAKER EG6252, 0         KELVINATOR/MODEL BAKER EG6252, 0       50         KELVINATOR/MODEL BAKER EG6252, 0       50         KELVINATOR/MODEL BAKER EG6252, 0       50
	OFOI :: 0         OFCI :: 0         CFCI :: 0         EQUIP #         001         002         003         004         005         006         007         008         001         010         011         012         013         014         015         016         017         018         019         020         021         022         023         024         025         026         027         028         030         031         032         033         034	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTAL EQUIPMENT SCHED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-MAIN - NOT USED - - NOT USED - REGULAR WASTE CONTAINER, TYPE 1 SHARPS WASTE CONTAINER MULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONT. TRACE CHEMO CONTAINER MULTI-ADD PUMP - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - NOT USED - TABLE MULTI-ADD PUMP - NOT USED - NOT USED - - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES A GLOVE CAC ISOLATOR - NOT USED - IV STORAGE(MOBILE) NONFER - IV STORAGE(MOBILE)	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	$\begin{array}{c} 27 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\$	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>MDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>53"</li> <li>7</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>7</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>7</li> <li>18"</li> <li>24"</li> <li>53"</li> <li>7</li> <li>7<td>E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 10" 10" 10" 10" 10" 10" 10" 10</td><td>DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/-     <!--</td--><td>IILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BAKER EG6252, 0         KELVINATOR/MODEL BAKER EG6252, 0</td></td></li></ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 19" 10" 10" 10" 10" 10" 10" 10" 10" 10" 10	DTECT TOILET         SUPPORT SIN         ELEV/SHT         -/A-9         -/- </td <td>IILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BAKER EG6252, 0         KELVINATOR/MODEL BAKER EG6252, 0</td>	IILAR TO DETAIL 8/A5-80.       30         REMAR       VBM SG404 BAKER STERI         VBM SG404 BAKER STERI         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BT301         KELVINATOR/MODEL BAKER EG6252, 0         KELVINATOR/MODEL BAKER EG6252, 0
	OFOI :: 0         OFCI :: 0         CFCI :: 0         EQUIP #         001         002         003         004         005         001         002         003         004         005         006         007         008         001         012         013         014         015         016         017         018         020         021         022         023         024         025         026         027         028         029         030         031         032         033         034         035         036         037	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY WULTI-ADD PUMP ROLLABLE STOOL IV LABEL PRINTER HAZARDOUS PHARMA. WASTE CONTAINER - NOT USED - PRINTER - NOT USED - PRINTER - NOT USED - MONITOR (PHARMACIST STATION) WHITE BOARD REFRIGERATOR MOBILE INCINERATION WASTE WALL HUNG CLEANING SUPPLIES GLOVE CAC ISOLATOR - NOT USED - IV STORAGE(MOBILE) INCINERATION WASTE REGULAR WASTE	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 100 LBS 100 LBS 680 LBS 680 LBS 1,000 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	$ \begin{array}{c} 27 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28$	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>74"</li> <li>53"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>10"</li> <li>12ø</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>11"</li> <li>-</li> &lt;</ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DTECT TOILET       SUPPORT SIN       ELEV/SHT       -/A-9       -/- <t< td=""><td>r ACCESSORY.</td></t<>	r ACCESSORY.
	OFOI :: 0         OFCI :: 0         CFCI :: 0         EQUIP #         OOI 000         OOI 000	WNER FURNISHED, OWNER INSTALLED WNER FURNISHED, CONTRACTOR INSTALLED ONTRACTOR FURNISHED, CONTRACTOR INSTALLED DESCRIPTION BSC WORKSTATION MONITOR CPU KEYBOARD PHARMACY REFRIGERATOR CHEMOTHERAPY REFRIGERATOR PHARMACY REFRIGERATOR PHARMACEUTICAL WASTE LAMINAR FLOW WORK BENCH LAMINAR FLOW WORK STATION PYXIS SUPPLY-AUXILLARY PYXIS SUPPLY-AUXILLARY NOT USED - NOT	LED VEIGHT(APPROX.) 800 LBS N/A N/A N/A 1,470 LBS 100 LBS 1,000 LBS 680 LBS 680 LBS 1,000 LBS 1,000 LBS 1,000 LBS N/A 1,000 LBS N/A N/A N/A N/A N/A N/A N/A N/A	$ \begin{array}{c} 27 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28 \\ 28$	<ul> <li>PRESERV</li> <li>TYPICAL</li> <li>WIDTH=b</li> <li>52.5"</li> <li>15"</li> <li>6"</li> <li>18"</li> <li>56"</li> <li>22"</li> <li>12"</li> <li>50"</li> <li>74"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>52"</li> <li>13"</li> <li>8"</li> <li>-</li> <li>220"</li> <li>-</li> <li>10"</li> <li>120</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>10"</li> <li>120</li> <li>11"</li> <li>-</li> <li>26"</li> <li>20"</li> <li>-</li> <li>11"</li> <li>-</li> <li>120</li> <li>11"</li> <li>-</li> <li>12"</li> <li>DIA.</li> </ul>	E AND PRO COUNTER S DEPTH=d 33.5" 7.5" 18" 6" 35" 21" 18" 34" 28" 28" 28" 28" 28" 28" 28" 28" 28" 28	DIECT TOILET       SUPPORT SIN       ELEV/SHT       -/A-9       -/- <t< td=""><td>r ACCESSORY.</td></t<>	r ACCESSORY.

copying, recoraing, taping, or

GENERA		10	TE	S:							S F E I R
1. THE GENERAL C AND MEASUREN	ONTRAC IENTS IN	TOR SI I THE F	HALL V IELD P	'ERIFY 'RIOR <sup>-</sup>	ALL E	XISTIN ARTING	G CON G CONS		IS TION.		A R C H I T E C T S
2. REFER TO GENE INDICATED ON T	RAL NOT HIS SHEE	ES ON ET.	SHEE	T A0-00	0 FOR	INFOR	ΜΑΤΙΟΙ	N NOT			5151 Shoreham Place, Suite 100 San Diego, Ca 92122
INTERIOR	ELE	EVA		ЛС	G	ΕN	ER	AL	NC	DTE	P: 619-299-3917 F: 619-299-5084
1. NOT USED.											www.sfeirarch.com
2. NOT USED.											TCMC
3. NOT USED.											PHARMACY
4. NOT USED.											USP 800
5. IN CASES OF CABINE FIELD AND PROVIDE	ET INSTA FILLER F	LLATIO PANEL	NS BE	TWEEN S AT E	I WALL	_S, VEI OR REI	RIFY DI DUCE E	MENSI END C,	ONS IN ABINET	1 -S	UPGRADE
6. ALL CABINET DOORS CABINET DOORS AND VERTICALLY DRAWER	AND DF FULL F	AWERS IEIGHT	S SHAL CABIN	L HAV	VE PUI HALL	LLS. HAVE	UPPER PULLS	AND MOUN	LOWER TED		Tri-City Medical Center
7. ALL FILE DRAWERS S	SHALL BE	E SIZEI BACK	D FOR	8 1/2 AWFR	2"x 11 UNIT	" FORI TYPICA	MS.P	Rovide	e file		
8. COORDINATE HEIGHT STUD FRAMING CONT	AND LO	CATION REF	N OF E ALSO	BACKIN	IG PLA TAIL 1	TES F 0 ON	OR CA SHEET	SEWOR S-1 F	K WITH FOR	4	Oceanside, California 92056
9. REFER TO SHEET A5 ANCHORAGE/BACKING	DN. 80 FOF G TRACK	R NEW	STAIN IECTIOI	LESS N.	STEEL	COUN	TER				OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056
10. GENERAL CONTRACTO COORDINATE W∕OWNI SHOP DRAWINGS AND	OR SHAL ER FOR D FABRIC	L VERI ALL EC CATION	FY ALI Quipme	L DIME INT CL	ENSION EARAN	IS OF NCES F	ROUGH PRIOR	OPEN TO PR	IINGS EPARIN	and Ng	ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100
<u>/4 \</u>											SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084 MEP: P2S ENGINEERING, INC.
· ^											9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
<u> </u>											STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188
											SEN MICHER THE
NEW CRASH RAILS. SEE 4	/ID-2 F	OR MC	ORE INF	FORMA	TION	and ID	PLAN	ON IE	<b>)</b> −1.		★ S No. C 28543 7 ★
HUMIDITY MONITOR & PRE DETAIL 3/A1-04.	SSURE N		R. MO		G HEIG	HT TO		LY WI			STATE OF CALL
											$-\underline{1}$ $\underline{1}$ $\underline{0}$ \underline{0} $\underline{0}$ $\underline{0}$ $\underline{0}$ $\underline{0}$ \underline{0} $\underline{0}$ $\underline{0}$ $\underline{0}$ $\underline{0}$ \underline{0} $\underline{0}$ \underline{0} $\underline{0}$ \underline{0} $\underline{0}$ $\underline{0}$ \underline{0} \underline{0} $\underline{0}$ $\underline{0}$ \underline{0} $\underline{0}$ $\underline{0}$ $\underline{0}$ \underline{0} $\underline{0}$ \underline{0} $\underline{0}$ \underline{0} \underline{0} \underline{0} \underline{0} \underline{0} $\underline{0}$ \underline{0} \underline{0} \underline{0} \underline{0}
KS	EXIS.	NEW	OFOI	OFCI	CFCI	QNTY	HVAC	ELECT	DATA	SEISMIC	$\frac{2}{\sqrt{3}} \frac{10-09-17}{12-11-17}$
LGARD, CALCS BY SSE	X	X	X	X		1	X N/A	X N/A	N/A N/A	X N/A	$\begin{array}{c c} \hline & \hline & \hline \\ \hline & \hline \\ \hline \\ \hline \\ \hline \\ \hline \\ \hline \\$
	X X		X X			2 4	N/A N/A	N/A N/A	X N/A	N/A N/A	6 05HPD COMMENTS 5-15-18 6 06 DESIGN CHANGES 6-05-18
RG-4.1, CALCS BY SSE	X			x		1	X	X	N/A	×	
4.9149510	X X			X X		1	N/A N/A	N/A N/A	N/A N/A	N/A N/A	
EG4252, CALCS BY SSE	X			X		1	X	X	N/A	X	
CALCS BY SSE				X X		1	X X	X X	N/A X	X X	
	X			X		1	X	X	X	X	REV: DESCRIPTION: DATE:
	X		X			1	N/A	N/A	N/A	N/A	
	X X		X X			1	N/A X	N/A X	N/A N/A	N/A N/A	OSHPD APPROVAL STAMP:
	×		X			9	N/A	N/A	N/A	N/A	OSHPD #: S171641-37-00
			X X			1	N/A	X N/A	X N/A	N/A N/A	REVIEWED IN ACCORDANCE WITH
	X		X			1	N/A	N/A	N/A	N/A	THE REQUIREMENTS OF T24, COR APPROVED with comments
	X X		x			1	N/A	x	N/A	N/A	KC Huang, Sr. Architect
											Planning & Development
	X		X			2	N/A	X	X	N/A	07/23/2018 08:10:09 AM
	x		X			2	N/A	N/A	N/A	N/A	#[ S171641-37-00 ] SHEET TITLE:
	X		X			1	N/A	N/A	N/A	N/A	INTERIOR
urg-3, CALCS BY SSE	x x										ELEVATIONS
	X										
		X		X		2					PROJECT TITLE: TCMC USP 800
	x										
	X										DRAWN BY: NI
										$\mid$	
	×	x								$\mid$	SCALE: $1/4" = 1'-0"$
	<u> </u>			•		•					DATE: 07/31/17 OF

ithout written permission of the ARCHITECT. 100% CONSTRUCTION DOCUMENT

![](_page_15_Picture_0.jpeg)

(	3 M sc	ETAL ALE: N
		F
<ol> <li>Wall Assembly manner described i following construct</li> <li>A. Studs — Wall fr nom 2 by 4 in. (51 Steel studs to be m</li> </ol>	— The 1, 2 in the individ ion features raming may by 102 mm hin 3-5/8 in.	, 3 or 4 hı dual U300 : consist of ) lumber (92 mm)
<ul> <li>B. Gypsum Board thickness, number UL Fire Resistance</li> <li>2. Through-Penet annular space betw conduit or tubing to be used:</li> <li>A. Steel Pipe – N</li> </ul>	* — Nom 1/ of layers, fa Directory. M trant — One yeen pipe, co o be rigidly s om 24 in. (6	(2 or 5/8 i istener ty lax diam o e metallic onduit or supported
<ul> <li>B. Iron Pipe — No or Class 50 (or hea</li> <li>C. Conduit — Nom</li> <li>D. Copper Tubing</li> <li>E. Copper Pipe —</li> </ul>	om 24 in. (6 ivier) ductile n 6 in. (152 — Nom 6 in. ( Nom 6 in. (	10 mm) d e iron pres mm) dian n. (152 m 152 mm)
<ul> <li>F. Through Penet</li> <li>1. Nom 2 in. (51 m floor or wall assem</li> <li>OMEGA FLEX INC</li> <li>2. Nom 1 in. (25 m floor or wall assem</li> </ul>	rating Prod m) diam (oi bly. m) diam (oi bly.	<b>luct</b> * — F r smaller) r smaller)
GASTITE, DIV OF 3. Nom 1 in. (25 m floor or wall assem WARD MFG L L C 3. Fill, Void or Ca	TITEFLEX Im) diam (or bly. vity Materi	r smaller) <b>al</b> * — Car
and 4 hr rated asse gypsum board/pen hourly fire rating of dent upon the type	emblies, res etrant interf f the wall as e or size of t	pectively, ace at po sembly in he pipe or o Dia
	1 (25) 1 (25) 4 (102)	

12 (305) +When copper pipe is used, T Rating is 0 h. **3M COMPANY** — CP 25WB+ or FB-3000 WT.

6 (152)

2 METALLIC WALL PENETRATION UL W-L-1001

\*Bearing the UL Classification Mark

![](_page_15_Figure_4.jpeg)

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or information and retrieval systems without written permission of the ARCHITECT. 100% CONSTRUCTION DOCUMENT

![](_page_16_Figure_0.jpeg)

- 1. THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- 2. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### **GENERAL NOTES FOR PARTITIONS:**

- 1. ALL GYP. BOARD SHALL BE TYPE 'X'. REFER TO FLOOR PLAN FOR LOCATION OF WALL TYPES.
- 2. REFER TO THE INTERIOR DESIGN SHEET AND RELATED DETAILS FOR FINISHES REQUIRED AND TO THE MANUFACTURER FOR SURFACE PREP. REQUIREMENTS.
- 3. REFER TO THE FLOOR PLAN, INTERIOR ELEVATIONS, DETAILS, MECHANICAL PLUMBING AND ELECTRICAL PLANS FOR WALL BACKING REQUIREMENTS AND IN WALL UTILITIES.
- 4. ALL DOOR JAMBS AND OPENINGS OVER 24" SHALL BE DOUBLE STUDDED WITH 16 GA. STUDS EXTENDED TO STRUCTURE ABOVE REFER TO STRUCTURAL DETAILS FOR MORE INFORMATION.
- 5. PROVIDE 6" STEEL STUDS AT ALL WALLS AND/OR WALLS WHERE RECESSED ELECTRICAL PANELS OR FIRE EXTINGUISHER CABINETS ARE LOCATED. COORDINATE WITH RELATED SUB-CONTRACTORS.
- 6. PROVIDE 3 5/8" X 20 GA. STEEL TRACK BACKING AT ALL WALL MOUNTED DOOR STOPS.
- 7. ALL STUDS SUPPORTING WALL HUNG CABINETS SHALL BE MIN. 16 GA. STUDS SPACED AT 16" O.C. MAXIMUM. REFER TO DETAILS 02 AND 03/A5-80 FOR REQUIRED BACKING MATERIAL AND CONNECTION.
- 8. ALL RATED WALLS (FIRE AND SMOKE) SHALL BE CONSTRUCTED SO THAT SECONDARY WALLS DO NOT PENETRATE SYSTEM. ALL PENETRATIONS SHALL BE SEALED W/ UL LISTED FIRE STOP SEALANT, UL LISTED ASSEMBLIES OR APPROVED EQUAL.
- 9. SUBMITTAL FOR WALL MATERIALS SHALL BE PROVIDED TO SUBSTANTIATE THE PROPOSED MATERIALS HAVE BEEN TESTED BY A RECOGNIZED TESTING AGENCY TO MEET THE REQUIRED RATINGS AND PERFORMANCE LEVELS OF THE SPECIFIED MATERIALS.
- 10. ALL PENETRATIONS IN RATED WALLS OVER 16 SQ. INCHES  $\sqrt{3}$  ALL BE  $\frac{11}{3}$ BACK WRAPPED WITH 5/8" TYPE 'X' GYP. BD. UNPROTECTED PENETRATIONS UNDER 16 SQ. INCHES SHALL NOT EXCEED 100 SQ. INCHES TOTAL FOR EACH 100 SQ. FEET OF WALL AREA. WHERE SUCH UNPROTECTED OPENINGS OCCUR ON OPPOSITE SIDES OF THE WALL SEPARATE THESE OPENINGS BY MIN. 24 INCHES.
- 11. DOOR OPENINGS SHALL BE PROTECTED BY A U.L. LISTED (OR EQUAL) DOOR AND DOOR FRAME. ALL RATED DOORS SHALL BE POSITIVE LATCHING, AUTOMATIC CLOSING AND GASKETED TO PREVENT THE PASSAGE OF SMOKE. DOORS EQUIPPED WITH A HOLD OPEN DEVICE SHALL BE INTERCONNECTED TO THE FIRE ALARM WHICH SHALL CLOSE THE DOOR UPON ACTIVATION.
- 12. COMPLY WITH THE FOLLOWING I.C.B.O. REPORTS: "CEMCO"- ICC #ESR-3064P (STUDS AND TRACKS) "ITW RAMSET/RAMSET"- I.C.C. #1799 (POWDER DRIVEN PINS) REFER TO THE FOLLOWING TABLE FOR ALLOWABLE WALL HEIGHTS, HEIGHTS ARE FOR NON-LOAD BEARING STEEL STUDS USED FOR INTERIOR PARTITIONS WITH BOTH FLANGES OF STUDS CONTINUOUSLY BRACED WITH GYP. BOARD OR FLAT STRAPS. ALLOWABLE HEIGHTS ARE THOSE LISTED WITHIN THE I.C.B.O. REPORT. BRACE ALL STUDS AS REQUIRED SO AS, NOT TO EXCEED THOSE ALLOWED HEIGHTS SET BY THE MFR. AND THE I.C.B.O. REPORT. SUBMIT FOR APPROVAL, CURRENT I.C.B.O. REPORT.

<u>STUD</u>	DESIGNATION	MAXIMUM H	<u>IEIGHT</u>	<u>REMARKS</u>	
		<u>16"0.C.</u>	<u>24"0.C.</u>		
3 5/8"-20 GA.	362DS20	16'—1"	14'-1"	INTERIOR ONLY	•
6"-20 GA.	600DS20	24'-1"	21'-1"	INTERIOR ONLY	

### S F R F A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

# **Tri-City Medical Center**

4002 Vista Way Oceanside, California 92056 OWNER: TRI-CITY MEDICAL CENTER

4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084

P2S ENGINEERING, INC.

SAN DIEGO, CA 92123

TEL(619)618-2347

MEP:

STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438-1188

9665 CHESAPEAKE DRIVE, SUITE 230

![](_page_16_Picture_27.jpeg)

OSHPD	APPROVAL	STAM
_		

REV: DESCRIPTION:

CONSULTANT

![](_page_16_Picture_29.jpeg)

DATE:

PROJECT TITLE: TCMC USP 800

PROJECT #: SHEET NUMB 01667.00 DRAWN BY: LN CHECKED BY: A5-10 SCALE: AS SHOWN DATE: 07/31/17

![](_page_17_Figure_0.jpeg)

![](_page_18_Figure_0.jpeg)

- THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING COND AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONST
- REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### GENERAL NOTES GWB CEILING:

DRYWALL CEILING SUSPENSION; CONVENTIONAL CONSTRUCTION REF: CBC 2016 AND ASCE 7-10.

- CONSTRUCTION, WORKMANSHIP AND MATERIAL SHALL CONFO CALIFORNIA BUILDING STANDARDS CODE (CBSC 2016).
- THE CONTRACTOR SHALL NOTIFY OSHPD AND THE REGISTER PROFESSIONAL (RDP) IN RESPONSIBLE CHARGE WHERE A COM DISCREPANCY OCCURS BETWEEN THE CONSTRUCTION DRAW OTHER PORTION OF THE CONSTRUCTION DOCUMENTS, FIELD WHERE ANY CONDITIONS ARISE NOT COVERED BY THESE DOC WORK WILL NOT COMPLY WITH CODE REQUIREMENTS.
- THE INTENT OF THE DRAWINGS AND SPECIFICATIONS IS TO CO HOSPITAL BUILDING IN ACCORDANCE WITH THE CALIFORNIA B STANDARD CODE, 2016 (CBSC 2016). SHOULD ANY CONDITION COVERED BY THE APPROVED CONSTRUCTION DOCUMENTS W WORK WILL NOT COMPLY WITH CBSC 2016, A CHANGE ORDER SPECIFYING THE REQUIRED WORK SHALL BE SUBMITTED TO A OSHPD BEFORE PROCEEDING WITH THE WORK.
- GALVANIZED METAL STUDS, TRACKS AND SHEET STEEL SHALI ASTM A653-11 MATERIAL, OR OTHER EQUIVALENT ASTM LISTE SECTION A2.1 OF THE AISI SI00-07/S2-10; NORTH AMERICAN SF FOR THE DESIGN OF COLD-FORMED STEEL STRUCTURAL MEM SUPPLEMENT 2, DATED 2010, WITH A MINIMUM YIELD STRENG FOR 43 MIL (18 GAGE) AND LIGHTER AND MINIMUM YIELD STRE FOR HEAVIER GAGES. METAL STUDS AND TRACKS SHALL BE ( THICKNESS AND SECTION PROPERTIES SHOWN ON TABLES 1-AISI MANUAL, COLD-FORMED STEEL DESIGN, 2008 EDITION. TH RESPONSIBLE CHARGE SHALL OBTAIN OSHPD APPROVAL FOR
- ELECTRICAL METALLIC TUBE (EMT) SHALL BE ANSI C80.3/UL 797 WITH G90 GALVANIZING. EMT SHALL HAVE MINIMUM YIELD STR KSI AND MINIMUM ULTIMATE STRENGTH OF (Fu = ) 48 KSI.
- SELECTED FASTENER CAPACITIES SHALL MATCH OR EXCEED LISTED HEREIN. THE FOLLOWING REQUIREMENTS SHALL ALSO
- SHEET METAL SCREWS SHALL COMPLY WITH ASTM C 151 B18.6.4-98 (R2005) AND ICC-ES AC 118. PENETRATION OF THROUGH JOINED MATERIAL SHALL NOT BE LESS TH**AN**F THREADS.
- WELDING SHALL BE IN ACCORDANCE WITH AWS D1.3 US ELECTRODES. FIELD WELDING SHALL HAVE SPECIAL INS ACCORDANCE WITH 2016 CBC SECTION 1705A.2.
- POST- INSTALLED ANCHORS (E.G. EXPANSION ANCHORS AND POWER ACTUATED FASTENERS) SHALL HAVE SPEC AND TESTING IN ACCORDANCE WITH THE 2016 CBC SEC 1913A.7. FOR QUALIFICATION, DESIGN AND USE OF POST ANCHORS IN CONCRETE SEE THE 2016 CBC SECTIONS 1 1908A.1.1. LISTING OF CURRENT ICC-ES EVALUATION RE REPORTS FROM OTHER TESTING AGENCIES ACCEPTABL
- SHALL BE REQUIRED FOR FASTENER USED. POWER-ACTUATED FASTENERS (PAF), POWDER DRIVEN (PDF), POWER DRIVEN PINS (PDP) AND SHOT PINS ALL R SAMÉ FASTENER AND WILL HEREAFTER BE REFERRED ACTUATED FASTENERS (PAF)PAF'S SHALL SATISFY THE ACCEPTANCE CRITERIA FOR FASTENERS POWER-DRIVE STEEL AND MASONRY ELEMENTS AND THE 2016 CBC SE LISTING OF CURRENT ICC ES EVALUATION REPORTS (OF OTHER TESTING AGENCIES ACCEPTABLE TO OSHPD) SH
- FOR FASTENERS USED.
- FOR PAF INSTALLED IN STEEL THE FASTENER PENETRAT THE ENTIRE POINTED END OF THE FASTENER DRIVEN TH AFMBER FXCEPT AS NOTED IN CURRENT REPORTS FRO AGENCIES ACCEPTABLE TO OSHPD. 7. DESIGN CRITERIA
  - BUILDING CODE: 2016 CALIFORNIA BUILDING CODE (2016 10, AISI S100-07/S2-10, ASTM C754-11. FOR LOAD COMBIN ALLOWABLE STRESS DESIGN SHALL BE IN ACCORDANCE CBC SECTION 1605A.3.1.
  - FASTENER CAPACITIES TABLES WERE DEVELOPED BASE REPORTS BY SEVERAL MANUFACTURERS. THE DESIGN ASSUMES THAT BUILDING ELEMENTS AND WHICH THE COMPONENTS ADDRESSED IN THIS DOCUME ANCHORED, HAVE SUFFICIENT CAPACITY TO CARRY THE IMPOSED BY THE COMPONENTS IN COMBINATION WITH /
- I OADS DESIGN CRITERIA IS LIMITED TO CEILING ASSEMBLIES HA DEAD WEIGHT OF 4 PSF, INCLUDING LIGHTING FIXTURES AND MECHANICAL SERVICES, EACH WEIGHING LESS THA ATTACHED TO CEILING FRAMING SYSTEM. HEAVIER SYS THOSE SUPPORTING LATERAL FORCES FROM PARTITION REQUIRE PROJECT SPECIFIC DESIGN.
- THE RDP SHALL VERIFY THE FIRE RESISTANCE AND ACOUST ALL CEILING ASSEMBLIES.
- 9. "CEILING WIRE" SHALL CONFORM WITH GALVANIZED SOFT ANI WIRE AS DEFINED IN ASTM A641 (CLASS 1 COATING) WITH 70 K STRENGTH
- FOUR (4) TWISTS OF WIRE WITHIN 1.5" DEVELOPS THE AI THE WIRE. THREE (3) TWISTS WITHIN 3" MAY BE USED TO DEVELOP
- ALLOWABLE LOAD. 10. SUSPENSION SYSTEM COMPONENTS SHALL COMPLY WITH AS MAIN RUNNERS SHALL CONSIST OF 1-1/2"-1.12 LB/FT., HC AT 4'-0" OC MAX. MAIN RUNNERS SHALL BE SUPPORTED AT 4'-0" OC MAX AND WITHIN 6" FROM EACH END.
- FURRING CHANNEL SHALL CONSIST OF 25 GAGE 7/8" (HA CHANNELS (087F125-18) AT 2'-0" OC MAX. FURRING CHA SADDLE TIED TO MAIN RUNNERS WITH 16 GAGE TIE WIRI STRAND OF 18 GAGE TIE WIRE. MAIN RUNNERS SHALL BE SPLICED BY LAPPING IN ACCO
- DETAIL 4/A5-60. `م ک FURRING CHANNELS SHALL BE SPLICED BY LAPPING IN WITH DETAIL 6/A5-60.
- MAIN RUNNERS AND FURRING CHANNELS ALONG WITH INTERSECTION CONNECTORS, AND EXPANSION DEVICE DESIGNED AND CONSTRUCTED TO CARRY A MEAN ULTI OF NOT LESS THAN 270 LBS. IN COMPRESSION & TENSIO HANGER AND BRACING WIRES SHALL BE #12 GAGE (0.10 SOFT ANNEALED, AND GALVANIZED STEEL WIRES WITH COATING. THEY MAY BE USED FOR UP TO AND INCLUDIN
- GRID SPACING ALONG AND ATTACHED TO MAIN RUNNER NOT PERMITTED IN ANY HANGER WIRE WIRE HANGERS SHALL BE SADDLE-TIED AROUND MAIN TO PREVENT TURNING OR TWISTING OF THE MEMBER.
- SUSPENSION SYSTEM INSTALLATION, SHALL COMPLY WITH A a. CEILING GRID MEMBERS SHALL BE ATTACHED TO TWO WALLS. MAIN RUNNERS AND FURRING CHANNEL SHALL CLEAR OF OTHER WALL AND FURRING SHALL BE AT LEA OF OTHER WALL. IF WALLS RUN DIAGONAL TO THE CEIL RUNNERS, ONE END OF MAIN RUNNER AND FURRING SHOULD BE FREE WITH S TANDARD CLEARANCES.
- THE WIDTH OF THE PERIMETER SUPPORTING CLOSURE ANGLE SHALL BE NOT LESS THAN TWO (2) INCHES. USE OF ANGLES WITH SMALLER WIDTHS IN CONJUNCTION WITH PERIMETER CLIPS SHALL REQUIRE AN ALTERNATE METHOD OF COMPLIANCE WITH ADEQUATE JUSTIFICATION.
- 12. EXPANSION JOINTS, SEISMIC SEPARATIONS, AND PENETRATIONS EXPANSION JOINTS SHALL BE PROVIDED IN THE CEILING AT INTERSECTIONS OF CORRIDORS AND AT JUNCTIONS OF CORRIDORS WITH LOBBIES OR OTHER SIMILAR AREAS.
- FOR CEILING AREAS EXCEEDING 2500 SQUARE FEET, A SEISMIC SEPARATION JOINT SHALL BE PROVIDED TO DIVIDE THE CEILING INTO AREAS NOT EXCEEDING 2500 SQ. FT.

ITIONS	
RUCTION	

ILING:			AND THE
NC			TWO THE
			ALL F
ORM TO THE 2016			MOVI OVEF
			SPRI SOFF
NFLICT OR	10		
CONDITIONS, OR	13.	LATE	RAL F
CUMENTS WHEREIN		SECT	ION F
DNSTRUCT THE		EXCE SUSF	PTIO PENDE
		OF 14 PRO\	14 SQ /IDED
HEREIN THE		CEILI	
ND APPROVED BY		u.	OF A
		b.	LATE
L CONFORM TO D MATERIALS IN			FRO
ECIFICATION BERS WITH		C.	ELE\ THE
TH OF 33 KSI NGTH OF 50 KSI			DEG PLAN
F SIZE, 1. 1-2 AND 1-3 OF THE		d.	STRI COM
	2		
	,. 14.	ATTA	CHM
RENGTH OF (Fy = 30)		a.	FAS1 (3) T
			BÉ T ANY
THE STRENGTHS ) BE MET:		h	WITH
13-10, ASME		0.	MAK
SCREWS REE EXPOSED		C.	HAN
			DIRE
PECTION IN		d.	POS SEP/
, SCREW ANCHORS			LEAS CON
TIONS 1705A.3 &		e.	HAN ARO
-INSTALLED 616A.1.19 AND			TRAI
PORTS (OR F TO OSHPD)			ADD
EASTENERS		_	ARE
		f.	HAN (VER
CURRENT AC70-		g.	SPE( WHE
N INTO CONCRETE, CTION 1908A.1.1.		0	IN RE 10 W
R REPORTS FROM ALL BE REQUIRED			FOR
TION SHALL HAVE			WIR
HROUGH THE STEEL			440 I IN C
	15.	CEILI a.	NG FI AL I
CBC), ASCE 7-			DEV
IATIONS, E WITH 2016		h	COM
ED ON ICC		D.	RUN
SUPPORTS. TO			WITH
		C.	SUR RUN
ALL OTHER			MAT
AVING MAXIMUM		d.	ACC CEIL
(LUMINERIES) AN 56 LBS AND			
TEM AND N WALLS WILL			SEN
			PERI
CAL RATINGS FOR	WAR	NING:	1.
			2.
NEALED MILD STEEL		e.	ALL
LLOWABLE LOAD FOR	ξ		HAVI FIXT
THE MAXIMUM 50% C	)F	f	NEC AL I
	Λ	••	
T ROLLED CHANNEL	<u> /3  </u>		ABO
) BY HANGER WIRES		g.	ALL
			APP
NNELS SHALL BE E OR A DOUBLE		h.	FRO
NNELS SHALL BE E OR A DOUBLE		h.	FRO GAU EILIN
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH		h. i.	FRO GAU EILIN SUPI ALI
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE		h. i.	FROI GAU EILIN SUPI ALL DIRE
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE		h. i.	FROI GAU EILIN SUPI ALL DIRE WITH DIAG
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD DN.		h. i.	FROI GAU EILIN SUPI ALL DIRE WITH DIAG OF F
NNELS SHALL BE E OR A DOUBLE DRDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD DN. 6" DIAMETER), CLASS 1		h. i.	FROI GAU EILIN SUPI ALL DIRE WITH DIAG OF F SUPI FIXT BE S
NNELS SHALL BE E OR A DOUBLE DRDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD DN. 6" DIAMETER), CLASS 1 NG 4'-0" X 4'-0" RS. SPLICES ARF		h. i.	FROI GAU EILIN SUPI ALL DIRE WITH DIAC OF F SUPI FIXT BE S IF TH EXCI
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD ON. 6" DIAMETER), CLASS 1 NG 4'-0" X 4'-0" RS. SPLICES ARE		h. i.	FROI GAU EILIN SUPI ALL DIRE WITH DIAC OF F SUPI FIXT BE S IF TH EXCI
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD ON. 6" DIAMETER), CLASS 1 IG 4'-0" X 4'-0" RS. SPLICES ARE RUNNERS SO AS		h. i. 16.	FROI GAU EILIN SUPI ALL DIRE WITH DIAC OF F SUPI FIXT BE S IF TH EXCI SUSI CEILI DETA
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD ON. 6" DIAMETER), CLASS 1 NG 4'-0" X 4'-0" RS. SPLICES ARE RUNNERS SO AS STM C754: 2) ADJACENT		h. i. 16.	FROI GAU EILIN SUPI ALL DIRE WITH DIAG OF F SUPI FIXT BE S IF TH EXCI SUSI CEILI DETA FROM
NNELS SHALL BE E OR A DOUBLE ORDANCE WITH ACCORDANCE THEIR SPLICES, S SHALL BE MATE TEST LOAD ON. 6" DIAMETER), CLASS 1 NG 4'-0" X 4'-0" RS. SPLICES ARE RUNNERS SO AS STM C754: 2) ADJACENT BE AT LEAST 1 INCH ST 3/4" INCH CI FAR		h. i. 16.	FROI GAU EILIN SUPI ALL DIRE WITH DIAG OF F SUPI FIXT BE S IF TH EXCI SUSI CEILI DETA FROM INSTA THE L ALL O

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or information and retrieval systems without written permission of the A

c. PENETRATIONS THROUGH THE CEILING FOR SPRINKLER HEADS OTHER SIMILAR DEVICES THAT ARE NOT INTEGRALLY TIED TO CEILING SYSTEM IN THE LATERAL DIRECTION SHALL HAVE A (2) INCH OVERSIZED RING, SLEEVE OR ADAPTER THROUGH CEILING TILE TO ALLOW FREE MOVEMENT OF ONE (1) INCH IN ORIZONTAL DIRECTIONS, A FLEXIBLE SPRINKLER HOSE NG THAT CAN ACCOMMODATE ONE (1) INCH OF CEILING EMENT SHALL BE PERMITTED TO BE USED IN LIEU OF THE RSIZED RING, SLEEVE OR ADAPTER. SUCH FLEXIBLE NKLER HOSE SHALL BE ADEQUATELY SUPPORTED FROM IT SO AS NOT TO EXCEED THE MAXIMUM TRIBUTARY WEIGHT HE CEILING. ORCE BRACING: ORCE BRACING IS REQUIRED IN ACCORDANCE WITH THIS OR ALL CEILING AREAS, UON. N: LATERAL FORCE BRACING MAY BE OMITTED FOR ED ACOUSTICAL CEILING SYSTEMS WITH A CEILING AREA FT. OR LESS, WHEN PERIMETER SUPPORT ARE AND PERIMETER WALLS ARE DESIGNED TO CARRY THE ATERAL FORCES. VIDE LATERAL-FORCE BRACING ASSEMBLIES CONSISTING STRUT AND FOUR (4) #12 GAGE BRACING WIRES NTED 90 DEGREESFROM EACH OTHER. RAL-FORCE BRACING ASSEMBLIES SHALL BE SPACED IN ORDANCE WITH DETAILS 1/A5-60, 10/A5-60 & 14/A5-60 M EACH WALL AND AT THE EDGES OF ANY CHANGE OF VATION OF THE CEILING. SLOPE OF BRACING WIRES MAY BE FROM 10 TO 45 REES BUT MAY NOT EXCEED 45 DEGREES FROM THE NE OF THE CEILING AND WIRES SHALL BE TAUT. UTS SHALL BE ADEQUATE TO RESIST THE VERTICAL

PONENT INDUCED BY THE BRACING WIRES, AND SHALL BE MORE THAN 1 (HORIZONTAL) IN 6 (VERTICAL) OUT OF ENT OF HANGER AND BRACING WIRES:

FEN #12 HANGER WIRES WITH NOT LESS THAN THREE GHT TURN IN 3 INCHES. HANGER WIRE LOOPS SHALL IGHTLY WRAPPED AND SHARPLY BENT TO PREVENT VERTICAL MOVEMENT OR ROTATION OF THE MEMBER IN THE LOOPS.

- TEN #12 BRACING WIRES WITH FOUR (4) TIGHT TURNS E ALL TIGHT TURNS WITHIN A DISTANCE OF 1 1/2" GER OR BRACING WIRE ANCHORED TO THE STRUCTURE
- OULD BE INSTALLED IN SUCH A MANNER THAT THE ECTION OF THE ANCHOR ALIGNS AS CLOSELY AS SIBLE WITH THE DIRECTION OF THE WIRE.
- ARATE ALL CEILING HANGER AND BRACING WIRES AT ST SIX (6) INCHES FROM ALL UNBRACED DUCTS, PIPES IDUITS, ETC. GER WIRES SHALL NOT BE ATTACHED TO OR BEND
- UND INTERFERING MATERIAL OR EQUIPMENT. PROVIDE PEZE OR OTHER SUPPLEMENTARY SUPPORT MEMBERS BSTRUCTIONS TO TYPICAL HANGER SPACING. PROVIDE ITIONAL HANGERS, STRUTS OR BRACES AS REQUIRED ALL CEILING BREAKS, SOFFITS, OR DISCONTINUOUS
- GER WIRES THAT ARE MORE THAN 1 (HORIZONTAL) IN 6 TICAL) OUT OF PLUMB SHALL REQUIRE PROJECT CIFIC DESIGN.
- N DRILLED-IN CONCRETE ANCHORS OR PAF ARE USED EINFORCED CONCRETE FOR HANGER WIRES, 1 OUT OF IRE/ ANCHOR ASSEMBLIES SHALL BE FIELD TESTED 200 LBS. IN TENSION. WHEN DRILLED-IN CONCRETE HORS ARE USED FOR BRACING WIRES. 1 OUT OF 2 E/ANCHOR ASSEMBLIES SHALL BE FIELD TESTED FOR BS. IN TENSION IN THE DIRECTION OF THE WIRE. PAF ONCRETE ARE NOT PERMITTED FOR BRACING WIRES.
- IXTURES, TERMINALS, AND DEVICES: LIGHT FIXTURES, AIR TERMINALS/GRILLS, OR OTHER ICES (REFERRED TO ALL BY COMMON TERM FIXTURES EAFTER) SHALL BE MOUNTED IN A MANNER THAT WILL NOT PROMISE CEILING PERFORMANCE. FIXTURES SHALL BE SUPPORTED DIRECTLY BY MAIN INERS OR BY SUPPLEMENTAL FRAMING WHICH IS
- PORTED BY MAIN RUNNERS AND POSITIVELY ATTACHED SCREWS OR OTHER APPROVED CONNECTORS. FACE MOUNTED FIXTURES SHALL BE ATTACHED TO A MAIN NER WITH A POSITIVE CLAMPING DEVICE MADE OF ERIAL WITH A MINIMUM OF 14 GAGE. ROTATIONAL SPRING MPS DO NOT COMPLY.
- ESS PANELS: ACCESS TO THE SPACE BETWEEN THE ING AND THE FLOOR OR ROOF ABOVE SHALL NOT BE OWED. SMALL ACCESS PANELS FOR THE INSPECTION USTMENT, OR REPAIR OF UTILITY SWITCHES, VALVES, SORS, ETC. MAY BE ALLOWED IF THE PANEL IS LESS THAN SQUARE INCHES. SUCH PANELS SHALL ALSO HAVE A MANENT WARNING LABEL AS FOLLOWS:
- DO NOT CLIMB, WALK, OR CRAWL ON THE GYPSUM BOARD CEILING. DO NOT STORE OR STOW ANYTHING ON THE GYPSUM BOARD CEILING.

FIXTURES WEIGHING LESS THAN OR EQUAL TO 10 LB. SHALL E ONE NO. 12 GAUGE SAFETY WIRE CONNECTED FROM URE HOUSING TO STRUCTURE ABOVE. IT IS NOT ESSARY FOR THESE SAFETY WIRES TO BE TAUT. FIXTURES WEIGHING GREATER THAN 10 LB BUT LESS THAN QUAL TO 56 LB SHALL HAVE TWO NO. 12 GAUGE SAFETY

E CONNECTED FROM FIXTURE HOUSING TO STRUCTURE VE. IT IS NOT NECESSARY FOR THESE SAFETY WIRES TO FIXTURES WEIGHING GREATER THAN 56 LB SHALL BE PORTED DIRECTLY FROM STRUCTURE ABOVE BY

ROVED HANGERS. DANT-HUNG FIXTURES SHALL BE SUPPORTED DIRECTLY M THE STRUCTURE ABOVE USING NO LESS THAN NO. 0-IGE WIRE OR AN APPROVED ALTERNATE SUPPORT. THE C IG SUSPENSION SYSTEM SHALL NOT PROVIDE ANY DIRECT PORT

RECESSED OR DROP-IN FIXTURES SHALL BE SUPPORTED ECTLY FROM FIXTURE HOUSING TO THE STRUCTURE ABOVE H A MINIMUM OF TWO NO. 12 GAUGE WIRES LOCATED AT ONALLY OPPOSITE CORNERS. LEVELING OR POSITIONING FIXTURES MAY BE PROVIDED BY CEILING GRID. FIXTURE PORT WIRES MAY BE SLIGHTLY LOOSE TO ALLOW THE URE TO SEAT IN THE GRID SYSTEM. FIXTURES SHALL NOT UPPORTED FROM MAIN RUNNERS OR FURRING CHANNELS HE WEIGHT OF THE FIXTURES CAUSES TOTAL DEAD LOAD TO EED THE DEFLECTION CAPABILITY OF THE CEILING PENSION SYSTEM.

NGS THAT ARE PART OF A FIRE RATED ASSEMBLY: PROVIDE AIL AND DESIGN NUMBER FOR RATED CEILING ASSEMBLIES A AN APPROVED TESTING AGENCY. THE COMPONENTS AND ALLATION DETAILS SHALL CONFORM IN EVERY RESPECT WITH ISTED DETAIL AND NUMBER. DETAILS SHALL CLEARLY DEPICT COMPONENTS, INCLUDING INSULATION MATERIALS, IING AND ATTACHMENT OF THE DESIGN SO THAT THE EMBLY CAN BE CONSTRUCTED AND INSPECTED ACCORDINGLY. POP RIVETS, SCREWS, OR OTHER ATTACHMENTS ARE NOT ACCEPTABLE UNLESS SPECIFICALLY DETAILED ON THE DRAWINGS AND APPROVED BY APPROVED TESTING AGENCY.

GYPSUM BOARD INSTALLATION SHALL COMPLY WITH ASTM C840-14 GYPSUM BOARD SHALL CONSIST OF SINGLE-PLY 5/8" THICK IN ACCORDANCE WITH ASTM C11-10a. GYPSUM BOARD SHALL BE INSTALLED PERPENDICULAR TO FURRING WITH SCREWS AT 12" OC MAXIMUM, IN

ACCORDANCE WITH ASTM C840-11. GYPSUM BOARD SHALL BE ATTACHED TO FURRING/FRAMING WITH ASTM C1002-07 TYPE S (ASTM A568-11b GRADES 1018 TO 1022) SCREWS (NOT LESS THAN, NO. 6, WITH MAJOR DIAMETER NOT LESS THAN 0.136 IN).

# S A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

# **Tri-City Medical Center**

	le, California 92056	
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 920	56
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUI SAN DIEGO, CALIFORNIA 921 TEL(619)299–3917 FAX(619	TE 100 22 9)299–508
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, S SAN DIEGO, CA 92123 TEL(619)618–2347	UITE 230
STRUCTURAL	: SUN STRUCTURAL ENGINEERI 2091 LAS PALMAS DRIVE, SI CARLSBAD, CA 92011 TEL(760)438–1188	NG UITE D
THE NO. C	228543 70 *	
	COMMENTS	
	CHANGES	10-09-17
	COMMENTS	12-11-17
		12–11–17
		5-15-18
	CHANGES	$\times \times \times \times \times \times$
		6-05-18 
		6-05-18 

OSHPD APPROVAL STAMP:

CONSULTANT

![](_page_18_Picture_65.jpeg)

As indicated DATE: 08/03/16 07/31/17 **100% CONSTRUCTION DOCUMENT** 

![](_page_19_Figure_0.jpeg)

- . THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICA ON THIS SHEET.

### **GENERAL NOTES:**

METAL SUSPENSION SYSTEMS FOR LAY-IN PANEL CEILINGS

- CONSTRUCTION, WORKMANSHIP AND MATERIAL SHALL CONFORM TO THE CALIFORNIA BUILDING STANDARDS CODE (CBSC 2016).
- 2. THE CONTRACTOR SHALL NOTIFY OSHPD AND THE REGISTERED DESIGN PROFESSIONAL (RDP) IN RESPONSIBLE CHARGE WHERE A CONFLICT OR DISCREPANCY OCCURS BETWEEN THE CONSTRUCTION DRAWINGS AND ANY OTHER PORTION OF THE CONSTRUCTION DOCUMENTS, FIELD CONDITIONS, O WHERE ANY CONDITIONS ARISE NOT COVERED BY THESE DOCUMENTS WHE WORK WILL NOT COMPLY WITH CODE REQUIREMENTS.
- . THE INTENT OF THE DRAWINGS AND SPECIFICATIONS IS TO CONSTRUCT TH HOSPITAL BUILDING IN ACCORDANCE WITH THE CALIFORNIA BUILDING STANDARD CODE, 2016 (CBSC 2016). SHOULD ANY CONDITION DEVELOP N COVERED BY THE APPROVED CONSTRUCTION DOCUMENTS WHEREIN THE W WILL NOT COMPLY WITH CBSC 2016, A CHANGE ORDER DETAILING AND SPECIFYING THE REQUIRED WORK SHALL BE SUBMITTED TO AND APPROVE OSHPD BEFORE PROCEEDING WITH THE WORK.
- 4. GALVANIZED METAL STUDS, TRACKS AND SHEET STEEL SHALL CONFORM STM A653-11 MATERIAL, OR OTHER EQUIVALENT ASTM LISTED MATERIALS SECTION A2.1 OF THE AISI SIOO-07/S2-10; NORTH AMERICAN SPECIFICA FOR THE DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS WITH SUPPLEMENT 2, DATED 2010, WITH A MINIMUM YIELD STRENGTH OF 33 KS FOR 43 MIL (18 GAGE) AND LIGHTER AND MINIMUM YIELD STRENGTH OF 5 KSI FOR HEAVIER GAGES. METAL STUDS AND TRACKS SHALL BE OF SIZE, THICKNESS AND SECTION PROPERTIES SHOWN ON TABLES 1-1, 1-2 AND OF THE AISI MANUAL, COLD-FORMED STEEL DESIGN, 2008 EDITION. THE F IN RESPONSIBLE CHARGE SHALL OBTAIN OSHPD APPROVAL FOR ANY SUBSTITUTIONS.
- ELECTRICAL METALLIC TUBE (EMT) SHALL BE ANSI C80.3/UL 797 CARBON STEEL WITH G90 GALVANIZING. EMT SHALL HAVE MINIMUM YIELD STRENGT (Fy = ) 30 KSI AND MINIMUM ULTIMATE STRENGTH OF (Fu = ) 48 KSI.
- THESE OPD REFER TO FASTENER TYPE AND SIZE BUT DO NOT SPECIFY C ENDORSE A SPECIFIC MANUFACTURER. THE RDP IN RESPONSIBLE CHARGE SHALL SELECT A MANUFACTURER AND SELECTED FASTENER CAPACITIES SHALL MATCH OR EXCEED THE STRENGTHS LISTED HEREIN. THE FOLLOWIN REQUIREMENTS SHALL ALSO BE MET:
- SHEET METAL SCREWS SHALL COMPLY WITH ASTM C 1513–10, ASME B18.6.4–98 (R2005) AND ICC–ES AC 118 AND ALLOWABLE STRENGTH SHALL BE BASED ON INFORMATION PROVIDED IN CL1.31 AND CL1.32. PENETRATION OF SCREWS THROUGH JOINED MATERIAL SHALL NOT BE LESS THAN THREE EXPOSED THREADS.
- b. WELDING SHALL BE IN ACCORDANCE WITH AWS D1.3 USING E60XX SERIES ELECTRODES. FIELD WELDING SHALL HAVE SPECIAL INSPECTI ACCORDANCE WITH 2016 CBC SECTION 1705A.2.
- c. POST- INSTALLED ANCHORS (E.G. EXPANSION ANCHORS, SCREW ANCHORS AND POWER ACTUATED FASTENERS) SHALL HAVE SPECIAL INSPECTION AND TESTING IN ACCORDANCE WITH THE 2016 CBC SECTIONS 1705A.3 & 1913A.7. FOR QUALIFICATION, DESIGN AND USI POST-INSTALLED ANCHORS IN CONCRETE SEE THE 2016 CBC SECTION 1616A.1.19 AND 1908A.1.1. LISTING OF CURRENT ICC-ES EVALUATION REPORTS (OR REPORTS FROM OTHER TESTING AGENCIES ACCEPTABL OSHPD) SHALL BE REQUIRED FOR FASTENER USED.

POWER-ACTUATED FASTENERS (PAF), POWDER DRIVEN FASTENERS (PDF), POWER DRIVEN PINS (PDP) AND SHOT PINS ALL REPRESENT THE SAME FASTENER AND WILL HEREAFTER BE REFERRED TO AS POWER ACTUATED FASTENERS (PAF). PAF'S SHALL SATISFY THE CURRENT AC70-ACCEPTANCE CRITERIA FOR FASTENERS POWER-DRIVEN INTO CONCRETE, STEEL AND MASONRY ELEMENTS AND THE 2016 CBC SECTION 1908A.1.1. LISTING OF CURRENT ICC ES EVALUATION REPORTS (OR REPORTS FROM OTHER TESTING AGENCIES ACCEPTABLE TO OSHPD) SHALL BE REQUIRED FOR FASTENERS USED.

e. FOR PAF INSTALLED IN STEEL THE FASTENER PENETRATION SHALL THE ENTIRE POINTED END OF THE FASTENER DRIVEN THROUGH THE STEEL MEMBER, EXCEPT AS NOTED IN CURRENT REPORTS FROM TES AGENCIES ACCEPTABLE TO OSHPD.

### DESIGN CRITERIA a. BUILDING CODE: 2016 CALIFORNIA BUILDING CODE (2016 CBC), ASCI 7-10, AISI S100-07/S2-10, ASTM E580-11b, C635-12, AND C636-

- FOR LOAD COMBINATIONS, ALLOWABLE STRESS DESIGN SHALL BEIN ACCORDANCE WITH 2016 CBC SECTION 1605A.3.1.b. FASTENER CAPACITIES TABLES WERE DEVELOPED BASED ON ICC
- REPORTS BY SEVERAL MANUFACTURERS. c. THE DESIGN ASSUMES THAT BUILDING ELEMENTS AND SUPPORTS, WHICH THE COMPONENTS ADDRESSED IN THIS DOCUMENT ARE ANCHORED, HAVE SUFFICIENT CAPACITY TO CARRY THE LOADS
- IMPOSED BY THE COMPONENTS IN COMBINATION WITH ALL OTHER L EVALUATION OF THE CAPACITY OF THESE SUPPORTING BUILDING ELEMENTS IS BEYOND THE SCOPE OF THE OPD. d. THIS OPD IS LIMITED TO CEILING ASSEMBLIES HAVING MAXIMUM DEA
- WEIGHT OF 4 PSF, INCLUDING LIGHTING FIXTURES (LUMINERIES) AND MECHANICAL SERVICES, EACH WEIGHING LESS THAN 56 LBS AND ATTACHED TO CEILING FRAMING SYSTEM. HEAVIER SYSTEM AND THO SUPPORTING LATERAL FORCES FROM PARTITION WALLS ARE OUTSIDE SCOPE OF THIS OPD AND WILL REQUIRE PROJECT SPECIFIC DESIGN.
- THE RDP IN RESPONSIBLE CHARGE SHALL VERIFY THE FIRE RESISTANCE ACOUSTICAL RATINGS FOR ALL CEILING ASSEMBLIES.
- "CEILING WIRE" SHALL CONFORM WITH GALVANIZED SOFT ANNEALED MILD STEEL WIRE AS DEFINED IN ASTM A641 (CLASS 1 COATING) WITH 70 KSI MINIMUM TENSILE STRENGTH:
- a. FOUR (4) TWISTS OF WIRE WITHIN 1.5" DEVELOPS THE ALLOWABLE
- FOR THE WIRE. b. THREE (3) TWISTS WITHIN 3" MAY BE USED TO DEVELOP THE MAXIN 50% OF ALLOWABLE LOAD.
- SUSPENSION SYSTEM COMPONENTS SHALL COMPLY WITH ASTM C635 AND E580 SECTION 5.1:
   a. THE CEILING GRID SYSTEM SHALL BE RATED HEAVY DUTY AS DEFINITION
- BY ASTM C635.
  HANGER AND BRACING WIRES SHALL BE #12 GAGE (0.106" DIAMETE SOFT ANNEALED, AND GALVANIZED STEEL WIRES WITH CLASS 1 COA THEY MAY BE USED FOR UP TO AND INCLUDING 4'-0"x 4'-0" GRID SPACING ALONG AND ATTACHED TO MAIN RUNNERS. SPLICES ARE NOT STRAIL TO THE AND AND ATTACHED TO MAIN RUNNERS.
- PERMITTED IN ANY HANGER WIRE. c. MAIN RUNNERS AND CROSS RUNNERS ALONG WITH THEIR SPLICES, INTERSECTION CONNECTORS, AND EXPANSION DEVICES SHALL BE DESIGNED AND CONSTRUCTED TO CARRY A MEAN ULTIMATE TEST LOAD OF NOT LESS THAN 180 LBS. IN COMPRESSION & TENS
- SUSPENSION SYSTEM INSTALLATION, SHALL COMPLY WITH ASTM C636 AND

IN ACCORDANCE WITH ASTM 580 SECTION 5.1.2.

- E580 SECTION 5.2:
  a. PROVIDE #12 GAGE HANGER WIRES AT THE ENDS OF ALL MAIN AND CROSS RUNNERS WITHIN EIGHT (8) INCHES OF THE SUPPORT OR WI ONE-FOURTH (1/4) OF THE LENGTH OF THE END TEE, WHICHEVER I LESS, FOR THE PERIMETER OF THE CEILING AREA. PERIMETER WIRES NOT REQUIRED WHEN THE LENGTH OF THE END TEE IS EIGHT (8) IN OR LESS.
- b. CEILING GRID MEMBERS SHALL BE ATTACHED TO TWO (2) ADJACENT WALLS, IN ACCORDANCE WITH ASTM E580 SECTION 5.2.3. CEILING G MEMBERS SHALL BE AT LEAST 3/4" INCH CLEAR OF OTHER WALLS. WALLS RUN DIAGONAL TO THE CEILING GRID SYSTEM RUNNERS, ONE OF MAIN AND CROSS RUNNERS SHOULD BE FREE, AND A MINIMUM 3/4 INCH CLEAR OF WALL.

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphi

ATED d. AT THE PERIMETER OF THE CEILING AREA WHERE MAIN OR CROSS RUNNERS ARE NOT CONNECTED TO THE ADJACENT WALL, PROVIDE INTERCONNECTION BETWEEN THE RUNNERS AT THE FREE END TO PREVENT LATERAL SPREADING. A METAL STRUT OR A #16 GAGE WIRE WITH A POSITIVE MECHANICAL CONNECTION TO RUNNER MAY BE USED. WHERE THE PERPENDICULAR DISTANCE FROM THE WALL TO THE FIRST PARALLEL RUNNER IS EIGHT (8) INCHES OR LESS. THIS	3
2016 12. EXPANSION JOINTS, SEISMIC SEPARATIONS, AND PENETRATIONS: a. EXPANSION JOINTS SHALL BE PROVIDED IN THE CEILING AT INTERSECTIONS OF CORRIDORS AND AT JUNCTIONS OF CORRIDORS WITH TONES	
<ul> <li>LOBBIES OR OTHER SIMILAR AREAS.</li> <li>FOR CEILING AREAS EXCEEDING 2500 SQUARE FEET, A SEISMIC SEPARATION JOINT SHALL BE PROVIDED TO DIVIDE THE CEILING INTO AREAS NOT EXCEEDING 2500 SQ. FT.</li> <li>PENETRATIONS THROUGH THE CEILING FOR SPRINKLER HEADS AND OTHER SIMILAR DEVICES THAT ARE NOT INTEGRALLY TIED TO THE</li> </ul>	
CEILING SYSTEM IN THE LATERAL DIRECTION SHALL HAVE A TWO (2) INCH OVERSIZED RING, SLEEVE OR ADAPTER THROUGH THE CEILING TILE TO ALLOW FREE MOVEMENT OF ONE (1) INCH IN ALL HORIZONTAL DIRECTIONS. A FLEXIBLE SPRINKLER HOSE FITTING THAT CAN ACCOMMODATE ONE (1) INCH OF CEILING MOVEMENT SHALL BE PERMITTED TO BE USED IN LIEU OF THE OVERSIZED RING, SLEEVE OR ADAPTER. SUCH FLEXIBLE SPRINKLER HOSE SHALL BE ADEQUATELY SUPPORTED FROM SOFFIT SO AS NOT TO EXCEED THE MAXIMUM TRIBUTARY WEIGHT OF THE CEILING	
13. LATERAL FORCE BRACING: LATERAL FORCE BRACING IS REQUIRED IN ACCORDANCE WITH THIS SECTION TRI-City Medical Ce FOR ALL CEILING AREAS, UON.	nte
50 , 1-3 RDP EXCEPTION: LATERAL FORCE BRACING MAY BE OMITTED FOR SUSPENDED ACOUSTICAL CEILING SYSTEMS WITH A CEILING AREA OF 144 SQ. FT. OR LESS, WHEN PERIMETER SUPPORT IN ACCORDANCE WITH ASTM E580 ARE PROVIDED AND PERIMETER WALLS ARE DESIGNED TO CARRY THE CEILING LATERAL 4002 Vista Way Oceanside, California 92056	
FORCES.         a.       PROVIDE LATERAL-FORCE BRACING ASSEMBLIES CONSISTING OF A STRUT         AND FOUR (4) #12 GAGE BRACING WIRES ORIENTED 90 DEGREES FROM         N         EACH OTHER.         b.       LATERAL-FORCE BRACING ASSEMBLIES SHALL BE SPACED IN             OWNER:             TRI-CITY MEDICAL CENTER         4002 VISTA WAY         OCEANSIDE, CALIFORNIA 92056	
ACCORDANCE WITH 1/A5-70 FROM EACH WALL AND AT THE EDGES OF ANY CHANGE OF ELEVATION OF THE CEILING. ANY CHANGE OF ELEVATION OF THE CEILING. THE SLOPE OF BRACING WIRES MAY BE FROM 10 TO 45 DEGREES BUT MAY NOT EXCEED 45 DEGREES FROM THE PLANE OF THE CEILING AND WIRES SHALL BE TAUT. ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL (619)299-3917 EAX(619)299-	5084
d. STRUTS SHALL BE ADEQUATE TO RESIST THE VERTICAL COMPONENT INDUCED BY THE BRACING WIRES, AND SHALL NOT BE MORE THAN 1 (HORIZONTAL) IN 6 (VERTICAL) OUT OF PLUMB. 14. ATTACHMENT OF HANGER AND BRACING WIRES: 14. ATTACHMENT OF HANGER AND BRACING WIRES:	30
a. FASTEN #12 HANGER WIRES WITH NOT LESS THAN THREE (3) TIGHT T URN IN 3 INCHES. HANGER WIRE LOOPS SHALL BE TIGHTLY WRAPPED AND SHARPLY BENT TO PREVENT ANY VERTICAL MOVEMENT OR ROTATION OF THE MEMBER WITHIN THE LOOPS. A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL A ROTATION OF THE MEMBER WITH FOUR (4) TIGHT TURNS MAKE ALL	
L TIGHT TURNS WITHIN A DISTANCE OF 1 1/2" INCHES. C. HANGER OR BRACING WIRE ANCHORED TO THE STRUCTURE SHOULD BE INSTALLED IN SUCH A MANNER THAT THE DIRECTION OF THE ANCHOR ALIGNS AS CLOSELY AS POSSIBLE WITH THE DIRECTION OF THE WIRE.	
<ul> <li>d. SEPARATE ALL CEILING HANGER AND BRACING WIRES AT LEAST SIX (6) INCHES FROM ALL UNBRACED DUCTS, PIPES CONDUITS, ETC.</li> <li>e. HANGER WIRES SHALL NOT BE ATTACHED TO OR BEND AROUND INTERFERING MATERIAL OR EQUIPMENT. PROVIDE TRAPEZE OR OTHER SUPPLEMENTARY SUPPORT MEMBERS AT OBSTRUCTIONS TO TYPICAL HANGER SPACING. PROVIDE ADDITIONAL HANGERS. STRUTS OR BRACES</li> </ul>	
AS REQUIRED AT ALL CEILING BREAKS, SOFFITS, OR DISCONTINUOUS AREAS. f. HANGER WIRES THAT ARE MORE THAN 1 (HORIZONTAL) IN 6 (VERTICAL) OUT OF PLUMB SHALL REQUIRE PROJECT SPECIFIC DESIGN. g. WHEN DRILLED-IN CONCRETE ANCHORS OR PAF ARE USED IN	
REINFORCED CONCRETE FOR HANGER WIRES, 1 OUT OF 10 WIRE/         ANCHOR ASSEMBLIES SHALL BE FIELD TESTED FOR 200 LBS. IN         TENSION. WHEN DRILLED-IN CONCRETE ANCHORS ARE USED FOR         BRACING WIRES, 1 OUT OF 2 WIRE/ANCHOR ASSEMBLIES SHALL BE FIELD         STING	9–17 9–17 –17
15. CEILING FIXTURES, TERMINALS, AND DEVICES: a. CEILING PANELS SHALL NOT SUPPORT ANY LIGHT FIXTURES, AIR TERMINALS/GRILLS, OR OTHER DEVICES (REFERRED TO ALL BY COMMON TERM FIXTURES HERE AFTER).	-17 -18 -18 -18
b. ALL FIXTURES SHALL BE MOUNTED IN A MANNER THAT WILL NOT COMPROMISE CEILING PERFORMANCE. c. ALL FIXTURES SHALL BE ATTACHED TO THE SUSPENDED CEILING SYSTEM BY MECHANICAL MEANS, UNLESS INDEPENDENTLY SUPPORTED. THE ATTACHMENT DEVICE SHALL HAVE THE CAPACITY OF 100% OF FIXTURE	
OADS. d. SURFACE MOUNTED FIXTURES SHALL BE ATTACHED TO THE MAIN NUMBER WITH POSITIVE CLAMPING DEVICES MADE OF MATERIAL WITH A MINIMUM 14 GAGE. A NO.12 GAUGE SAFETY WIRES SHALL BE ATTACHED BETWEEN THE CLAMPING DEVICE AND TO THE STRUCTURE ABOVE IN NO AD	
CASE SHALL THE FIXTURES EXCEED THE DESIGN CAPACITY OF THE SUPPORTING MEMBERS. e. ALL FIXTURES WEIGHING LESS THAN OR EQUAL TO 10 LB. SHALL HAVE ONE NO. 12 GAUGE SAFETY WIRE CONNECTED FROM FIXTURE HOUSING TO STRUCTURE ABOVE. IT IS NOT NECESSARY FOR THESE SAFETY	
AND f. ALL FIXTURES WEIGHING GREATER THAN 10 LB BUT LESS THAN OR EQUAL TO 56 LB. SHALL HAVE TWO NO. 12 GAUGE SAFETY WIRE CONNECTED FROM FIXTURE HOUSING TO STRUCTURE ABOVE. IT IS NOT NECESSARY FOR THESE SAFETY WIRES TO BE TAUT. OSHPD #: S171641-37-00	
<ul> <li>g. ALL FIXTURES WEIGHING GREATER THAN 56 LB. SHALL BE SUPPORTED – DIRECTLY FROM STRUCTURE ABOVE BY APPROVED HANGERS.</li> <li>h. PENDENT-HUNG FIXTURES SHALL BE SUPPORTED DIRECTLY FROM THE STRUCTURE ABOVE USING NO LESS THAN NO. 9–GAUGE WIRE OR AN APPROVED ALTERNATE SUPPORT. THE CEILING SUSPENSION SYSTEM</li> </ul>	
i. ALL RECESSED OR DROP-IN FIXTURES SHALL BE SUPPORTED DIRECTLY FROM FIXTURE HOUSING TO THE STRUCTURE ABOVE WITH A MINIMUM OF TWO NO. 12 GAUGE WIRES LOCATED AT DIAGONALLY OPPOSITE CORNERS. LEVELING OR POSITIONING OF FIXTURES MAY BE PROVIDED BY CEILING OF Statewide Health	
GRID. FIXTURE SUPPORT WIRES MAY BE SLIGHTLY LOOSE TO ALLOW THE FIXTURE TO SEAT IN THE GRID SYSTEM. FIXTURES SHALL NOT BE SUPPORTED FROM MAIN RUNNERS OR CROSS RUNNERS IF THE WEIGHT OF THE FIXTURES CAUSES TOTAL DEAD LOAD TO EXCEED THE DEFLECTION CAPABILITY OF THE CEILING SUSPENSION SYSTEM.	
16. ADDITIONAL REQUIREMENTS: a. CEILINGS THAT ARE PART OF A FIRE RATED ASSEMBLY: PROVIDE A DETAIL AND DESIGN NUMBER FOR RATED CEILING ASSEMBLIES FROM AN APPROVED TESTING AGENCY. THE COMPONENTS AND INSTALLATION	
DETAILS CONFORM IN EVERY RESPECT WITH THE LISTED DETAIL AND NUMBER. DETAILS SHALL CLEARLY DEPICT ALL COMPONENTS, INCLUDING INSULATION MATERIALS, FRAMING AND ATTACHMENT OF THE DESIGN SO THAT THE ASSEMBLY CAN BE CONSTRUCTED AND INSPECTED ACCORDINGLY, POP RIVETS, SCREWS, OR OTHER ATTACHMENTS ARE NOT	
ACCEPTABLE UNLESS SPECIFICALLY DETAILED ON THE DRAWINGS AND APPROVED BY APPROVED TESTING AGENCY. IS S ARE NCHES NCHES DRAWINGS AND OTHER PANELS: METAL PANELS AND PANELS WEIGHING MORE THAN 1/2 PSF, OTHER THAN MINERAL FIBER ACOUSTICAL TILE, ARE TO NCHES	
T       C.       BUILDING EXIT WAYS: CEILINGS IN EXIT WAYS SHALL BE INSTALLED IN         T       ACCORDANCE WITH SECTION 13.5.6.2.2(1) OF ASCE 7–10 AS AMENDED         GRID       BY 2016 CBC SECTION 1616A.1.20. SPLICES OR INTERSECTION OF         IF       RUNNERS SHALL BE ATTACHED WITH THROUGH CONNECTORS SUCH AS         F FND       FOR PUNCTS SOPEWS DIAS DI ATES WITH SUD TARE OR OTHER	دَد ۲
OF APPROVED CONNECTORS. PINS, PLATES WITH END TABS OK UTHER APPROVED CONNECTORS.	

![](_page_20_Figure_0.jpeg)

			S F E I R
	LEGEND:		ARCHITECTS
	*** REFER TO EQUIPMENT SCHEDULE.		5151 Shoreham Place, Suite 100
	CASEWORK LEGEND		San Diego, Ca 92122
	CASE ID NUMBER HEIGHT		P: 619–299–3917 F: 619–299–5084 www.sfeirarch.com
-0"	$\frac{D100G24}{\Box \Box \Box CASE WIDTH (INCHES) ( = AS REQ'D.)}$		
"/ " OR	CASE HEIGHT A 18" CASE TYPE (REFER TO W.I.C.) SPECIAL PREFIX D = DOUBLE C 27"		
	M = MODIFY $D = 30"$ $E = 30"$ $F = 33"$		PHARMACY
	$\begin{array}{cccc} & & & & & & & \\ TASK24 &= 24 & TASK LIGHT MODULE & & & & & & \\ TASK48 &= 48" TASK LIGHT MODULE & & & & & & & \\ TASK48 &= 48" TASK LIGHT MODULE & & & & & & & \\ \end{array}$		USP 800
	FIPED= SINK FOOT CONTROL PEDALSK48"L54"L54"DEPTH (U.O.N. ON ELEVATIONS)M72"		UPGRADE
	LOWER CASE: 24" DEEP U.O.N. UPPER CASE: 14" DEEP U.O.N. Q 96"		
	TALL CASE: 14" DEEP U.O.N.		Tri-City Medical Center
	A – MEDICAL COMPRESSED AIR N – NURSE CALL C – CODE BLUE NO – NITROUS OXIDE		4002 Vista Way
EL	D – DATA O – OXYGEN DP – DICTAPHONE PS – NURSE CALL PULL S DS – DIMMER SWITCH S – SWITCH	STATION	Oceanside, California 92056
	E – DUPLEX ELECT. OUTLET T – TELEPHONE F – FAX MACHINE TL – TASK LIGHT IC – INTERCOM TV – TELEVISION		OWNER: TRI-CITY MEDICAL CENTER
	J - JUNCTION BOX V - VACUUM VC - VOLUME CONTROL VS - VACUUM SLIDE	_	OCEANSIDE, CALIFORNIA 92056
	1. ALL CASEWORK SHALL BE "CUSTOM" GRADE AS DEFINED BY THE WOOL	DWORK	ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122
SE RT	6 2. PRIME AND PAINT ALL STEEL ANGLES & CEMENTITIOUS BD. UNDER COUNTERTOPS.		TEL(619)299-3917 FAX(619)299-5084
ASE	3. BASES ON CASEWORK SHALL BE 4" UNLESS OTHERWISE NOTED. PROVI FINISH BASE MATERIAL AS ADJACENT WALLS. EXTEND BASE TO WALL	DE SAME AT ALL	9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
7	<ul> <li>CABINET RETURNS AND END PANELS.</li> <li>4. IN CASES OF CABINET INSTALLATIONS BETWEEN WALLS, VERIFY DIMENS FIELD AND PROVIDE FILLER PANEL STRIPS AT ENDS OR REDUCE END ( WIDTL AS DECUMPED TO FIL SPACE AS INDICATED</li> </ul>	ions in	STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011
	5. ALL CABINET DOORS AND DRAWERS SHALL HAVE PULLS, U.N.O. UPPE LOWER CABINET DOORS AND FULL HEIGHT CABINETS SHALL HAVE PULL MOUNTED VERTICALLY DRAWERS SHALL HAVE HORIZONTAL PULLS	R AND	TEL(760)438–1188
	6. ALL FILE DRAWERS SHALL BE SIZED FOR 8 1/2"x 11" FORMS. PROVID	e file	CENSED R.
	7. COORDINATE HEIGHT AND LOCATION OF BACKING PLATES FOR CASEWO	RK WITH	→ (2) ★ (2) No. C 28543 → (1)
	DETAILS.	CREINC	N POK 1-31-19 15
	9 GENERAL CONTRACTOR SHALL VERIEY ALL DIMENSIONS OF ROLICH OPF		OF CALIFOR
	COORDINATE W/OWNER FOR ALL EQUIPMENT CLEARANCES PRIOR TO PE SHOP DRAWINGS AND FABRICATION.	REPARING	$\frac{2}{2} \frac{1}{2} \frac{1}{2} \frac{1}{2} \frac{1}{2} \frac{1}{2} \frac{1}{2} \frac{1}{2} \frac{10-09-17}{10-09-17}$
			$ \begin{array}{c} \hline 3 \\ \hline 4 \\ \hline 4 \\ \hline 4 \\ \hline \end{array} \\ \hline \end{array} \\ \begin{array}{c} 0 \\ \hline 0 \\ \hline$
<. •			5     0SHPD COMMENTS     5-15-18       6     6     DESIGN CHANGES
		_	REV: DESCRIPTION: DATE:
			oshpd approval stamp: OSHPD #: S171641—37—00
ND		_	REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR
			APPROVED with comments
			KC Huang, Sr. Architect
			Planning & Development FACILITIES DEVELOPMENT DIVISION
O B			07/23/2018 08:10:09 AM #[ S171641-37-00 ] SHEET TITLE:
VEN C.			
			DETAILS
3" 0			PROJECT TITLE:
AT			TCMC USP 800
			PROJECT #: 01667.00 SHEET NUMBER: DRAWN BY: I N
			AS SHOWN DATE: 07/31/17
lectronic, or	mechanical, including photocopying, recording, taping, or information and retrieval systems without written permission of the ARCHITECT.	0% CO	NSTRUCTION DOCUMENT

![](_page_21_Figure_0.jpeg)

E4 E3	DOC	DR A	AND FRA	ME SO	CHEDU	ULE		I				-	I	
E2	OPNG. NO.	DOC	)R	1	1	FRA	ME		DETAILS	1	1	LABEL	HDWR. SET	R. NOTES:
		TYPE	OPENING SIZE	MATERIAL	FINISH	TYPE	MATERIAL	FINISH	HEAD	JAMB	THRESHOLD	Z		
	030A	B,D	3'-6"x 7'-0"	STEEL	PTD	A	STEEL	PTD	9	10		NR	01	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
	031A 032A	В	3-6 x 7-0 3'-6"x 7'-0"	STEEL	PTD	A	STEEL	PTD	9	10		NR	02	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
D FLOOR														
							S/8' FINIS RUNI REFE DOUL REFE VIW "*/E PAIN PRO (PRO (PRO	" GWB, PRIME SH SCHEDULE NER TRACK ( ER TO DETAIL BLE STUD BO ER TO DETAIL ITED HOLLOW VIDE MIN. 3 A DVIDE 2 ADDIT	X HEADER, 3/SD2 4 X HEADER, 3/SD2 4 X METAL DOOR FRAM ANCHORS PER JAME TONAL ANCHORS AT	ТО Е. З.		3/4" MIN.		PAINTED HOLLOW METAL DOOR FRAME. PROVIDE MIN. 3 ANCHORS PER JAMB. (PROVIDE 2 ADDITIONAL ANCHORS AT HEAD SECTION OF PAIRS OF DOORS. WELD ANCHORS TO DOOR FRAME WELD ANCHORS TO DOOR FRAME FASTEN FRAME TO STUDS WITH 2 #12 SMS PER ANCHOR DOOR JAMB, REFER TO STRUCT. DETAIL 3/SD2.
/04				NOTE: REFER TO	D FLOOR PLAN	N FOR REG		D SECTION OF D ANCHORS T N	<sup>7</sup> PAIRS OF DOORS. O DOOR FRAME			-	4"	WALL LOCATION AT SIMILAR CONDITION.
0				TTPE ANI	D NUMBER OF	GTP. BUA	AND LATERS.					NOTE: REFER T TYPE AN	O FLOOR PLAN D NUMBER OF	N FOR REQUIRED PARTITION F GYP. BOARD LAYERS.
<u>s head</u>			9 <u>T</u>	YPICAL =1'-0"	DOOR	HEA	DER					(10) <u>TYPI</u> 3"=1'-0'	CAL DC	OOR JAMB
										rights reserved. No part of this work	may be reproduced or copied i	in any form or by any means. graphic., e	DOOI 1. PROVIDE 2. ALL DOO TO DET 3. GLAZED INCHES 4. GLAZED INCHES 5. FRAMES DOOR F 6. CENTER UON. 1 PROV (2 NOT (3) TEMF (4) FLOO (5) EXIST WITH (6) REUS DOOI SCWD PL PTD AC E	<b>DE SCHEDULE GENERAL NOTES:</b> DE SANITARY "HOSPITAL STOPS" AT ALL NON-RATED INTERIOR DOOR FRAMES. NOORS SHALL RECEIVE LEVER TYPE HARDWARE WITH A PROFILE EQUAL TAIL 3-B THIS SHEET DE OPENINGS IN 20 AND 45 MINUTE ASSEMBLIES SHALL NOT EXCEED 1296 SO. S AND SHALL BE CLAZED WITH 1/4" WIRE CLASS SET IN PAINTED STEEL FRAME. ED OPENINGS IN 60 AND 90 MINUTE ASSEMBLIES SHALL NOT EXCEED 100 SO. S AND SHALL BE CLAZED WITH 1/4" WIRE CLASS SET IN PAINTED STEEL FRAME. ES OF LOPENINGS IN 100 AND 90 MINUTE ASSEMBLIES SHALL NOT EXCEED 100 SO. S AND SHALL BE CLAZED WITH 1/4" WIRE CLASS SET IN PAINTED STEEL FRAME. ES OF DOOR HINGE PIVOT SHALL BE LOCATED AT 4" FROM ADJACENT PARTITION <b>OR SCHEDULE KEYNOTES:</b> OVIDE STAINLESS STEEL KICKPLATE, 30" HIGH ON PUSH SIDE OF DOOR. MERED GLASS. DOOR MOUNTED DOOR STOP. ISTING AUTOMATIC DOOR OPENER TO BE REINSTALLED, AND IT IS EQUIPPED <b>OXIDE STAINLESS</b> STEEL KICKPLATE, 30" HIGH ON PUSH SIDE OF DOOR. <b>OX</b> <b>DE SCHEDULE FINISH LEGEND</b> . <b>DOWNOUNTED DOOR STOP.</b> STING AUTOMATIC DOOR OPENER TO BE REINSTALLED, AND IT IS EQUIPPED <b>DE SCHEDULE FINISH LEGEND</b> . <b>DE SCHEDULE FINISH LEGEND</b> . MAR MARBLE PAINTED BAST BAUSTIC STEEL ACROVIN MAR MAR MARBLE EXISTING <b>DOUR WOOD DOOR</b> ST MAR MARBLE <b>DOUL CORE WOOD DOOR</b> ST MAR MARBLE <b>DID CORE WOOD DOOR</b> ST MAR MARBLE <b>DID CORE WOOD DOOR</b> ST MAR MARBLE <b>DID CORE WOOD DOOR</b> ST MAR MARBLE

![](_page_21_Figure_2.jpeg)

### S R Ε F A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619–299–3917 F: 619–299–5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

# **Tri-City Medical Center**

	5			
4002 Vista Way Oceanside, California 92056				
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056			
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084			
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347			
STRUCTURAL:	SUN STRUCTURAL ENGINEERING			

2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188 No. C 28543 St Par 1-31-1 S OF CALIFO ••••••

$\overline{\Lambda}$	OSHPD COMMENTS	10-09-17
$\frac{2}{2}$	– – DESIGN CHANGES	10–09–17
$\overline{3}$	oshpd comments	12–11–17
	DESIGN CHANGES	12–11–17
	OSHPD COMMENTS	5-15-18
	DESIGN CHANGES	6-05-18
~~~		

### OSHPD APPROVAL STAMP:

![](_page_21_Picture_33.jpeg)

A6-00

**100% CONSTRUCTION DOCUMENT** 

AS SHOWN

07/31/17

CHECKED BY:

SCALE:

DATE:

![](_page_22_Figure_0.jpeg)

- THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION.
- REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT 2 INDICATED ON THIS SHEET.

## PARTITION LEGEND:

![](_page_22_Figure_5.jpeg)

ACCESSIBLE PATH OF TRAVEL.

EGRESS PATH OF TRAVEL.

ONE-HOUR RATED CORRIDOR.

INDICATES AN EXISTING MEMBRANE OF PARTITION OR PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS.

INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS.

SB SB SB SB SB III INDICATES AN EXISTING 1 HOUR SMOKE BARRIER

FP FP FP FP FP FP FP INDICATES AN EXISTING ONE HOUR FIRE RATED PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP

SYSTEM. BARRIER TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM. FB FB FB FB FB FB INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.

						-				
RKS	EXIS.	NEW	OFOI	OFCI	CFCI	QNTY	HVAC	ELECT	DATA	SEISMIC
RILGARD, CALCS BY SSE		Х		Х		1	x	x	N/A	X
	X		Х			4	N/A	N/A	N/A	N/A
	X		Х			2	N/A	N/A	Х	N/A
	X		Х			4	N/A	N/A	N/A	N/A
ORG-4.1, CALCS BY SSE	X			Х		1	Х	Х	N/A	Х
564.9149510	X			Х		1	N/A	N/A	N/A	N/A
	X			Х		1	N/A	N/A	N/A	N/A
EL EG4252, CALCS BY SSE	X			Х		1	Х	Х	N/A	X
CALCS BY SSE	X			Х		1	Х	Х	N/A	Х
	X			Х		1	х	Х	х	Х
	X			Х		1	х	Х	Х	X
	X		Х			1	N/A	N/A	N/A	N/A
	X		Х			1	N/A	N/A	N/A	N/A
	X		Х			2	Х	Х	N/A	N/A
	X		Х			9	N/A	N/A	N/A	N/A
	X		Х			1	N/A	Х	Х	N/A
	X		Х			1	N/A	N/A	N/A	N/A
	X		Х			1	N/A	N/A	N/A	N/A
	X									
	X		Х			1	N/A	Х	N/A	N/A
	X		х			2	N/A	Х	Х	N/A
	x		x			2	N/A	N/A	N/A	N/A
	X		X			1	N/A	N/A	N/A	N/A
50RG-3. CALCS BY SSE	x			х						
	x									
	x									
				x		2				
						-				
	×									
	1	I X			1	1				1

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or info

### S F R HITECTS ARC

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

# **Tri-City Medical Center**

4002 V Oceans	ista Way side, California  92056	
OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 9203	56
ARCHITECT	: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUI SAN DIEGO, CALIFORNIA 9212 TEL(619)299–3917 FAX(619	TE 100 22 )299–5084
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SI SAN DIEGO, CA 92123 TEL(619)618–2347	UITE 230
STRUCTUR	AL: SUN STRUCTURAL ENGINEERII 2091 LAS PALMAS DRIVE, SU CARLSBAD, CA 92011 TEL(760)438–1188	NG JITE D
A C C C C C C C C C C C C C C C C C C C	D AR NICHAR C 28543 70 * 1-31-9 DF CALFORN DF CALFORN DF CALFORN SIGN CHANGES HPD COMMENTS SIGN CHANGES	
		6-05-18

OSHPD APPROVAL STAMP:

REV: DESCRIPTION:

\_\_\_\_\_

CONSULTANT

![](_page_22_Picture_22.jpeg)

DATE:

PROJECT TITLE: TCMC USP 800

Project #: 01667.00 DRAWN BY: CHECKED BY: SCALE: 1/4" = 1'-0"DATE: 07/31/1

R R S	Δ6.	-2(
" — 7	/ (0	

SHEET NUME

![](_page_23_Figure_0.jpeg)

### I.D. KEYNOTES:

6

REUSE EXISTING THRESHOLD. (1

PRIME AND PAINT DOOR FRAME. (2)

 $\sqrt{3}$ 

∕3∖

<u>/6</u>

3

/	
$\sim$	$\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!\sim\!\!$
3)	CRASH RAILS PER DETAIL 4/ID-2.
	\//P_2

<u>         </u>						
FLOORS:				WALL PRO	DTECTION:	
SV-1	MANUFACTUR TYPE: PATTERN: COLOR:	ER: MANNINGTON 6' WIDE ROLL BIOSPEC #15366 "GRASSLAND"		WP-1	MANUFACTURER: TYPE: PATTERN: COLOR: NOTE:	ACROVYN PEBBELETTE SUEDE TEXTURE #101 "FRENCH CREAM" SEE ELEVATIONS FOR
> 1-2 >	TYPE: PATTERN: COLOR: GROUT:	'KEYSTONES' PORCELA 1"x1" UPTOWN TAUPE D132 MAPEI 'CACAO'		WP-2	MANUFACTURER: TYPE: PATTERN:	ACROVYN CRASH RAIL SUEDE TEXTURE
BASE				$\geq$	COLOR:	#101 "FRENCH CREAM" SEE PLAN AND ELEVATION
B-1	6" SHEET VINY SHEET VINYL A THE WALL, REI ON SHEET ID-2	'L SELF COVE OF ADJACENT TO FER TO DETAIL #1 2		> > > T-1	MANUFACTURER: TYPE:	FOR LOCATION. SEE DETAIL 4/ID-2. DALTILE 'SEMI-GLOSS' GLAZED CERAN
B-2	6" RUBBER BA	SE TO MATCH	$\Delta$	>	PATTERN: COLOR: GROUT:	4.25"x4.25", TO 48" A.F.F. MIN., BULLNOSE TOP COURSE URBAN PUTTY 0161 MAPEI 'NAVAJO BROWN'
В-3	MANUFACTUR	ER: DALTILE	$\langle \cdot \rangle$			
> > >	TYPE: PATTERN: COLOR: GROUT:	BUILD-UP BASE MB-4C 1"x1", COVED BASE UPTOWN TAUPE D132 MAPEI 'CACAO'		CEILINGS	GYPSUM BOARD (	CEILING
(		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~			SHERWIN WILLIAM "ANTIQUE WHITE"	<i>I</i> S SW 6119
DOOR & F	RAME		$\sqrt{3}$		GLOSS FINISH	
DR-030A	FRAME:	PRIME AND PAINT MATCH FRAME PRIME AND PAINT SHERWIN WILLIAMS SW 7032 "WARM		C-2	EXISTING GYPSUN CEILING - REPAIN SHERWIN WILLIAM "ANTIQUE WHITE" GLOSS FINISH	M BOARD T AS SW 6119
	NOTE:	STRONG BEIGE" REUSE EXISTING FRAME		ACP-1	MANUF: U MATERIAL: / STYLE: M	USG ACOUSTICAL CEILING PANEL MATCH EXISTING
DR-032A	DOOR:	PRIME AND PAINT MATCH			SIZE: 2 GRID COLOR: N	24"x24" WHITE
	FRAME:	PRIME AND PAINT SHERWIN WILLIAMS SW 7032 "WARM STRONG BEIGE"		CASEWOF ALL EXPO	RK & SED SURFACES:	
DR-032A	DOOR:	PRIME AND PAINT MATCH FRAME		ST STL	MANUFACTURER: COLOR:	STANLEY N/A
	FRAME:	PRIME AND PAINT SHERWIN WILLIAMS SW 7032 "WARM STRONG BEIGE"		COUNTER	TOPS	
	NOTE:	REUSE EXISTING FRAME		ST STL	MANUFACTURER: COLOR:	STANLEY N/A
				WALLS:		
				P-1	MANUFACTURER: TYPE: COLOR:	ICI SEMI-GLOSS #8211 "SANDY LANE"
		PART	<b>FITION</b>	I LEG	END:	
			$\rightarrow$	ACCESSIBI	LE PATH OF TRAVEL	-
		-	->	EGRESS P/	ATH OF TRAVEL.	

![](_page_23_Picture_6.jpeg)

 $\sqrt{3}$ 

# NEW BATHROOM FINISH PLAN

ONE-HOUR RATED CORRIDOR.

	======	INDICATES AN EXISTING MEMBRANE OF PARTITION OR PARTITION TO BE REMOVED. REFER TO DEMOLITION PLAN FOR FURTHER REQUIREMENTS.
		INDICATES AN EXISTING PARTITION TO REMAIN. REFER TO PLAN FOR UPGRADE REQUIREMENTS.
	SB SB SB SB	INDICATES AN EXISTING 1 HOUR SMOKE BARRIER
3	SP SP SP SP SP	INDICATES AN EXISTING 1 HOUR SMOKE PARTITION
	FP FP FP	INDICATES AN EXISTING ONE HOUR FIRE RATED PARTITION TO REMAIN. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	FB FB FB FB FB	INDICATES AN EXISTING ONE HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	EFB FB FFB FFF FFB FFF	INDICATES AN EXISTING TWO HOUR RATED FIRE BARRIER TO REMAIN, ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
	SB SB SB	INDICATES A NEW 1 HOUR SMOKE BARRIER
	SP SP SP SP SP	INDICATES A NEW 1 HOUR SMOKE PARTITION
		INDICATES A NEW ONE HOUR RATED FIRE PARTITION EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
		INDICATES A NEW ONE HOUR RATED FIRE BARRIER EXTENDING TO THE UNDERSIDE OF THE STRUCTURE ABOVE. ALL PENETRATIONS SHALL BE PROTECTED WITH A UL-LISTED FIRE STOP SYSTEM.
		THICK LINE INDICATES NEW SURFACE FINISH.
		INDICATES AN EXISTING STRUCTURAL CONCRETE WALL TO REMAIN. LOCATE REINFORCING STEEL AND OBTAIN APPROVAL FROM STRUCTURAL ENGINEER PRIOR TO CORING AND/ OR CUTTING.
		PE REFERENCE REFER TO SHEET A5-10.
	PARTITION NOTES:	

ALL DIMENSIONS SHOWN ARE TO FINISHED FACE OF GYP. BOARD, TYPICAL U.O.N. REFER TO SHEET A5-10 FOR GENERAL NOTES AND **REQUIREMENTS FOR PARTITIONS.** 

EXISTING WALLS WERE CONSTRUCTED WITH MANY PERMITS AND/OR 2. CONTRACTS. FIELD VERIFY CONSTRUCTION AND WIDTH PRIOR TO FABRICATION OF DOOR FRAMES OR COMPONENTS WHICH REQUIRE THE WIDTH OF WALL TO BE SET.

### **GENERAL NOTES:**

THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### FINISH PLAN GENERAL NOTES:

- PATCH AND REPAIR FINISHES IN LIKE KIND WHERE AFFECTED BY NEW CONSTRUCTION ON EXISTING BUILDING FINISHES.
- 2. ALL WINDOW COVERING TO BE CENTERED ON STOREFRONT AND INTALL PER MANUFACTURER'S REQUIREMENTS.
- REFER TO ENLARGE FLOOR PLANS FOR CORNER GUARDS, 3. CRASH RAIL AND CHAIRD RAIL LOCATONS.
- 4. REFER TO INTERIOR ELEVATIONS AND SHEET A5-80 FOR ALL CASEWORK FINISHES.
- 5. CONTRACTOR SHALL SUBMIT SIX (6) COPIES OF MANUFACTURER'S SPECIFICATIONS AND INSTALLATION INSTRUCTIONS FOR ALL FLOORING, CEMENT LEVELING AND PATCHING MATERIALS. PERFORM STRICTLY IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS. PROVIDE MAINTENANCE INFORMATION TO THE FACILITIES MAINTENANCE DEPARTMENT.
- PATCH AND REPAIR EXISTING SUB FLOOR SLAB AS REQUIRED 6. TO PROVIDE A SMOOTH SURFACE FOR NEW FLOORING PER MANUFACTURER'S INSTALLATION REQUIREMENTS. PROVIDE SELF-LEVELING UNDERLAYMENT CONCRETE.
- 7. FLOORING PREPARATION SHALL BE PERFORMED AS REQUIRED BY THE FLOOR FINISH MANUFACTURER IN A MANNER SUCH THAT THE MANUFACTURER'S PRODUCT WARRANTY WILL REMAIN IN EFFECT. IF FIELD CONDITIONS REQURIE VARIATIONS FROM MANUFACTURER'S REQUIREMENTS, THE CONTRACTOR SHALL NOTIFY THE FACILITIES MANAGER IN WRITING TO RECEIVE INSTRUCTIONS ON HOW TO PROCEED.
- 8. ALL ADHESIVES FOR FINISH MATERIALS SHALL HAVE LOW VOC EMISSIONS. CONTRACTOR SHALL PROVIDE DIRECT VENTILATION TO PREVENT VOC'S OUT GASSING FROM ADHESIVES FROM ENTERING THE BUILDING HVAC SYSTEM AND AFFECTING THE OCCUPANTS OF THE BUILDING.
- CONTRACTOR TO PROVIDE TRANSITIONS BETWEEN FLOORING MATERIALS PER DETAILS ON SHEET ID-2. ALL TRANSITIONS LOCATED UNDER DOORS, TO BE CENTERED UNDER DOOR.
- DOOR SWING: CONTRACTOR SHALL INSTALL ALL NEW FLOORING SUCH THAT IT DOES NOT INTERFERE WITH EXISTING DOORS AND SUCH A WAY THAT EXISTING DOORS DO NOT TOUCH THE SURFACE OF NEW FLOORING. ANY PROBLEMATIC DOORS SHALL BE BROUGHT TO THE ATTENTION FO THE FACILITIES CONSTRUCTION REPRESENTATIVE PRIOR TO FLOORING PREPARATION.
- 10. PERFORM CALCIUM CHLORIDE TEST FOR ALL SLAB SUBFLOORS WHERE SLAB IS NEW, OR ALL EXISTING SLAB ON GRADE LOCATIONS. WHERE EXISTING SLAB IS ABOVE GRADE, CONTRACTOR MAY LIMIT TESTING TO AREAS NEAR A SOURCE OF WATER SUCH AS AROUND PLUMBING LINES, SHOWER STALLS, ROOF DRAINS, ETC. WHERE MOISTURE IN THE SLAB EXCEEDS FINISH MATERIAL'S MANUFACTURER'S RECOMMENDATIONS, REFER TO NOTES ABOVE FOR MANUFACTURER'S WARRANTY 11.
- REQUIREMENTS. 12. CONTRACTOR TO INCLUDE ALLOWANCE FOR CONCRETE SLAB SEALER TO BE FURNISHED AND APPLIED UNDER ALL FLOOR
- FINISHES ON SLAB ON GRADE. 13. CONTRACTOR SHALL VERIFY LEAD TIMES FOR ALL FINISH MATERIALS AND SHALL BE RESPONSIBLE TO HAVE ALL MATERIALS ON THE JOB SITE ON TIME. NO SUBSTITUTIONS
- SHALL BE MADE DUE TO LATE ORDERING OF MATERIALS. 14. CONTINUE ALL FLOOR FINISHES UNDER ALL APPLIANCES AND REMOVABLE CABINETS AND EQUIPMENT.

### PAINT AND WALL FINISHES:

- 15. PAINT FINISHES (SHEEN) AS FOLLOWS: WALLS: EGGSHELL SHEEN EXCEPTIONS SIMI GLOSS SHEEN AT: TOILETS PUBLIC AND LABS, FOOD SERVICE AREAS, TRASH AND UTILITY ROOMS. PAINTED DOORS & FRAMES: SEMI GLOSS CEILING AND SOFFITS: FLAT
  - NOTE: REFER TO INTERIOR ELEVATIONS WHERE FOR LOCATIONS WHERE EPOXY PAINT IS REQUIRED.
- 16. SUBMIT ALL FINISH SAMPLES TO ARCHITECT FOR APPROVAL, INCLUDING DRAW DOWNS OF ALL PAINT COLORS IN ALL FINISH TYPES AS USED.
- 17. PAINT ALL ACCESS PANELS TO MATCH ADJ. WALL SURFACE.
- 18. PLASTER FINISH SHALL BE LEVEL FOR WHERE A PAINTED FINISH SURFACE IS SHOWN.

### **RESILIENT FLOORING:**

- 19. ALL RESILIENT FLOORING INSTALLATIONS SHALL BE COMPLETED TO THE POINT READY FOR THE FIRST DAY OF USE AND IN AS NEW CONDITION, CLEAN CONSTRUCTION DUST AND DERBY, DAMP MOP AND APPLY A SEALER OR WAXED PER MANUFACTURER'S RECOMMENDATIONS FOR THE PRODUCT. FLOORING CONTRACTOR TO PROVIDE THE PRODUCT SPECIFICATION AND A RECOMMENDED REAPPLICATION TIME FOR THE SEALER OR WAX TO THE FACILITIES MAINTENANCE OFFICE.
- 20. ALL SHEET GOODS OF RESILIENT FLOORING SHALL BE INSTALLED USING HEAT WELD SEAMS, WELDING RODS SHALL MATCH THE COLOR OF THE FLOORING MATERIAL UNLESS OTHERWISE NOTED ON THE FINISH PLAN OR LEGEND.

CASEWORK AND MILL WORK:

- 21. ALL CASEWORK AND MILL WORK TO CONFORM TO THE REQUIREMENTS OF THE LATEST EDITION OF W.I.C. FOR CUSTOM GRADE.
- 22. NOT USED.
- 23. SHOP DRAWINGS SHALL BE SUBMITTED FOR ALL CASEWORK AND MILL WORK.

### FLAME SPREAD:

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or information and retrieval systems without written permission of the ARCHII

24. FLAME SPREAD OF FINISH MATERIALS: WALL, FLOOR AND CEILING SHALL NOT EXCEED THE FLAME SPREAD CLASSIFICATIONS IN CBC TABLE 803.5

### S R F A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

## **Tri-City Medical Center**

<u>(_6)</u>	DESIGN CH	ANGES	6–05–18 
	OSHPD COI	MMENTS	5-15-18
	DESIGN CH	ANGES	12-11-17
$\frac{\sqrt{3}}{\sqrt{3}}$	OSHPD CO	MMENTS	12–11–17
	DESIGN CH	ANGES	10-09-17
	oshpd coi	MMENTS	10-09-1
415 JOSE CE	No. C 28	AP 47 47 47 47 47 47 47 47 47 47	
STRUCI	URAL:	SUN STRUCTURAL ENGINE 2091 LAS PALMAS DRIVE, CARLSBAD, CA 92011 TEL(760)438–1188	ERING SUITE D
MEP:		P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SAN DIEGO, CA 92123 TEL(619)618-2347	SUITE 230
ARCHIT	ECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, S SAN DIEGO, CALIFORNIA 9 TEL(619)299–3917 FAX(6	SUITE 100 2122 S19)299–508
		4002 VISTA WAY OCEANSIDE, CALIFORNIA 9	c 2056

### OSHPD APPROVAL STAMP:

![](_page_23_Picture_52.jpeg)

### NEW FINISHES PLAN

PROJECT TITLE: TCMC USP 800

4

PROJECT #: 01667.00 DRAWN BY:

HECKED

DATE:

SHEET NUMBER

**100% CONSTRUCTION DOCUMENT** 

07/31/17

![](_page_24_Picture_0.jpeg)

THE GENERAL CONTRACTOR SHALL VERIFY ALL EXISTING CONDITIONS AND MEASUREMENTS IN THE FIELD PRIOR TO STARTING CONSTRUCTION. REFER TO GENERAL NOTES ON SHEET A0-00 FOR INFORMATION NOT INDICATED ON THIS SHEET.

### FINISH PLAN GENERAL NOTES:

- PATCH AND REPAIR FINISHES IN LIKE KIND WHERE AFFECTED BY NEW CONSTRUCTION ON EXISTING BUILDING FINISHES.
- 2. ALL WINDOW COVERING TO BE CENTERED ON STOREFRONT AND INTALL PER MANUFACTURER'S REQUIREMENTS.
- REFER TO ENLARGE FLOOR PLANS FOR CORNER GUARDS, CRASH RAIL AND CHAIRD RAIL LOCATONS.
- 4. REFER TO INTERIOR ELEVATIONS AND SHEET A5-80 FOR ALL CASEWORK FINISHES.
- CONTRACTOR SHALL SUBMIT SIX (6) COPIES OF MANUFACTURER'S SPECIFICATIONS AND INSTALLATION INSTRUCTIONS FOR ALL FLOORING, CEMENT LEVELING AND PATCHING MATERIALS. PERFORM STRICTLY IN ACCORDANCE WITH MANUFACTURER'S SPECIFICATIONS. PROVIDE MAINTENANCE INFORMATION TO THE FACILITIES MAINTENANCE DEPARTMENT.
- PATCH AND REPAIR EXISTING SUB FLOOR SLAB AS REQUIRED TO PROVIDE A SMOOTH SURFACE FOR NEW FLOORING PER MANUFACTURER'S INSTALLATION REQUIREMENTS. PROVIDE SELF-LEVELING UNDERLAYMENT CONCRETE.
- FLOORING PREPARATION SHALL BE PERFORMED AS REQUIRED BY THE FLOOR FINISH MANUFACTURER IN A MANNER SUCH THAT THE MANUFACTURER'S PRODUCT WARRANTY WILL REMAIN IN EFFECT. IF FIELD CONDITIONS REQURIE VARIATIONS FROM MANUFACTURER'S REQUIREMENTS, THE CONTRACTOR SHALL NOTIFY THE FACILITIES MANAGER IN WRITING TO RECEIVE INSTRUCTIONS ON HOW TO PROCEED.
- ALL ADHESIVES FOR FINISH MATERIALS SHALL HAVE LOW VOC EMISSIONS. CONTRACTOR SHALL PROVIDE DIRECT VENTILATION TO PREVENT VOC'S OUT GASSING FROM ADHESIVES FROM ENTERING THE BUILDING HVAC SYSTEM AND AFFECTING THE OCCUPANTS OF THE BUILDING.
- 9. CONTRACTOR TO PROVIDE TRANSITIONS BETWEEN FLOORING MATERIALS PER DETAILS ON SHEET ID-2. ALL TRANSITIONS LOCATED UNDER DOORS, TO BE CENTERED UNDER DOOR.
- 10. DOOR SWING: CONTRACTOR SHALL INSTALL ALL NEW FLOORING SUCH THAT IT DOES NOT INTERFERE WITH EXISTING DOORS AND SUCH A WAY THAT EXISTING DOORS DO NOT TOUCH THE SURFACE OF NEW FLOORING. ANY PROBLEMATIC DOORS SHALL BE BROUGHT TO THE ATTENTION FO THE FACILITIES CONSTRUCTION REPRESENTATIVE PRIOR TO FLOORING PREPARATION.
- 11. PERFORM CALCIUM CHLORIDE TEST FOR ALL SLAB SUBFLOORS WHERE SLAB IS NEW, OR ALL EXISTING SLAB ON GRADE LOCATIONS. WHERE EXISTING SLAB IS ABOVE GRADE, CONTRACTOR MAY LIMIT TESTING TO AREAS NEAR A SOURCE OF WATER SUCH AS AROUND PLUMBING LINES. SHOWER STALLS. ROOF DRAINS, ETC. WHERE MOISTURE IN THE SLAB EXCEEDS FINISH MATERIAL'S MANUFACTURER'S RECOMMENDATIONS. REFER TO NOTES ABOVE FOR MANUFACTURER'S WARRANTY REQUIREMENTS.
- 12. CONTRACTOR TO INCLUDE ALLOWANCE FOR CONCRETE SLAB SEALER TO BE FURNISHED AND APPLIED UNDER ALL FLOOR FINISHES ON SLAB ON GRADE.
- 13. CONTRACTOR SHALL VERIFY LEAD TIMES FOR ALL FINISH MATERIALS AND SHALL BE RESPONSIBLE TO HAVE ALL MATERIALS ON THE JOB SITE ON TIME. NO SUBSTITUTIONS SHALL BE MADE DUE TO LATE ORDERING OF MATERIALS.
- 14. CONTINUE ALL FLOOR FINISHES UNDER ALL APPLIANCES AND REMOVABLE CABINETS AND EQUIPMENT.

### PAINT AND WALL FINISHES:

- 15. PAINT FINISHES (SHEEN) AS FOLLOWS: WALLS: EGGSHELL SHEEN EXCEPTIONS SIMI GLOSS SHEEN AT: TOILETS PUBLIC AND LABS, FOOD SERVICE AREAS, TRASH AND UTILITY ROOMS. PAINTED DOORS & FRAMES: SEMI GLOSS CEILING AND SOFFITS: FLAT
- NOTE: REFER TO INTERIOR ELEVATIONS WHERE FOR LOCATIONS WHERE EPOXY PAINT IS REQUIRED.
- 16. SUBMIT ALL FINISH SAMPLES TO ARCHITECT FOR APPROVAL, INCLUDING DRAW DOWNS OF ALL PAINT COLORS IN ALL FINISH TYPES AS USED.
- 17. PAINT ALL ACCESS PANELS TO MATCH ADJ. WALL SURFACE.
- 18. PLASTER FINISH SHALL BE LEVEL FOR WHERE A PAINTED FINISH SURFACE IS SHOWN.

### **RESILIENT FLOORING:**

- 19. ALL RESILIENT FLOORING INSTALLATIONS SHALL BE COMPLETED TO THE POINT READY FOR THE FIRST DAY OF USE AND IN AS NEW CONDITION, CLEAN CONSTRUCTION DUST AND DERBY, DAMP MOP AND APPLY A SEALER OR WAXED PER MANUFACTURER'S RECOMMENDATIONS FOR THE PRODUCT. FLOORING CONTRACTOR TO PROVIDE THE PRODUCT SPECIFICATION AND A RECOMMENDED REAPPLICATION TIME FOR THE SEALER OR WAX TO THE FACILITIES MAINTENANCE OFFICE.
- 20. ALL SHEET GOODS OF RESILIENT FLOORING SHALL BE INSTALLED USING HEAT WELD SEAMS, WELDING RODS SHALL MATCH THE COLOR OF THE FLOORING MATERIAL UNLESS OTHERWISE NOTED ON THE FINISH PLAN OR LEGEND.

### CASEWORK AND MILL WORK:

- 21. ALL CASEWORK AND MILL WORK TO CONFORM TO THE REQUIREMENTS OF THE LATEST EDITION OF W.I.C. FOR CUSTOM GRADE.
- 22. NOT USED.
- 23. SHOP DRAWINGS SHALL BE SUBMITTED FOR ALL CASEWORK AND MILL WORK.

### FLAME SPREAD:

24. FLAME SPREAD OF FINISH MATERIALS: WALL, FLOOR AND CEILING SHALL NOT EXCEED THE FLAME SPREAD CLASSIFICATIONS IN CBC TABLE 803.5

# S ARCHITECTS

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

# **Tri-City Medical Center**

	DESIGN CHANGES		6-05-18
5	OSHPD COMMENTS		5-15-18
	DESIGN CHANGES	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	12-11-1
	OSHPD COMMENTS		12-11-1
$\overline{2}$	DESIGN CHANGES		10-09-1
1	OSHPD COMMENTS		10-09-1
415 JOSEC EX	No. C 28543 TO NO. C 28543 TO POR 1-31-19 OF CALIFORNIA		
STRUCI	URAL: SUN STRU 2091 LAS CARLSBAD TEL(760)4	ICTURAL ENGINEE PALMAS DRIVE, 0, CA 92011 38–1188	ERING SUITE D
MEP:	P2S ENGI 9665 CHE SAN DIEG TEL(619)6	NEERING, INC. SAPEAKE DRIVE, D, CA 92123 18–2347	SUITE 230
ARCHIT	ECT: SFEIR ARG 5151 SHO SAN DIEG TEL(619)2	CHITECTS REHAM PLACE, S O, CALIFORNIA 9 99–3917 FAX(6	SUITE 100 2122 519)299–50
	4002 VIS OCEANSID	TA WAY E, CALIFORNIA 9	2056

### OSHPD APPROVAL STAMP:

![](_page_24_Picture_40.jpeg)

PROJECT TITLE: TCMC USP 800

DATE:

4

PROJECT #: 01667.00 DRAWN BY: SCALE: 1/4" = 1'-0

07/31/17

SHEET NUMB

- 1. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, ELEVATIONS, SITE CONDITIONS PRIOR TO STARTING CONSTRUCTION. THE ARCHITECT AND STRUCTURAL ENGINEER SHALL BE NOTIFIED OF ANY DISCREPANCIES OR INCONSISTENCIES.
- 2. THE ARCHITECT AND STRUCTURAL ENGINEER SHALL BE NOTIFIED OF ANY CONFLICTS OR OMISSIONS BETWEEN THE WORKING DRAWINGS OR SPECIFICATIONS BEFORE PROCEEDING ANY WORK SO AFFECTED. A CLARFICATION SHALL BE ISSUED FOR SUCH CONFLICTS. ANY WORK PERFORMED IN CONFLICT WITH THE CONTRACT DOCUMENTS OR ANY CODE REQUIREMENTS SHALL BE CORRECTED BY THE ARCHITECT AND STRUCTURAL ENGINEER
- 3. THE STRUCTURAL DRAWINGS AND SPECIFICATIONS FOR CONSTRUCTION REPRESENT THE FINISHED STRUCTURE. THEY DO NOT INDICATE THE METHOD OF CONSTRUCTION. THE CONTRACTOR SHALL PROVIDE ALL MEASURES NECESSARY TO PROTECT THE STRUCTURE DURING CONSTRUCTION. SUCH MEASURES INCLUDE, BUT NOT LIMITED TO, BRACING, SHORING, TO INSURE THE VERTICAL AND LATERAL STABILITY OF THE STRUCTURE. OBSERVATION VISITS TO THE SITE BY THE ARCHITECT AND STRUCTURAL ENGINEER SHAL NOT INCLUDE INSPECTION OF THE ABOVE ITEMS AND DOES NOT RELIEVE THE CONTRACTOR'S RESPONSIBILITIES.
- 4. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR CONFORMING TO ALL LOCAL, STATE AND FEDERAL SAFETY AND HEALTH STANDARDS, LAWS AND REGULATIONS. THE ARCHITECT AND STRUCTURAL ENGINEER WILL NOT ENFORCE SAFETY MEASURES OR REGULATIONS.
- 5. NOTES AND DETAILS ON THE DRAWINGS SHALL TAKE PRECEDENCE OVER THE GENERAL NOTES AND TYPICAL DETAILS. DIMENSIONS SHALL TAKE PRECEDENCE OVER SCALES SHOWN ON THE DRAWINGS IN CASE OF CONFLICT.
- ALL WORKS SHALL CONFORM TO THE STANDARDS OF THE 2016 CALIFORNIA BUILDING CODE. 7. A.S.T.M. SPECIFICATIONS NOTED ON THE DRAWINGS SHALL BE OF THE LATEST
- 8. NO STRUCTURAL SUBSTITUTIONS OR CHANGES SHALL BE MADE IN THE FIELD. WRITTEN APPROVAL MUST BE OBTAINED FROM THE STRUCTURAL ENGINEER AND OSHPD FOR ANY SUBSTITUTIONS OR CHANGES FROM THE APPROVED CONSTRUCTION DOCUMENTS.
- 9. CONTRACTOR SHALL PROVIDE AND BE RESPONSIBLE FOR THE PROTECTION AND REPAIR OF ADJACENT EXISTING SURFACES AND AREAS WHICH MAY BE DAMAGED AS A RESULT OF NEW WORK.

### EXPANSION ANCHOR BOLTS

3/8"ø HILTI KB TZ

EPOXY ANCHOR

1. ALL FIELD INSTALLED CONCRETE EXPANSION ANCHORS SHALL BE HILTI KB-TZ ANCHORS. ANCHOR TYPE ICC-ES ESR#

2. ALL ANCHORS SHALL BE TESTED BASED ON THE FOLLOWING CRITERIA:

ANCHOR TYPE TORQUE ICC-ES ESR# 3/8"Ø HILTI KB TZ ANCHOR 25 FT-LBS 1917

MINIMUM ANCHOR EMBEDMENT SHALL BE 2" FOR 3/8"Ø, (INSTALLED IN NORMAL WT. CONCRETE WITH fc' = 3000 PSI)

WHEN INSTALLING DRILLED-IN ANCHORS AND/OR POWDER DRIVEN PINS IN EXISTING NON-PRESTRESSED REINFORCED CONCRETE, USE CARE AND CAUTION TO AVOID CUTTING OR DAMAGING THE EXISTING REINFORCING BARS OR EMBEDED PIPES AND CONDUITS IN THE SLAB BY USING A NON DESTRUCTIVE METHOD PRIOR TO INSTALLATION WHEN INSTALLING THEM INTO PRESTRESSED CONCRETE (PRE OR POST TENSIONED) LOCATED THE PRESTRESSED TENDONS BY USING A NON DESTRUCTIVE METHOD PRIOR O INSTALLATION. EXERCISE EXTREME CARE AND CAUTION TO AVOID CUTTING OR DAMAGING THE TENDONS DURING INSTALLATION. MAINTAIN 1" MINIMUM CLEARANCE BETWEEN EXISTING REINFORCEMENT AND THE

1917

APPLY PROOF TEST LOADS TO EPOXY ANCHORS WITHOUT REMOVING THE NUT IF POSSIBLE. OTHERWISE, REMOVE THE NUT AND INSTALL A THREADED COUPLER UP TO THE SAME TIGHTNESS OF THE ORIGINAL NUT USING A TORQUE WRENCH AND APPLY THE LOAD.

TESTING SHOULD OCCUR A MINIMUM 24 HOURS AFTER INSTALLATION OF THE SUBJECTED ANCHORS. IF THE MANUFACTURER'S RECOMMENDED INSTALLATION TORQUE IS LESS THAN THE TEST TORQUE, THE MANUFACTURER'S RECOMMANDED INSTALLATION TORQUE SHOULD BE USED IN LIEU OF THE TEST TORQUE. ANCHOR DIAMETER REFERS TO THE THREAD SIZE.

REACTION LOADS FROM TEST FIXTURES MAY BE APPLIED CLOSE TO THE ANCHOR BEING TESTED. PROVIDE THE ANCHOR IS NOT RESTRAINED FROM WITHDRAWING BY THE FIXTURE.

TEST EQUIPMENT INCLUDING TORQUE WRENCHES SHALL BE CALIBRATED BY AN APPROVED TESTING LABORATORY IN ACCORDANCE WITH STANDARD RECOGNIZED PROCEDURES. TEST METHODS; THE FOLLOWING CRITERIA APPLY FOR THE ACCEPTANCE OF

INSTALLED ANCHORS: A). HYDRAULIC RAM METHOD: ANCHORS TESTED WITH A HYDRAULIC JACK OR SPRING LOADED DEVICES SHALL MAINTAN THE TEST LOAD FOR MINIMUM OF 15 SECONDS AND SHALL EXHIBIT NO DISCERNABLE MOVEMENT DURING THE TENSION TEST, e.g., AS EVIDENCED BY LOOSENING OF THE WASHER UNDER NUT.

B). TORQUE WRENCH METHOD: ANCHORS TESTED WITH A CALIBRATED TORQUE WRENCH MUST ATTAIN THE SPECIFIED TORQUE WITHIN  $\frac{1}{2}$  TURN OF THE NUT. EXCEPTIONS:

1. WEDGDE OR SLEEVE TYPE: ONE-QUARTER (1) TURN OF THE NUT FOR A 3 IN. SLEEVE ANCHOR ONLY. 2. THREADED TYPE: ONE QUARTER ( $rac{1}{4}$ ) TURN OF THE SCREW AFTER INITIAL SEATING OF THE SCREW HEAD.

TESTING SHOULD OCCUR 24 HOURS MINIMUM AFTER INSTALLATION OF THE EPOXY ANCHOR.

MINIMUM OF 50% OF THE INSTALLED ANCHOR SHALL BE TESTED. (ALTERNATE ANCHORS IN ANY GROUP ARRANGEMENT) IF ANY ANCHOR FAILS TESTING, TEST ALL ANCHORS OF THE SAME TYPE, INSTALLED BY THE SAME TRADE, NOT PREVIOUSLY TESTED UNTIL TWENTY (20) CONSECUTIVE ANCHORS PASS, THEN RESUME THE INITIAL TEST FREQUENCY. TESTS SHALL BE PERFORMED PER CBC 2016, 1910A.5.

ALL TESTS SHALL BE PERFORMED IN THE PRESENCE OF THE INSPECTOR OF

COLD-FORMED STEEL FRAMING

- DESIGN, MANUFACTURE AND INSTALLATION OF LIGHT GAGE, COLD-FORMED STEEL JOISTS, PURLINS AND STUDS SHALL CONFORM WITH THE LATEST EDITION OF THE LIGHT GAGE, COLD-FORMED STEEL DESIGN MANUAL ISSUED BY THE AISI.
- STRUCTURAL LIGHT GAUGE STUDS, TRACK, BRIDGING, AND ACCESSORIES SHALL COMPLY WITH STEEL STUD MANUFACTURERS ASSOCIATION ICC ES ESR# 3064P STRUCTURAL LIGHT GAUGE CH STUDS, J RUNNER TRACK, AND ACCESSORIES SHALL COMPLY WITH DIETRICH
- METAL FRAMING ICC-ESR# 1166P ALL WELDING SHALL BE IN CONFORMANCE WITH AWS D1.3 "STRUCTURAL WELDING CODE – SHEET STEEL". QUALIFICATION OF WELDERS SHALL BE IN ACCORDANCE WITH AWS D1.1, CHAPTER 5, PART C, "WELDER QUALIFICATION". SEE LATEST EDITION OF THE AISI SPECIFICATIONS FOR THE "DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS" FOR ALLOWABLE WELD
- VALUES.
- FRAMING SHALL BE ERECTED PLUMB, LEVEL AND SQUARE. BRIDGING AND DIAGONAL TENSION STRAPS SHALL BE USED.
- TEMPORARY BRACING SHALL BE PROVIDED AS REQUIRED UNTIL ERECTION IS COMPLETE AND SAFELY SECURED TO STRUCTURE.
- 6. COLD-FORMED STEEL YIELD STRENGTH (fy) IS 33 KSI. IDENTIFICATION OF SSMA PRODUCTS

MEMBER DEPTH:  $3.62'' = 362 \times 1/100$  INCHES ALL MEMBER DEPTHS ARE TAKEN IN 1/100 INCHES FOR ALL "T" SECTIONS MEMBER DEPTH IS THE

FLANGE WIDTH:  $2" = 200 \times 1/100$  INCHES ALL FLANGE WIDTH ARE TAKEN IN 1/100 INCHES

MIN. BASE METAL THICKNESS

4

REPRESENTS 95% OF THE

DESIGN THICKNESS

INSIDE TO INSIDE DIMENTION

(362)(\$)(162) -54 MATERIAL THICKNESS: 0.054" = 54 MILS (16 GA.) STYLE: MATERIAL THICKNESS IS THE

S = STUD OR JOIST SECTIONST = TRACK SECTIONS<u>EXAMPLE</u>

COLD-FORMED STEEL STUDS PROPERTIES

IDENTIFICATION	MEMBER DEPTH	FLANGE WIDTH	MATERIAL THICKNESS
362S162-43	3.62"	1.625"	18 GA.
362S162-54	3.62"	1.625"	16 GA.
362T125-43	3.62"	1.25"	18 GA.
400S162-43	4"	1.625"	18 GA.
600T125-54	6"	1.25"	16 GA.
250S125-54	2.5"	1.25"	16 GA.
250T125-54	2.5"	1.25"	16 GA.

### STRUCTURAL STEEL:

STRUCTURAL STEEL SHALL COMPLY WITH THE FOLLOWING U.N.O.: STEEL CHANNELS AND ANGLES ASTM A36 STRUCTURAL TUBES A500, GRADE B STEEL PLATE ASTM A36 STEEL BOLT ASTM A307 ALL STEEL MEMBERS TO BE PRIME PAINTED.

SEISMIC LOAD

SITE LOCATION:

LONGITUDE: 117.29178° WEST, LATITUDE: 33.18425° NORTH DESIGN SPECTRAL RESPONSE ACCLERATION:

SEISMIC IMPORTANCE FACTOR, Ip = 1.5SEISMIC FORCE COEFFICIENTS:  $a_p = 1.0, R_P = 2.5$ SEISMIC DESIGN CATEGORY "D"

S<sub>DS</sub>= 0.760, S<sub>D1</sub>= 0.435

![](_page_25_Figure_46.jpeg)

All rights reserved. No part of this work may be reproduced or copied in any form or by any means, graphic, electronic, or mechanical, including photocopying, recording, taping, or information and retrieval systems without written

![](_page_26_Figure_0.jpeg)

### EQUIPMENT SCHEDULE

EQUIP #	DESCRIPTION	WEIGHT(APPROX.)	DETAIL
( 001 )	BSC WORKSTATION	800 LBS	1 SD1 2 SD1
(005)	PHARMACY REFRIGERATOR	1470 LBS	5 SD1 6 SD1
(008)	LAMINAR FLOW WORK BENCH	440 LBS	7 SD1 8 SD1
(009)	LAMINAR FLOW WORK STATION	680 LBS	9 SD1 (SD1)
(010)	PYXIS SUPPLY-AUXILLARY	1000 LBS	11 SD3 (12 SD3
(011)	PYXIS SUPPLY-MAIN	1000 LBS	11 SD3 (12 SD3
	STAINLESS STEEL CABINET	1000 LBS	11 SD1 (12 SD1
(029)	REFRIGERATOR	1654 LBS	3 SD1 4 SD1

EXISTING 4" CONC. SLAB ON GRADE (fc' = 2500 PSI) W/ #4 @ 16" O.C. EA. WAY

# PARTIA

\_\_\_\_\_

### NOTES

- 1. DO NOT SCALE THESE DRAWINGS. PRIOR TO START OF CONSTRUCTION, ALL DIMENSIONS AND ELEVATIONS MUST BE VERIFIED WITH THE APPRD. SET OF ARCHITECHURAL DRAWINGS. IN CASE OF DISCREPENCIES, STRUCTURAL ENGINEER OF RECORD MUST BE NOTIFIED IN WRITING.
- 2. ALL EXISTING MEMBER SIZES, SPACING, & DIMENSIONS MUST BE FIELD VERIFIED. IN CASE OF DISCREPANCIES STRUCTURAL ENGINEER MUST BE NOTIFIED IN WRITING.
- 3. THE EXISTING FLOOR FRAMING PLAN IS BASED ON THE STATE DEPT. OF HEALTH FACH CONSTR. SECT. APPROVED STRUCTURAL DRAWING, APPROVAL# H0161

	S F E I R A R C H I T E C T S 5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619–299–3917 F: 619–299–5084 www.sfeirarch.com
	USP 800 UPGRADE Tri-City Medical Center 4002 Vista Way Oceanside, California 92056 WNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 ARCHITECT: SFEIR ARCHITECTS EIST SHOREHAM PLACE, SUITE 100 CAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084
	MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347 STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188 TEL(760)438–1188
AL PENTHOUSE ROOF PLAN	6       GSHPD COMMENTS       6-05-18
SCALE: 1/4"=1'-0"	With comments         KC Huang, Sr. Architect.         Office of Statewide Health         Planning & Development         FACILITIES DEVELOPMENT DIVISION         DREET TITLE:         PROJECT TITLE:         PROJECT TITLE:         PROJECT TITLE:         PROJECT TITLE:         DRAWN BY:         OTE:         OT667.00         SCALE:         DTE:         OT/31/17

![](_page_27_Figure_0.jpeg)

![](_page_28_Figure_0.jpeg)

_		
_		

![](_page_29_Figure_1.jpeg)

""100% CONSTRUCTION DOCUMENT

![](_page_30_Figure_0.jpeg)

							GEINE
DESCRIPTION	SYMBOL	DESCRIPTION	ABBREVIATI	ON DESCRIPTION	ABBREVIA	TION DESCRIPTION	4. IN THE E
			ABV	ABOVE	<u>, 100 112 11 1</u>	INCHES	SPECIFI
NOTE CALLOUT	$\rightarrow$				K/W	KII OWATTS	
	<	DAMPER, OPPOSED BLADE					5. THIS CO
	>						PROPER
NUMBER ON TOR DENOTES DETAIL NUMBER			AHU		LBS		SPECIFI
NUMBER ON BOTTOM DENOTES SHEET DETAIL IS SHOWN	· · · · · · · · · · · · · · · · · · ·		AP	ACCESS PANEL	LD		
		DAMPER PARALLEL BLADE	BDD	BACK DRAFT DAMPER	LWT	LEAVING WATER TEMPERATURE	6. ALL NEV
			BHP	BRAKE HORSEPOWER	MAX	MAXIMUM	UNDERV
MECHANICAL EQUIPMENT CALLOUT, SEE MECHANICAL PLANS FOR			BLDG	BUILDING	MBH	THOUSAND BTU PER HOUR	DESIGN
EXACT LOCATION AND REQUIREMENTS			BMS	BUILDING MANAGEMENT SYSTEM	MCA	MINIMUM CIRCUIT AMPS	
			BTU	BRITISH THERMAL UNIT	MIN	MINIMUM	7. THIS CO
			CAV	CONSTANT AIR VOLUME	MOCP	MAXIMUM OVERI OAD CIRCUIT PROTECTION	
		FILTER			NIC		
SECTION CALLOUT							FNOVIDE
			CFIVI		UAT		
			CV	CONSTANT VOLUME BOX	OBD	OPPOSED BLADE DAMPER	0. ALL VUO
	~ ~ ~ ~ ~ ~ ~		D	DRAIN	OSA	OUTSIDE AIR	MINIMIZE
		LOUVER	DB	DRY BULB	PD	PRESSURE DROP	IN OPER
			DEG	DEGREES	PERF	PERFORATED	
POINT OF DISCONNECTION	AD	ACCESS DOOR OR ACCESS PANEL (AP) IN DUCTWORK	DIA	DIAMETER	PH	PHASE	9. NO PIPIN
				DOWN	POD	POINT OF DISCONNECT	WITH TH
NEW LINEWORK						PRESSURE RELIEF	NOT WIT
		TURNING VANES (RECTANGULAR)					SUFFICI
			(ヒ)	EXISTING	PRV = -	PRESSURE REDUCING VALVE	WHEN T
			EA	EXHAUST AIR	PSID	POUNDS PER SQUARE INCH DIFFERENTIAL	
			EAT	ENTERING AIR TEMPERATURE	PSIG	POUNDS PER SQUARE INCH GAUGE	10. THE ARF
	Ý	DRAIN, FUNNEL	EF	EXHAUST FAN	RA	RETURN AIR	
NEW PIPING (SIZE-SERVICE)	I		EFF	EFFICIENCY	RAR	RETURN AIR REGISTER	
			FI	FI EVATION	RF	RETURN FAN	
	$\bigcirc$	PUMP	FO	FOLIAL	BG		FEATURI
	•						EQUIPMI
SHEET METAL DUCT	$\frown$		EK		RHC		VALVES
	(	CENTRIFUGAL FAN	ESP	EXTERNAL STATIC PRESSURE	RLA	RATED LOAD AMPS	PROVIDE
	$\bigcirc$		EWT	ENTERING WATER TEMPERATURE	RPM	REVOLUTIONS PER MINUTE	
HIDDEN SHEET METAL DUCT			°F	DEGREES FAHRENHEIT	SA	SUPPLY AIR	11. THIS CO
	_		FC	FAN COOL UNIT	SAR	SUPPLY AIR REGISTER	DRAWIN
		ELECTRONIC 2-WAY VALVE	FD	FIRE DAMPER	SD	SMOKE DAMPER	PIPES AN
			FF	FAN FILTER	SE	SUPPLY FAN	OTHER 1
					SMRL		INTEREE
	( )		FLA				
			FLR	FLOOR	SID	STANDARD	AND CO
			FOB	FLAT ON BOTTOM	IAD	TRANSFER AIR DUCT	
STANDARD BRANCH FOR SUPPLY AND RETURN			FOT	FLAT ON TOP	TEMP	TEMPERATURE	
		DDC OUTPUT	FP	FIRE PUMP	TG	TRANSFER GRILLE	PURCHA
			FPI	FINS PER INCH	TMBH	TOTAL MBH	
	$\frown$		FPM	FFFT PER MINUTE	TSP	TOTAL STATIC PRESSURE	13. BEFORE
KOOND ELBOM DOMN	()	LOCALLY MOUNTED INSTRUMENT	FT		TYP		AND CH
	$\bigcirc$						
	_		FA				14. CONTRA
NUUNU ELBUN UK	(C02)	CARBON DIOXIDE SENSOR	GA	GAUGE	UON	UNLESS UTHERWISE NUTED	
			GALV	GALVANIZED	V	VOLIS	15. EXISTINO
	DPS	DIFFERENTIAL PRESSURE SENSOR	GC	GENERAL CONTRACTOR	VAV	VARIABLE AIR VOLUME UNIT	INDICAT
HEUTANGULAK TU KUUND TKANSITIUN			GPH	GALLONS PER HOUR	VD	VOLUME DAMPER	
			GPM	GALLONS PER MINUTE	VFD	VARIABLE FREQUENCY DRIVE	16. ALL EQU
			HB	HOSE BIBB	W/	WITH	INSTRUC
FLEXIBLE DUCT			нп		W/O	WITHOUT	
	(FS)	AIRFLOW SENSOR	U	HEARTING HOT WATER SUPPLY AND	v v/ C	WITTOOT	17. GALVAN
	_		HHWS&R	RETURN	WB	WET BULB	SUPPOR
	(HS)	RELATIVE HUMIDITY SENSOR	П				SMACNA
FLEX CONNECTION	)		Π٢		VVC		
		TEMPERATURE SENSOR	HP	HORSEPOWER	WG	WATER GAUGE	
			HT	HEIGHT	WT	WEIGHT	
			H7	HERTZ			
		AVERAGING TEMPERATURE SENSUR				/ENT ABBBEV/IATIONS NOT MENTIONED HEREIN	TO SUIT
FIRE DAMPER				ARREVIATIONS AND OTHER STANDARD IND			
	∠////	ANALOG SIGNAL			CONVEN		19. THIS CO
	· /// ·						MECHAN
	<b>、</b>		11/03				STANDA
COMBINATION FIRE AND SMOKE DAMPER	<u> </u>	DIGITAL SIGNAL	1. CONT	RACTOR SHALL COORDINATE ARCHITECTUR	AL REFLECTED	CEILINGS PLANS WITH ALL DISCIPLINES TO VERIFY	
			CLEAF	RANCES BETWEEN HVAC DUCTS, HVAC PIPIN	G, LIGHT FIXTUF	RES, ELECTRICAL DATA CONDUITS, PLUMBING	20. THIS CO
			LINES	, FIRE PROTECTION LINES, STRUCTURAL MEI	MBERS, ETC. SP	ECIAL ATTENTION IS REQUIRED ALONG THE	WRITTEN
			LENG	TH OF MAIN MECHANICAL SUPPLY AND RETU	JRN AIR DUCTS	WHERE THERE IS LIMITED CLEARANCE FOR	
		RREVIATIONS	PASSA	AGE OR ROUTING OF UTILITIES.			21. ALL PIPE

ABBREVIATION DESCRIPTION

ABBREVIATION

VSI

ΖO

DESCRIPTION

STATUS

SETPOINT

START/STOP

TEMPERATURE

PRESSURE TRANMITTER

TEMPERATURE INDICATOR

DAMPER/VALVE ACTUATOR

VELOCITY PRESSURE

CLOSED END SWITCH

POSITION INDICATOR

OPEN END SWITCH

VIBRATION SWITCH

RELATIVE HUMIDITY

SPEED CONTROL

SPEED INDICATOR

4	ALARM
AI	ANALOG INPUT
40	ANALOG OUTPUT
וכ	DIGITAL INPUT
00	DIGITAL OUTPUT
)P	DIFFERENTIAL PRESSURE
S	FLOW SWITCH
M	FLOW METER
HOA	HANDS OFF AUTO
<w< td=""><td>KILOWATTS</td></w<>	KILOWATTS
A	LEVEL ALARM
NOD	MOTOR OPERATED DAMPER
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
PS	PRESSURE SWITCH

REFERENCE WILL BE MADE TO ANSI Y1.1, MILITARY STANDARD IN THE EVENT ABBREVIATIONS NOT MENTIONED HEREIN ARE USED, ABBREVIATIONS, AND OTHER STANDARD INDUSTRY CONVENTIONS.

TRANSFER GRILLE OR LOUVER

UNDERCUT DOOR

SUPPLY DIFFUSER: 2-WAY/3-WAY/4-WAY

GRILLE: RETURN/EXHAUST

1'x2' RETURN AIR GRILLE

2'x2' RETURN AIR GRILLE

SUPPLY AIR DUCT SECTION

RETURN AIR DUCT SECTION

EXHAUST AIR DUCT SECTION

POWER OR GRAVITY ROOF VENTILATOR - EXHAUST

POWER OR GRAVITY ROOF VENTILATOR - SUPPLY

DOOR GRILLE OR LOUVER

SINGLE DUCT VAV BOX WITH REHEAT COIL

SINGLE DUCT VAV BOX WITHOUT REHEAT COIL

SPACE TEMPERATURE SENSOR

SMOKE DETECTOR

DESCRIPTION

STATIC PRESSURE SENSOR

### 

- THE SPACE FOR DUCT WORK & MECHANICAL EQUIPMENT FOR THIS PROJECT IS LIMITED. COORDINATION WITH OTHER TRADES IS CRITICAL. PROCEED WITH PREPARATION OF SHOP DRAWINGS IMMEDIATELY UPON RECEIVING AN AUTHORIZATION TO PROCEED FOR THE PROJECT. COMPLETE SHOP DRAWINGS PRIOR TO MATERIAL FABRICATION AND INSTALLATION. SHOP DRAWINGS SHALL BE REVIEWED BY COMMISSIONING AGENT, MEOR AND OWNER'S REPRESENTITIVE PRIOR TO SUBMITTAL.
- <sup>3.</sup> PROVIDE ORIGINALLY PREPARED CONTRACTOR'S SHOP DRAWINGS IN ELECTRONIC FORMAT. IN ADDITION TO THE REQUIREMENTS SPECIFIED ELSEWHERE, THE SHOP DRAWINGS SHALL INCLUDE THE FOLLOWING:
- A. DUCT, PIPE AND PLUMBING ELEVATIONS.
- B. DOUBLE LINE DUCTWORK AND PIPING (6" AND LARGER).
- C. ACTUAL SIZE OF PURCHASED EQUIPMENT. PER APPROVED CONTRACTOR'S SHOP DRAWINGS.
- D. ACCESS PANELS INCLUDING CEILING PANELS.
- E. ACCESS CLEARANCES FOR EQUIPMENT.
- F. ACTUAL LOCATIONS OF CEILING DIFFUSERS, REGISTERS, AND RETURN REGISTERS.
- G. LOCATIONS OF STRUCTURAL MEMBERS SUCH AS BEAMS.
- H. ACTUAL LOCATIONS OF CONTROL PANELS AND POWER CONNECTIONS TO EQUIPMENT.
- I. COLOR CODED DUCT AND PIPING BASED ON MATERIAL USED.
- J. MINIMUM 1/4"=1'0" SCALE DRAWINGS.
- K. LABEL AND TAG SCHEDULE FOR EQUIPMENT.
- L. DUCT TRANSITIONS TO CLEAR BEAMS OR TIGHT AREAS.
- M. ROOM TEMPERATURE SENSOR LOCATIONS.
- N. POINT OF CONNECTION TO UTILITIES OUTSIDE THE BUILDING.
- O. SECTIONS OR 3-D DRAWINGS OF CONGESTED AREAS.
- P. GRID LINES.
- Q. UTILITY PROFILES FOR UNDERGROUND PIPING.
- 4. DO NOT COMMENCE WITH ANY INSTALLATION, ORDERING OF ANY EQUIPMENT OR MATERIAL FABRICATION WITHOUT AN APPROVED SHOP DRAWING SUBMITTAL.
- FOR EACH SUBMITTAL, THE CONTRACTOR SHALL PROVIDE A LETTER (ON COMPANY LETTERHEAD) AND SIGNED BY THE PROJECT MANAGER INDICATING THE SUBMITTAL HAS BEEN FULLY IN HOUSE REVIEWED TO ENSURE FULL COMPLIANCE WITH THE CONTRACT DOCUMENTS AND COORDINATION WITH OTHER TRADES. ANY EXCEPTIONS TO THE CONTRACT DOCUMENTS SHALL BE CLEARLY INDICATED ON THIS LETTER. ANY DISCREPANCIES/EXCEPTIONS NOT IDENTIFIED IN WRITING SHALL BE CORRECTED AT THE SOLE EXPENSE OF THE CONTRACTOR AND AT NO EXPENSE TO THE OWNER AND ENGINEER.

### GENERAL NOTES

- 1. ALL WORK SHALL COMPLY WITH THE 2013 EDITIONS OF THE CALIFORNIA BUILDING, MECHANICAL, PLUMBING, AND OTHER APPLICABLE FEDERAL, STATE, OR LOCAL CODES AS ADOPTED AND ENFORCED BY THE LOCAL JURISDICTION. IN CASE THE PLANS SHOW MORE STRINGENT REQUIREMENTS, THE PLANS SHALL GOVERN THE DESIGN, YET NOTHING ON THE DESIGN DOCUMENTS SHALL BE INTERPRETED AS AUTHORITY TO VIOLATE CODE(S) OR REGULATION(S).
- 2. SUBMISSION OF BID IN CONNECTION WITH THIS WORK SHALL IMPLY THAT THE BIDDER HAS EXAMINED THE JOB SITE UNDER WHICH THE CONTRACTOR WILL BE OBLIGATED TO OPERATE UNDER THIS CONTRACT. NO EXTRA CHARGE WILL BE ALLOWED FOR FAILURE OF ANY BIDDER TO EXAMINE THE SITE PRIOR TO BID.
- 3. WHERE USED, THE TERM "PROVIDE" SHALL MEAN "FURNISH AND INSTALL"

- CMC-602.2.

# CHAPTER 13.

THE ATTACHMENT OF THE FOLLOWING MECHANICAL AND ELECTRICAL COMPONENT SHALL BE POSITIVELY ATTACHED TO THE STRUCTURE, BUT NEED NOT BE DETAILED ON THE PLANS. THESE COMPONENTS SHALL HAVE FLEXIBLE CONNECTIONS PROVIDED BETWEEN THE COMPONENT AND ASSOCIATED DUCTWORK, PIPING, AND CONDUIT.

WALL

FOR THOSE ELEMENTS THAT DO NOT REQUIRE DETAILS ON THE APPROVED DRAWINGS, THE INSTALLATION SHALL BE SUBJECT TO THE APPROVAL OF THE STRUCTURAL ENGINEER OF RECORD. THE PROJECT INSPECTOR WILL VERIFY THAT ALL COMPONENTS AND EQUIPMENT HAVE BEEN ANCHORED IN ACCORDANCE WITH ABOVE REQUIREMENTS.

PIPING, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEMS SHALL BE BRACED TO COMPLY WITH THE FORCES AND DISPLACEMENTS PRESCRIBED IN ASCE 7-05 SECTION 13.3 AS DEFINED IN ASCE 7-10 13.6.1 TO 13.6.8 AND 2016 CBC SECTIONS 1616A.1.23, 1616A.1.24, 1616A.1.25 AND 1616A.1.26.

COPIES OF THE MANUAL SHALL BE AVAILABLE ON THE JOBSITE PRIOR TO THE START OF HANGING AND BRACING OF THE PIPE, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEMS.

# **GENERAL NOTES CONTINUED**

NT OF A CONFLICT OR INCONSISTENCY BETWEEN ITEMS INDICATED ON DESIGN PLANS / TIONS WITH CODE REQUIREMENTS, THE MORE STRINGENT STANDARD SHALL PREVAIL.

RACTOR SHALL FURNISH LABOR, MATERIALS, EQUIPMENT, AND TRANSPORTATION AS REQUIRED TO INSTALL ALL NEW HVAC SYSTEMS OR RELATED COMPONENTS AS INDICATED ON PLANS AND HEREIN.

QUIPMENT AND MATERIAL TO BE INSTALLED AS PART OF THIS PROJECT SHALL BEAR AN TERS' LABORATORIES LABEL (UL), AND INSTALLED IN SUCH A MANNER FOR WHICH THEY ARE AND APPROVED.

RACTOR SHALL DOCUMENT AND RELAY ANY MAJOR DEVIATIONS FROM THE DESIGN DOCUMENTS, N APPROVAL FROM THE MECHANICAL ENGINEER BEFORE PROCEEDING. AS-BUILT COPIES SHALL BE INDICATING ALL CHANGES / DEVIATIONS MADE DURING CONSTRUCTION.

SHALL BE PERFORMED IN A CLEAN AND WORKMANLIKE MANNER, CARE SHALL BE EXERCISED TO NY INCONVENIENCE OR DISTURBANCE TO OTHER AREAS OF THE BUILDING WHICH ARE TO REMAIN ION. ISOLATE WORK AREAS BY MEANS TO KEEP DUST AND DIRT WITHIN THE CONSTRUCTION AREA.

EQUIPMENT, ETC. SHALL BE REMOVED, DISCONNECTED OR SHUT DOWN WITHOUT PRIOR REVIEW DWNER TO CONFIRM THAT AREAS TO REMAIN IN OPERATION WILL NOT BE AFFECTED. IF ANY AREAS N THE SCOPE OF WORK ARE AFFECTED BY ANY SHUTDOWN, REMOVAL OR DISCONNECTION, T ADVANCE NOTICE MUST BE GIVEN TO THE OWNER INDICATING WHICH AREAS WILL BE AFFECTED, PROPOSED SHUTDOWN WILL OCCUR, AND FOR HOW LONG A PERIOD OF TIME.

IGEMENT OF EQUIPMENT AND PIPING SHOWN ON THE DRAWINGS IS BASED UPON INFORMATION TO THE ENGINEER AT THE TIME OF DESIGN AND IS NOT INTENDED TO SHOW EXACT DIMENSIONS TO A SPECIFIC MANUFACTURER. THE DRAWINGS ARE, IN PART, DIAGRAMMATIC AND SOME OF THE ILLUSTRATED EQUIPMENT INSTALLATION MAY REQUIRE REVISION TO MEET ACTUAL T INSTALLATION REQUIREMENTS. STRUCTURAL SUPPORTS, FOUNDATIONS, CONNECTED PIPING, D ELECTRICAL CONDUIT SPECIFIED MAY HAVE TO BE ALTERED TO ACCOMMODATE THE EQUIPMENT NO ADDITIONAL PAYMENT WILL BE MADE FOR SUCH REVISIONS AND ALTERATIONS.

RACTOR SHALL VERIFY ALL DIMENSIONS AT THE SITE MAKING FIELD MEASUREMENTS AND SHOP NECESSARY FOR FABRICATION OR ERECTION OF HVAC SYSTEMS. MAKE ALLOWANCE FOR BEAMS, OTHER OBSTRUCTIONS IN BUILDING CONSTRUCTION. CHECK DRAWINGS SHOWING WORK OF ADES AND CONSULT WITH THE OWNER'S REPRESENTATIVE IN THE EVENT OF POTENTIAL NCE. SHOP DRAWINGS SHALL BE MINIMUM 1/4"=1'-0" SCALE, INDICATING FITTINGS, SIZES, WELDS IGURATIONS AND SUBMITTED TO ENGINEER FOR REVIEW.

RACTOR SHALL COORDINATE HIS WORK WITH ALL OTHER TRADES PRIOR TO FABRICATION, AND/OR INSTALLATION OF ALL WORK.

DMMENCEMENT OF WORK, THIS CONTRACTOR SHALL VERIFY THE EXACT LOCATIONS, ELEVATIONS, ACTERISTICS OF ALL UTILITIES.

OR SHALL SECURE AND PAY ALL FEES AND PERMITS PERTAINING TO THE CONTRACT.

IATERIALS THAT ARE REMOVED SHALL NOT BE REUSED IN NEW SYSTEMS, EXCEPT WHERE AS BEING RELOCATED.

MENT SHALL BE INSTALLED IN STRICT COMPLIANCE WITH THE MANUFACTURER'S WRITTEN ONS.

D SHEET METAL SHALL BE PROVIDED FOR ALL HVAC DUCT SYSTEMS, AND CONSTRUCTED / D / INSTALLED IN ACCORDANCE WITH THE 2016 CALIFORNIA MECHANICAL CODE AND THE LATEST TANDARDS.

SHALL BE INSTALLED AS INDICATED ON THE DRAWINGS IN A NEAT WORKMANSHIP-LIKE MANNER IPPORTED AS REQUIRED BY CODES. PIPING SHALL BE SET UP AND DOWN AND OFFSET AS REQUIRED ELD CONDITIONS. DIELECTRIC COUPLINGS SHALL BE USED WHERE DISSIMILAR METALS ARE JOINED.

RACTOR SHALL PROVIDE ALL NECESSARY SUPPORTS FOR FIXTURES, DUCTWORK, PIPING, AND AL EQUIPMENT, IN ORDER TO COMPLY WITH CALIFORNIA BUILDING CODE, SMACNA INSTALLATIÓN S, AND ALL RELATED LOCAL ORDINANCES.

RACTOR SHALL NOT BORE, NOTCH, CUT, OR PENETRATE INTO A STRUCTURAL MEMBER WITHOUT PPROVAL FROM A DESIGNATED STRUCTURAL ENGINEER AND THE OWNER.

BOWS SHALL BE LONG RADIUS UNLESS OTHERWISE SPECIFICALLY NOTED ON THE DRAWINGS.

22. ISOLATE AND DRAIN EXISTING PIPING SYSTEM AS REQUIRED TO ACCOMMODATE INSTALLATION OF THE WORK.

23. ALL MATERIAL EXPOSED WITHIN RA PLENUMS SHALL BE NON-COMBUSTIBLE OR SHALL HAVE A FLAME SPREAD INDEX NOT GREATER THAN 25 AND SMOKE DEVELOPED INDEX NOT GREATER THAN 50. COMPLY WITH

24. 2016 CBC MECHANICAL, ELECTRICAL AND PLUMBING EQUIPMENT ANCHORAGE NOTES:

ALL MECHANICAL, PLUMBING, AND ELECTRICAL COMPONENTS SHALL BE ANCHORED AND INSTALLED PER THE DETAILS ON THE OSHPD APPROVED CONSTRUCTION DOCUMENTS. WHERE NO DETAIL IS INDICATED, THE FOLLOWING COMPONENTS SHALL BE ANCHORED OR BRACED TO MEET THE FORCES AND DISPLACEMENT REQUIREMENTS PRESCRIBED IN THE 2016 CBC SECTIONS 1615A.1.17 THROUGH 1616A.1.27 AND ASCE 7-10

1) ALL PERMANENT EQUIPMENT AND COMPONENTS.

2) TEMPORARY OR MOVABLE EQUIPMENT THAT IS PERMANENTLY ATTACHED (E.G. HARD WIRED) TO THE BUILDING UTILITY SERVICES SUCH AS ELECTRICITY, GAS OR WATER.

3) MOVABLE EQUIPMENT WHICH IS STATIONED IN ONE PLACE FOR MORE THAN 8 HOURS AND HEAVIER THAN 400 POUNDS ARE REQUIRED TO BE ANCHORED WITH TEMPORARY ATTACHMENTS.

A. COMPONENTS WEIGHING LESS THAN 400 POUNDS AND HAVE A CENTER OF MASS LOCATED 4 FEET OR LESS ABOVE THE ADJACENT FLOOR OR ROOF LEVEL THAT DIRECTLY SUPPORTS THE COMPONENT.

B. COMPONENTS WEIGHING LESS THAN 20 POUNDS, OR IN THE CASE OF DISTRIBUTED SYSTEMS, LESS THAN 5 POUNDS PER FOOT, WHICH ARE SUSPENDED FROM A ROOF OR FLOOR OR HUNG FROM A

25. PIPING, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEM BRACING NOTES:

THE STRUCTURAL ENGINEER OF RECORD SHALL VERIFY THE ADEQUACY OF THE STRUCTURE TO SUPPORT THE HANGER AND BRACE LOADS.

# 5 ARCHITE

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

### Tri-City Medical Center

		,	
OWNER	:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 9: TEL (760) 940-7709	2056
ARCHIT	ECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, S SAN DIEGO, CALIFORNIA 9. TEL(619)299–3917 FAX(6	GUITE 100 2122 319)299-508
MEP:		P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SAN DIEGO, CA 92123 TEL(619)618–2347	SUITE 230
STRUC	TURAL:	SUN STRUCTURAL ENGINEE 2091 LAS PALMAS DRIVE, CARLSBAD, CA 92011 TEL(760)438–1188	ERING SUITE D
1 05 C	No. C2	ALA OFFICIA 8543 R + CICIA 8543 R + CICIA	
1 1 C	No. C2	ALLEORIT	L US 10 № 4/с пр. L US 10 № 4/с пр. тр. тр. тр. тр. тр. тр. тр. т
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	No. C 2 PEN. 1- OF C	ALLOTICA 8543 TO 31-19 CALLED DMMENTS	10-09-17
(1) * (5,7) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1) * (1)	No. C 2 PEN. 1- OF C DESIGN C	ALLOT ALLO ALLO ALLO ALLO ALLO ALLO ALLO	10-09-17 10-09-17
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN. 1- OF C OSHPD CC OSHPD CC	ALLO TO	10-09-17 10-09-17 12-11-17
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN. 1- OF C OSHPD CC DESIGN CC DESIGN CC	ALLO TO ALLO T	10-09-17 12-11-17 12-11-17
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN. 1- OF ( OSHPD CC DESIGN CI OSHPD CC OSHPD CC OSHPD CC		10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 5-15-18 6-05-18
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN, 1- OF C OSHPD CC OSHPD CC OSHPD CC OSHPD CC OSHPD CC	A A A A A A A A A A A A A A A A A A A	10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 12-11-17 5-15-18 6-05-18
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN, 1- OF C OSHPD CC DESIGN CC DESIGN CC DESIGN CC	ALLO ALLO ALLO ALLO ALLO ALLO ALLO ALLO	10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 12-11-17 5-15-18 6-05-18
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN, 1- OF ( OSHPD CC DESIGN CC DESIGN CC DESIGN CC	A LOS	10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 5-15-18 6-05-18
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN, 1- OF ( OSHPD CC OSHPD CC OSHPD CC DESIGN CI DESIGN CI	ALLOW ANGES	10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 5-15-18 6-05-18
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN, 1- OF C OSHPD CC DESIGN CC DESIGN CC DESIGN CC	A LOS	10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 5-15-18 6-05-18
$\begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \begin{array}{c} \end{array} \\ \end{array} $	No. C 2 PEN, 1- OF C OSHPD CC DESIGN CC DESIGN CC DESIGN CC	A LOS	10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 10-09-17 12-11-17 5-15-18 6-05-18

![](_page_30_Picture_108.jpeg)

San Diego, CA 92123 T 619.618.2347 F 619.330.0668 www.p2seng.com

![](_page_30_Picture_110.jpeg)

![](_page_30_Picture_111.jpeg)

GENERAL NOTES, LEGEND, SYMBOLS

AND SHEET INDEX

PROJECT TITLI TCMC USP 800

PROJECT #: 01667.00 DRAWN BY: CHECKED BY

![](_page_30_Picture_116.jpeg)

	AIR BALA	ANCE SCH	<b>IEDULE</b> [	3 4 5 6						1											
Ī						CODE REQUIREMENTS PER CMC TABLE 4-A ( USP 797 & USP 800) PROPOSED DESIGN												ROOM SUPPLY (CFM)			
	ROOM NUMBER	ROOM NAME	ROOM AREA (SF)	CEILING HEIGHT	ROOM SUPPLY (CFM)	ROOM EXHAUST (CFM)	ROOM RETURN (CFM)	I ROOM OUTSIDE (CFM)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	AIR BALANCE RELATIONSHIP TO ADJACENT AREAS 8	ROOM EXHAUST (YES/NO)	ROOM SUPPLY (CFM)	ROOM EXHAUST (CFM)	ROOM RETURN (CFM)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	AIR BALANCE AND STATIC PRESSURE RELATIONSHIP TO ADJACENT 9 AREAS	ROOM SUPPLY (CFM)	JPPLY I) I) I) I) I) I) I) I) I) I)
Ī	032	BSC	100	8'	300	400	-	-	30	-	N	YES	300	450 1	-	33.75 1	-	33.75			
Ī	031	ANTE ROOM	370	8'	1480	-	-	100	30	2	Р	NO A	1480		3 1305	30	2	-			
	030	IV PREP ROOM	160	8'	640	-	-	45	30	2	Р	NO	600 <u>/</u>	1 -	525	28 7	2	-			
$\sum_{i=1}^{3}$	041	TOILET	48	8'-1"	-	65	-	-	10	-	N	YES	-	65	-	10	-	10			

(E) SPACES AIR BALANCE TABLE VALUES FROM OSHPD APPROVED DRAWINGS FOR TRI-CITY MEDICAL CENTER PHARMACY 797 USP UPGRADE APPROVED JAN. 18, 2007.

2 15 AC/HR IS RECIRCULATED AIR THROUGH THE FINAL FILTERS.

3 EXISTING AH-3 SERVES THE SPACES SHOW IN TABLE. EXISTING AIR HANDLING UNIT HAS 33% OSA AS PROVIDED BY OSHPD APPROVED DRAWINGS FOR TRI-CITY MEDICAL CENTER PHARMACY 797 USP UPGRADE APPROVED JAN. 18, 2007.

4 EXISTING AH-3 SERVING THE AREA OF WORK IS EQUIPPED WITH MERV 8 FILTER UPSTREAM OF THE COIL IN THE AHU (TABLE 4B, POSITION 1) AND MERV 15 AIR FILTER DOWNSTREAM OF THE COIL IN THE AHU (TABLE 4B, POSITION 2), WHICH IS CODE COMPLIANT.

5 EXISTING AIR HANDLING UNIT SERVING THE AREA IS EQUIPPED WITH SMOKE DETECTOR.

6 EXISTING AIR HANDLING UNIT SERVING THE AREA IS EQUIPPED WITH EMERGENCY POWER.

(E) SA OF 600 CFM AND THE (2) PRIMARY ENGINEERING CONTROL (PEC) UNITS THAT ARE HEPA FILTERED PROVIDE IN EXCESS OF 30 AC/HR.

8 N - NEGATIVE, P - POSITIVE, NR - NO REQUIREMENT FOR CONTINUOUS DIRECTIONAL CONTROL.

9 CONTRACTOR TO STATE AIR BALANCE RELATIONSHIP & MEASURE STATIC PRESSURE TO ADJACENT SPACE. SEE AIRFLOW DIAGRAM 4/M6-10 FOR REQUIREMENTS.

10 CONTRACTOR TO COMPLETE WITH ACTUAL TESTED VALUES.

### SHEET INDEX

SHEET	DESCRIPTION
M0-01	GENERAL NOTES, LEGEND, SYMBOLS & SHEET INDEX

- M0-02 SCHEDULES M1-10
- ZONING PLAN PARTIAL RENOVATION FIRST FLOOR AND ROOF PLAN M2-10
- PARTIAL RENOVATION HEATING HOT WATER FLOOR PLAN M2-11 M5-10 DIAGRAMS
- M6-10 DETAILS

MD2-10 PARTIAL DEMOLITION FLOOR PLAN MD2-11 PARTIAL DEMOLITION HEATING HOT WATER FLOOR PLAN

### MECHANICAL PIPE AND DUCT SYSTEM SEISMIC SUPPORT NOTES

MECHANICAL & PLUMBING:

1. SUPPORT AND BRACING FOR NEW PIPING, EXCEPT FIRE SPRINKLER PIPING, AND FOR NEW DUCTWORK SHALL BE PROVIDED PER OPM-0043-13 MASON SEISMIC RESTRAINT COMPONENTS FOR SUSPENDED UTILITIES OR OTHER APPROVED OSHPD OPM.

2. LAYOUT DRAWINGS, SHOWING THE BRACING/SUPPORT LOCATIONS AND REFERENCES TO DETAILS FROM THE RELEVANT OSHPD PRE-APPROVALS NEED TO BE SUBMITTED FOR USE BY THE INSPECTOR OF RECORD AND OSHPD FIELD STAFF. THE LAYOUT DRAWINGS, PREPARED PER ASCE 7 CHAPTER 13 AS MODIFIED BY CBC SECTIONS 1613A/1616A, SHALL BE PREPARED BY THE SUBCONTRACTOR AND SIGNED BY A STRUCTURAL ENGINEER LICENSED IN THE STATE OF CALIFORNIA. REFERENCES TO DETAILS FROM THE OSHPD PRE-APPROVAL SHALL BE FOR AN ENTIRE DETAIL AS SUBMITTED OR REFERENCE SHALL BE FOR EACH ASPECT OF A SUBMITTED DETAIL. CUSTOM DETAILS SHALL BE PROVIDED FOR SITUATIONS WHERE OSHPD PRE-APPROVALS DO NOT APPLY. AT LEAST FOUR WEEKS PRIOR TO BEGINNING INSTALLATION, FOUR COPIES OF THE PLANS SHALL BE SUBMITTED TO THE ARCHITECT OF RECORD WHO WILL SUBMIT THEM TO THE STRUCTURAL ENGINEER OF RECORD FOR REVIEW AND APPROVAL. AFTER THIS APPROVAL, THE DRAWINGS WILL BE SUBMITTED TO THE OSHPD DISTRICT STRUCTURAL ENGINEER FOR REVIEW AND APPROVAL. THE PLANS SHALL BE COORDINATED WITH THE PLANS OF OTHER TRADES. A COPY OF THE CHOSEN BRACING SYSTEM INSTALLATION GUIDE/MANUAL SHALL BE ON THE JOBSITE PRIOR TO STARTING THE INSTALLATION.

3. THE STRUCTURAL ENGINEER FOR THE CONTRACTOR SHALL DETERMINE THE APPROPRIATE SEISMIC FORCES BASED ON THE DESIGN CRITERIA SHOWN ON THE STRUCTURAL DRAWINGS.

4. ONCE THE EXACT LOCATIONS OF ALL PIPING AND DUCTWORK HAVE BEEN ESTABLISHED, THE STRUCTURAL ENGINEER MUST CHECK THE ADEQUACY OF THE SUPPORTING STRUCTURE TO ENSURE THAT THE ORIGINAL DESIGN IS STILL ADEQUATE. THE INSPECTOR OF RECORD SHALL INSURE THAT ALL WORK IS PROPERLY INSTALLED PER THE APPLICABLE OSHPD PRE-APPROVAL.

	l		

 $\Lambda$ 

																				S	F f	ΕI	R
							N									Δ				A F	2 C H I	TEC	T S
R BALANC LATIONSH ADJACEN AREAS 8	E IP IT ROOM EXHAUST (YES/NO)	ROOM SUPPLY (CFM)	ROON EXHAU (CFM)	M ST )	DOM RETURN (CFM)	ROOM TC AIR CHAN (AC/HF	DTAL NGES OU R) (	ROOM JTSIDE AIR (AC/HR)	ROOM EXHAUS (AC/HR)	AIR BAI AND S PRESS RELATIO TO ADJ	LANCE STATIC SURE DNSHIP ACENT	ROOM SUPPLY (CFM)	ROOM EXHAUST (CFM)	ROOM (C	I RETURN CFM)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	REMARKS	5151 Sł San Die P: 619- F: 619- www.sfe	oreham Place, Sui go, Ca 92122 -299-3917 -299-5084 irarch.com	te 100	
N	YES	300	450		-	33.75	5 1	-	33.75		<u>-A5</u>								1 2				
P P	NO A	1480 600 /	-		1305	30 28	7	2	-													<b>IACY</b>	
		JLE	00					-	10												3P 80 PGRA	0 DE	
	MANUFACTURER						AIRFLOW			ΔIR	SIDE		HEATING CC	DIL	WATERS	DE							
MARK	& MODEL	LOCA	TION	DIA	Y/N	MAX CFM	MIN CFM	MAX HTG. CFM	HTG. MBH	EAT °F	LAT	MAX PD	GPM	EWT °F	LWT °F	MAX PD FT	ROWS		REMARKS	Tri-	City Me	edical C	ent
CAV-1	PRICE SDV	BSC R	ROOM	7"	N	300	300	300	11,340	55	90	0.18	1.1	180	160	0.05	2	-		4002	Vista Way	02056	
CAV-2	PRICE SDV	ANTE F	ROOM	10"	N	750	750	750	28,350	55	90	0.33	2.2	180	160	0.09	2	-				a 92050	
FXIS			HED	ULE																OWNER:	TRI-CITY ME 4002 VISTA OCEANSIDE, TEL (760) S CT: SFEIR ARCH 5151 SHOPE	EDICAL CENTER WAY CALIFORNIA 92056 940–7709 ITECTS	, 100
							AIRFLOW						HEATING CC	DIL							SAN DIEGO, TEL(619)299	CALIFORNIA 92122 0–3917 FAX(619)2	299-5084
MARK	MANUFACTURER & MODEL	LOCA	TION	INLET SIZE DIA	DCV Y/N	MAX	MIN	MAX HTG.	HTG.	EAT		MAX PD	GPM	EWT	LWT	DE MAX PD	ROWS		REMARKS	MEP:	P2S ENGINE 9665 CHES	ERING, INC. APEAKE DRIVE, SUI	TE 230
(E) CAV-3	KRUGER LMHS	IV PF	REP	8"	N	CFM 600	CFM 600	CFM 600	24.6	°F 55	°F 90	0.8	2.5	°F 180	°F 160	0.8	1	_			SAN DIEGO, TEL(619)618	CA 92123 3–2347	
							AN F         MARK         FF-2         FF-3         FF-4         FF-5         FF-6         FF-7         RECIRCU         XIST         MARK         (E) FF-1	ENVIRCO, LEDC - ENVIRCO, LEDC - ENVIRCO, LEDC - ENVIRCO, LEDC - ENVIRCO, LEDC - ENVIRCO, LEDC - JLATED AIR. ING F MANUFACTI & MODEL	R BO	X LOCATIO BSC ROO ANTE RO ANTE RO ANTE RO ANTE RO ANTE RO ANTE RO ILCTER	ON OM OOM OOM OOM OOM CNET CO <b>R BC</b>	SIZE 2"X2" ( 2"X2" ( 2"X2" ( 2"X2" ( 2"X2" ( 2"X2" ( 2"X2" ( 2"X2" ( 3) ( 3) ( 3) ( 3) ( 3) ( 3) ( 3) ( 3)	CFM 300 365 250 250 250 4ACE.	HP 1/3 1/3 1/3 1/3 1/3 1/3 El HP El HP	ELECTRIC VOLT 120 120 120 120 120 120 120 120	AL PH 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	WEIGHT           LBS           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54           54		REMARKS		TEL(760)438	B-1188	0 0 0 0 0 0 0 0 0 0 0 0 0 0
							ו ווסי			TEDO			DC							OSHPD APF	ROVAL STAMP:	v.p2seng.com	.330.0006
										MATEDIAL	וע, ס ו	STVIE					IISH		REMARKS	OSHP	D #: S171647	1 - 37 - 00	1
							FG-1		530	STEFI		SITLE			UAIVIPER							IENTS OF T24, COR	
							EG-2	PRICE	PDDR	STEEL		LAY-IN	-		N/A		-				With co	omments Architect	
							RG-1	PRICE	530	STEEL		SIDEWALL	HORIZON	JTAL	N/A	1	-				Office of Statewi Planning & Deve	de Health lopment	
								NATE WITH A	RCHITECT.											SHEET TITL SCH PROJECT TI TCMC PROJECT # DRAWN BY: CHECKED B SCALE: DATF	07/23/2018 08:10 #[ \$171641-37 EDULES ILE: JSP 800 01667.00 ED Y: SJ	0:09 AM 7-00 ] ET NUMBER:	2

																				S F E I
					PROP	DSED DESIG	N							ACTUAL	_ 10	$\bigwedge$				A R C H I T E C T
AIR BALANCE ELATIONSHIP O ADJACENT AREAS 8	ROOM EXHAUST (YES/NO)	ROOM SUPPLY (CFM)	ROOM EXHAUS (CFM)	1 ST RC	OM RETURI (CFM)	ROOM TO AIR CHAN (AC/HF	DTAL NGES O R)	ROOM UTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	AIR BAL AND ST PRESS RELATIO TO ADJA	ANCE FATIC SURE ROO INSHIP	OM SUPPLY (CFM)	ROOM EXHAUST (CFM)	ROOM RETU (CFM)		OOM TOTAL IR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	REMARKS	5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com
N	YES	300	450		-	33.75	5 1	-	<u>_1</u> 33.75	9 ARE/	AS								1 2	
P	NO A	. 1480 600 /	-	3	1305	30	7	2	-											PHARMACY
N	YES	-	65		-	10		-	10											USP 800
CAV	SCHED	ULE																		UPGRADE
	MANUFACTURER						AIRFLOW	-		AIRS	SIDE		HEATING COIL	W		Γ				
MARK	& MODEL	LOCA	TION	DIA	Y/N	MAX CFM	MIN CFM	MAX HTG. CFM	HTG. MBH	EAT °F	LAT	MAX PD IN	GPM	EWT °F	LWT °F	MAX PD FT	ROWS		REMARKS	Tri-City Medical Ce
CAV-1	PRICE SDV	BSC F	OOM	7"	N	300	300	300	11,340	55	90	0.18	1.1	180	160	0.05	2 -			4002 Vista Way
CAV-2	PRICE SDV	ANTE F	ROOM	10"	N	750	750	750	28,350	55	90	0.33	2.2	180	160	0.09	2 -			
																				OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY
																				TEL (760) 940-7709
EXIS	ING CA			ULE									HEATING COIL							- SI EIK AKGINIEUTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL (619)299–3917 FAX(619)299–
MARK	MANUFACTURER & MODEI	LOCA	TION	INLET SIZE DIA	DCV Y/N		AIRFLOW			AIRS	SIDE			W.	ATERSIC				REMARKS	MEP: P2S ENGINEERING, INC.
	MODEL					CFM	CFM	CFM	MBH	°F	°F	IN IN	GPM	°F	°F	FT	ROWS			SAN DIEGO, CA 92123 TEL(619)618-2347
(E) CAV-3	KRUGER LMHS	IV PF	REP	8"	N	600	600	600	24.6	55	90	0.8	2.5	180	160	0.8	1 -			STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D
						F	AN	FILTER	R BOX	Κ										CARLSBAD, CA 92011 TEL(760)438–1188
														ELE	ECTRICA	AL.	WEIGHT			SED AN CHESSIONAL PROFESSIONAL
							MARK	MANOFACT & MODE	L	LOCATIO	DN	SIZE	CFM	ЦР		РН	I BS	-	REMARKS	★ No. C 28543 7 ★ (1) (1) (1) (1) (1) (1) (1) (1) (1) (1)
							FF-2	ENVIRCO, N	1AC-10	BSC BOC	DM	2"x2"	300	1/3	120		54	2		V PER 1-31-19 IT OF CHANICAL
							FF-3	LEDC - R ENVIRCO, N LEDC - R	SRE 1AC-10 SRE	ANTE ROO	OM	2"x2"	365	∑ 1/3	120	1	54	1 2		OF CALLO OSHPD COMMENTS
							FF-4	ENVIRCO, N LEDC - R	IAC-10 SRE	ANTE ROO	ОМ	2"x2"	365	1/3	120	1	54	1 2		$\frac{2}{2}$ $\frac{2}{2}$ $\frac{10-0'}{12,1}$ $\frac{10-0'}{12,1}$
							FF-5	ENVIRCO, N LEDC - R	IAC-10 SRE	ANTE ROO	ОМ	2"x2"	250	1/3	120	1	54	2		- OSHPD COMMENTS 12-11 DESIGN CHANGES 12-11
							FF-6	ENVIRCO, N LEDC - R ENVIRCO, N	SRE 1AC-10			2"x2"	250	1/3	120	1	54	2		- OSHPD COMMENTS 5-15- CONTRACTOR OF COMMENTS 5-15- CONTRACTOR OF CONTRACTOR OF CONT
									SRE				$ACE \Lambda$	1/3	120		54			
																				]
												►								
							MARK	MANUFACTU &	RER	LOCATION	SIZ	E C	FM	ELECT			WEIGHT		REMARKS	
								MODEL					н	P VOI	LT	PH	LBS			CONSULTANT P2S Engineering, In
						(	(E) FF-1	ENVIRCO - LI	EDC IV	PREP ROOM	1 2"x4	4" 6	500 1/	3 12	0	1	71 -			9665 Chesapeake Dr., Suite San Diego, CA 92123
							GRIL	LES, R	EGIS	TERS	, DIFI	FUSE	RS							OSHPD APPROVAL STAMP:         OSHPD #         OSHPD #         S1716/11_37_00
							MARK	DESCRIP	TION	MATERIAL	S	STYLE	FRONT BLAD	DES DA	MPER	FIN	IISH		REMARKS	REVIEWED IN ACCORDANCE WITH
							EG-1	PRICE 5	530	STEEL	SIC	DEWALL	HORIZONT	AL 1	N/A	1	-			APPROVED with commontr
							EG-2	PRICE PI	DDR	STEEL	L	AY-IN	-	I	N/A	1	-			KC Huang, Sr. Architect
							RG-1	PRICE 5	530	STEEL	SID	DEWALL	HORIZONTA		N/A	1	-			Office of Statewide Health Planning & Development
						1		INATE WITH AR	CHITECT.											FACILITIES DEVELOPMENT DIVISION 07/23/2018 08:10:09 AM #E \$171641-37-00 1
																				SCHEDULES
																				PROJECT #: SHEET NUMBER:
																				SCALE:

														S	F	ΕI	R
														A R	C H	ΙΤΕ	CTS
M TOTAL HANGES C/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	AIR BALAI AND STA PRESSU RELATION TO ADJAC	NCE TIC RE R SHIP ENT	ROOM SUPPI (CFM)	-Y ROC EXHAI (CFI	M JST M)	OOM RETURN (CFM)	ROOM T AIR CHA (AC/F	TOTAL ANGES HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	REMARKS	5151 Sha San Dieg P: 619- F: 619-1	oreham Place, o, Ca 92122 299-3917 299-5084	Suite 100	
3.75		33.75	9 AREAS	5									12	www.sfeir	arch.com		
30	2	-											1 2 3				-
28 7	2	-													IAR	MAC	Y
		10													SP 8	00	
		I													PGR	ADE	
AIRFLO	W		AIRSI	DE		HEATING		WATE	RSIDE				REMARKS		∩itv/ N/	lodical	Conto
	MAX HTG. 1 CFM	HTG. MBH	EAT °F	LAT °F	MAX F IN	D GPN		WT LV °F °	NT M F	1AX PD FT	ROWS					ICUICAI	Cente
300 750	750	11,340 28,350	55	90 90	0.18	2.2	1	180 10 180 10	60 60	0.05	2 · 2 ·	-		4002 V Ocean	side, Califo	rnia 92056	
		$\Delta$				$\Delta$								OWNER:	TRI-CITY 4002 VIS	MEDICAL CENTER	
															OCEANSII TEL (760	DE, CALIFORNIA 9 ) 940-7709	2056
						HEATING	COIL							ARCHITEC	CI: SFEIR AF 5151 SH SAN DIE TEL(619)	CHITECTS DREHAM PLACE, S GO, CALIFORNIA 9 299—3917 FAX(6	SUITE 100 2122 319)299-5084
	DW MAX HTG.	HTG.	AIRSII	DE LAT	MAX F	D	. E		RSIDE	1AX PD			REMARKS	MEP:	P2S ENG 9665 CH	INEERING, INC. ESAPEAKE DRIVE,	SUITE 230
CFN 600	1 CFM 600	MBH 24.6	°F 55	°F 90	IN 0.8	2.5	1	°F °	°F 60	FT 0.8	1 ·	-			SAN DIEC TEL(619)	GO, CA 92123 618-2347	
FAN		R BO	X												CARLSBA 2091 LAS CARLSBA TEL(760)	5 PALMAS DRIVE, D, CA 92011 438–1188	SUITE D
MARK	MANUFAG & MOE	CTURER	LOCATION		SIZE	CFM	HF	ELECT	RICAL	PH	WEIGHT LBS	_	REMARKS	17 C N	o. C 28543 70	Red States	FESS / 0/14/ LUS (FR) M29400 7/31/17
FF-2	ENVIRCO, LEDC -	MAC-10 RSRE	BSC ROOM	1	2"x2"	300	1/3	3 12	20	1	54	2			N. 1-31-19 OF CALIFORT	OF ATEC	HANICAL PRINT
FF-3	ENVIRCO, LEDC - ENVIRCO,	MAC-10 RSRE MAC-10		Л	2"x2"	365	1/3	3 12	20	1	54	12			SHPD COMMENTS	···.	<u> </u>
FF-5	ENVIRCO, LEDC -	RSRE MAC-10 RSRE	ANTE ROOM	Л	2 x2 2"x2"	250	1/3	3 12	20	1	54	2		$\begin{array}{c} \hline \\ \hline $	SHPD COMMENTS		12-11-17
FF-6	ENVIRCO, LEDC -	MAC-10 RSRE MAC-10	ANTE ROOM	Л	2"x2"	250	1/3	3 12	20	1	54	2			SHPD COMMENTS	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~	5-15-18 6-05-18
FF-7	RCULATED AIR.	RSRE 2 PROV	ANTE ROOM		2"x2" NTROL INTE	rface. Z	1/3	3   12	20	1	54	2					
EXIS	STING F	FAN F	ILTER	BO	X									]			
	MANUFACT	URER						ELECTRIC	AL		WEIGHT			·			
MARK	MODE		LOCATION		SIZE	CFM	HP	VOLT	PH	-	LBS		REMARKS	REV: DI	ESCRIPTION:		DATE:
(E) FF-1	ENVIRCO -	LEDC I'	V PREP ROOM	2	2"x4"	600	1/3	120	1		71 -					<b>25 Engineer</b> 665 Chesapeake I an Diego, CA 921	Dr., Suite #230
GRI	LLES, F	REGIS	STERS,	DIF	FUS	ERS								oshpd appr OSHPE	val stamp: ) #: \$1716	619.618.2347 F ww.p2seng.com	019.330.0008
MARK	DESCR	PTION	MATERIAL		STYLE	FRONT	BLADES	DAMPE		FIN	NISH		REMARKS		REVIEWED I THE REQUI	N ACCORDANCE WITH REMENTS OF T24, CCR	
EG-1 EG-2	PRICE	530 PDDR	STEEL		SIDEWALL	HORIZ	ONTAL	N/A N/A		1	-				with	comments	
RG-1	PRICE	530	STEEL		SIDEWALL	HORIZ	ONTAL	N/A		1	-				Office of State Planning & D	or. Architect ewide Health evelopment	
1 COO	RDINATE WITH A	RCHITECT.												SHEET TITLE: SCHE	07/23/2018 #[ \$17164	PM ENT DIVISION 8:10:09 AM 1-37-00 ]	
															F.		
														TCMC U	SP 800 01667.00	SHEET NUMBER:	
														DRAWN BY: CHECKED BY: SCALE:	ED	M0-	02

								I					S A R	F E																				
ESIGN								ACTUAL 10						- 11 1 1																				
M TOTAL HANGES O C/HR)	ROOM UTSIDE AIR (AC/HR)	ROOM EXHAUST (AC/HR)	AIR BALA AND ST, PRESSI RELATION TO ADJA 9 AREA	ANCE ATIC JRE NSHIP CENT AS	ROOM SUPPL (CFM)	Y ROO EXHAU (CFM	M JST 1)	OOM RETURN (CFM)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIF (AC/HR)	ROOM EXHAUST (AC/HR)	REMARKS	5151 Shoreha San Diego, C P: 619-299- F: 619-299- www.sfeirarch	m Place, Suite 100 a 92122 -3917 -5084 .com																				
33.75 1	-	33.75										1 2		AC.																				
30	2	-													$\sim$																			
10	-	10																																
															_																			
						HEATING								JRADI																				
AIRFLOW			AIRS	BIDE				WATE	RSIDE			REMARKS	Tri-Ci	tv Medic	al Cent																			
CFM	CFM	MBH	°F	°F	IN IN	GPM		°F °	F FT	ROWS																								
300 750	300 750	28,350	55 55	90 90	0.18	2.2		180 16	60         0.05           60         0.09	2	-		Oceanside	e, California 920	56																			
													OWNER:	TRI-CITY MEDICAL CI	ENTER																			
													_	OCEANSIDE, CALIFORI TEL (760) 940-7709	NIA 92056																			
		1											ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLA SAN DIEGO, CALIFOR	CE, SUITE 100 NIA 92122																			
AIRFLOW	/		AIRS	SIDE		HEATING	COIL	WATE	RSIDE			REMARKS	MEP:	TEL(619)299-3917 P2S ENGINEERING, IN	FAX(619)299-5084 C.																			
MIN CFM	MAX HTG. CFM	HTG. MBH	EAT °F	LAT °F	- MAX P IN	D GPM	E	WT LV °F °	VT MAX PD F FT	ROWS				9665 CHESAPEAKE E SAN DIEGO, CA 9212 TEL(619)618-2347	RIVE, SUITE 230 3																			
600	600	24.6	55	90	0.8	2.5	-	180 16	60 0.8	1	-		STRUCTURAL:	SUN STRUCTURAL EN 2091 LAS PALMAS D	IGINEERING RIVE, SUITE D																			
			/											CARLSBAD, CA 9201 TEL(760)438–1188																				
			1										ENSED MIC		PROFESSIONAL																			
MARK	MANUFAC & MOD	EL	LOCATIO	N	SIZE	CFM		ELECTI		WEIGHT	_	REMARKS	→ No. C		No. M29400																			
	ENVIRCO.	 MAC-10					HF	P VO	LT PH	LBS			Rep. 1	-31-19 25	07/31/17 <b>*</b>																			
FF-2 FF-3	LEDC - ENVIRCO,	RSRE MAC-10 RSBE	ANTE ROC	M DM	2"x2" 2"x2"	300	1/3	3 12 3 12	0 1	54	1 2			CALIFOL	10-09-17																			
FF-4	ENVIRCO, LEDC -	MAC-10 RSRE	ANTE ROC	DM	2"x2"	365	1/3	3 12	0 1	54	1 2		$-\underbrace{22}_{\cancel{3}} \underbrace{2}_{\cancel{2}}$	CHANGES	<u> </u>																			
FF-5	ENVIRCO, LEDC - ENVIRCO.	MAC-10 RSRE MAC-10	ANTE ROC	DM	2"x2"	250	1/:	3 12	0 1	54	2																							
FF-6	ENVIRCO,	MAC-10	ANTE ROC	DM DM	2"x2" 2"x2"	250 250	1/3	3 12 3 12	0 1 0 1	54	2																							
1 RECIRC	ULATED AIR.	2 PROV	IDE WITH BAC	NET CO	ONTROL INTER	FACE.		I	I	I																								
EXIS	TING F	AN F	ILTER	BO	X																													
	MANUFACT	URER						ELECTRICA	AL	WEIGHT																								
MARK	& MODEI	-	LOCATION		LOCATION		LOCATION	LOCATION	LOCATION	LOCATION	LOCATION	LOCATION	LOCATION	LOCATION	DCATION		OCATION		CATION		DCATION	DCATION	ATION S	SIZE	CFM	HP	VOLT	PH	LBS		REMARKS	REV: DESCRIP	10N:	DATE:
(E) FF-1	ENVIRCO -		PREP ROOM		2"x4"	600	1/3	120	1	71 -				S P2S Engin 9665 Chesape	neering, Inc. eake Dr., Suite #230																			
				<b>I</b>										T 619.618.23 www.p2seng	4 92 123 47 F 619.330.066 .com																			
GRIL	LES, F	REGIS	TERS	, DI	FFUSE	IRS							oshpd approval s OSHPD #	<sup>тамр:</sup> : S171641—37—	00																			
MARK	DESCRI	PTION	MATERIAL		STYLE	FRONT	BLADES	DAMPE	ER FI	INISH		REMARKS		REVIEWED IN ACCORDANC THE REQUIREMENTS OF T	E WITH 14, COR																			
EG-1	PRICE	530	STEEL		SIDEWALL	HORIZ	ONTAL	N/A	1	-				APPROVE with comment	D s																			
EG-2 BG-1	PRICE F	2DDR	STEEL		LAY-IN	HOBIZ	- ONTAI	N/A		-			KC Of	Huang, Sr. Archite fice of Statewide Health	ct																			
		RCHITECT.											P FACILIT	anning & Development IES DEVELOPMENT DIVIS	ION																			
1 COORD	DINATE WITH A	RCHITECT.												07/23/2018 08:10:09 AM #[ \$171641-37-00 ]																				
													PROJECT TITLE: TCMC USP 8	300																				
													PROJECT #: O1	687.00 SHEET NUMBER:																				
													DRAWN BY: CHECKED BY:																					
													SCALE:		J-UZ																			

ED DESIGN  ROOM TOTAL AIR CHANGES (AC/HR)  33.75  30  28  7  10  AIRFLOW  MAX CFM  MIN CFM  300  300  300  750  750  750  750  750	ROOM ISIDE AIR AC/HR) - 33.75 2 - 2 - 10	AIR BALANC AND STATIC PRESSURE RELATIONSH TO ADJACEN 9 AREAS	E ROOM SUPP (CFM)	LY ROOM EXHAUS (CFM)	ACT 1 ST ROOM (CI	TUAL 10 RETURN =M)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST	REMARKS	ARCHITECTS 5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917
ED DESIGN  ROOM TOTAL AIR CHANGES (AC/HR)  33.75  30  28  7  10  AIRFLOW  MAX CFM  CFM  MIN CFM  N  300  300  1  1	ROOM TSIDE AIR AC/HR) - 33.75 2 - 2 - 2 - 10	AIR BALANC AND STATIC PRESSURE RELATIONSH TO ADJACEN 9 AREAS	E ROOM SUPP (CFM)	LY ROOM EXHAUS (CFM)	ACT 1 ST ROOM (CI	TUAL 10 RETURN FM)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST	REMARKS	5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917
ROOM TOTAL AIR CHANGES (AC/HR) CUTS 33.75 1 30 28 7 10 10 AIRFLOW MAX MIN CFM CFM N 300 300 750 750	ROOM ISIDE AIR AC/HR) - 33.75 2 - 33.75 2 - 10	AIR BALANC AND STATIC PRESSURE RELATIONSH TO ADJACEN 9 AREAS	E IP IT ROOM SUPP (CFM)	LY ROOM EXHAUS (CFM)	1 ST ROOM (Cl	RETURN =M)	ROOM TOTAL AIR CHANGES (AC/HR)	ROOM OUTSIDE AIR (AC/HR)	ROOM EXHAUST	REMARKS	5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917
33.75       1         30       28       7         10       10       10         AIRFLOW       MAX       MIN       N         S00       300       300       10         300       300       10       10	- 33.75 2 - 2 - - 10	9 AREAS							(AC/TIN)		F: 619-299-5084
30       30       28       7       10       AIRFLOW       MAX     MIN CFM       CFM       300       300       750	2 - 2 - - 10									12	www.sfeirarch.com
28 7 10 AIRFLOW MAX MIN CFM CFM N 300 300 1 750 750 1	2 - - 10										
10 AIRFLOW MAX MIN CFM CFM N 300 300 750 750	- 10									1 7	<b>PHARMACY</b>
AIRFLOW MAX MIN CFM CFM 300 300 750 750											USP 800
AIRFLOW MAX MIN N CFM CFM 300 300 750 750											
MAX MIN M CFM CFM 300 300 750 750				HEATING C	COIL						
CFM         CFM           300         300           750         750	MAX HTG. HTG.	AIRSIDE	LAT MAX F	2D 0.5M	EWT	WATERS	SIDE - MAX PD			REMARKS	Tri-Citv Medical Cent
750 750	CFM MBH	°F	°F IN	GPM	°F	°F	FT	ROWS			4002 Vista Way
	750 28,350	55	90 0.33	3 2.2	180	160	0.09	2	-		Oceanside, California 92056
	1			1							OWNER: TRI-CITY MEDICAL CENTER
											4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 
											ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100
AIRFLOW		AIRSIDE		HEATING C	COIL	WATERS	SIDE				SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084
MAX MIN N CFM CFM	MAX HTG. HTG. CFM MBH	EAT °F	LAT MAX F	PD GPM	EWT °F	LWT °F	MAX PD	ROWS		REMARKS	MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123
600 600	600 24.6	55	90 0.8	2.5	180	160	0.8	1	-		
											2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438-1188
FAN FI	ILTER BO	X									
						ELECTRIC	CAL	WEIGHT			AND
MARK	& MODEL	LOCATION	SIZE	CFM	нр		- РН	LBS	_	REMARKS	No. C 28543 7 ★ ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) ( ) (
FF-2	ENVIRCO, MAC-10	BSC ROOM	2"x2"	300	1/3	120	1	54	2		VALCHANICALIFORNY VALCHANICALIFORNY VALCHANICALIFORNY OF CALIFORNY
FF-3	ENVIRCO, MAC-10 LEDC - RSRE	ANTE ROOM	2"x2"	365	1/3	120	1	54	1 2	/	OF CAR OSHPD COMMENTS 10-09-17
FF-4	ENVIRCO, MAC-10 LEDC - RSRE	ANTE ROOM	2"x2"	365	1/3	120	1	54	1 2		$\begin{array}{c c} \hline & \hline & \hline & \hline & \hline & \\ \hline & & \hline & & \hline \\ \hline & & & \hline \\ \hline \\$
FF-5	ENVIRCO, MAC-10 LEDC - RSRE	ANTE ROOM	2"x2"	250	1/3	120	1	54	2		design changes
FF-6 FF-7	LEDC - RSRE ENVIRCO, MAC-10	ANTE ROOM	2"x2"	250 250	1/3	120	1	54	2		Competition Comments
1 RECIRCULA	_ATED AIR. 2 PRC	VIDE WITH BACNET		RFACE.	<u> </u>						
EXISTI			SOX								]
					FI	ECTRICAL		WEIGHT			-
MARK	MANUFACTURER & MODEL	LOCATION	SIZE	CFM						REMARKS	REV: DESCRIPTION: DATE:
					HP	VOLT	PH	LBS			P2S Engineering, Inc.
(E) FF-1 EI	ENVIRCO - LEDC	IV PREP ROOM	2"x4"	600	1/3	120	1	71 -			9665 Chesapeake Dr., Suite #230 San Diego, CA 92123 T 619.618.2347 F 619.330.066
											www.p2seng.com
GRILL			JILLOS	EKJ							OSHPD #: S171641-37-00
MARK	DESCRIPTION	MATERIAL	STYLE	FRONT B	LADES	DAMPER		NISH		REMARKS	REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, COR APPROVED
EG-1	PRICE 530	STEEL		HORIZO	DNTAL	N/A		-			with comments
RG-1	PRICE 530	STEEL	SIDEWALL	HORIZC	ONTAL	N/A					KC Huang, Sr. Architect Office of Statewide Health
	I I	I									

![](_page_32_Picture_0.jpeg)

![](_page_32_Figure_1.jpeg)

All rights reserv

### NOTES

- 1 THERMOSTAT FOR (E) CAV-3.
- 2 ANALOG TYPE PRESSURE MONITOR TO MEASURE PRESSURE BETWEEN 0.01 IN. OF W.C. TO 0.05 IN. OF W.C. WITH PLUS OR MINUS 2% ACCURACY. PRESSURE MONITOR TO BE MOUNTED ON WALL.

3 HUMIDITY LEVEL MONITORS.

![](_page_32_Picture_6.jpeg)

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

### Tri-City Medical Center

	4002 Vista	
	Oceanside	e, California 92056
	OWNER:	TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709
	ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084
	MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
	STRUCTURAL:	SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188
	V RSED	ALC ATTO 28543 元 ★ (100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 10
		CALLOTT
_	$\begin{array}{c} 2 \\ \hline 3 \\ \hline 4 \\ \hline 4 \\ \hline \end{array} \begin{array}{c} 2 \\ \hline 2 \\ \hline \\ \hline$	HANGES         10-09-17           OMMENTS         12-11-17           CHANGES         12-11-17
	6 C C C C C C C C C C C C C C C C C C C	OMMENTS 5–15–18 HANGES 6–05–18
_	REV: DESCRIPT	ION: DATE:
	CONSULTANT	<b>P2S Engineering, Inc.</b> 9665 Chesapeake Dr., Suite #230 San Diego, CA 92123 T 619.618.2347 F 619.330.0668 www.p2seng.com
	OSHPD APPROVAL S	S171641-37-00
_		REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR APPROVED with comments
	KC Of PI FACILIT	Huang, Sr. Architect fice of Statewide Health anning & Development IES DEVELOPMENT DIVISION
		07/23/2018 08:10:09 AM #[ S171641-37-00 ]
	SHEET TITLE: ZONING	6 PLAN
	PROJECT TITLE: TCMC USP 8	300
	PROJECT #: O1 DRAWN BY: CHECKED BY:	667.00 SHEET NUMBER:
KEY PLAN 0 4 SCALE: 1/4" = 1'-0"	SCALE:	

07/31/17 100% CONSTRUCTION DOCUMENT

![](_page_33_Figure_0.jpeg)

![](_page_33_Figure_1.jpeg)

**RENOVATION FIRST FLOOR PLAN** SCALE: 1/4" = 1'-0"

![](_page_33_Figure_3.jpeg)

**XEA** 

![](_page_34_Figure_0.jpeg)

All rights reserved. No part of this work may be reproduced or copied in any form a

	A R C H I T E C T S 5151 Shoreham Place, Suite 100 San Diego, Ca 92122
	P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com TCMC PHARMACY USP 800 USP 800 UPGRADE
	<b>Tri-City Medical Cente</b> 4002 Vista Way Oceanside, California 92056
	OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709 ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084
	MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347 STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188
	No. C 28543 70 X OF CALIFORNIC
	$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
	REV:     DESCRIPTION:     DATE:       CONSULTANT     P2S Engineering, Inc.       965 Chesapeake Dr., Suite #230       San Diego, CA 92123       T 619.618.2347 F 619.330.0668       www.p2seng.com
	OSHPD #: S171641-37-00 REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR APPROVED with comments KC Huang, Sr. Architect Office of Statewide Health Planning & Development FACILITIES DEVELOPMENT DIVISION
	D7/23/2018 08:10:09 AM #[ S171641-37-00 ] SHEET TITLE: PARTIAL RENOVATION HEATING HOT WATER FLOOR PLAN
KEY PLAN $KEY PLAN$	PROJECT TITLE: TCMC USP 800 PROJECT #: 01667.00 DRAWN BY: ED CHECKED BY: SJ SCALE: DATE: 07/31/17

![](_page_35_Picture_0.jpeg)

1. CONNECT TO (E) BMS. 2. PROVIDE WITH FAN AND FILTER ALARM.

Ś

SS

![](_page_35_Picture_3.jpeg)

# FAN FILTER UNIT

P

**DPS** 

HS

![](_page_35_Picture_6.jpeg)

![](_page_35_Picture_7.jpeg)

![](_page_35_Figure_9.jpeg)

![](_page_35_Picture_10.jpeg)

NOT
1
2
3
4
6

HHWR	2	ф
















#### GENERAL NOTES:

- 1. DUCT TRAVERSES SHALL BE TAKEN PRIOR TO THE COMMENCEMENT OF ANY WORK. RESULTS SHALL BE TURNED OVER TO MECHANICAL ENGINEER FOR EVALUATION PRIOR TO ANY WORK.
- 2 CONDITIONS SHOWN ON DRAWINGS ARE BASED ON REVIEW OF AVAILABLE AS-BUILT DRAWINGS AND FIELD INVESTIGATIONS TO THE EXTENT POSSIBLE. CONTRACTOR SHALL VERIFY EXISTING CONDITIONS. ANY DISCREPENCIES DISCOVERED SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT, ENGINEER AND OWNERS REPRESENTATIVE PRIOR TO THE COMMENCEMENT OF ANY WORK.

#### NOTES

1 REMOVE (E) CAV AND ITS ASSOCIATED APPURTENANCES.

- 2 REMOVE (E) THERMOSTAT.
- 3 (E) THERMOSTAT TO REMAIN.
- 4 PRIOR TO COMMENCEMENT OF ANY WORK, A DUCT TRAVERSE SHALL BE PERFORMED AT MAIN SUPPLY AND RETURN DUCTS TO DOCUMENT AIRFLOW PRIOR TO CONSTRUCTION. PROVIDE MANUAL BALANCING DAMPER AT TRAVERSE LOCATION TO ALLOW BALANCING TO "PRE-READ" AIR QUANTITY.
- 5 PRE-CONSTRUCTION AIR READS HAVE BEEN TAKEN AS OF 05/04/17.
- 6 POINT OF DISCONNECT FOR (E) 8"Ø EXHAUST AIR DUCT FROM (E) EXHAUST DUCT. REMOVE (E) 8"Ø EXHAUST AIR DUCT THROUGH EXHAUST HOOD ON ROOF.
- 7 POINT OF DISCONNECT FOR (E) 8"Ø EXHAUST AIR DUCT FROM (E) EF-4. (E) BSC HOOD: 310 CFM PER PRE-CONSTRUCTION AIR READS TAKEN AS OF 5/04/17.
- (E) 8" Ø EXHAUST AIR DUCT UP TO (E) EF-4 IN SHAFT TO REMAIN.
- (E) 26" Ø SUPPLY AIR DUCT UP TO (E) 40" Ø SUPPLY AIR DUCT TO (E) AHU-3 IN MECHANICAL PENTHOUSE.
- 11 REMOVE EXISTING FD IN EXISTING EA DUCT AT SHAFT. 3
- 12 PROVIDE GRILLE AIRFLOW MEASUREMENT PRIOR TO THE COMMENCEMENT OF ANY WORK.



5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

### **Tri-City Medical Center**

4002 Vista Way Oceanside, California 92056 TRI-CITY MEDICAL CENTER OWNER:

4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709 ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084 MEP: P2S ENGINEERING, INC.

9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618-2347

STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438-1188



DATE:





07/23/2018 08:10:09 AM **#[ S171641-37-00 ]** 

### PARTIAL DEMOLITION FIRST FLOOR AND ROOF PLAN

PROJECT TITLE: TCMC USP 800

PROJECT #: 01667.00 DRAWN BY: CHECKED BY: SCALE

DATE:

KEY PLAN









All rights re:

	SFEIR ARCHITECTS
	5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917 F: 619-299-5084
	TCMC PHARMACY USP 800 USP 800 UPGRADE
	<b>Tri-City Medical Center</b> 4002 Vista Way Oceanside, California 92056
	OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709 ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL (610)200 3017 EAY(610)200 5084
	MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347 STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011
	TEL(760)438−1188
	$\begin{array}{c c} & 1 & -3 \\ \hline & 0F \\ \hline \hline & 0F \\ \hline \hline \hline & 0F \\ \hline \hline \hline & 0F \\ \hline \hline \hline \hline & 0F \\ \hline \hline \hline & 0F \\ \hline $
	6         DESIGN CHANGES         6-05-18           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —           —         —         —
	REV: DESCRIPTION: DATE: DATE: DESCRIPTION: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE: DATE:
	www.p2seng.com         OSHPD APPROVAL STAMP:         OSHPD #: S171641-37-00         REVIEWED IN ACCORDANCE WITH         THE REQUIREMENTS OF T24, COR         APPROVED
	With comments KC Huang, Sr. Architect Office of Statewide Health Planning & Development FACILITIES DEVELOPMENT DIVISION 07/23/2018 08:10:09 AM #[ \$171641-37-00 ]
	SHEET TITLE: PARTIAL DEMOLITION HEATING HOT WATER FLOOR PLAN
KEY PLAN $KEY PLAN$	PROJECT TITLE: TCMC USP 800 PROJECT #: 01667.00 DRAWN BY: ED CHECKED BY: SJ SCALE: DATE: 07 /74 /47

### LEGEND DESCRIPTION SYMBOL NOTE CALLOUT DETAIL CALLOUT - NUMBER ON TOP DENOTES DETAIL NUMBER - NUMBER ON BOTTOM DENOTES SHEET DETAIL IS SHOWN MECHANICAL EQUIPMENT CALLOUT. SEE MECHANICAL PLANS FOR EXACT LOCATION AND REQUIREMENTS $\bigcirc$ POINT OF CONNECTION POINT OF DISCONNECTION EXISTING PIPE/EQUIPMENT INDIRECT WASTE SANITARY SEWER/WASTE UNDERGROUND SANITARY SEWER/WASTE ABOVEGROUND $\rightarrow$ - - - $\rightarrow$ DOMESTIC HOT WATER RETURN DOMESTIC HOT WATER SUPPLY · \_ \_ \_ \_ \_ \_ \_ \_ \_ \_ DOMESTIC COLD WATER STORM DRAIN PIPING SOFT COLD WATER CONDENSATE DRAIN

ELBOW DOWN O→→→ PIPE TEE UP & DOWN OR ELBOW UP PIPE TEE DOWN PIPE TEE UP DESCRIPTION GATE VALVE BALL VALVE HOSE BIBB FLOOR DRAIN FLOOR SINK, 1/2 GRATE FLOOR CLEANOUT CLEANOUT TO GRADE WALL CLEANOUT WATER HAMMER ARRESTOR

\_\_\_\_\_<u>\_</u>\_\_\_\_

 $\longrightarrow$ 

SYMBOL

\_\_\_\_\_

 $\Theta$ 

Φ

TRAP PRIMER

### ABBREVIATIONS

BREVIATION	DESCRIPTION
3V	
ך ר	ABEA DRAIN
-F	ABOVE FINISHED FLOOR
- =G	ABOVE FINISHED GRADE
-SR	AUTOMATIC FIRE SPRINKLER RISER
7	ARGON GAS
/	ACID VENT
N	ACID WASTE
EL	BELOW
P	BACKFLOW PREVENTER
G	BELOW GRADE
F	BELOW FLOOR
M	BOTTOM
/	
P	
G	
DTG	CLEAN-OUT TO GRADE
J	CUBIC
N	COLD WATER
EPT	DEPARTMENT
=	DRINKING FOUNTAIN
A	DIAMETER
N	DOWN
5	DOWNSPOUT
WG	DRAWING(S)
)	
	EQUIPMENT
VC	ELECTRIC WATER COOLER
	FIRE
Ą	FROM ABOVE
В	FROM BELOW
0	FLOOR CLEAN-OUT
)	FLOOR DRAIN
:	FINISHED FLOOR
Λ	FORCE MAIN
) -	FLOOR SINK
A 1	NATURAL GAS (LOW PRESSURE)
- IVI	
RCW	HOT AND COLD WATER
Ľ	HIGH LEVEL
_ DR	HEADER
Г	HEIGHT
	INCHES
1	INDIRECT WASTE
or LAV	LAVATORY
AX	MAXIMUM
N	MINIMUM
PG	NATURAL MEDIUM PRESSURE GAS
ID FO	MOUNTED
10	
Ъ	
- 5&Y	OPEN SCREW AND YOKE
	POINT OF CONNECTION
DD	POINT OF DISCONNECTION
SI	POUNDS PER SQUARE INCH
)	ROOF DRAIN
&C	ROUGH-IN AND CONNECT
	SINK, SEWER, SOIL
)	STORM DRAIN
OV .	SHUT-OFF VALVE
2	
о Л	
R	
-	TRAP PRIMER
′Ρ	TYPICAL
G	UNDERGROUND
NC	UNLESS OTHERWISE NOTED
7	URINAL
	SANITARY VENT
OLT	VOLTAGE
ſR	VENT THRU ROOF
,	WASTE
/	WITH
HA	

REFERENCE WILL BE MADE TO ANSI Y1.1, MILITARY STANDARD IN THE EVENT ABBREVIATIONS NOT MENTIONED HEREIN ARE USED, ABBREVIATIONS, AND OTHER STANDARD INDUSTRY CONVENTIONS.

### **GENERAL NOTES**

- PRIOR TO BID.

- AND SPECIFIED HEREIN.
- VERSION OF AUTOCAD.
- WITHIN THE CONSTRUCTION AREA.
- FOR HOW LONG A PERIOD OF TIME.
- ADDITIONS.
- PURCHASE AND/OR INSTALLATION OF ALL WORK.

- INDICATED AS BEING RELOCATED.
- INSTRUCTIONS.
- DISSIMILAR METALS ARE JOINED.
- AIR-GAP AS REQUIRED BY LOCAL CODES.
- DRAWINGS
- THE WORK.
- EQUIPMENT CONNECTIONS.
- 23. EQUIPMENT ANCHORAGE NOTES:

### SHEET INDEX SHEE P0-01

P0-02

P2-10

PD2-10

GENERAL NOTES, LEGEND, SYMBOLS & SHEET INDEX SCHEDULES AND DETAILS PARTIAL RENOVATION FLOOR PLAN PARTIAL DEMOLITION FLOOR PLAN

1. ALL WORK SHALL COMPLY WITH THE 2016 EDITIONS OF THE CALIFORNIA BUILDING, MECHANICAL, PLUMBING, AND OTHER APPLICABLE FEDERAL, STATE, OR LOCAL CODES AS ADOPTED AND ENFORCED BY THE LOCAL JURISDICTION. IN CASE THE PLANS SHOW MORE STRINGENT REQUIREMENTS, THE PLANS SHALL GOVERN THE DESIGN, YET NOTHING ON THE DESIGN DOCUMENTS SHALL BE INTERPRETED AS AUTHORITY TO VIOLATE CODE(S) OR REGULATION(S).

2. SUBMISSION OF BID IN CONNECTION WITH THIS WORK SHALL IMPLY THAT THE BIDDER HAS EXAMINED THE JOB SITE UNDER WHICH THE CONTRACTOR WILL BE OBLIGATED TO OPERATE UNDER THIS CONTRACT. NO EXTRA CHARGE WILL BE ALLOWED FOR FAILURE OF ANY BIDDER TO EXAMINE THE SITE

3. WHERE USED, THE TERM "PROVIDE" SHALL MEAN "FURNISH AND INSTALL"

4. IN THE EVENT OF A CONFLICT OR INCONSISTENCY BETWEEN ITEMS INDICATED ON DESIGN PLANS / SPECIFICATIONS WITH CODE REQUIREMENTS, THE MORE STRINGENT STANDARD SHALL PREVAIL.

5. CONTRACTOR SHALL FURNISH LABOR, MATERIALS, EQUIPMENT, AND TRANSPORTATION AS REQUIRED TO PROPERLY INSTALL ALL PLUMBING SYSTEMS OR RELATED COMPONENTS AS INDICATED ON PLANS

6. ALL NEW EQUIPMENT AND MATERIAL TO BE INSTALLED AS PART OF RENOVATION / NEW CONSTRUCTION SHALL BEAR AN UNDERWRITERS LABORATORIES LABEL (UL), AND INSTALLED IN SUCH A MANNER FOR WHICH THEY ARE DESIGNED AND APPROVED.

7. CONTRACTOR SHALL DOCUMENT AND RELAY ANY MAJOR DEVIATIONS FROM THE DESIGN DOCUMENTS, AND ATTAIN APPROVAL FROM THE MECHANICAL ENGINEER BEFORE PROCEEDING. AS-BUILT COPIES SHALL BE PROVIDED INDICATING ALL CHANGES / DEVIATIONS MADE DURING CONSTRUCTION. CONTRACTOR SHALL PROVIDE COMPLETED AS-BUILT DRAWINGS IN THE LATEST

8. ALL WORK SHALL BE PERFORMED IN A CLEAN AND WORKMANLIKE MANNER. CARE SHALL BE EXERCISED TO MINIMIZE ANY INCONVENIENCE OR DISTURBANCE TO OTHER AREAS OF THE BUILDING WHICH ARE TO REMAIN IN OPERATION. ISOLATE WORK AREAS BY MEANS TO KEEP DUST AND DIRT

9. NO PIPING, EQUIPMENT, ETC. SHALL BE REMOVED, DISCONNECTED OR SHUT DOWN WITHOUT PRIOR REVIEW WITH THE COLLEGE TO CONFIRM THAT AREAS TO REMAIN IN OPERATION WILL NOT BE AFFECTED. IF ANY AREAS NOT WITHIN THE SCOPE OF WORK ARE AFFECTED BY ANY SHUTDOWN, REMOVAL OR DISCONNECTION, SUFFICIENT ADVANCE NOTICE MUST BE GIVEN TO THE COLLEGE INDICATING WHICH AREAS WILL BE AFFECTED, WHEN THE PROPOSED SHUTDOWN WILL OCCUR, AND

10. THE ARRANGEMENT OF EQUIPMENT AND PIPING SHOWN ON THE DRAWINGS IS BASED UPON INFORMATION AVAILABLE TO THE ENGINEER AT THE TIME OF DESIGN AND IS NOT INTENDED TO SHOW EXACT DIMENSIONS PECULIAR TO A SPECIFIC MANUFACTURER. THE DRAWINGS ARE, IN PART, DIAGRAMMATIC AND SOME FEATURES OF THE ILLUSTRATED EQUIPMENT INSTALLATION MAY REQUIRE REVISION TO MEET ACTUAL EQUIPMENT INSTALLATION REQUIREMENTS. STRUCTURAL SUPPORTS, FOUNDATIONS, CONNECTED PIPING, VALVES, PIPE SUPPORTS AND ELECTRICAL CONDUIT SPECIFIED MAY HAVE TO BE ALTERED OR ADDITIONAL ITEMS REQUIRED TO ACCOMMODATE THE EQUIPMENT PROVIDED. NO ADDITIONAL PAYMENT WILL BE MADE FOR SUCH REVISIONS, ALTERATIONS AND / OR

11. CONTRACTOR SHALL VERIFY ALL DIMENSIONS AT THE SITE MAKING FIELD MEASUREMENTS AND PROVIDE SHOP DRAWINGS NECESSARY FOR FABRICATION OR ERECTION OF ALL HVAC AND PIPING SYSTEMS. MAKE ALLOWANCE FOR BEAMS, PIPES AND OTHER OBSTRUCTIONS IN BUILDING CONSTRUCTION. CHECK DRAWINGS SHOWING WORK OF OTHER TRADES AND CONSULT WITH THE UNIVERSITY REPRESENTATIVE IN THE EVENT OF POTENTIAL INTERFERENCE. SHOP DRAWINGS SHALL BE MINIMUM 1/4"=1'-0" SCALE, INDICATING FITTINGS, SIZES, WELDS AND CONFIGURATIONS AND SUBMITTED TO ENGINEER FOR REVIEW. CONTRACTOR SHALL PROVIDE DIMENSIONED SHOP DRAWINGS COMPLETED IN THE LATEST VERSION OF AUTOCAD.

12. CONTRACTOR SHALL COORDINATE HIS WORK WITH ALL OTHER TRADES PRIOR TO FABRICATION,

13. BEFORE COMMENCEMENT OF WORK, CONTRACTOR SHALL VERIFY THE EXACT LOCATIONS, ELEVATIONS, AND CHARACTERISTICS OF ALL UTILITIES.

14. CONTRACTOR SHALL SECURE AND PAY ALL FEES AND PERMITS PERTAINING TO THE CONTRACT.

15. EXISTING MATERIALS THAT ARE REMOVED SHALL NOT BE REUSED IN NEW SYSTEMS, EXCEPT WHERE

16. ALL EQUIPMENT SHALL BE INSTALLED IN STRICT COMPLIANCE WITH THE MANUFACTURER'S WRITTEN

17. ALL PLUMBING FIXTURE VENTS TO TERMINATE MINIMUM 12 INCHES FROM ANY VERTICAL SURFACE AND 10 FEET FROM OR 3 FEET ABOVE ANY OUTSIDE AIR INTAKES. NO FLAGPOLING PERMITTED.

18. ALL PIPING SHALL BE INSTALLED AS INDICATED ON THE DRAWINGS IN A NEAT WORKMANSHIP-LIKE MANNER AND BE SUPPORTED AS REQUIRED BY CODES. PIPING SHALL BE SET UP AND DOWN AND OFFSET AS REQUIRED TO SUIT FIELD CONDITIONS. DIELECTRIC COUPLINGS SHALL BE USED WHERE

19. ALL PIPING DISCHARGING INTO FLOOR-SINKS AND/OR FLOOR DRAINS SHALL MAINTAIN MINIMUM

20. ALL VALVES, UNIONS, ETC. TO BE SAME SIZE AS LINE SIZE UNLESS OTHERWISE INDICATED ON

21. ISOLATE AND DRAIN EXISTING PIPING SYSTEM AS REQUIRED TO ACCOMMODATE INSTALLATION OF

22. UNIONS SHALL BE PROVIDED AND INSTALLED AFTER EACH SCREW-TYPE VALVE AND PRIOR TO

ALL MECHANICAL, PLUMBING, AND ELECTRICAL COMPONENTS SHALL BE ANCHORED AND INSTALLED PER THE DETAILS ON THE OSHPD APPROVED CONSTRUCTION DOCUMENTS. WHERE NO DETAIL IS INDICATED, THE FOLLOWING COMPONENTS SHALL BE ANCHORED OR BRACED TO MEET THE FORCE

AND DISPLACEMENT REQUIREMENTS PRESCRIBED IN THE 2016 CBC, SECTION 1616A. AND ASCE 7-10 CHAPTER 6 AND 30. A. ALL PERMANENT EQUIPMENT AND COMPONENTS B. TEMPORARY OR MOVABLE EQUIPMENT THAT IS PERMANENTLY ATTACHED (E.G. HARD WIRED) TO THE BUILDING UTILITY SERVICES SUCH AS ELECTRICITY, GAS OR WATER. C. MOVABLE EQUIPMENT WHICH IS STATIONED IN ONE PLACE FOR MORE THAN 8 HOURS AND HEAVIER THAN 400 POUNDS ARE REQUIRED TO BE ANCHORED WITH TEMPORARY ATTACHMENTS. THE ATTACHMENT OF THE FOLLOWING MECHANICAL AND ELECTRICAL COMPONENTS SHALL BE POSITIVELY ATTACHED TO THE STRUCTURE, BUT NEED NOT BE DETAILED ON THE PLANS. THESE COMPONENTS SHALL HAVE FLEXIBLE CONNECTIONS PROVIDED BETWEEN THE COMPONENT AND ASSOCIATED DUCTWORK, PIPING, AND CONDUIT: A. COMPONENTS WEIGHING LESS THAN 400 POUNDS AND HAVE A CENTER OF MASS LOCATED 4 FEET OR LESS ABOVE THE ADJACENT FLOOR OR ROOF LEVEL THAT DIRECTLY SUPPORT THE COMPONENT.

B. COMPONENTS WEIGHING LESS THAN 20 POUNDS, OR IN THE CASE OF DISTRIBUTED SYSTEMS, LESS THAN 5 POUNDS PER FOOT, WHICH ARE SUSPENDED FROM A ROOF OR FLOOR OR HUNG FROM A WALL.

FOR THOSE ELEMENTS THAT DO NOT REQUIRE DETAILS ON THE APPROVED DRAWINGS, THE INSTALLATION SHALL BE SUBJECT TO THE APPROVAL OF THE STRUCTURAL ENGINEER OF RECORD AND THE DSA DISTRICT STRUCTURAL ENGINEER. THE PROJECT INSPECTOR WILL VERIFY THAT ALL COMPONENTS AND EQUIPMENT HAVE BEEN ANCHORED IN ACCORDANCE WITH ABOVE REQUIREMENTS.

24. PIPING, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEM BRACING NOTE

PIPING, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEMS SHALL BE BRACED TO COMPLY WITH THE FORCES AND DISPLACEMENTS PRESCRIBED IN ASCE 7-10 SECTION 13.3 AS DEFINED IN ASCE 7-10 SECTION 13.6.8, 13.6.7, 13.6.5.6 ITEM 6, AND 2016 CBC SECTIONS 1616A.

THE BRACING AND ATTACHMENTS TO THE STRUCTURE SHALL BE DETAILED ON THE APPROVED DRAWINGS OR THEY SHALL COMPLY WITH ONE OF THE OSHPD PRE-APPROVALS (OPM #) AS MODIFIED TO SATISFY ANCHORAGE REQUIREMENTS OF ACI 318, APPENDIX D.

COPIES OF THE MANUAL SHALL BE AVAILABLE ON THE JOBSITE PRIOR TO THE START OF HANGING AND BRACING OF THE PIPE, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEM.

THE STRUCTURAL ENGINEER OF RECORD SHALL VERIFY THE ADEQUACY OF THE STRUCTURE TO SUPPORT THE HANGER AND BRACE LOADS.

- 25. PLUMBING FIXTURES AND FAUCETS SHALL BE CERTIFIED BY THE STATE OF CALIFORNIA ENERGY COMMISSION AS REQUIRED BY THE CALIFORNIA ENERGY EFFICIENCY STANDARDS SECTION S-5314 AND TABLE "G".
- 26. ALL SOIL, WASTE, STORM DRAIN AND VENT PIPING SHALL SLOPE AT 2% UNLESS OTHERWISE INDICATED.
- 27. PIPING THROUGH FIRE RATED WALLS SHALL BE PER U.L. FIRE RESISTANCE SYSTEM NO. W1001. SEE ARCHITECTURAL PLANS FOR ALL WALL LOCATIONS.
- 28. REFER TO THE SPECIFICATIONS BOOK FOR ADDITIONAL REQUIREMENTS.
- 29. ALL CLEANOUTS SHALL BE INSTALLED WHERE READILY ACCESSIBLE. THE CONTRACTOR SHALL COORDINATE ALL CLEANOUT LOCATIONS WITH EQUIPMENT, CABINETS, ETC, AND THE ARCHITECT PRIOR TO ANY INSTALLATION.
- 30. KEEP ALL PIPING FROM LOAD BEARING FOOTINGS. IF UNABLE TO CLEAR FOOTINGS OR GRADE BEAMS, INSTALL PIPING THROUGH PIPE SLEEVES.
- 31. BEFORE FABRICATION OR INSTALLATION, THE CONTRACTOR SHALL VERIFY EXACT LOCATIONS OF ALL EQUIPMENT AND FIXTURES. EXACT ROUGH-IN LOCATIONS AND REQUIREMENTS SHALL BE COORDINATED IN FIELD.
- 32. ACCESSIBLE PLUMBING FIXTURES SHALL COMPLY WITH ALL OF THE REQUIREMENTS OF 2016 CBC CHAPTER 11A AND/OR 11B. HEIGHTS AND LOCATION OF ALL FIXTURES SHALL BE ACCORDING TO CBC 2016 SECTION 1138A. FIXTURE CONTROLS SHALL COMPLY WITH CBC 2016 SECTION 1138A.4.
- 33. ALL VALVES, TRAP PRIMERS, WATER HAMMER ARRESTERS OR OTHER EQUIPMENT SHOWN IN WALLS OR ABOVE NON-ACCESSIBLE CEILINGS SHALL BE INSTALLED BEHIND AN ACCESS PANEL
- 34. ALL VENT THROUGH ROOF SHALL BE MINIMUM OF 3 FEET VERTICALLY AND 10 FEET HORIZONTALLY FROM ANY AIR CONDITIONING EQUIPMENT FRESH AIR INTAKES.
- 35. VERIFY WITH ARCHITECTURAL DRAWINGS FOR EXACT LOCATIONS OF ALL FLOOR DRAINS, ROOF, OVERFLOW DRAINS AND FLOOR SINKS.
- 36. FIXTURES SHALL BE PROTECTED DURING CONSTRUCTION FROM ANY DAMAGES. REFINISHED FIXTURES WILL NOT BE ACCEPTABLE UNDER ANY CONDITIONS.
- 37. HOSE BIB WITH VACUUM BREAKER SHALL BE PROVIDED UNDER LAVATORY IN EACH PUBLIC RESTROOM.
- 38. INSULATE INDIRECT DRAIN LINES FROM REFRIGERATORS, FREEZERS, ICE MAKER AND ICE BINS WITH MANVILLE AERO-TUBE OR EQUAL TO PREVENT CONDENSATE DRIPS.
- 39. INSULATE WASTE PIPE AND P-TRAP FROM FLOOR SINK, FLOOR DRAINS OR FUNNEL DRAINS COLLECTING INDIRECT DRAINS FROM REFRIGERATORS, FREEZERS, ICE MAKER AND ICE BINS TO PREVENT CONDENSATE DRIPS. INSULATE WASTE PIPE UP TO THE NEXT 3" OR 4" MAIN CONNECTION.
- 40. PROVIDE AND INSTALL GAS COCKS AND UNION AT EACH GAS FIRED EQUIPMENT.
- 41. PROVIDE AND INSTALL CHROME ANGLE VALVES ON HOT AND COLD WATER SUPPLY AT EACH PLUMBING FIXTURES.
- 42. ALL WATER FAUCETS SHALL BE PROVIDED WITH CODE APPROVED FLOW RESTRICTORS.

### MECHANICAL PIPE AND DUCT SYSTEM SEISMIC SUPPORT NOTES

#### MECHANICAL & PLUMBING

- 1. SUPPORT AND BRACING FOR NEW PIPING, EXCEPT FIRE SPRINKLER PIPING, AND FOR NEW DUCTWORK SHALL BE PROVIDED PER OPM-0043-13 MASON SEISMIC RESTRAINT COMPONENTS FOR SUSPENDED UTILITIES OR OTHER APPROVED OSHPD OPM.
- INSTALLATION GUIDE/MANUAL SHALL BE ON THE JOBSITE PRIOR TO STARTING THE INSTALLATION.
- TO ENSURE THAT THE ORIGINAL DESIGN IS STILL ADEQUATE. THE INSPECTOR OF RECORD SHALL INSURE THAT ALL WORK IS PROPERLY INSTALLED PER THE APPLICABLE OSHPD PRE-APPROVAL.

- 43. COVER ALL FLOOR DRAINS, FLOOR SINKS, ROOF AND OVERFLOW DRAINS DURING CONSTRUCTIONS TO PREVENT DEBRIS FROM ENTERING PIPE AND PROTECT GRATES FROM DAMAGES.
- 44. COORDINATE WITH ELECTRICAL CONTRACTOR PRIOR TO ORDERING EQUIPMENT FOR AVAILABLE VOLTAGES AT ALL EQUIPMENT LOCATIONS.
- 45. COORDINATE WITH ELECTRICAL CONTRACTOR FOR ALL TAMPER AND FLOW SWITCH LOCATIONS.
- 46. BECAUSE OF THE SMALL SCALE DRAWINGS, IT IS NOT POSSIBLE TO INDICATE ALL OFFSETS, FITTINGS AND ACCESSORIES WHICH MAY BE REQUIRED. THE CONTRACTOR SHALL CAREFULLY INVESTIGATE THE CONDITIONS SURROUNDING INSTALLATION OF HIS WORK. FURNISHING THE NECESSARY PIPING FITTINGS, VALVES, TRAPS, AND OTHER DEVICES WHICH MAY BE REQUIRED TO COMPLETE THE INSTALLATION.
- 47. UNLESS SPECIFIED ON STRUCTURAL DRAWINGS, ANY ALTERATION OR MODIFICATIONS TO STRUCTURAL ELEMENTS BY CUTTING, DRILLING, BORING, BRACING, WELDING ETC. SHALL HAVE WRITTEN APPROVAL STRUCTURAL ENGINEER PRIOR TO START WORK.
- 48. ITEMS NOT SHOWN IN THE DRAWINGS BUT NECESSARY FOR COMPLETE OPERATION OF THE SYSTEM/FIXTURES/EQUIPMENT OR FOR COMPLETE CODE INSTALLATION SHALL BE PROVIDED AT NO ADDED COST TO THE OWNER.
- 49. DIELECTRIC UNION ISOLATOR WITH THREADED CONNECTIONS SHALL BE PROVIDED FOR CONNECTIN INCOMPATIBLE MATERIALS.
- 50. ALL PLUMBING FIXTURES SHALL BE APPROVED BY OWNER PRIOR TO ORDERING.
- 51. CONTRACTOR SHALL FIELD VERIFY EXACT LOCATION OF ALL EXISTING UTILITIES TO WHERE HE IS TO CONNECT PRIOR TO INSTALLATION OF ANY PIPING. EXTEND NEW PIPING IF NECESSARY TO WHERE THE EXISTING IS.
- 52. ALL CONNECTIONS TO EXISTING SERVICES SHALL BE MADE SUCH THAT INTERRUPTION TIME WILL BE AS SHORT AS POSSIBLE. THE CONTRACTOR SHALL GIVE THE OWNER'S REPRESENTATIVE SUFFICIENT NOTICE OF SUCH INTERRUPTION AND THE ACTUAL SHUT DOWN TIME SHALL BE AT A TIME DESIGNATED BY THE OWNER'S REPRESENTATIVE.
- 53. ALL EXISTING PIPING DAMAGED DURING CONSTRUCTION SHALL BE REPAIRED WITH MATERIALS TO MATCH EXISTING BY THE CONTRACTOR.
- 54. PROVIDE AND INSTALL WATER HAMMER ARRESTORS IN THE FOLLOWING LOCATIONS (ONLY NON-FERROUS ARRESTORS MAY BE INSTALLED IN ANY WATER SYSTEM):
  - A. WATER LINES TO LAVATORY HEADERS, WATER CLOSET AND URINAL HEADERS, SERVICE SINKS KITCHEN SINKS, WASH FOUNTAINS, DRINKING FOUNTAINS, LABORATORIES WITH MEDICAL TYPE FAUCETS AND ON WASH SINKS HAVING 3 OR MORE STATIONS AND ALL OTHER QUICK CLOSING FIXTURE SUCH AS CLOTHES WASHERS, AS CLOSE TO FIXTURE AS POSSIBLE.
  - B. BETWEEN LAST 2 FIXTURES WHEN 3 OR MORE FIXTURES, OTHER THAN THOSE LISTED IN "A" ABOVE, ARE SERVED BY A COMMON HEADER.
  - C. WHEN ARRESTOR SHALL BE INSTALLED IN WALL OR FURRING, FURNISH WITH AN ACCESS PLATE LARGE ENOUGH TO PERMIT REMOVAL OF ARRESTOR. ACCESS PLATE SHALL BE A MINIMUM OF 2 INCHES LARGER IN EACH DIRECTION THAN ARRESTOR.
- 55. ALL PIPING INTO STEM WALLS AND FOOTINGS SHALL BE DOUBLE HALF LAP WRAPPED WITH 1/8" THICK "ARMAFLEX" INSULATION. THE CONTRACTOR SHALL ALSO PROVIDE BLOCKED OUT AREAS IN STEM WALL AND FOOTING. ALL PIPING SHALL AVOID THE LOWER 8" OF THE FOOTING.
- 56. ALL HOT WATER PIPING SHALL BE INSULATED. INSULATION SHALL HAVE A FLAME SPREAD OF NOT MORE THAN 25 AND A SMOKE DENSITY NOT EXCEEDING 50 PER 2016 CMC SEC. 1201.2. SEE SPECIFICATION FOR OTHER REQUIREMENTS.
- 57. ALL CONNECTIONS TO SITE PIPING SHALL BE DONE BY THE PLUMBING CONTRACTOR.
- 58. CLEANOUTS SHALL BE PROVIDED PER 2016 CPC SECTION 707.0 & 719.0 AND TO THE FOLLOWING LOCATIONS:
  - A. AT EACH BASE OF ROOF DRAIN DOWNSPOUTS.
  - B. AT EACH BASE OF WASTE STACK
  - C. AT EVERY 100 FT OF STRAIGHT RUN OF HORIZONTAL PIPING
  - D. AT EACH AGGREGATE HORIZONTAL CHANGE IN DIRECTION EXCEEDING ONE HUNDRED THIRTY-FIVE (135) DEGREES.
  - E. AT EACH HORIZONTAL DRAINAGE PIPE UPPER TERMINAL
  - F. ABOVE EACH URINAL
  - G. BELOW EACH SINK.
- 59. PROVIDE SEDIMENT TRAP AS CLOSE AS POSSIBLE TO ALL GAS APPLIANCES AND GAS FIRED EQUIPMENTS INLET EXCEPT FOR APPLIANCES LISTED PER 2016 CPC SECTION 1210.8. SEE SEDIMENT TRAP INSTALLATION PER 2016 CPC FIGURE 1210.8.
- 60. DOMESTIC WATER PIPING AND COMPONENTS SHALL BE PROVIDED AND INSTALLED IN COMPLIANCE WITH CALIFORNIA AB 1953 LEGISLATION, WHICH LIMITS THE ALLOWABLE LEAD CONTENT IN CERTAIN DOMESTIC WATER SYSTEM COMPONENTS.

2. LAYOUT DRAWINGS, SHOWING THE BRACING/SUPPORT LOCATIONS AND REFERENCES TO DETAILS FROM THE RELEVANT OSHPD PRE-APPROVALS NEED TO BE SUBMITTED FOR USE BY THE INSPECTOR OF RECORD AND OSHPD FIELD STAFF. THE LAYOUT DRAWINGS, PREPARED PER ASCE 7 CHAPTER 13 AS MODIFIED BY CBC SECTIONS 1613A/1616A, SHALL BE PREPARED BY THE SUBCONTRACTOR AND SIGNED BY A STRUCTURAL ENGINEER LICENSED IN THE STATE OF CALIFORNIA. REFERENCES TO DETAILS FROM THE OSHPD PRE-APPROVAL SHALL BE FOR AN ENTIRE DETAIL AS SUBMITTED OR REFERENCE SHALL BE FOR EACH ASPECT OF A SUBMITTED DETAIL. CUSTOM DETAILS SHALL BE PROVIDED FOR SITUATIONS WHERE OSHPD PRE-APPROVALS DO NOT APPLY. AT LEAST FOUR WEEKS PRIOR TO BEGINNING INSTALLATION, FOUR COPIES OF THE PLANS SHALL BE SUBMITTED TO THE ARCHITECT OF RECORD WHO WILL SUBMIT THEM TO THE STRUCTURAL ENGINEER OF RECORD FOR REVIEW AND APPROVAL. AFTER THIS APPROVAL, THE DRAWINGS WILL BE SUBMITTED TO THE OSHPD DISTRICT STRUCTURAL ENGINEER FOR REVIEW AND APPROVAL. THE PLANS SHALL BE COORDINATED WITH THE PLANS OF OTHER TRADES. A COPY OF THE CHOSEN BRACING SYSTEM

3. THE STRUCTURAL ENGINEER FOR THE CONTRACTOR SHALL DETERMINE THE APPROPRIATE SEISMIC FORCES BASED ON THE DESIGN CRITERIA SHOWN ON THE STRUCTURAL DRAWINGS.

4. ONCE THE EXACT LOCATIONS OF ALL PIPING AND DUCTWORK HAVE BEEN ESTABLISHED, THE STRUCTURAL ENGINEER MUST CHECK THE ADEQUACY OF THE SUPPORTING STRUCTURE

### S ARCHITECTS

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

### **Tri-City Medical Center**

4002 Vista Way Oceanside, California 92056

OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709 ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084 MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230

> SAN DIEGO, CA 92123 TEL(619)618-2347

STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438-1188

		GED MARA			FESSIO	
	1055 CEN	No. C 28543	TER X	24 24 24 24 24 24 24 24 24 24 24 24 24 2	A. LUS REAL	
۵		OF CALIFOR			FCALIFO	
<u>/</u>		OSHPD COMMENTS			10-09-17	
	2	DESIGN CHANGES			10-09-17	
$\overline{\mathbf{A}}$	$\sqrt{3}$	OSHPD COMMENTS			12-11-17	
	4	DESIGN CHANGES	~~~~~	~~~~~	12-11-17	<b>^</b>
<u>چ</u>	5	OSHPD COMMENTS			5-15-18	3
<u> </u>	6	DESIGN CHANGES			6-05-18	3
	REV:	DESCRIPTION:			DATE:	
	CONSULTA	25	9665 Ch 9665 Ch San Dieg T 619.6 www.p2	<b>nginee</b> esapeake go, CA 921 18.2347 F seng.com	r <b>ing, Inc.</b> Dr., Suite #23 23 - 619.330.06	30 68
	OSHPD AF	PPROVAL STAMP:				
	OSH	⊃D #: S17	71641-	37-00		



### GENERAL NOTES LEGEND, SYMBOLS, AND SHEET INDEX

TCMC USP 800

PROJECT #: 01667.00 DRAWN BY: CHECKED BY:

SCALE

SHEET NUMBER



100% CONSTRUCTION DOCUMENT

07/31/17



IARK	FIXTURE	CW	HW	S OR W	V	REMARKS
S-1	HAND SINK	1/2"	1/2"	2"	1-1/2"	CUSTOM STAINLESS STEEL HAND SCRUBBING SINK. SEE ARCHITECTURAL DRAWINGS. PROVIDE WITH CHICAGO FAUCET #201-AGN10ASE33-317AB (2.2 GPM), LOOSE KEY STOPS AND RIGID SUPPLIES, AND P-TRAP.
EEW	EMERGENCY EYE / FACE WASH	1"	1/2"	<b>}</b> <u>6</u> _	-	HAWS "AXION MSR SINK MOUNT EYE/FACE WASH" 7610 WITH THERMOSTATIC MIXING 3 VALVE.
/EEW-1	TEMPORARY EMERGENCY EYE / FACE WASH			-	-	HAWS 15 GAL PRESSURIZED EMERGENCY EYEWASH 7603.
T/S-1	TEMPORARY HAND SINK	-	-	-	-	POLY PORTABLE TWIN FREE-STANDING HAND WASH STATION-PPST-05 45 GAL FRESH & 45 GAL GRAY HOLDING TANKS
T/S-1 <u>OTE:</u> ALL F ECOMMEN	TEMPORARY HAND SINK FIXTURES SHALL BE PROV IDATIONS. THE PLUMBING	- IDED WITH MINII CONTRACTOR	- MUM ROUGH-IN SHALL RUN ALL	- CONNECTIONS A SERVICE LINES, F	- S INDICATED IN OUGH-IN AND	WASH STATION-PPST-05 45 GAL FRESH & 45 GAL GRAY HOLDING TANKS I THIS SCHEDULE OR PER MANUFACTURERS MAKE FINAL CONNECTIONS TO ALL FIXTURES.

### PIPE SCHEDULE

SERVICE	ERVICE LOCATION	
	COLD WATER	Т
DOMESTIC WATEN	HOT WATER	S S
	ABOVE GRADE	N V
SANITANT WASTE	BELOW GRADE	N V
	CONCEALED	N V
SANITARY VENT	EXPOSED	N V







#### MATERIALS

TYPE "L" COPPER TUBING W/ WROUGHT COPPER SWEAT FITTINGS. SAME AS ABOVE W/ 1" THICK MINERAL FIBER, PREFORMED PIPE INSULATION FOR NPS 1-1/4" AND SMALLER. USE 1-1/2" THICK FOR NPS 1-1/2" AND LARGER. NO-HUB CAST IRON BY "AB&I, TYLER OR CHARLOTTE", LISTED WITH C.I.S.P.I. AND SHALL COMPLY WITH STANDARD 301, HEAVY-DUTY STAINLESS STEEL FOUR BAND COUPLINGS ASTM C 1277. NO-HUB CAST IRON BY "AB&I, TYLER OR CHARLOTTE", LISTED WITH C.I.S.P.I. AND SHALL COMPLY WITH STANDARD 301, HEAVY-DUTY STAINLESS STEEL FOUR BAND COUPLINGS ASTM C 1277. NO-HUB CAST IRON BY "AB&I, TYLER OR CHARLOTTE", LISTED WITH C.I.S.P.I. AND SHALL COMPLY WITH STANDARD 301, HEAVY-DUTY STAINLESS STEEL FOUR BAND COUPLINGS ASTM C 1277. NO-HUB CAST IRON BY "AB&I, TYLER OR CHARLOTTE", LISTED WITH C.I.S.P.I. AND SHALL COMPLY WITH STANDARD 301, HEAVY-DUTY STAINLESS STEEL FOUR BAND COUPLINGS ASTM C 1277.





6 20 GA. GALV. IRON SHEET SHIELD (12" LONG).

7 PROVIDE A SECTION OF HIGH COMPRESSION STRENGTH INSULATION AT EACH HANGER POINT. INSULATION MAY BE HALF ROUND OR FULL ROUND & EXTENDED 2" BEYOND GALV. SHIELD EA. WAY.



5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

### Tri-City Medical Center

4002 Vis Oceansi	ta Way de, California  92056	
OWNER:	TRI—CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 9205 TEL (760) 940—7709	6
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUIT SAN DIEGO, CALIFORNIA 9212 TEL(619)299–3917 FAX(619)	E 100 2 299-5084
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SU SAN DIEGO, CA 92123 TEL(619)618–2347	ITE 230
STRUCTURAI	L: SUN STRUCTURAL ENGINEERIN 2091 LAS PALMAS DRIVE, SUI CARLSBAD, CA 92011 TEL(760)438–1188	G TE D
V V V No.	C 28543 70 *	10Ny ENGINEER
NATION OF	1-31-19 CALIFOR	LIFORM
	COMMENTS	10-09-17
	N CHANGES	10-09-17
		12-11-17
		5-15-18
6 DESIG	N CHANGES	6-05-18
REV: DESCE	RIPTION:	DATE:
OSHPD	P2S Engineering 9665 Chesapeake Dr., San Diego, CA 92123 T 619.618.2347 F 619 www.p2seng.com STAMP: #: S171641-37-00	<b>g, Inc.</b> Suite #23 9.330.060
	REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR APPROVED with comments	
K FACI	C Huang, Sr. Architect Office of Statewide Health Planning & Development LITIES DEVELOPMENT DIVISION	
	07/23/2018 08:10:09 AM #[ \$171641-37-00 ]	
SHEET TITLE:		
SCHEE	DULES AND	
DETAII	_S	

PROJECT TITLE: TCMC USP 800

PROJECT #: 01667.00 DRAWN BY: ED CHECKED BY: SJ SCALE:

DATE:







I		SFEIR
ATION OF SINK		ARCHITECTS
OLITION, N OF ANY	2 POC 2" W TO (E) 2" W.	5151 Shoreham Place, Suite 100
	1" CW DN & 1/2" HW CONNECTION TO THERMOSTATIC         MIXING VALVE FOR EMERGENCY EYE WASH.	San Diego, Ca 92122 P: 619-299-3917
	5 (E) 1/2" HW UP.	F: 619-299-5084 www.sfeirarch.com
	6 (E) 2" CW UP.	TCMC
	<ul> <li>7 (E) 1/2" HVV.</li> <li>8 (E) 1/2" CW UP.</li> </ul>	PHARMACY
	9 (E) 1 1/2" V UP.	USP 800
	10 (E) 3" W UP. 11 POC 1" CW TO (E) 2 1/2" CW.	
	12 POC AT HW LINE.	
	13 POC AT CW LINE.	Tri-City Medical Center
	15 POC TO (E) WASTE LINE.	4002 Vista Way
		Oceanside, California 92056
	<ul><li>17 1-1/2" WASTE DOWN THROUGH SLAB.</li><li>(E) WATER CLOSET WASTE DOWN THROUGH SLAB.</li></ul>	OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY
		OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709
		5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–5084
		MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230
		SAN DIEGO, CA 92123 TEL(619)618–2347
		STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL (700)478 1188
		TEL(760)438-1188
		SED ANCONTRACTOR
		★ No. C 28543 70 ★
		OF CALIFOR
		$ \underbrace{ \begin{array}{c} 1 \\ 2 \\ 2 \\ 1 \\ 2 \\ 1 \\ 1 \\ 1 \\ 1 \\ 1 \\$
		$\begin{array}{c c} \hline 3 \\ \hline 4 \\ \hline 4 \\ \hline 4 \\ \hline \\ \hline \\ \hline \\ \hline \\ \hline \\$
		5     OSHPD COMMENTS     5-15-18       6     DESIGN CHANGES     6-05-18
		REV: DESCRIPTION: DATE:
		P2S Engineering, Inc. 9665 Chesapeake Dr., Suite #230 San Diago, CA 02122
		T 619.618.2347 F 619.330.0668 www.p2seng.com
		OSHPD APPROVAL STAMP: OSHPD #: \$171641-37-00
		REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CCR
		with comments
		KC Huang, Sr. Architect Office of Statewide Health Planning & Development
		FACILITIES DEVELOPMENT DIVISION
		FLOOR PLAN
		PROJECT TITLE: TCMC USP 800
		PROJECT #: 01667.00 SHEET NUMBER:
		CHECKED BY: SJ SCALF: P2-10
I	$\frac{1}{0} \frac{1}{4}$ SCALE: 1/4" = 1'-0"	DATE: 07/31/17 OF



#### GENERAL NOTES



1. CONDITION SHOWN ON DRAWINGS AF REVIEW OF AVAILABLE AS-BUILT DRAV INVESTIGATIONS TO THE EXTENT POS CONTRACTOR SHALL VERIFY EXISTING DISCREPENCIES DISCOVERED SHALL THE ATTENTION OF THE ARCHITECT, OWNERS REPRESENTATIVE PRIOR TO THE COMMENCEMENT OF ANY WORK.

#### NOTES

RE BASED ON
WINGS AND FIELD
SIBLE.
G CONDITIONS. ANY
BE BROUGHT TO
ENGINEER AND
THE

1 REMOVE (E) SINK AND ITS ASSOCIATED APPURTENANCES.
2 REMOVE (E) 1/2" CW FROM SINK TO PIPE IN WALL.
3 REMOVE (E) 2" W FROM SINK TO PIPE IN WALL.
4 REMOVE (E) 1/2" HW FROM SINK TO PIPE IN WALL.
5 (E) 2" W UP TO (E) SH.
6 (E) 1/2" HW UP.
7 (E) 2" CW UP.

8 (E) 1 1/2" V UP.

9 (E) 1/2" HW UP.

10 (E) 1/2" CW UP.

 $\underline{\land}$ 

(E) SINK WASTE DOWN THROUGH SLAB. CONTRACTOR TO 
 11
 VERIFY THE SIZE OF (E) SINK WASTE PRIOR TO THE DEMOLITION OR PROCUREMENT OF ANY MATERIALS OR
 COMPONENTS.

[12] (E) WATER CLOSET WASTE DOWN THROUGH SLAB. (E) CW DOWN WALL TO LAV AND WATER CLOSET AND HW

 

 13
 UTILITIES PRIOR TO THE DEMOLITION, PROCUREMENT AND/OR FABRICATION OF ANY MATERIALS OR

 COMPONENTS.

POD AT EXISTING VENT. CONTRACTOR TO VERIFY THE14SIZE OF (E) SINK VENT PRIOR TO THE DEMOLITION OR PROCUREMENT OF ANY MATERIALS OR COMPONENTS.

15POD AT EXISTING HW LINE. CONTRACTOR TO VERIFY THE<br/>SIZE OF (E) HW LINE PRIOR TO THE DEMOLITION OR<br/>PROCUREMENT OF ANY MATERIALS OR COMPONENTS. (E) FIXTURE TO BE REMOVED DURING DEMOLITION IN

- 16 PREPARATION FOR RE-USE. CONTRACTOR TO STORE AND PROTECT (E) SINK DURING CONSTRUCTION.
- 17 PRESERVE & PROTECT THE (E) WATER CLOSET DURING DEMOLITION.

F S R E A R C H I T E C T S

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY USP 800 UPGRADE

### **Tri-City Medical Center**

4002 ∖ Ocean	/ista Way side, California 92056	
OWNER:	TRI—CITY MEDICAL CENTEI 4002 VISTA WAY OCEANSIDE, CALIFORNIA S TEL (760) 940—7709	२ 92056
ARCHITEC	T: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SAN DIEGO, CALIFORNIA S TEL(619)299–3917 FAX(	SUITE 100 92122 619)299-5084
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE SAN DIEGO, CA 92123 TEL(619)618–2347	, SUITE 230
STRUCTUF	RAL: SUN STRUCTURAL ENGINE 2091 LAS PALMAS DRIVE, CARLSBAD, CA 92011 TEL(760)438–1188	ERING SUITE D
	o. C 28543 T	$\begin{array}{c} & & & & \\ & & & & \\ & & & & \\ & & & \\ & & & \\ \hline \\ & & & \\ \hline \\ & & & \\ \hline \\ \\ \\ & & \\ \hline \\ \\ & & \\ \hline \\ \\ \hline \\ \\ \hline \\ \\ \\ \hline \\ \\ \hline \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \hline \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \hline \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \hline \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\ \\ \\ \hline \\$
CONSULTANT	<b>P2SE P2S Enginee</b> 9665 Chesapeake San Diego, CA 922 T 619.618.2347 F www.p2seng.com	DATE: <b>ring, Inc.</b> Dr., Suite #230 123 = 619.330.0668
OSHPE	#: S171641-37-00	

REVIEWED IN ACCORDANCE WITH

THE REQUIREMENTS OF T24, CCR

**APPROVED** 

with comments

SHEET NUMBER:

PD2-10

KC Huang, Sr. Architect Office of Statewide Health

Planning & Development

FACILITIES DEVELOPMENT DIVISION

07/23/2018 08:10:09 AM **#[ S171641-37-00 ]** 

PARTIAL DEMOLITION

FLOOR PLAN

01667.00

07/31/17

PROJECT TITLE: TCMC USP 800

PROJECT #:

CHECKED BY:

SCALE:

DATE:

DRAWN BY: ED



### LEGEND

# <u>SYMBOL</u> <u>\_\_\_\_\_ - \_\_\_\_ - \_\_\_\_</u> ~**—**—**—**—<del>,</del>

A-1

ГЧ

DESCRIPTION

NOTE CALLOUT
NEW LINEWORK
EXISTING LINEWORK
CONDUIT CONCEALED IN WALL OR ABOVE CEILING
CONDUIT EXPOSED
CONDUIT & WIRE TO BE DEMOLISHED
CONDUIT CAPPED
BRANCH CIRCUIT HOMERUN TO PANELBOARD AND CIRCUITS AS INDICATED
CONDUIT EMERGENCY
3/4" CONDUIT, TICK MARKS INDICATE QUANTITY OF #12 AWG WIRES (UNLESS NOTED OTHERWISE, NO MARKS INDICATES 2#12 & 1#12 GND WIRES) - SMALL MARK DENOTES HOT WIRE - LARGE MARK DENOTES NEUTRAL WIRE - DIAGONAL DENOTES GROUND WIRE
CIRCUIT BREAKER
TRANSFER SWITCH
TRANSFORMER
GROUND CONNECTION
GROUND CONNECTION FUSED DISCONNECT SWITCH
GROUND CONNECTION FUSED DISCONNECT SWITCH SINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED +48" MAX AND +36" MIN FROM THE CENTER OF DEVICE:
GROUND CONNECTION FUSED DISCONNECT SWITCH SINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED +48" MAX AND +36" MIN FROM THE CENTER OF DEVICE: JUNCTION BOX
GROUND CONNECTION FUSED DISCONNECT SWITCH SINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED +48" MAX AND +36" MIN FROM THE CENTER OF DEVICE: JUNCTION BOX DUPLEX - WALL +18" A.F.F.
GROUND CONNECTION FUSED DISCONNECT SWITCH SINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED +48" MAX AND +36" MIN FROM THE CENTER OF DEVICE: JUNCTION BOX DUPLEX - WALL +18" A.F.F. CONNECT TO EMERGENCY GENERATOR;
GROUND CONNECTION FUSED DISCONNECT SWITCH SINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED +48" MAX AND +36" MIN FROM THE CENTER OF DEVICE: JUNCTION BOX DUPLEX - WALL +18" A.F.F. CONNECT TO EMERGENCY GENERATOR; JUNCTION BOX - WALL
GROUND CONNECTIONFUSED DISCONNECT SWITCHSINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED +48" MAX AND +36" MIN FROM THE CENTER OF DEVICE:JUNCTION BOXDUPLEX - WALL +18" A.F.F.DUPLEX - WALL +18" A.F.F. (CONNECT TO EMERGENCY GENERATOR)JUNCTION BOX - WALLPANELBOARD, 120/208V - RECESSED
GROUND CONNECTIONFUSED DISCONNECT SWITCHSINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED + 48" MAX AND + 36" MIN FROM THE CENTER OF DEVICE:JUNCTION BOXJUNCTION BOXDUPLEX - WALL + 18" A.F.F.DUPLEX - WALL + 18" A.F.F. (CONNECT TO EMERGENCY GENERATOR)JUNCTION BOX - WALLPANELBOARD, 120/208V - RECESSEDPANELBOARD, 120/208V - SURFACE
GROUND CONNECTIONFUSED DISCONNECT SWITCHSINGLE POLE SWITCH, DEVICE SHALL BE MOUNTED + 48" MAX AND + 36" MIN FROM THE CENTER OF DEVICE:JUNCTION BOXDUPLEX - WALL + 18" A.F.F.DUPLEX - WALL + 18" A.F.F. (CONNECT TO EMERGENCY GENERATOR)JUNCTION BOX - WALLPANELBOARD, 120/208V - RECESSEDPANELBOARD, 120/208V - SURFACEPANELBOARD, 277/480V - SURFACE

### ABBREVIATIONS

ABBREV

ABBREVIATION	DESCRIPTION	1.	
A OR AMP	AMPERES		C
ABV	ABOVE		SF
AFF	ABOVE FINISHED FLOOR		
AIC	AMPERE INTERRUPTING CAPACITY	2.	AF
AL			20
ARCH.			20
ASCC			)
AUX			20
AWG	AMERICAN WIRE GAUGE		) ) )
BKBD	BACKBOARD		20
BKR	BREAKER		(
BLDG	BUILDING		20
С	CONDUIT		(
СВ	CIRCUIT BREAKER		(
CKT	CIRCUIT		20
			(
CLG			
C.SED	COMBINATION SMOKE FIRE DAMPER	З.	Th
CU	COPPER		BC
DIAG	DIAGRAM		
DWP	DEPARTMENT OF WATER & POWER		
EA	EACH		AN
ELEC.	ELECTRICAL		O
EMT	ELECTRICAL METALLIC TUBING		W
EQUIP	EQUIPMENT		
EXIST/(E)	EXISTING		IN
(ENL)	LOCATION		PL
(ERR)	EXISTING TO BE REMOVED, RELOCATED		SF
			JC
FLR	FLOOR		~
FT	FEET	4.	O
GFI	GROUND FAULT INTERRUPTER		
GEC	GROUNDING ELECTRODE CONDUCTOR		NC
GND	GROUND		DE
HP	HORSEPOWER		SE
HT	HEIGHT		
HZ	HERTZ	5.	Tŀ
ISC			TH
L C MII J R			FI(
KV			SU
KW	KILOWATT		FI
LEMC			W
LUC.		6.	M
ΜΔΧ			(U
MEGR	MANUFACTURER		AF
MTD	MOUNTED	7	ΤL
MTG	MOUNTING	1.	M
Ν	NORTH		FN
NIC	NOT IN CONTRACT		<u> </u>
NO.	NUMBER	8.	W
Ρ	POLE		С
PB	PULL BOX		RE
PF	POWER FACTOR		(P
	PHASE		N
PVC	POLY-VINYL CHLORIDE		C/
PWR	POWER		
(R)	REMOVE		וט
REC/RECEPT	RECEPTACLE	9.	Cl
REQ'D	REQUIRED		С
RGS	RIGID GALVANIZED STEEL		С
RM	ROOM		
SPECS	SPECIFICATIONS	10.	C
SWBD	SWITCHBOARD		
SWGR			
IKANSE/XEMR			50
TYP		11.	FC
UUN	UNLESS OTHERWISE NOTED		ES
v VA			SC
vA W			IN
W/	WITH		W
W/O	WITHOUT	12	F١
WP	WEATHERPROOF		W
Z	IMPEDANCE		-
IN THE EVENT ABE	BREVIATIONS NOT MENTIONED HEREIN ARE		

IN THE E USED, REFERENCE WILL BE MADE TO ANSI Y1.1, MILITARY STANDARD ABBREVIATIONS, AND OTHER STANDARD INDUSTRY CONVENTIONS.

### **GENERAL NOTES**

1. ALL WORK SHALL COMPLY WITH THE 2016 EDITION OF THE CALIFORNIA ELECTRICAL CODE ND ALL OTHER APPLICABLE FEDERAL, STATE, AND LOCAL CODES. WHERE THE ONSTRUCTION DOCUMENTS INDICATE MORE RESTRICTIVE REQUIREMENTS, THE ONSTRUCTION DOCUMENTS SHALL GOVERN BUT THE CONSTRUCTION DOCUMENTS HALL NOT BE INTERPRETED AS AUTHORITY TO VIOLATE ANY CODE OR REGULATION.

PPLICABLE CODES:

- 015 IBC AND 2016 CALIFORNIA AMENDMENTS
- (2016 CALIFORNIA BUILDING CODE PART 2, TITLE 24, CCR)
- 014 NEC AND 2016 CALIFORNIA AMENDMENTS
- (2016 CALIFORNIA ELECTRICAL CODE PART 3, TITLE 24, CCR)
- 015 UMC AND 2016 CALIFORNIA AMENDMENTS
- (2016 CALIFORNIA MECHANICAL CODE PART 4, TITLE 24, CCR) 015 UPC AND 2016 CALIFORNIA AMENDMENTS
- (2016 CALIFORNIA PLUMBING CODE PART 5, TITLE 24, CCR)-
- (PUBLISHER:IAPMO) 015 IFC AND 2016 CALIFORNIA AMENDMENTS
- (2016 CALIFORNIA FIRE CODE PART 9, TITLE 24, CCR)

HE INTENT OF THE DRAWINGS AND SPECIFICATIONS IS TO RECONSTRUCT THE HOSPITAL UILDING IN ACCORDANCE WITH THE CALIFORNIA BUILDINGS STANDARD CODE, TITLE 24, ALIFORNIA CODE OF REGULATIONS. SHOULD ANY CONDITION DEVELOP NOT COVERED Y THE CONTRACT DOCUMENTS WHEREIN THE FINISHED WORK WILL NOT COMPLY WITH HE SAID TITLE 24, CALIFORNIA CODE OF REGULATIONS, A CHANGE ORDER DETAILING ND SPECIFYING THE REQUIRED WORK SHALL BE SUBMITTED TO AND APPROVED BY FFICE OF STATE WIDE HEALTH PLANNING AND DEVELOPMENT BEFORE PROCEEDING VITH THE WORK.

I THE EVENT OF A CONFLICT OR INCONSISTENCY BETWEEN ITEMS INDICATED ON THE LANS AND/OR SPECIFICATIONS OR WITH CODE REQUIREMENTS, THE NOTE, PECIFICATION OR CODE WHICH PRESCRIBES AND ESTABLISHES THE MORE COMPLETE OB OR THE HIGHER STANDARD SHALL PREVAIL.

MISSIONS FROM THE DRAWINGS OR SPECIFICATIONS OR THE MISDESCRIPTION OF ETAILS OF WORK WHICH ARE MANIFESTLY NECESSARY TO CARRY OUT THE INTENT OF HE DRAWINGS AND SPECIFICATIONS, OR WHICH ARE CUSTOMARILY PERFORMED, SHALL OT RELIEVE THE CONTRACTOR FROM PERFORMING SUCH OMITTED OR MISDESCRIBED ETAILS OF THE WORK BUT THEY SHALL BE PERFORMED AS IF FULLY AND CORRECTLY ET FORTH AND DESCRIBED IN THE DRAWINGS AND SPECIFICATIONS.

HE CONTRACTOR SHALL CHECK ALL DRAWINGS FURNISHED TO HIM IMMEDIATELY UPON HEIR RECEIPT AND SHALL PROMPTLY NOTIFY THE OWNER OF ANY DISCREPANCIES. GURES MARKED ON DRAWINGS SHALL IN GENERAL BE FOLLOWED IN PREFERENCE TO CALE MEASUREMENTS. LARGE SCALE DRAWINGS SHALL IN GENERAL GOVERN SMALL CALE DRAWINGS. THE CONTRACTOR SHALL COMPARE ALL DRAWINGS AND VERIFY THE GURES BEFORE LAYING OUT THE WORK AND WILL BE RESPONSIBLE FOR ANY ERRORS HICH MIGHT HAVE BEEN AVOIDED THEREBY.

ATERIALS AND EQUIPMENT SHALL BE NEW AND SHALL BEAR THE UNDERWRITERS' LABEL JL) AND SHALL BE INSTALLED IN THE MANNER FOR WHICH THEY ARE DESIGNED AND PPROVED.

HE CONTRACTOR SHALL NOT BORE, NOTCH OR IN ANY WAY CUT INTO ANY STRUCTURAL EMBER WITHOUT WRITTEN APPROVAL FROM THE ARCHITECT OR STRUCTURAL NGINEER.

HEN INSTALLING DRILLED-IN ANCHORS IN EXISTING NON-PRESTRESSED REINFORCED ONCRETE, USE CARE AND CAUTION TO AVOID CUTTING OR DAMAGING THE EXISTING EINFORCING BARS. WHEN INSTALLING THEM INTO EXISTING PRESTRESSED CONCRETE. PRE- OR POST-TENSIONED), LOCATE THE PRESTRESSED TENDONS BY USING A ON-DESTRUCTIVE METHOD PRIOR TO INSTALLATION. EXERCISE EXTREME CARE AND AUTION TO AVOID CUTTING OR DAMAGING THE TENDONS DURING INSTALLATION. AINTAIN A MINIMUM CLEARANCE OF ONE INCH BETWEEN THE REINFORCEMENT AND THE RILLED-IN ANCHOR.

UT AND PATCH EXISTING CEILING AND WALL CONSTRUCTION AS REQUIRED FOR ONDUIT, OUTLET BOX, SUPPORTS AND EQUIPMENT INSTALLATION. REPAIR OF EXISTING ONSTRUCTION SHALL MATCH EXISTING TO THE ARCHITECTS SATISFACTION.

ONDUIT CONNECTIONS TO MACHINES AND EQUIPMENT SUBJECT TO VIBRATION NCLUDING TRANSFORMERS) SHALL BE MADE WITH LFMC. PROVIDE SUFFICIENT SLACK O ELIMINATE VIBRATION. ARRANGE CONNECTIONS TO PREVENT THE ENTRANCE OF OISTURE. PROVIDE CONTINUOUS GROUND WIRE THROUGH LFMC TO ASSURE GROUND ONTINUITY. REFERENCE CEC 250.64 FOR GEC INSTALLATION.

OR PURPOSES OF CLEARNESS AND LEGIBILITY, THE ELECTRICAL DRAWINGS ARE SSENTIALLY DIAGRAMMATIC. THE SIZE AND LOCATION OF EQUIPMENT IS SHOWN TO CALE WHEREVER POSSIBLE. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS, DATA IFORMATION AS INDICATED ON THE DRAWINGS AND IN THE SPECIFICATION SECTIONS HERE ELECTRICAL WORK INTERFACES WITH OTHER TRADES.

LECTRICAL CONTRACTOR SHALL COMPLY WITH THE CALIFORNIA STATE HANDICAP LAWS /ITH REGARD TO THE FOLLOWING:

A. MOUNTING HEIGHT OF RECEPTACLES - NO OUTLET SHALL BE MOUNTED ON A WALL AT LESS THAN 18" AFF.

B. MOUNTING HEIGHT OF SWITCHES AND THERMOSTATS - DEVICES SHALL BE MOUNTED AT NO HIGHER THAN 48" AFF FROM CENTER OF DEVICE, BUT NOT LESS THAN 36" AFF.

13. THE CONTRACTOR SHALL MAINTAIN AS-BUILT DRAWINGS TO REFLECT ALL CHANGES MADE DURING CONSTRUCTION AND ANY DEVIATIONS FROM THE ELECTRICAL DRAWINGS. THIS INCLUDES DEVIATIONS FROM CIRCUIT NUMBERS AND ANY ADDITION, DELETION OR RELOCATION OF OUTLETS SHOWN ON WORKING DRAWINGS.

14. 2016 CBC MECHANICAL, ELECTRICAL AND PLUMBING EQUIPMENT ANCHORAGE NOTES:

ALL MECHANICAL, PLUMBING, AND ELECTRICAL COMPONENTS SHALL BE ANCHORED AND INSTALLED PER THE DETAILS ON THE OSHPD APPROVED CONSTRUCTION DOCUMENTS. WHERE NO DETAIL IS INDICATED, THE FOLLOWING COMPONENTS SHALL BE ANCHORED OR BRACED TO MEET THE FORCES AND DISPLACEMENT REQUIREMENTS PRESCRIBED IN THE 2016 CBC, SECTIONS 1616A.1.23, 1.24, 1.25, 1.26 AND ASCE 7-05 CHAPTER 13.

- A. ALL PERMANENT EQUIPMENT AND COMPONENTS.
- B. TEMPORARY OR MOVABLE EQUIPMENT THAT IS PERMANENTLY ATTACHED (E.G. HARD WIRED) TO THE BUILDING UTILITY SERVICES SUCH AS ELECTRICITY, GAS OR WATER.
- C. MOVABLE EQUIPMENT WHICH IS STATIONED IN ONE PLACE FOR MORE THAN 8 HOURS AND HEAVIER THAN 400 POUNDS ARE REQUIRED TO BE ANCHORED WITH TEMPORARY ATTACHMENTS.

THE ATTACHMENT OF THE FOLLOWING MECHANICAL AND ELECTRICAL COMPONENT SHALL BE POSITIVELY ATTACHED TO THE STRUCTURE, BUT NEED NOT BE DETAILED ON THE PLANS. 5. WHERE NEW WALL OR CEILING OR OTHER CONSTRUCTION WILL COVER EXISTING OUTLETS, THESE COMPONENTS SHALL HAVE FLEXIBLE CONNECTIONS PROVIDED BETWEEN THE COMPONENT AND ASSOCIATED DUCTWORK, PIPING, AND CONDUIT.

- A. COMPONENTS WEIGHING LESS THAN 400 POUNDS AND HAVE A CENTER OF MASS LOCATED 4 FEET OR LESS ABOVE THE ADJACENT FLOOR OR ROOF LEVEL THAT DIRECTLY SUPPORTS THE COMPONENT.
- B. COMPONENTS WEIGHING LESS THAN 20 POUNDS, OR IN THE CASE OF DISTRIBUTED SYSTEMS, LESS THAN 5 POUNDS PER FOOT, WHICH ARE SUSPENDED FROM A ROOF OR FLOOR OR HUNG FROM A WALL.

FOR THOSE ELEMENTS THAT DO NOT REQUIRE DETAILS ON THE APPROVED DRAWINGS, THE INSTALLATION SHALL BE SUBJECT TO THE APPROVAL OF THE STRUCTURAL ENGINEER OF RECORD. THE PROJECT INSPECTOR WILL VERIFY THAT ALL COMPONENTS AND EQUIPMENT HAVE BEEN ANCHORED IN ACCORDANCE WITH ABOVE REQUIREMENTS.

15. PIPING, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEM BRACING NOTES:

A. PIPING, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEMS SHALL BE BRACED TO COMPLY WITH THE FORCES AND DISPLACEMENTS PRESCRIBED IN ASCE 7-05 SECTION 13.3 AS DEFINED IN ASCE 7-05 SECTION 13.6.8, 13.6.7, 13.6.5.6, AND 2016 CBC, SECTIONS 1616A.1.23, 1.24, 1.25, 1.26.

B. THE BRACING AND ATTACHMENTS TO THE STRUCTURE SHALL BE DETAILED ON THE APPROVED DRAWINGS OR THEY SHALL COMPLY WITH ONE OF THE OSHPD PRE-APPROVALS (OPA #) AS MODIFIED TO SATISFY ANCHORAGE REQUIREMENTS OF ACI 318, APPENDIX D.

C. COPIES OF THE MANUAL SHALL BE AVAILABLE ON THE JOBSITE PRIOR TO THE START OF HANGING AND BRACING OF THE PIPE, DUCTWORK, AND ELECTRICAL DISTRIBUTION SYSTEMS.

D. THE STRUCTURAL ENGINEER OF RECORD SHALL VERIFY THE ADEQUACY OF THE STRUCTURE TO SUPPORT THE HANGER AND BRACE LOADS.

- 16. THE CONTRACTOR SHALL INSTALL ALL CONDUITS AND WIRES WITH A MINIMUM NUMBER OF BENDS AND IN SUCH A MANNER AS TO CONFORM TO THE STRUCTURE. AVOID OBSTRUCTIONS, PRESERVE HEAD ROOM, KEEP OPENINGS AND PASSAGEWAYS CLEAR AND MEET ALL STRUCTURAL CODE REQUIREMENTS.
- 17. PROVIDE TYPEWRITTEN DIRECTORY CARD IN ALL PANELS, IDENTIFY LOAD SERVED BY EACH CIRCUIT BREAKER.
- 18. EXPOSED CONDUITS BELOW 8 FEET SHALL BE RIGID GALVANIZED STEEL (RGS) UON.
- 19. REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATIONS OF CEILING MOUNTED FIXTURES.
- 20. ALL CONDUIT PENETRATIONS OF FIRE RATED WALLS, FLOORS AND ROOF SHALL BE FIRE STOPPED. FIRE STOP MATERIALS SHALL BE TESTED ASSEMBLY APPROVED BY THE OSHPD FIRE MARSHAL.
- 21. CONTRACTOR SHALL COMPLY WITH ALL GROUNDING AND BONDING REQUIREMENTS OF C.E.C. 517-13, 517-14, 517-19, 517-20, 517-78, 517-82.
- 22. LOCATIONS OF DISCONNECT SWITCHES AND CONNECTIONS FOR MECHANICAL AND PLUMBING EQUIPMENT ARE SHOWN DIAGRAMMATICALLY. VERIFY ACTUAL CONNECTION LOCATIONS WITH EQUIPMENT SHOP DRAWINGS AND LOCATE DISCONNECT SWITCHES TO PROVIDE CODE REQUIRED CLEARANCES AND ACCESS. PROVIDE ANGLE IRON SUPPORT BRACKETS.
- 23. THE CONTRACTOR SHALL OBTAIN BUILDING AND LICENSING PERMITS AND PAY ALL FEES, EXPENSES, AND INCIDENTAL COSTS ASSOCIATED WITH PROVIDING A COMPLETE AND OPERABLE INSTALLATION INCLUDING ALL CHARGES AND EXPENSES ASSOCIATED WITH FEDERAL, STATE, AND LOCAL AGENCIES.
- 24. THE CONTRACTOR SHALL COORDINATE HIS WORK WITH OTHER TRADES AND INCLUDE THE COSTS FOR SUCH COORDINATION IN THE BID.
- 25. THE CONTRACTOR SHALL PROVIDE AN AS-BUILT SET OF DOCUMENTS AT PROJECT COMPLETION SHOWING CHANGES TO THE CONTRACT DOCUMENTS.
- 26. THE CONTRACTOR SHALL PROVIDE CONNECTION AND TERMINATION TO OWNER FURNISHED EQUIPMENT.
- 27. REFERENCE CEC 110.16 AND 110.24. CONTRACTOR TO PROVIDE ARC FLASH LABELS ON ALL ELECTRICAL EQUIPMENT AFFECTED BY SCOPE OF WORK.

### **DEMOLITION NOTES**

DRAWINGS OF EXISTING CONDITIONS HAVE BEEN COMPILED FROM EXISTING DATA SUPPLIED BY THE OWNER TO THE ARCHITECT. THE ARCHITECT MAKES NO WARRANTY, EITHER EXPRESSED OR IMPLIED, FOR THE ACCURACY OR COMPLETENESS OF THE EXISTING INFORMATION RECORDED. FIELD VERIFY ALL EXISTING CONDITIONS NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES.

2. THE OWNER RESERVES THE RIGHT TO SALVAGE ANY DEMO ITEM. VERIFY ITEMS TO BE SALVAGED WITH THE OWNER PRIOR TO THE START OF DEMOLITION. REMOVE, PROTECT, AND TURN OVER SUCH ITEMS BY DIRECTED BY THE OWNER.

ALL EXISTING ELECTRICAL, LIGHTING, TELEPHONE, DATA, AND PUBLIC ADDRESS CONDUIT AND WIRING SHALL REMAIN EXCEPT WHERE INDICATED OTHERWISE ON THESE PLANS. RECONNECT EXISTING OUTLETS, DEVICES AND CIRCUITS IN ADJACENT SPACES DISRUPTED BY REMOVAL OF EXISTING OUTLETS, DEVICES OR CIRCUITS IN THIS CONTRACT.

4. PROTECT ALL EXISTING CONDUIT, WIRE AND SIGNAL SYSTEMS CABLES PASSING THRU REMODEL AREAS THAT SERVE ADJACENT AREAS.

EQUIPMENT OR DEVICES MAKING THEM INACCESSIBLE, RELOCATE THE EXISTING OUTLET, EQUIPMENT OR DEVICE AS REQUIRED OR MAKE OTHER PROVISIONS TO PROVIDE ACCESS.

RECONNECT EXISTING OUTLETS, LIGHTS, ETC. THAT ARE TO REMAIN THAT ARE DISRUPTED BY REMOVAL OF OTHER EXISTING OUTLETS IN THE CONDUIT RUN AS REQUIRED TO PROVIDE CONTINUITY OF THE CIRCUITS.

REMOVE ALL EXISTING CONDUITS IN CEILING SPACES FOR SYSTEMS, EQUIPMENT AND DEVICES OR OUTLETS BEING REMOVED THAT ARE NOT BEING REUSED AND ALL ABANDONED EXISTING CONDUITS. REMOVE ALL EXISTING CONDUITS IN WALLS OR FLOORS FOR DEVICES BEING REMOVED THAT INTERFERE WITH NEW CONSTRUCTION. REMOVE WIRE FROM ABANDONED CONDUITS.

8. REMOVE ALL ABANDONED SIGNAL SYSTEM CABLES IN CEILING SPACE.

9. THE WORD "ELECTRICAL" USED IN THE CONTEXT OF THESE DEMOLITION PLANS INCLUDES LIGHTING, ELECTRICAL DEVICES & EQUIPMENT, AND ALL SIGNAL SYSTEMS.

10. REFER TO LIGHTING, POWER & SIGNAL PLANS FOR ADDITIONAL EXISTING ELECTRICAL TO REMAIN.

11. WHERE EXISTING DEVICES OR EQUIPMENT ARE INDICATED TO BE REMOVED IN WALLS THAT ARE TO REMAIN, ALSO REMOVE OUTLET BOX OR BACKBOX AND PATCH WALL FINISH TO MATCH SURROUNDING AREA.

12. WHERE EXISTING OUTLETS ARE REMOVED AND THE EXISTING CIRCUIT IS NOT SERVING REMAINING OUTLETS. REMOVE EXISTING WIRE AND CONDUIT BACK TO THE SERVING PANELBOARD AND UPDATE THE PANELBOARD CIRCUIT DIRECTORY INDICATING "SPARE" FOR ALL UNUSED CIRCUIT BREAKERS.

### SITE MAP



PROJECT LOCATION -

### SHEET INDEX

	<u>SHEET</u>	DESCRIPTION
、 、	E0.1	GENERAL NOTES, LEGEND, AND SHEET INDEX
て	E0.2	PARTIAL SINGLE LINE DIAGRAM & SCHEDULE
{	E0.3	PANEL SCHEDULES & LOAD SUMMARIES
	ED2.1	PARTIAL DEMOLITION FLOOR PLANS
	E2.1	PARTIAL RENOVATION FLOOR PLANS

### 5 ARCHITE

5151 Shoreham Place, Suite 100 San Diego, Ca 92122

P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com

# TCMC PHARMACY **USP 800** UPGRADE

### 

	e, California 92056
OWNER:	TRI—CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940—7709
ARCHITECT:	SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299–3917 FAX(619)299–508-
MEP:	P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
STRUCTURAL:	SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438–1188
× No. C2 × No. C2 × No. C2 × OF OSHPD C ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓	Image: Sector of the sector
REV: DESCRIPT	TON: DATE: <b>P2S Engineering, Inc.</b> 9665 Chesapeake Dr., Suite #23 San Diego, CA 92123 T 619.618.2347 F 619.330.060 WWW p2seng.com
REV: DESCRIPT	Date:           Date:           Date:           Date:           Description           P2S Engineering, Inc.           9665 Chesapeake Dr., Suite #23           San Diego, CA 92123           T 619.618.2347           F 619.330.060           www.p2seng.com
REV: DESCRIPT CONSULTANT DOSHPD APPROVAL S' OSHPD #:	TON: DATE: <b>S P2S Engineering, Inc.</b> 9665 Chesapeake Dr., Suite #23 San Diego, CA 92123 T 619.618.2347 F 619.330.060 www.p2seng.com TAMP: S171641-37-00 <b>REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CR APPROVED with comments</b>
REV: DESCRIPT CONSULTANT DOSHPD APPROVAL SI OSHPD #: OSHPD #: KC I OF PL FACILIT	TON: DATE: <b>Son P2S Engineering, Inc.</b> 9665 Chesapeake Dr., Suite #23 San Diego, CA 92123 T 619.618.2347 F 619.330.060 www.p2seng.com TAMP: S S171641-37-00 REVIEWED IN ACCORDANCE WITH THE REQUIREMENTS OF T24, CR APPROVED with comments Huang, Sr. Architect fice of Statewide Health aning & Development IES DEVELOPMENT DIVISION
REV: DESCRIPT CONSULTANT CONSULTANT DOSHPD APPROVAL SI OSHPD #: OSHPD #: COSHPD #: COSHPD #: COSHPD #: COSHPD #: COSHPD #: COSHPD #: COSHPD COSH COSHPD COSH COSHP	NON:       DATE:         SS       P2S Engineering, Inc.         9665 Chesapeake Dr., Suite #23         San Diego, CA 92123         T 619.618.2347 F 619.330.064         www.p2seng.com         TAMP:         :       S171641-37-00         REVIEWED IN ACCORDANCE WITH         THE REQUIREMENTS OF T24, CCR         APPROVED         with comments         Huang, Sr. Architect         fice of Statewide Health         aning & Development         ES DEVELOPMENT DIVISION         OT/23/2018 08:10:09 AM         #[S171641-37-00]         AL NOTES,         O, SYMBOLS,         IEET INDEX

DRAWN BY: CHECKED B





TYPE	DESCRIPTION	TOTAL		LAMP	S	VOLTAGE	MTG.	REMARKS
R1 74	RECESSED FLANGED 1X4 CLEANROOM FIXTURE WITH PATTERN 12, 0.125" THICK ACRYLIC LENS, IP65 MINIMUM, COLD ROLLED STEEL HOUSING, DIE-FORMED STEEL OVERLAPPING DOOR, AND WHITE POWDER COAT FINISH. TWO (2) LED MODULES, STANDARD OUTPUT, 4000K. EATON FAIL-SAFE CLMF-12-4-OLS-A12125-LD4-2STD-40-UNV-EDC1	74	<u>-</u>	<u>V-A</u> 74	LED	UNV	R	NOTES 1, 2
R2 38	RECESSED FLANGED 2X2 CLEANROOM FIXTURE WITH PATTERN 12, 0.125" THICK ACRYLIC LENS, IP65 MINIMUM, COLD ROLLED STEEL HOUSING, DIE-FORMED STEEL OVERLAPPING DOOR, AND WHITE POWDER COAT FINISH. TWO (2) LED MODULES, HIGH OUTPUT, 4000K. EATON FAIL-SAFE CLMF-24-2-OLS-A12125-LD4-2HI-40-UNV-EDC1	38	-	38	LED	UNV	R	NOTES 1, 2
X1 3	LED EDGE LIT CEILING MOUNTED EXIT SIGN WITH 90-MIN INTEGRAL EMERGENCY BATTERY BACKUP. PROVIDE WITH INTEGRAL BATTERY TEST SWITCH. SIGN LETTER COLOR TO MATCH BUILDING STANDARD. PROVIDE DIRECTION ARROWS AS INDICATED ON DRAWINGS. 3VA,LED,120/277V,UNV, LITHONIA LPP 1-RC-120/277 ELN	3	-	3	LED	UNV	S	
D1 31	RECESSED 4" LED DOWNLIGHT. CLEAR TRIM, SEMI-SPECULAR FINISH. WET LOCATION LISTED, 3500K, 2500 LUMENS. LITHONIA #LDN4-35/25-L04-AR-LSS-MVOLT-WL	31	-	31	LED	UNV	R	
D2 21	RECESSED 4" LED DOWNLIGHT. CLEAR TRIM, SEMI-SPECULAR FINISH. WET LOCATION LISTED, 3500K, 1500 LUMENS. LITHONIA #LDN4-35/15-L04-AR-LSS-MVOLT-WL	21	-	21	LED	UNV	R	
	GENERAL NOTES:							ABBREVIATIONS
	1. ALL LUMINARIES SHALL MATCH EXISTING FIXTURE COLOR TEMPERATURE.							P = PENDANT R = RECESSED S = SURFACE W = WALL PO = POLE

KEY NOTES:

PROVIDE COMPLETE WITH ALL MOUNTING HARDWARE REQUIRED FOR A COMPLETE
1. INSTALLATION.
2. REFER TO ARCHITECTURAL PLANS FOR CEILING TYPE.





		S F E I R
	NOTES	5151 Shoreham Place, Suite 100
3	CONTRACTOR TO PROVIDE REPORT FROM OSHPD     IOR/ACO INDICATING THAT EXISTING AUTOMATIC     TRANSFER SWITCH AND DOWNSTREAM DISTRIBUTION IS     NON-SEGREGATED EMERGENCY BRANCH.	San Diego, Ca 92122 P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com
		TCMC PHARMACY USP 800 UPGRADE
		Tri-City Medical Center
<u>S:</u>		4002 Vista Way Oceanside, California 92056
		OWNER: TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056 TEL (760) 940-7709 ARCHITECT: SFEIR ARCHITECTS 5151 SHOREHAM PLACE, SUITE 100 SAN DIEGO, CALIFORNIA 92122 TEL(619)299-3917 FAX(619)299-5084
		MEP: P2S ENGINEERING, INC. 9665 CHESAPEAKE DRIVE, SUITE 230 SAN DIEGO, CA 92123 TEL(619)618–2347
		STRUCTURAL: SUN STRUCTURAL ENGINEERING 2091 LAS PALMAS DRIVE, SUITE D CARLSBAD, CA 92011 TEL(760)438-1188
N BOARD "DBH"		$\begin{array}{c} SED \\ K \\ SED \\ MICHAR $
		$\begin{array}{c ccccccccccccccccccccccccccccccccccc$
		CONSULTANT CONSULTANT CONSULTANT CONSULTANT P2S Engineering, Inc. 9665 Chesapeake Dr., Suite #230 San Diego, CA 92123 T 619.618.2347 F 619.330.0668 www.p2seng.com
		OSHPD #: S171641-37-00 REVIEWED IN ACCORDANCE WITH THE RE QUIREMENTS OF T24, COR APPROVED with comments KC Huang, Sr. Architect Office of Statewide Health
		Planning & Development FACILITIES DEVELOPMENT DIVISION 07/23/2018 08:10:09 AM #[ \$171641-37-00 ]
		PROJECT TITLE: TCMC USP 800
1		O1667.00       DRAWN BY:     EC       CHECKED BY:     RS       SCALE:     07/31/17
ans, graphic, electronic, or mechani	nical, including photocopying, recording, taping, or information and retrieval systems without written permission of 14 AO11090 C	ONSTRUCTION DOCUMENT

PANEL (E)EABL	_D)			1			1)					
VOLTAGE : 208/120 VOLTS BUS AMPS : 100 AMPS MAIN : 100A MCB BRANCH TYPE : EMERGENCY BRANCH	3 PHASE, 4 WIRE		A.I.C. RATING : 10kA LOCATION : PHARMACY 046 FED FROM : EA1L MOUNTING : FLUSH PANEL OPTIONS: -		VOLTAGE BUS AMPS MAIN BRANCH TYPE	(E)EABLA : 208/120 VOLTS : 225 AMPS : 150A MCB : EMERGENCY BRANCH	3 PHASE, 4 WIRE				A.I.C. RATING LOCATION FED FROM MOUNTING	j: 10kA J: PHARM J: EDBA G: FLUSH
LOAD TYPE LOAD SERVED	VOLT-AMPS     BKR/     BK       A     B     C     CKT	R/ VOLT-AMPS LE CKT A B C	LOAD SERVED LOAD TYPE		LOAD TYPE	LOAD SERVED	VOLT-AMPS     BKR       A     B     C     CKT	/ BKR E A B C POLI	/ VO Е СКТ А	B C	LOAD SERVED	LOA
ECEPTACLE       (E) COMPUTER MED REC.         -       (E) MEDICAL RECORDS         (E) HP PRINTER       (E) SPARE         (E) POWER POLE       (R) MEDICAL RECORDS         (R) MEDICAL RECORDS       (R) MEDICAL RECORDS         (E) PNEUMATIC SYSTEM       (E) DICTATION         (E) DICTATION       (E) DICTATION         (R) MEDICAL RECORDS       (R) MEDICAL RECORDS         (R) MEDICAL RECORDS	1       30/2       *       20,         3       -       -*-       20,         5       20/1      *       20,         7       20/1       *       20,         9       30/1       -*-       20,         11       20/1       *       20,         11       20/1      *-       20,         11       20/1      *-       20,         13       20/1      *-       20,         13       20/1      *-       20,         14       15       20/1      *-       20,         15       20/1      *-       20,         19       20/1      *-       20,         23       20/1      *       20,         25       20/1       *       20,         27       20/1       -*-       20,         29       20/1      *       20,         20       27       20/1      *       20,         20       29       20/1      *       20,         20       29       20/1      *       20,         20       29       20	/1       2         /1       4         /1       6         /1       8         /1       10         /1       10         /1       12         /1       12         /1       14         /1       14         /1       14         /1       16         /1       18         /1       16         /1       18         /1       20         /1       22         /1       24         /1       26         /1       28         /1       30         (E) S         /1       30         (E) S <th>(E) MEDICAL RECORDS (E) MEDICAL RECORDS (E) MEDICAL RECORDS (E) PEF (E) DOOR HOLDERS (E) PHARMACY (E) PHARMACY (E) PHARMACY (E) DOOR STRIKE SINGLE OUTLET SOUTH WALL (E) REF (E) MED REC OFFICE (E) OKI PRINTER SINGLE OUTLET SOUTH WALL (E) CONTRUCTION (E) OKI PRINTER (E) OKI PRINTE</th> <th>3 1 3 1 7 2 7 1 7 2</th> <th>MISC MISC MISC PANEL CALCULA LOAD TYPE: RECEPTACLE LIGHTING MOTOR MISC 0 ELEVATOR(S) 0 X-RAY(S)</th> <th>(E) LOAD [016] RM 030         (E) LOAD [009] RM 030         (E) LOAD [023] RM 030         (E) LOAD [023] RM 030         SPARE         REFRIGERATOR [005] RM 031         SPARE         U/C REF [006], REC RM 031,032         (E) LOAD [001,002,003] 031,032         (E) LOAD [001,002,003] 031,032         (E) LOAD [018,026,038] RM 032         (E) LOAD [018,026,038] RM 032         (E) LOAD         MEDICAL RECORDS         (E) LOAD         (E) LOAD         MEDICAL RECORDS         (E) LOAD         MEDICAL RECORDS         (E) LOAD         MEDICAL RECORDS         SPACE         SPACE         SPACE         SPACE         SPACE         3,444         0         0         0         0         0         0         0         0         0         0         0</th> <th>Image: state of the state</th> <th>*       20/1         - * -       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       -         *       20/1         *       -         *       20/1         *       -         *       20/1         *       -         *       20/1         *       -         *       20/1</th> <th>2    </th> <th>540 540 540 180 180 455 455 455 455 455 455 455 455 455 45</th> <th>(E) LOA (E) LOA (E) LOA (E) LOA LAB FREEZER [013] RM 04 PYXIS SUPPLY [010,011] RM 04 MEDICAL RECORD (E) LOA (E) LOAD + PRINTER [02 (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) DA (E) LOA (E) LOA (E)</th> <th>.D         .D         .D         .D         .ID         .ID         .ID         .S         .S         .JD         .S         .JD         .S         .JD         .S         .JD         .S         .JD         .S         .JD         .S         .32         .JD         .S         .32         .JD        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        O         KVA        O      <trtr>      O</trtr></th>	(E) MEDICAL RECORDS (E) MEDICAL RECORDS (E) MEDICAL RECORDS (E) PEF (E) DOOR HOLDERS (E) PHARMACY (E) PHARMACY (E) PHARMACY (E) DOOR STRIKE SINGLE OUTLET SOUTH WALL (E) REF (E) MED REC OFFICE (E) OKI PRINTER SINGLE OUTLET SOUTH WALL (E) CONTRUCTION (E) OKI PRINTER (E) OKI PRINTE	3 1 3 1 7 2 7 1 7 2	MISC MISC MISC PANEL CALCULA LOAD TYPE: RECEPTACLE LIGHTING MOTOR MISC 0 ELEVATOR(S) 0 X-RAY(S)	(E) LOAD [016] RM 030         (E) LOAD [009] RM 030         (E) LOAD [023] RM 030         (E) LOAD [023] RM 030         SPARE         REFRIGERATOR [005] RM 031         SPARE         U/C REF [006], REC RM 031,032         (E) LOAD [001,002,003] 031,032         (E) LOAD [001,002,003] 031,032         (E) LOAD [018,026,038] RM 032         (E) LOAD [018,026,038] RM 032         (E) LOAD         MEDICAL RECORDS         (E) LOAD         (E) LOAD         MEDICAL RECORDS         (E) LOAD         MEDICAL RECORDS         (E) LOAD         MEDICAL RECORDS         SPACE         SPACE         SPACE         SPACE         SPACE         3,444         0         0         0         0         0         0         0         0         0         0         0	Image: state of the state	*       20/1         - * -       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       20/1         *       -         *       20/1         *       -         *       20/1         *       -         *       20/1         *       -         *       20/1         *       -         *       20/1	2	540 540 540 180 180 455 455 455 455 455 455 455 455 455 45	(E) LOA (E) LOA (E) LOA (E) LOA LAB FREEZER [013] RM 04 PYXIS SUPPLY [010,011] RM 04 MEDICAL RECORD (E) LOA (E) LOAD + PRINTER [02 (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) LOA (E) DA (E) LOA (E)	.D         .D         .D         .D         .ID         .ID         .ID         .S         .S         .JD         .S         .JD         .S         .JD         .S         .JD         .S         .JD         .S         .JD         .S         .32         .JD         .S         .32         .JD        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        D        O         KVA        O <trtr>      O</trtr>
X-RAY(S) 0 5% OF LARGEST MOTOR	PER CEC ART. 517.73(2) 0 VA 0 VA	SPARE CAPACITY PANEL AMPS	0% 0 AMPS		25% OF LARGES PROJECT NAME PROJECT #: 201 <b>LOAD SUMN</b> 72-HR METER RI DATE OF RE <b>REMOVED LOA</b> CKT #8 CKT #9 CKT #10 CKT #10 CKT #12 CKT #13 CKT #13 CKT #14 CKT #15 <b>ADDED LOAD</b> <b>TOTAL LOAD (H</b> TOTAL LOAD (A MAIN BUS RATH	ST MOTOR         1: TCMC USP 800         7-8730         MARY: (E)EABLA         EADING X 1.25         CORDING: (5/9/17 - 5/11/17)         D         (VA)         ) @       208/120 VOLTS         NG / MAIN CB RATING	= 24.7  KVA $= 0.96  KVA$ $= 0.54  KVA$ $= 1.04  KVA$ $= 1.04  KVA$ $= 0.96  KVA$ $= 0.96  KVA$ $= 0.54  KVA$ $= 0.54  KVA$ $= 4.2  KVA$ $= 63  A$ $= 150  A$	0 VA	OAD SUMM/ ETER RECORDIN DATE OF RECO EMOVED LOAD DDED LOAD OTAL LOAD (KV OTAL LOAD (A) @ AIN BUS RATING	ARY: (E)DIS NG X 1.25 DRDING: (5/9/1 / / / / / / / / / / / / / / / / / /	1 T BOARD EDBA 17 - 5/11/17) = 208/120 VOLTS ATING =	= 54 = 6.1 = 4.1 = 14 = 40

PANEL:														
VOLTAGE BUS AMPS MAIN BRANCH TYPE	: 208/120 VOLTS : 100 AMPS : 100A MCB : EMERGENCY BRANCH	3 PHAS	e, 4 wire	Ξ									A.I.C. RATING : LOCATION : FED FROM : MOUNTING : PANEL OPTIONS:	10kA PHARMACY 0 EA1L FLUSH -
		V A	OLT-AM B	PS C	скт	BKR/	ABC	BKR/	СКТ		OLT-AM B	PS C	LOAD SERVED	
RECEPTACIE			-	-	1	30/2	*	20/1	2		1	-		20/10/11
	-				3		_ * _	20/1	<u></u> Δ				(E) MEDICAL RECORDS	
	(E) MEDICAL RECORDS	-			5	20/1	*	20/1	6				(E) MEDICAL RECORDS	
	(E) HP PRINTER				7	20/1	*	20/1	8				(E) RFF	
6 MOTOR	(E) FAN FILTER FF-7		1.176		9	20/1	_ * _	20/1	10				(E) DOOR HOLDERS	
	(E) POWER POLE		.,,,,,		11	20/1	*	20/1	12				(E) PHARMACY	
MOTOR	(E) FAN FILTER FF-8	1.176			13	20/1	*	20/1	14				(E) PHARMACY	
	(E) FAN FILTER FF-3	1,1,0	1.176		15	20/1	_ * _	20/1	16				(E) MED REC LOUNGE	
MOTOR	(E) FAN FILTER FF-5			1 1 7 6	17	20/1	*	20/1	18				(E) PHARMACY	
	(E) PNEUMATIC SYSTEM				19	20/1	*	20/1	20				(E) DOOR STRIKE	
******					21	20/1	_ * _	20/1	22				(E) SINGLE OUTLET SOUTH WALL	
					23	20/1	*	20/1	24				(E) REF	
MOTOR	(E) FAN FILTER FF-2	1.176			25	20/1	*	20/1	26				(E) MED REC OFFICE	
KMOTOR	(E) FAN FILTER FF-6		1.176		27	20/1	_ * _	20/1	28				(E) OKI PRINTER	
MOTOR	(E) CAV-1,CAV-2,CAV-4			300	29	20/1	*	20/1	30				(E) SINGLE OUTLET SOUTH WALL	
4														
PANEL CALCULA	TIONS:		******						LOA	D SUMM	ARY:		⊈	
LOAD TYPE:	LOAD (VA)	DEMAN	ID FACT	OR		DEMA		D	PHA	SE A			2.4	KVA
RECEPTACLE	0	PER CEC	CART. 22	20.44			0	VA	РНА	SE B			3.5	KVA
LIGHTING	0	125%					0	VA	РНА	SE C			1.5	KVA
MOTOR	7,356	100%					7,356	VA						
MISC	0	100%					0	VA	тот	AL CONN	VECTED	LOAD	7.4	KVA
	0	0%					0	VA	тот	AL DEMA	AND LOA	AD	7.7	KVA
0 ELEVATOR(S)	0	0%					0	VA	LINE	-TO-LINE	VOLTA	GE	208	VOLTS
0 X-RAY(S)	0	PER CEC	CART. 51	7.73(2)			0	VA	SPA	RE CAPA	CITY		0%	
25% OF LARGES	TMOTOR			. ,			294	VA	PAN	FL AMPS			21 /	AMPS

102		
	mment 0092 - LAFDD (NTiubun)	
	(7/23/2018) Use Equipment Branch for HVAC equipment (fan filters and CAVs) [CEC 517.34 (B)(1.1)]	
	Based that the existing panel schedule "EABL" is segregated to "Critical Branch" based on the loads even do it is fed from a single ATS. This is in compliance with OSHPD CAN 2-102.6 requirements that a panel connected to non- segregated ESS shall be segregated at the panel board level. Adding the new HVAC equipment to this panel will not comply with the OSHPD CAN 2-102.6. Please coordinate with ACO and IOR for the field verification of this panel to resolve this issue.	
	LOAD SUMMARY: (E)EABL	
	72-HR METER READING X 1.25	(/10/10)
	DATE OF RECORDING: (6/19/18	- 6/ 19/ 18)

72-HR METER READING X 1.25	=	18.6	KVA
DATE OF RECORDING: (6/19/18 - 6/19/18)			
REMOVED LOAD	=	0.0	KVA
ADDED LOAD	=	7.7	KVA
TOTAL LOAD (KVA)	=	26	KVA
TOTAL LOAD (A) @ 208/120 VOLTS	=	73	А
MAIN BUS RATING / MAIN CB RATING	=	100	А

### LOAD SUMMARY: (E)DIST BOARD EA1L

METER RECORDING X 1.25 DATE OF RECORDING: (6/19/18 - 6/19/18) REMOVED LOAD

ADDED LOAD

TOTAL LOAD (KVA) TOTAL LOAD (A) @ 208/120 VOLTS MAIN BUS RATING / MAIN CB RATING



		SFEIR ARCHITECTS
	NOTES	
A.I.C. RATING : 10kA LOCATION : PHARMACY 046 FED FROM : EDBA MOUNTING : FLUSH PANEL OPTIONS: - O SERVED LOAD TYPE (E) LOAD	<ol> <li>UTILIZE (E) 20A, 1P CIRCUIT BREAKER FOR NEW LOADS.</li> <li>PROVIDE NEW 20A, 1P CIRCUIT BREAKER IN EXISTING SPACE. MANUFACTURER AND KAIC RATING SHALL MATCH EXISTING.</li> <li>CIRCUIT BREAKER RENDERED SPARE AS RESULT OF WORK.</li> </ol>	5151 Shoreham Place, Suite 100 San Diego, Ca 92122 P: 619-299-3917 F: 619-299-5084 www.sfeirarch.com
(E) LOAD         (E) LOAD         (E) LOAD         EZER [013] RM 046         MISC         '[010,011] RM 046         MISC         'EDICAL RECORDS         (E) LOAD         D + PRINTER [025]         RECEPTACLE         (E) LOAD         EDICAL RECORDS         (E) LOAD         D + PRINTER [025]         RECEPTACLE         (E) LOAD         IEDICAL RECORDS         (E) LOAD         (E) LOAD         (E) LOAD         (E) LOAD         (E) LOAD	<ul> <li>PROVIDE NEW 20A, 2P CIRCUIT BREAKER IN EXISTING SPACE. MANUFACTURER AND KAIC RATING SHALL MATCH EXISTING.</li> <li>EXISTING BRANCH CIRCUIT WIRING TO BE INTERCEPTED IN CEILING ABOVE PANEL AND RE-CONNECTED TO EXISTING CRITICAL BRANCH PANEL EABLA.</li> <li>REPLACE 30A, 1P CIRCUIT BREAKER WITH NEW 20A, 1P CIRCUIT BREAKER. MANUFACTURER AND KAIC RATING SHALL MATCH EXISTING.</li> <li>TERMINATE EXISTING 2#12, 1#12, 3/4"C FROM CEILING SPACE ABOVE PANEL EABL TO NEW CIRCUIT LOCATION IN PANEL EABLA.</li> </ul>	PHARMACY USP 800 UPGRADE
(E) LOAD         BSC FAN @ ROOF         -         -         (E) LOAD         SPACE         SPACE         SPACE         SPACE         1.0 KVA         1.4 KVA         1.6 KVA         4.1 KVA         4.2 KVA         208 VOLTS         0%         12 AMPS             BA             =       54.0 KVA             BA             =       54.0 KVA             BA             =       54.0 KVA             =       54.0 KVA		<section-header><section-header><section-header><form></form></section-header></section-header></section-header>
= 7.65 KVA = 109 A = 400 A		<text><text><text><text><text><text><text><text><text><text><text><text><text></text></text></text></text></text></text></text></text></text></text></text></text></text>







#### OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT

**FACILITIES DEVELOPMENT DIVISION** – www.oshpd.ca.gov/fdd 400 R Street, Suite 200 ~ Sacramento, California 95811 700 N. Alameda Street, Suite 2-500 ~ Los Angeles, California 90012

Phone (916) 440-8300 Phone (213) 897-0166 FAX (916) 324-9188 FAX (213) 897-0168

### Testing, Inspection and Observation Program

2016 California Building Standards Code - OSHPD 1

This program is prepared and submitted for an OSHPD 1 project. OSHPD 1 projects include all construction and remodel projects for general acute-care hospitals and acute psychiatric hospitals. OSHPD 1 projects also include construction and remodel of skilled nursing facilities and/or intermediate care facilities except those of single-story, Type V, wood or light steel-frame construction.

SECTIC	ON A	PROJECT INFORMATION							
Facility #:	Fac	cility Name:		Project #:	Sub #:				
12372	Tri City	Medical Center		S171641-37-00					
Street Address:	4002 Vista Way								
City:	Oceanside	County:	San Diego						
Record Name	e (Scope of Project):	USP 800							
Abbreviations: CAC: California A	dministrative Code CBC: California Building Cod	e RDP: Registered	d Design Professional		Version: R02.3				



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENTFACILITIES DEVELOPMENT DIVISION – www.oshpd.ca.gov/fdd400 R Street, Suite 200 ~ Sacramento, California 95811Phone (916) 4700 N. Alameda Street, Suite 2-500 ~ Los Angeles, California 90012Phone (213) 8

Phone (916) 440-8300 Phone (213) 897-0166

FAX (916) 324-9188 FAX (213) 897-0168

#### **Testing, Inspection and Observation Program**

2016 California Building Standards Code - OSHPD 1

	SI	EC	ΓΙΟΝ Β	NOTE: A evaluate	Approved agencies, individuals, and all changes to the TIO program shall be ad by the DPOR and approved by OSHPD prior to proceeding with the related	identified, d work.
	Facili	ity #:	Faclity Name:		Project #:	Sub #:
	12	2372	Tri City Medical Center		S171641-37-00	0
	Dl	<u>JRIN</u>	G CONSTRUCTION DOCUMENT SUBMITTAL		DURING CONSTRUCTION	
	Index #	REQUIRED (Select)	TESTS	PERFORMED OFF-SITE	RESPONSIBLE APPROVED AGENCY AND/OR INDIVIDUAL	OSHPD/FDD USE
STR	JCT	<b>FURA</b>	AL TESTS			
С	onci	rete				
	B-C15	х	Post-installed anchors CBC 1910A.5 Installation verification test			DSE:
ELEC	CTR	ICAL	TESTS			
	B-E10	х	Conductor Insulation Resistance Test CEC 110.3 (A)(4) & 110.7			CO:
	B-E11	х	Continuity, Polarity and Retention Test - Receptacles CEC 200.11, NFPA 99-2012 6.3.2.2.6.3			CO:
MEC	ЭНА	NIC	AL TESTS			
	B-ME7	х	<b>Hydronics</b> CMC 1205.2, 1220.3.6 & 1221.3 Pressure test of steam and water piping		TBD	CO:
	B-ME9	х	Ventilation system CMC 407.3.1 & Table 4-A Areas tested and balanced		твр	CO:
PLU	MB	ING	TESTS	II		
	B-P1	Х	Disinfection of potable water systems CPC 609.9			CO:
	B-P4	х	Existing sewers and drains CPC 102.4.1, 105.3 & 712.0 Tested for conformance with requirements for new work			CO:
	B-P5	х	Water supply system CPC 105.3 & 609.4 Pressure tested prior to covering or concealment			CO:
	B-P6	х	Plumbing, drainage, and venting systems CPC 105.3 & 712.0 Water or air tested prior to use, covering or concealment			CO:
	B-P7	х	<b>Building sewer</b> CPC 105.3, 712.0 & 723.0 Water or air tested prior to use, covering or concealment			CO:
	B-P12	х	<b>Defective systems</b> CPC 105.3.1 Air test of defective drainage and plumbing systems			CO:
	B-P13	х	Moved structures CPC 102.7 All parts of plumbing systems tested			CO:
	B-P14	х	Retesting CPC 105.3.2 Retest after corrections			CO:
FIRE	PR	OTE	CTION EQUIPMENT TESTS			
	B-FP1	х	Fire Alarm CFC 901.5 & CFC 907.7 NFPA 72-2016 §14.4 Acceptance and Reacceptance Testing			FLSO:
	B-FP5	х	Fire sprinkler CFC 901.5 & NFPA 13-2016 Chapter 25 Acceptance testing – Aboveground piping			FLSO:



#### OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION – www.oshpd.ca.gov/fdd

**FACILITIES DEVELOPMENT DIVISION** – www.oshpd.ca.gov/fdd 400 R Street, Suite 200 ~ Sacramento, California 95811 700 N. Alameda Street, Suite 2-500 ~ Los Angeles, California 90012

Phone (916) 440-8300 Phone (213) 897-0166

FAX (916) 324-9188 FAX (213) 897-0168

#### Testing, Inspection and Observation Program

2016 California Building Standards Code – OSHPD 1

	S	EC		NOTE: A evaluate	pproved agencies, individuals, and all changes to the TIO program d by the DPOR and approved by OSHPD prior to proceeding with t	n shall be id the related	dentified, work.				
	Facili	ity #:	Faclity Name:		Project #:		Sub #:				
	12	2372	Tri City Medical Center	S171641-37-00 0							
	D	JRIN	G CONSTRUCTION DOCUMENT SUBMITTAL		DURING CONSTRUCTION						
	Index #	REQUIRED (Select)	SPECIAL INSPECTIONS	PERFORMED OFF-SITE	RESPONSIBLE APPROVED AGENCY AND/OR INDIVIDUAL	COMPLIANCE VERIFICATION BY IOR	OSHPD/FDD USE				
STR	UCT	TURA	L SPECIAL INSPECTIONS								
C	onc	rete									
_	c-c5	х	Concrete CBC 1705A.3 CIP & Post-installed anchors				DSE:				
s	teel										
	C-S1	Х	<b>Steel</b> CBC 1705A.2 & 1705A.12.1 Steel shop fabrication				DSE:				
r	lons	tructu	ral components, supports and attachments								
	C-N1	Х	Architectural components CBC 1705A.12.5 & 1705A.16 Cladding, nonbearing walls and veneer				CO:				
	C-N2	х	<b>Ceiling</b> CBC 1705A.12.5 Suspended ceiling systems and their anchorage				CO:				
FIRE	PR	OTE	CTION SPECIAL INSPECTIONS								
	C-FP3	Х	Penetration firestops CBC 1705A.17.1 Penetration firestop systems that are tested and listed				FLSO:				
OTH	ER	SPEC									
	с-отз	Х	Signs and/or Identification devices. CBC 11B-703.1.1.2 Information, appearance, location and Braille.								
	C-0T4	Х	Glass and Glazing identification CBC 2403.1 Manufacturer's Material Mark Inspection								



#### OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT

**FACILITIES DEVELOPMENT DIVISION** – www.oshpd.ca.gov/fdd 400 R Street, Suite 200 ~ Sacramento, California 95811 700 N. Alameda Street, Suite 2-500 ~ Los Angeles, California 90012

Phone (916) 440-8300 Phone (213) 897-0166 FAX (916) 324-9188 FAX (213) 897-0168

#### **Testing, Inspection and Observation Program**

2016 California Building Standards Code – OSHPD 1

SECTION D			CONSTRUCTION VERIFICATION							N		
Facility #:	Faclity Na	ame: Project #:					Sub #:					
12372	Tri City Medica	cal Center \$171641-37-00										
	VERIFIED CONSTRUCTION INSPECTION AND OBSERVATION REPORTING											
Reference	PROJECT MILESTONE OR INTERVAL	VERIFIED COMPLIANCE REPORT REQUIRED AS INDICATED (Form OSH-FD-123) (See "PERSONAL KNOWLEDGE" as defined in California Administrative Code, Section 7-151)					Code,	FOR OSHPD USE ONLY				
		GEOR	AOR	SEOR	MEOR	EEOR	CONT	IOR	SP INSP	TEST LAB		OSHPD FDD
	PROJECT COMPLETION		х	х	х	х	х	х				



#### OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT

FACILITIES DEVELOPMENT DIVISION -- www.oshpd.ca.gov/fdd 400 R Street, Suite 200 ~ Sacramento, California 95811 700 N. Alameda Street, Suite 2-500 ~ Los Angeles, California 90012

Phone (916) 440-8300 Phone (213) 897-0166

FAX (916) 324-9188 FAX (213) 897-0168

### **Testing, Inspection and Observation Program** 2016 California Building Standards Code – OSHPD 1

OF OLIOI	IF P	LAN RI	EVIEW AP	PROVAL		
Facility #	: Facility Name:			Project #:		Sub #:
12372	Tri City Medical Cer	iter		S171641-37-00		
NOTE: For	testing, Inspection and Observation Program Ins	tructions, visit o	our website: http://osl	npd.ca.gov/FDD/Plan	Review/TIO.h	tml#TIO
Submitted by: I have reviewed th as "required" on th	ne approved construction documents for th nis form.	is project and	all tests and specia	al inspections requ	uired by Cod	e are marked
Joseph Sfeir			t	10/26,	17	10/26/17
Architect/Engineer of I	Record (Print Name)	/	Architect/Enginee	of Record (Signature	)	Date
Changhua S	Sun	-	Clyh	n An	~	5/16/18
Structural Engineer of	Record (Print Name)		Structural Enginee	er of Record (Signature	e)	Date
	FO	R OSHPD USE	ONLY	1		-Statio
DSHPD Plan Approv Name Comments:	REVIEWED IN ACCORDANCE WIT THE REQUIREMENTS OF T24, CCI APPROVED KC Huang, Sr. Archited July 23, 2018	H t t	A	AC	D	



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENTFACILITIES DEVELOPMENT DIVISION – www.oshpd.ca.gov/fdd400 R Street, Suite 200 ~ Sacramento, California 95811Phone (916) 4700 N. Alameda Street, Suite 2-500 ~ Los Angeles, California 90012Phone (213) 8

Phone (916) 440-8300 Phone (213) 897-0166

FAX (916) 324-9188 FAX (213) 897-0168

### **Testing, Inspection and Observation Program** 2016 California Building Standards Code – OSHPD 1

SECTION G	BUILDING	PERMIT APPROVAL	
Facility #:	Faclity Name:	Project #:	- Sub #:
12372	Tri City Medical Center	S171641-37-00	
NOTE: For testing, Inspect	ion and Observation Program Instructions, visit o	our website: http://oshpd.ca.gov/FDD/Plan_Revi	ew/TIO.html#TIO
Samples of Test and Inspect	tion Reports are: (NOT required for tests p	erformed by laboratories approved throug	h OPAA Program)
To be provided following of prior to proceeding with the	determination of the responsible firm(s) or indiv a work that requires tests or special inspections	idual(s). Samples shall be submitted to and a	approved by the Office,
Not applicable. Project ha	as no required tests or special inspections.		
Required test and inspection and inspections. If not desig	n reports shall be prepared and submitted to gnated, all reports shall be submitted to the	OSHPD/FDD within days of the com Office within 15 calendar days.	pletion of all tests
In addition to the preprinted te indicated: Other Tests	sts and special inspections identified on this for	m, this program includes additional tests and	special inspections as
Other Special Inspections			
<ul> <li>1703A.1.1:</li> <li>Verification of independen In accordance with the C/</li> <li>Testing agency qualification</li> <li>Inspection agency qualific</li> <li>This program has been prep projects for general acute cas skilled nursing facilities and Submitted by:</li> </ul>	nce and acceptance of test and inspection ager AC Section 7-141. on for approval or approval of testing agencies ration for approval. ared and submitted for an OSHPD 1 project are hospitals and acute psychiatric hospitals for intermediate care facilities except those	cies by Registered Design Professional (RDF through OPAA program. OSHPD 1 projects include all constructions. OSHPD 1 projects also include constructions of single-story, Type V, wood or light stee	<sup>D</sup> ) in responsible charge on and remodel ction and remodel of I-frame construction.
Joseph Sfeir	C28543		10/17/2017
Architect/Engineer of Record (Print Nar	me) Professional License #	Architect/Engineer of Record (Signature)	Date
	FOR OSHPD USE	ONLY	
OSHPD TI&O Program Approval:			
Name	Date	A AC	D
Comments:			

## TCMC PHARMACY USP 800 UPGRADE

### **Tri-City Medical Center**



Office of Statewide Health Planning & Development FACILITIES DEVELOPMENT DIVISION 4002 Vista Way Oceanside, California 92056

### SPECIFICATIONS

SA PROJECT NO. 01667.00 OSHPD #S171641-37-00 07/27/2017 DELTA 1 - OSHPD COMMENTS – 10-09-2017 DELTA 2 - DESIGN CHANGES – 10-09-2017 DELTA 3 - OSHPD COMMENTS – 12-11-2017 DELTA 4 - DESIGN CHANGES – 12-11-2017



A R C H I T E C T S, INC.

5151 Shoreham Place, Suite 100 San Diego, California 92122

> P: 619 299 3917 F: 619 299 5084

www.sfeirarch.com

#### PROJECT DIRECTORY

TCMC PHARMACY USP 800 UPGRADE TRI-CITY MEDICAL CENTER OCEANSIDE, CALIFORNIA 92056	
Tri-City Healthcare District 4002 Vista Way Oceanside, California 92056 Tel: 760.940.7709 Fax: 760.940.3435	Owner
S F E I R Architects 5151 Shoreham Place, Suite 100 San Diego, California 92122 Tel: 619.299.3917 Fax: 619.299.5084 Contacts: Michael Kosen - <u>mkosen@sfeirarch.com</u> Joseph Sfeir - <u>jmsfeir@sfeirarch.com</u>	Architect
SUN Structural Engineering, Inc. 2091 Las Palmas Drive, Suite D Carlsbad, California 92011 Tel: 760.438.1188 Fax: 760.438.1180 Contact: Chang Hua Sun – <u>sunengineering@sbcglobal.net</u>	Structural Engineer
P2S Engineering, Inc. 9665 Chesapeake Drive, Suite 230 San Diego, California 92123 Tel: 619.618-2347 Fax: 619.330.0668 Contact: Peter Luster - <u>paul.luster@p2seng.com</u>	Mechanical, Plumbing, and Electrical Engineer
Specifications Consultants, Inc. PO Box 3010 Colorado Springs, Colorado 80934 Tel: 719.577.9414 Fax: 719.623.0172 Contact: Paul DeArment - <u>pdearment@specscons.com</u>	Specifications Consultant

END OF PROJECT DIRECTORY

TCMC PHARMACY USP 800 UPGRADE TRI-CITY MEDICAL CENTER OCEANSIDE, CALIFORNIA 92056

ARCHITECT-OF-RECORD'S SEAL



ELECTRICAL ENGINEER-OF-RECORD'S SEAL



#### TCMC PHARMACY USP 800 UPGRADE TRI-CITY MEDICAL CENTER 4002 VISTA WAY OCEANSIDE, CALIFORNIA 92056

#### SPECIFICATIONS 07/27/2017 DELTA 3 - OSHPD COMMENTS 12/11/2017 DELTA 4 – DESIGN CHANGES 12/11/2017

#### TABLE OF CONTENTS

#### SPECIFICATIONS GROUP

		Pages	<u>Revision</u>
GENERAL RI	EQUIREMENTS SUBGROUP:		
DIVISION 01	GENERAL REQUIREMENTS		
01 10 00	Summary	1-4	
01 25 00	Substitution Procedures	1-2	
01 26 00	Contract Modification Procedures	1-2	
01 29 00	Payment Procedures	1-4	
01 31 13	Project Coordination	1-2	
01 31 19	Project Meetings	1-2	
01 33 00	Submittal Procedures	1-6	
01 35 16	Alteration Project Procedures	1-4	
01 41 00	Regulatory Requirements	1-2	
01 42 00	References	1-4	
01 45 20	Quality Control Services	1-3	
01 50 00	Temporary Facilities and Controls	1-4	
01 60 00	Product Requirements	1-3	
01 61 65	Low-Emitting Material Requirements	1-4	Delta 4
01 64 00	Owner-Furnished Products	1-2	
01 71 16	Acceptance of Conditions	1-2	
01 73 19	Installation	1-2	
01 73 29	Cutting and Patching	1-2	
01 77 00	Closeout Procedures	1-4	
01 78 36	Warranties	1-2	

#### FACILITY CONSTRUCTION SUBGROUP:

<i>DIVISION 02</i> 02 41 19 02 42 00	EXISTING CONDITIONS Selective Demolition Removal and Salvage of Construction Materials	1-5 1-2	Delta 3
DIVISION 03 03 20 00 03 30 53 03 62 00	CONCRETE Concrete Reinforcing Miscellaneous Cast-in-Place Concrete Non-Shrink Grouting	<mark>1-3</mark> 1-4 1-3	Delta 3 Delta 3

DIVISION 04 MASONRY - Not Used

I

1

DIVISION 05	5 METALS		
05 05 19	Post-Installed Concrete Anchors	1-5	
05 12 53	Miscellaneous Structural Steel	1-4	
05 40 00	Cold-Formed Metal Framing	1-2	
05 50 00	Metal Fabrications	1-5	Delta 4
DIVISION 06	WOOD, PLASTICS AND COMPOSITES		
06 10 53	Miscellaneous Rough Carpentry	1-3	
06 16 63	Cementitious Sheathing	1-2	
<del>06-41-00</del>	Architectural Wood Casework	<u> </u>	Delta 3
DIVISION 07	THERMAL AND MOISTURE PROTECTION		
07 02 52	Cutting and Patching of Modified Bituminous Membrane Roofing	1-6	
07 26 16	Below-Grade Vapor Retarders	1-4	Delta 3
07 60 00	Flashing and Sheet Metal	1-3	Delta 4
07 71 41	Manufactured Roof Penetration Seals	1-3	
07 84 00	Firestopping	1-5	
07 92 00	Joint Sealants	1-6	Delta 4
DIVISION 08	OPENINGS		Delte 4
08 11 13	Hollow Metal Doors and Frames	1-4	Delta 4
$\frac{1001213}{1001416}$	Hollow Metal Frames		Delta 3
09 21 00	Access Deere and Penele		Deita 3
08 56 10	Access Doors and Parleis	1 2	
08 50 19	Pass Willows	1-3	Dolta 3
08 80 00	Glazing	1-20 1-4	Dena 5
00 00 00	Glazing		
DIVISION	) FINISHES		
09 05 61	Common Work Results for Flooring Preparation	1-9	
09 21 16	Gypsum Board Assemblies	1-10	
09 28 13	Cementitious Backing Boards	1-3	
09 30 00	Tiling	1-10	Delta 3
09 51 13	Acoustical Panel Ceilings	1-4	
09 65 13	Resilient Base and Accessories	1-2	
09 65 16	Resilient Sheet Flooring	1-5	
09 81 16	Acoustic Blanket Insulation	1-2	
09 91 23	Interior Painting	1-7	Delta 4
DIVISION 10	) SPECIALTIES		
10 14 10	Interior Signage	1-3	Delta 3
10 26 13	Corner Guards	1-2	Delta 4
10 26 23	Protective Wall Covering	1-3	
10 28 13	Toilet Accessories	1-2	Delta 3
DIVISION 11	EQUIPMENT		
11 00 00	Equipment	1-3	
DIVISION 12	C FURNISHINGS	4.0	
12 31 00	Matal Cauntartana	1-6	
12 30 10	Simulated Stope Countertane	1-4	Delte 2
12 30 01	- Simulated Stone Countertops		Deita 3

DIVISION 13 SPECIAL CONSTRUCTION - Not Used

DIVISION 14 CONVEYING EQUIPMENT - Not Used

DIVISIONS 15 TO 19 - Reserved

#### FACILITY SERVICES SUBGROUP:

#### DIVISION 20 - Reserved

DIVISION 21 FIRE SUPPRESSION - Not Used

DIVISION 22	PLUMBING	
22 05 00	Common Work Results For Plumbing	1-11
22 05 23	General-Duty Valves For Plumbing Piping	1-13
22 05 29	Hangers And Supports For Plumbing Piping and Equipment	1-11
22 05 53	Identification For Plumbing Piping And Equipment	1-5
22 07 00	Plumbing Insulation	1-28
22 11 16	Domestic Water Piping	1-17
22 11 19	Domestic Water Piping Specialties	1-13
22 13 16	Sanitary Waste And Vent Piping	1-11
22 13 19	Sanitary Waste Piping Specialties	1-14
22 43 00	Healthcare Plumbing Fixtures	1-11

#### DIVISION 23 HEATING, VENTILATING, AND AIR CONDITIONING (HVAC)

23 00 10	Mechanical General Requirements	1-11
23 00 50	Basic Mechanical Materials And Methods	1-12
23 05 00	Common Work Results For HVAC	1-10
23 05 13	Common Motor Requirements For HVAC Equipment	1-3
23 05 19	Meters And Gages For HVAC Piping	1-7
23 05 23	General-Duty Valves For HVAC Piping	1-5
23 05 29	Hangers And Supports For HVA Piping And Equipment	1-9
23 05 48	Vibration And Seismic Controls For HVAC Piping And Equipment	1-6
23 05 53	Identification For HVAC Piping And Equipment	1-6
23 05 93	Testing, Adjusting, And Balancing For HVAC	1-10
23 07 13	Duct Insulation	1-12
23 07 19	HVAC Piping Insulation	1-10
23 09 00	Instrumentation And Control For HVAC	1-18
23 09 70	Direct Digital Control (DDC) System Commissioning	1-15
23 09 95	Mechanical System Commissioning	1-3
23 09 95b	Exhibit B - Sample Functional Test Plan	1-2
23 21 13	Hydronic Piping	1-11
23 31 13	Metal Ducts	1-12
23 33 00	Air Duct Accessories	1-10
23 36 00	Air Terminal Units	<u>    1-6    </u>
23 37 13	Diffusers, Registers, And Grilles	1-3
23 41 33	High-Efficiency Particulate Filtration	1-4

#### DIVISION 24 - Reserved

#### DIVISION 25 INTEGRATED AUTOMATION - Not Used

#### **DIVISION 26 ELECTRICAL**

26 00 10	Electrical General Provisions	1-12
26 05 00	Common Work Results For Electrical	1-4
26 05 19	Low-Voltage Electrical Power Conductors And Cables	1-3

26 05 26	Grounding And Bonding For Electrical Systems	1-5
26 05 29	Hangers And Supports For Electrical Systems	1-4
26 05 33	Raceway And Boxes For Electrical Systems	1-16
26 05 53	Identification For Electrical Systems	1-6
26 27 26	Wiring Devices	1-7
26 51 00	Interior Lighting Fixtures	1-12
26 57 00	Medical Facilities	1-2

DIVISION 27 COMMUNICATIONS - Not Used

DIVISION 28 ELECTRONIC SAFETY AND SECURITY - Not Used

DIVISION 29 - Reserved

#### SITE AND INFRASTRUCTURE SUBGROUP:

DIVISIONS 30 TO 39 - Not Used

**DIVISION 30 - Reserved** 

DIVISION 31 EARTHWORK 31 23 33 Trenching and Backfilling 1-5

DIVISION 32 EXTERIOR IMPROVEMENTS - Not Used

DIVISION 33 UTILITIES - Not Used

**DIVISION 34 TRANSPORTATION - Not Used** 

DIVISION 35 WATERWAY AND MARINE CONSTRUCTION - Not Used

DIVISIONS 36 TO 39 - Reserved

#### PROCESS EQUIPMENT SUBGROUP:

DIVISIONS 40 TO 49 - Not Used

APPENDICES

Appendix 1 - Equipment Cut Sheets

END OF TABLE OF CONTENTS

**DIVISION 01 – GENERAL REQUIREMENTS** 

#### **SECTION 01 10 00**

#### SUMMARY

#### PART 1 GENERAL

#### 1.01 GENERAL REQUIREMENTS

- A. Division 01 General Requirements relates to and expands upon the Conditions of the Contract, including the General Conditions and the Supplementary Conditions, but does not supersede requirements specified in those documents or in the Owner/Contractor Agreement.
- B. Division 01 General Requirements governs work under all other divisions of the Specifications, including Project Specifications issued under separate cover, and the Drawings.

#### 1.02 PROJECT IDENTIFICATION AND PRINCIPAL ENTITIES

A. Project Identification and Location:

TCMC Pharmacy USP 800 Upgrade Tri-City Medical Center 4002 Vista Way Oceanside, California 92056

B. Owner: Wherever the word "Owner" is used in this Project Manual, it shall mean:

Tri-City Healthcare District 4002 Vista Way Oceanside, California 92056

C. Architect: Wherever the word "Architect" is used in this Project Manual, it shall mean:

S F E I R Architects 1350 Columbia Street, Suite 603 San Diego, California 92101

D. General Contractor: Wherever the words "Contractor" or "General Contractor" are used in this Project Manual, they shall mean the contractor who is party to the Owner/Contractor Agreement.

#### 1.03 WORK COVERED BY CONTRACT DOCUMENTS

- A. Single Contract: Unless otherwise indicated or specified, all Work indicated on the Drawings and described in the Specifications is to be executed under one prime contract between Owner and General Contractor.
- B. Scope of Work: The Work consists of an upgrade and remodeling of the existing inpatient pharmacy on the basement level to the standards of United States Pharmacopeia Chapter 800.
- C. The locations of all existing utilities, as indicated on the Drawings, are approximate. General Contractor shall be responsible for verifying location of all underground and above ground utilities indicated on the Architectural, Mechanical, and Electrical Drawings prior to construction. Any damage to these utilities shall be the Contractor's responsibility and they shall be repaired at no cost to the Owner.

D. Failure to Visit Site: Will not relieve Contractor from necessity of furnishing materials or performing work that may be required to complete the Work in accordance with Drawings and Specifications without additional cost to Owner.

#### 1.04 WORK BY OWNER OR UNDER SEPARATE CONTRACT

- A. Work by Others to be Executed During or After Completion of this Contract:
  - Remediation of Hazardous Materials: No information is available regarding possible hazardous materials in the structures designated for demolition or the areas designated for remodeling. If hazardous materials, such as asbestos or lead-based paints, are encountered, remediation of such materials will be performed by others under separate contract to the Owner. Immediately notify Owner if such materials are observed before or during demolition operations. Coordinate with Owner to reschedule demolition and construction work to be completed after hazardous material remediation is accomplished.
  - 2. Other items indicated to be by Owner, OFOI, or not in contract (N.I.C.) on Drawings.

#### 1.05 COORDINATION WITH OCCUPANTS

- A. Owner Occupancy: Owner will occupy the premises during entire construction period, with the exception of areas under construction. Cooperate with Owner during construction operations to minimize conflicts and facilitate Owner usage. Perform the Work so as not to interfere with Owner's operations. Maintain existing exits, unless otherwise indicated.
  - 1. Maintain access to existing walkways, corridors, and other adjacent occupied or used facilities. Do not close or obstruct walkways, corridors, or other occupied or used facilities without written permission from Owner and authorities having jurisdiction.
    - a. Emergency Exits: Maintain all required fire exits from existing building at all times existing building is occupied during construction process.
    - b. Exit Doors, Stairways and Discharge Areas: Acceptable to local code authority.
  - 2. Take precautions to allow for continued medical center operations including employee and public access.
  - 3. Related Requirements: See Section 01 35 16 Alteration Project Procedures.
- B. Disruptive Operations: Noisy and disruptive operations (such use of jack hammers and other noisy equipment) shall not be allowed within existing building without prior authorization by the Owner.
  - 1. Schedule and coordinate such operations with Owner so that they occur at least disruptive times.
  - 2. Upon notification from Owner, cease operations which are, in opinion of Owner, disruptive to occupants.
- C. Existing Utility Interruptions: Do not interrupt utilities serving facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary utility services according to requirements indicated:
  - 1. Notify Owner not less than two days in advance of proposed utility interruptions.
  - 2. Do not proceed with utility interruptions without Owner's written permission.
  - 3. In general outages shall be scheduled at times when the building is not being utilized by occupants.
- D. Provide not less than 72 hours' notice to Owner of activities that will affect Owner's operations.
- E. Construction Parking: Parking for construction labor on site shall be coordinated with the Owner.
- F. No smoking or use of tobacco products anywhere on Owner's property shall be allowed.

#### 1.06 USE OF SITE

- A. General: Contractor shall have limited use of premises for construction operations as indicated on Drawings by the Contract limits and as defined at the Pre-construction Conference.
- B. Limit use of premises to areas within the Contract limits indicated. Do not disturb portions of building or Project site beyond areas in which the Work is indicated.
  - 1. Owner Occupancy: Restrict access to extent required to allow for on-going occupancy of portions of the building outside the area of work.
  - 2. Driveways and Entrances: Keep driveways and entrances serving premises clear and available to Owner, Owner's employees, and emergency vehicles at all times. Do not use these areas for parking or storage of materials.
    - a. Schedule deliveries to minimize use of driveways and entrances.
    - b. Schedule deliveries to minimize space and time requirements for storage of materials and equipment on-site.
- C. Use of Existing Building: Maintain existing building in a weathertight condition throughout construction period. Repair damage caused by construction operations. Protect building and its occupants during construction period.
  - 1. Related Requirements:
    - a. Section 01 35 16 Alteration Project Procedures.
    - b. Section 01 50 00 Temporary Facilities and Controls.
- D. On-Site Work Hours: Work shall be generally performed inside the existing building during normal business working hours, Monday through Friday, unless specifically authorized by the Owner's Representative.

#### 1.07 WORK SEQUENCE AND CONSTRUCTION PHASING

- A. Sequencing of Construction Plan: Before start of construction on site, submit three copies of construction plan regarding access to work; use of site; and scheduling and phasing of new, demolition and renovation work for acceptance by Owner and Architect. After acceptance of plan, construction sequencing shall comply with accepted plan unless deviations are accepted in writing.
  - 1. No work may commence until Notice to Proceed is provided by the Owner.
- B. Phasing: Schedule work to be completed in two principal construction phases. See Phasing Plan and Phasing Plan Keynotes on Drawings for detailed requirements.

#### 1.08 PROJECT MANUAL FORMATS AND CONVENTIONS

- A. MasterFormat: This Project Manual is organized on the basis of the 2016 Edition of the Construction Specifications Institute (CSI) MasterFormat.
  - 1. The system of groups, subgroups and Divisions are listed in the Table of Contents of this Project Manual. It consists of 50 Divisions, Division 00 though Division 49, some of which are not used or are reserved for future expansion of the MasterFormat.
- B. Specification Language: These Specifications are of abbreviated, simplified or streamlined type and include incomplete sentences.
  - 1. Omissions of words or phrases such as "the contractor shall", "in conformity therewith", "shall be", "as noted on the Drawings", "a", "the", are intentional.
  - 2. Supply omitted words or phrases by inference.
  - 3. Supply words "shall be" or "shall" by inference when colon is used within sentences or phrases.

4. Supply words "on the Drawings" by inference when "as indicated" is used with sentences or phrases.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION - Not Used

END OF SECTION

#### **SECTION 01 25 00**

#### SUBSTITUTION PROCEDURES

#### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Administrative and procedural requirements for consideration of requests for substitution during the construction phase of the Project.
  - 2. Product substitution procedures.
  - 3. Execution substitution procedures.

#### B. Related Requirements:

- 1. General Conditions.
- 2. Product Requirements: Section 01 60 00.

#### 1.02 LIMITATIONS ON SUBSTITUTIONS

- A. During Procurement Phase: Comply with Instructions to Bidders.
- B. During Construction Phase: Requests for substitutions of products will be considered only within 35 days after date of Owner-Contractor Agreement. Other requests will be considered only in case of product unavailability or other conditions beyond control of Contractor.
- C. Substitutions:
  - 1. Will not be considered when indicated on shop drawings or product data submittals without separate formal request, when requested directly by subcontractor or supplier, or when acceptance will require substantial revision of Contract Documents.
  - 2. Do not order or install substitute products without written acceptance.
  - 3. Only one request for substitution for each product will be considered. When substitution is not accepted provide specified product.
  - 4. Architect will determine acceptability of substitutions.
  - 5. In addition to other requirements, proposed substitutions also require specific prior approval by OSHPD.
- D. Value Engineering: For "value engineering" or similar cost or time reduction proposals that would result in changes to the Drawings and Specifications, the Contractor shall follow procedures specified herein and any and all such changes are to be submitted in "Substitution Approval Request Form" provided by Architect upon request of the Contractor.

#### 1.03 CONTRACTOR REPRESENTATION

- A. Request for Product Substitution: Representation that Contractor has investigated proposed product and has determined that it is equal to or superior in all respects to specified product:
  - 1. Contractor will provide same warranty for substitution as for specified product.
  - 2. Contractor will coordinate installation of accepted substitute, making such changes as may be required for work to be complete in all respects.
  - 3. Contractor waives claims for additional costs related to substitution which may later become apparent.

B. Replacement: If substituted products do not meet or exceed above requirements, whether before, during, or after incorporated into work, Contractor shall, at no additional cost to Owner, replace substituted products with products originally specified.

#### 1.04 SUBSTITUTION REQUEST SUBMITTAL PROCEDURES

- A. Submittal : Submit two copies of each request. Submit separate request for each substitution.
  - Identify products by Specifications section and article numbers.
     Provide manufacturer's name and address, trade name of products, and r
  - 2. Provide manufacturer's name and address, trade name of products, and model or catalog number.
  - 3. List fabricators and suppliers as appropriate.
- B. Documentation: Document each request with complete data substantiating compliance of proposed substitution with requirements of Contract Documents:
  - 1. Attach Product Data as specified in Section 01 33 00.
  - 2. Give itemized comparison of proposed substitution with specified product, listing variation, and reference to specification section and article numbers.
  - 3. Give quality and performance comparison between proposed substitution and specified product.
  - 4. List availability of maintenance services and replacement materials.
  - 5. State effect of substitution on construction schedule, and changes required in other work or products.
  - 6. Reference UL Fire Resistance Directory design number if applicable.
- C. Architect: Will review Contractor's requests for substitutions with reasonable promptness.
  - 1. If accepted by Architect, products proposed for substitution will be accepted subject to modifications by manufacturer, if necessary, to meet detailed requirements of Drawings and Specifications.
  - 2. Architect will not make exhaustive attempt to determine that products proposed for substitution are equal to, or can be modified in order to be equal to specified products.
- D. Architect's Acceptance: Architect will notify Contractor, in writing, of decision to accept or reject requested substitution.
- E. For Accepted Products: Submit shop drawings, product data, and samples in accordance with Section 01 33 00.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION – Not Used

END OF SECTION
### **SECTION 01 26 00**

## **CONTRACT MODIFICATION PROCEDURES**

# PART 1 GENERAL

# 1.01 SUMMARY

- A. This section specified administrative and procedural requirements necessary for handling and processing Contract modifications.
- B. Related Sections: The following sections contain requirements that relate to this section:
  - 1. Division 01 Section "Submittal Requirements" for requirements for the Contractor's Construction Schedule.
  - 2. Division 01 Section "Payment Procedures" for administrative procedures governing application for payment.
- 1.02 MINOR CHANGES IN THE WORK
  - A. Supplemental Instructions authorizing minor change in the Work, not involving an adjustment to the Contract Sum or Contract Time, may be issued by the Architect on an AIA form G711, Architect Supplemental Instructions.

### 1.03 CHANGE ORDER PROPOSAL REQUESTS

- A. Owner-Initiated Proposal Request: Proposed changes in the Work that will require adjustment to the Contract Sum or Contract Time will be issued by the Owner, with a detailed description of the proposed change and supplemental or revised Drawings and Specifications, if necessary.
  - 1. Proposal requests issued by the Owner are for information only. Do not consider them instruction either to stop work in progress, or to execute the proposed change.
  - 2. Unless otherwise indicated in the proposal request, within 30 days of receipt of the proposal request, submit to the Architect and the Owner for review an estimate of cost necessary to execute the proposed change.
    - a. Include a list of quantities of products to be purchased and unit costs, along with the total amount of purchases to me made. Where requested, furnish survey data to substantial quantities.
    - b. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
    - c. Include a statement indicating the effect the proposed change in the Work will have on the Contract Time.
- B. Contractor-Initiated Change Order Proposal Requests: When latent or other unforeseen conditions require modifications to the Contract, the Contractor may propose changes by submitting a request for a change to the Owner and Architect.
  - 1. Include a statement outlining the reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. Indicate the effect of the proposed change on the Contract Sum and Contract Time.
  - 2. Include a list of the quantities of products to be purchased and unit costs along with the total amount of purchases to be made. Where requested, furnish survey data to substantiate quantities.
  - 3. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
  - 4. Comply with requirements in Section 'Products Substitutions " if the proposed change in the work requires the substitutions of one product or system for a product or system specified.

C. Proposal Request Form: Use forms approved by the Owner for Change Order Proposals.

# 1.04 CHANGE ORDER PROCEDURES:

- A. In addition to the procedure and information stated in the section, herein before: the Contractor shall follow Change Order procedures and information as stated in the General Conditions of the Contract and on the Bid Form.
- B. Upon the Owner's approval of a Change Order proposal Request, the owner will issue a Change Order for signatures of the Owner, Contractor, and Architect.
- C. OSHPD Approvals: In accordance with Part 1, Title 24, California Code of Regulations, all addenda and modifications to the Work requiring OSHPD approval shall be approved by the Office of Statewide Health Planning and Development (OSHPD) prior to proceeding with the work.
- 1.05 CONTRACT MODIFICATION LOG
  - A. All changes to the Contract Documents, including change orders and minor non-material modifications, shall be logged for the Project record by the Architect.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION - Not Used

### **SECTION 01 29 00**

### PAYMENT PROCEDURES

# PART 1 GENERAL

### 1.01 SUMMARY

- A. This Section specifies administrative, and procedural requirements governing the Contractor's Applications for Payment.
- B. The Contractor's Construction Schedule and Submittal Schedule are included in Section " Submittals".

### 1.02 COORDINATION

- A. Coordinate preparation of the Schedule of Values with preparation of the Contractor's Construction Schedule.
  - 1. Correlate line items in the Schedule of Values with other required administrative schedules and forms, including:
    - a. Contractor's construction schedule.
    - b. Application for Payment form.
    - c. List of subcontractors.
    - d. Schedule of allowances.
    - e. List of products.
    - f. List of principal suppliers and fabricators.
    - g. Schedule of submittals.
  - 2. Submit the Schedule of Values- Schedule Amounts to the Owner at the earliest feasible date, but in no case later than 7 days before the date schedule for submittal of the initial Application for payment.

### 1.03 SCHEDULE OF VALUES

- A. Identification; Include the following Project identification on the Schedule of Values:
  - 1. Name of Owner.
  - 2. Project name and location.
  - 3. Name of Architect.
  - 4. Project number.
  - 5. Contractor's name and address.
  - 6. Date of submittal.
- B. Arrange the Schedule of Values in a tabular form with separate columns to indicate the following for each item listed;
  - 1. Generic name.
  - 2. Relate Specification Section.
  - 3. Name OF subcontractor.
  - 4. Name of manufacturer or fabricator.
  - 5. Name of supplier.
  - 6. Change Orders (numbers) that have affected value.
  - 7. Dollar value.
  - 8. Percentage of Contract Sum to the nearest one-hundredth percent, adjusted to total 100 percent.

- C. Provide a breakdown of the Contract Sum in sufficient detail to facilitate continued evaluation of Applications for Payment and progress evaluation of Applications fro Payment and progress report. Break principle subcontract amounts down into several line items.
- D. Round amounts off to the nearest whole dollar; the total shall equal the Contract Sum.
- E. For each part of the Work where an Application for Payment may include materials or equipment, purchased or fabricated and stored, but not yet installed, provide separate line items on the schedule of Values for initial cost of the materials, for each subsequent stage of completion, and for total installed value of that part of the work.
- F. Margins of Cost: Show line items for indirect costs, and margins on actual costs, only to the extent that such items will be listed individually and Applications for Payment. Each item in the Schedule of Values and Applications for Payment shall be completed including its total cost and proportionate share of general overhead and profit margin.
- G. At the Contractor's option, temporary facilities and other major cost items that are not direct cost of actual work-in-place may be shown as separate line items in the Schedule of Values or distributed as general overhead expense.
- H. Schedule Updating: Update and resubmit the Schedule of Values when change Orders result in a change in the Contract sum.

### 1.04 APPLICATIONS FOR PAYMENT:

- A. Each Application for payment shall be consistent with previous applications and payments ad certified by the Architect and paid for by the Owner.
  - 1. The initial Application for payment, the Application fro payment at time of Substantial Completion, and the final Application for Payment involved additional requirements.
- B. Payment Application Times: The date for each progress payment is the first construction progress meeting of each month. The period of construction Work covered by each Application for Payment is the period ending at the last day of the month prior to the date for each progress payment and starting the day following the end of the preceding period.
- C. Payment Applications Forms: Use AIA Document G702 and G703.
- D. Application Preparation: Complete every entry on the form, including notarization and execution by person authorized to sign legal documents on behalf of the Owner. Incomplete applications will be returned without action.
  - 1. Entries shall match data on the Schedule of Values and Contractor's Construction Schedule. Use updated schedule if revisions have been made.
  - 2. Include amounts of Change Orders and Construction Change Directives issued prior to the last day of the construction period covered by the application.
- E. Transmittal: Submit 5 executed copies of each Application for payment to the Owner and Architect at the first of the bi-weekly Construction Progress Meeting. This meeting will extend into preview and acceptance by all required parties of the Contractors application of payment.
  - 1. Transmit each copy with a transmittal form listing attachments, and recording appropriate information related to the application in a manner acceptable to the Architect.

- F. Waivers of Mechanics Lien: With each Application for Payment submit waivers of Mechanic liens from subcontractors or sub-subcontractors and supplier for the construction period covered by the pervious application.
  - 1. Submit partial waivers on each item for the amount requested, prior to deduction for retainage, on each item.
  - 2. When an application shows completion of an item, submit final or full waivers.
- G. The Owner reserves the right to designate which entities involved in the Work must submit waivers.
  - 1. Wavier Delays: Submit each Application for Payment with the Contractors Wavier of Mechanics lien for the period of construction covered by the application.
  - 2. Submit final Application for payment with or proceeded by final wavier from every entity involved with performance with Work covered by the Application who could lawfully be entitled to a lien.
  - 3. Waiver Forms: Submit Wavier of lien of forms, and executed in a manner, acceptable to Owner.
- H. Initial Application for payment: Administrative action and submittal that must precede or coincide with submittal of the first Application for Payment include but not limited to the following:
  - 1. List of subcontractors and their agreements with the Contractor.
  - 2. List of principle suppliers and fabricators.
  - 3. Schedule of Values.
  - 4. Contractors Construction Schedule (preliminary if not final).
  - 5. Schedule of principle products.
  - 6. Submittal Schedule (preliminary if not final).
  - 7. List of Contractor's staff assignments.
  - 8. List of Contractor's principle consultants.
  - 9. Copies of building permits.
  - 10. Copies of authorization and licenses from governing authorities for performance of the Work.
  - 11. Certificates of insurance and insurance policies.
  - 12. Data needed to acquire Owner's insurance.
- I. Application for Payment at Substantial Completion: Following issuance of the Certificate of Substantial Completion, on the entire project, submit an Application for Payment.
- J. Administrative actions and submittals that shall precede or coincide with this application include:
  - 1. Occupancy permits and similar approvals.
  - 2. Warranties (guarantees) and maintenance agreements.
  - 3. Test/ adjust / balance records.
  - 4. Maintenance instructions.
  - 5. Changeover information related to owner's occupancy, use, operation and maintenance.
  - 6. Final cleaning.
  - 7. Application for reduction of retainage, and consent of surety.
  - 8. Advice on shifting insurance coverage.
  - 9. Final progress photographs.
  - 10. List of delayed work, recognized as exceptions to Architect's Certificate of Substantial Completion.
- K. Final Payment Application: Administrative actions and submittals, which must precede or coincide with submittal of the final payment Application for Payment include the following:
  - 1. Completion of project closeout requirements.
  - 2. Completion of items specified for completion after Substantial Completion.
  - 3. Assurance that unsettled claims will be settled.
  - 4. Assurances that work not complete and accepted will complete without undo delay.
  - 5. Transmittal of required Project Construction Records to the Owner.

- 6. Proof that taxes, fees and similar obligations have been paid.
- 7.
- Removal of temporary facilities and services. Removal of surplus materials, rubbish and similar elements. 8.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION - Not Used

### **SECTION 01 31 13**

## PROJECT COORDINATION

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. This section specified administrative and supervisory requirements necessary for Project coordination including, but necessary limited to:
  - 1. Coordination.
  - 2. Administrative and Supervisory personnel.
  - 3. General installation provision.
  - 4. Cleaning and protection.
  - 5. Time and Manner.
- B. Progress meetings, coordination meetings and pre-installation conferences are included in Section "Project Meetings."
  - Requirements for the Contractor's Construction Schedule are included in Section "Submittals."

#### 1.02 COORDINATION

- A. Coordination: Coordinate construction activities included under various Sections of these Specifications to assure efficient and orderly installation of each part of the Work. Coordinate construction operations include under different Sections of the Specifications that are dependent upon each other for proper installation, connection, and operation.
  - 1. Where installation of one part of the Work is dependent on installation of other components, either before or after its own installation, schedule Construction activities in the sequence to obtain the best results.
  - 2. Where availability of space is limited, coordinate installation of different components to assure maximum accessibility for required maintenance, service and repair.

### 1.03 COORDINATION

- A. Make adequate provisions to accommodate items scheduled for later installation.
- B. Administrative Procedures: Coordinate scheduling and timing of required Administrative Procedures with other constructions activities to avoid conflicts and ensure orderly progress of the work. Such administrative activities include, but are not limited to the following:
  - 1. Preparation of Schedules.
  - 2. Installation and removal of temporary facilities.
  - 3. Delivery and processing of submittals.
  - 4. Progress Meetings.
  - 5. Project closeout activities.
- C. Conservation: Coordinate Construction activities to ensure that operations are carried out with considerations given to conservation of energy, water, and materials.
  - 1. Salvage materials and equipment involved in performance of, but not actually incorporated in, the Work. Refer to other sections for disposition of salvaged materials that are designated as Owner's property.

#### PART 2 PRODUCTS - Not Used

TCMC Pharmacy USP 800 Upgrade Tri-City Medical Center SA Project No. 01667.00

# PART 3 EXECUTION

#### 3.01 GENERAL INSTALLATION PROVISIONS

- A. Inspection of Conditions: Require the Installer of each major component to inspect both the substrate and conditions under which Work is to be performed. Do not proceed until unsatisfactory conditions have been corrected in an acceptable manner.
- B. Manufacturer's Instructions: Comply with manufacturer's installation instructions and recommendations, to the extent that those instructions and recommendations are more explicit or stringent than requirements contained in Contract Documents.
- C. Inspect materials or equipment immediately upon delivery and again prior to installation. Reject damage and defective items.

#### 3.02 GENERAL INSTALLATION PROVISIONS:

- A. Provide attachment and connection devices and methods necessary for securing Work. Secure Work true to line and level. Allow for expansion and building movement.
- B. Visual effects: Provide uniform joint widths in exposed Work. Arrange joints in exposed Work to obtain the best visual effect. Refer questionable choices to the Architect for final decision.
- C. Recheck measurements and dimensions, before starting each installation.
- D. Coordinate temporary enclosures with required inspections and tests, to minimize the necessity of uncovering completed construction for that purpose.
- E. Mounting Heights: Where mounting heights are not indicated, install individual components at standard mounting heights recognized with the industry for the particular application indicated. Refer questionable mounting height decisions to the Architect for the final decision.

## 3.03 CLEANING AND PROTECTION

- A. Cleaning and Maintenance:
  - 1. Special cleaning requirements for specific units of Work are included in the appropriate sections of the specifications. Final cleaning is required under section 01700.
  - 2. The Contractor shall remove and dispose of all waste materials and rubbish due to all construction operations under the contract.
- B. Protection: In addition to the General Conditions, the Contractor or alteration work. Use only new materials in construction of all protection. If wood is called for, it shall be fire retardant treated wood if used within the interior of the building. No cutting of materials shall be done within occupied spaces.

#### 3.04 OWNER OCCUPANCY:

A. Partial Owner Occupancy: The Owner reserves the right to place and install equipment as necessary in completed areas of the building and to occupy such completed areas prior to substantial completion, provided that such occupancy does not substantially interfere with completion of the work. Such placing of equipment and partial occupancy shall not constitute acceptance of the work or any part of the work.

### **SECTION 01 31 19**

#### **PROJECT MEETINGS**

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. This Section specifies administrative and procedural requirements for project meetings including but not limited to:
  - 1. Pre-Construction Conference.
  - 2. Pre-Installation Conferences.
  - 3. Progress Meetings.
- B. Construction schedules are specified in another Division-01 Section.

#### 1.02 PRE-CONSTRUCTION CONFERENCE

- A. Schedule a pre-construction conference and organizational meeting at the Project site or other convenient location no later than 5 days after the notice to proceed and prior to commencement of construction activities. Conduct the meeting to review responsibilities and personnel assignments.
- B. Attendees: The Owner, Architect and their consultants, the Prime Contractors and their superintendent, major subcontractors, manufactures, suppliers and other concerned parties shall each be represented at the conference by persons familiar with and authorized to conclude matters relating to the Work.
- C. Agenda: Discuss items of significance that could affect progress including but not limited to such topics as:
  - 1. Tentative construction schedule.
  - 2. Critical Work sequencing.
  - 3. Designation of responsible personnel.
  - 4. Procedures for processing filed decisions and Change Orders.
  - 5. Procedures for processing Applications for Payment.
  - 6. Distribution of Contract Documents.
  - 7. Submittal of Shop Drawings, Product Data and Samples.
  - 8. Preparation of record documents.
  - 9. Use of the premises.
  - 10. Office, work and storage areas.
  - 11. Equipment deliveries and priorities.
  - 12. Safety procedure
  - 13. First aid.
  - 14. Security
  - 15. Housekeeping.
  - 16. Working Hours.

### 1.03 PRE-INSTALLATION CONFERENCES

A. Conduct a pre-installation conference at the site before each construction activity that requires coordination with other construction and as specified herein. The Installer and representatives of manufacturers and fabricators involved in or affected by the installation, and its coordination or integration with other materials and installations that have preceded or will follow, shall attend the meeting. Advise the Architect of Schedule meeting dates.

- B. Review the progress of other construction activities and preparations for the particular activity under consideration at each pre-installation conference.
- C. Do not proceed if the conference cannot be successfully concluded. Indicate whatever actions are necessary to resolve impediments to performance of Work and reconvene the conference at the earliest feasible date.

# 1.04 PROGRESS MEETINGS

- A. Conduct progress meetings at Project site bi-weekly. Coordinate dates of meeting with preparation of the payment request.
- B. Attendees: In addition to representative of the Owner and Architect, each subcontractor, supplier or other entity concerned with current progress or involved in planning, coordination or performance of future activities shall be represented at these meetings by persons familiar with the Project and authorized to conclude matters relating to progress.
- C. Agenda: Review and correct or approve minutes of the previous progress meeting. Review other items of significance that could affect progress. Include topics for discussion as appropriate to the current of the Project.
  - 1. Contractor's Construction Schedule: Review progress since the last meeting. Determine where each activity is in relation to the Contractor's Construction Schedule, whether on time or ahead or behind schedule. Determine how construction behind schedule will be expedited; secure commitments from parties involved to do so. Discuss schedule revisions are required to ensure that current and subsequent activities will be completed within the Contract Time.
  - 2. Schedule Updating: Revise the construction schedule after each progress meeting where revisions to the schedule have been made or recognized. Issue the revise schedule to the Owner and Architect.

PART 2 PRODUCTS - Not used

PART 3 EXECUTION - Not used

### **SECTION 01 33 00**

### SUBMITTAL PROCEDURES

# PART 1 GENERAL

#### 1.01 SUMMARY

- A. This Section specifies administrative and procedural requirements for submittals required for performance of the Work, including:
  - 1. Contractor's construction schedule.
  - 2. Submittal schedule.
  - 3. Construction progress photographs.
  - 4. Shop Drawings.
  - 5. Product Data.
  - 6. Samples.
- B. Administrative Submittals: T=Refer to other Division-1 Sections and other Contract Documents for requirements for administrative submittals. Such submittals include, but are not limited to:
  - 1. Permits.
  - 2. Applications for payment.
  - 3. Performance and payment bonds.
  - 4. Insurance certificates.
  - 5. List of Subcontractors.
- C. The schedule of Values submittal is included in Section "Applications for Payment."
- D. Inspection and test reports are included in Section "Quality Control Services."

#### 1.02 SUBMITTAL PROCEDURES

- A. Coordination: Coordinate preparation and processing of submittals with performance of construction activities. Transmit each submittal sufficiently in advance of performance of related construction activities to avoid delays.
  - 1. Coordinate each submittal with fabricate, purchasing, testing, delivery, other submittals and related activities that require sequential activities.
  - Coordinate transmittal of different types of submittals for related elements of the Work so
    processing will not be delayed by the need to review submittals constructed for coordination.

     The Architect reserves the right to withhold action on a submittal requiring coordination
    - The Architect reserves the right to withhold action on a submittal requiring coordination with other submittals until related submittals are received.
- B. Processing: Allow sufficient review time so that installation will not be delayed as result of the time required to process submittals, including time for resubmittals.
  - 1. Allow two weeks for initial review. Allow Additional time if processing must be delayed to permit coordination with subsequent submittals. The Architect will promptly advise the contractor when a submittal being processed must be delayed for coordination.
  - 2. If an intermediate submittal is necessary, process the same as initial submittal.
  - 3. Allow two weeks for reprocessing each submittal.
  - 4. No extension of Contract Time will be authorized because of failure to transmit submittals to the Architect sufficiently in advance of the work to permit processing.

- C. Submittal Preparation: Place a permanent label or title block on each submittal for identification. Indicate the name of the entity that prepared each submittal on the label or title block.
  - Provide a space approximately 4" x 5" on the label or beside the title block on Shop Drawings and product Data to record the Contractor's review and approval markings and the action taken for accuracy, completeness and compliance with the Contract Documents. Submittals without evidence of the Contractor's review and approval will be returned for resubmission.
  - 2. Include the following information on the label for processing and recording action taken.
    - a. Project name.
    - b. Date.
    - c. Name and address of Architect.
    - d. Name and address of Contractor.
    - e. Name and address of subcontractor.
    - f. Name and address of supplier.
    - g. Name manufacturer.
    - h. Number and title of appropriate Specifications Section.
    - i. Drawings number and detail references, as appropriate.
- D. Submittal Transmittal: Package each submittal appropriately for transmittal and handling. Transmit each submittal from Contractor to Architect using a transmittal form with copy of transmittal to Owner. Submittal received from sources other than the Contractor will be returned without action.
  - 1. On the transmittal Record relevant information and requests for data. On the form, or separate sheet, record deviations from Contract Document requirement, including minor variations and limitations. Include Contractor's certification that information complies with Contract Document requirements.

### 1.03 CONTRACTORS' CONSTRUCTION SCHEDULE

- A. Bar-Chart Schedule: The General Contractor shall prepare a fully developed, horizontal bar-chart type contractors' construction schedule. Submit within 10 days of the date of the notice to proceed.
  - 1. Provide a separate time bar for each significant construction activity including the related contracts activities. Provide a continuous vertical line to identify the first working day of each week. Use the same breakdown of units of the work as indicate in the "Schedule of Values."
  - 2. Within each time bar indicated estimate completion percentage in 10 percent increments. As Work progress, place a contrasting mark in each bar to indicate Actual Completion.
  - 3. Prepare the schedule on a sheet, or series of sheets, of stable transparency, or other reproducible media, of sufficient width to show data for the entire construction period.
  - 4. Secure time commitments for performing critical elements of the Work from parties involved. Coordinate each element on the schedule with other construction activities; include minor elements involved in the sequence of the Work. Show each activity in proper sequence. Indicate graphically sequences necessary for completion of related portions of the Work.
  - 5. Coordinate the Contractors' construction schedule with the schedule of values, list of subcontracts, submittal schedule, progress reports, payment requests and other schedule.
  - 6. Indicate completion in advance of the date established for schedule Completion. Indicate Substantial Completion on the schedule to allow time for the Architect's procedures necessary for certification of Substantial Completion.
- B. Distribution: Following response to the initial submittal, print and distribute copies to the Architect, Owner, related Prime Contractor, subcontractors, and other parties require to comply with schedule dates. Post copies in the project meeting room and temporary field office.
  - 1. When revisions are made, distribute to the same parties and post in the same locations. Delete parties from distribution when they have completed their assigned portion of the Work and are no longer involved in construction activities.

C. Schedule Updating: Revise and reissue the schedule after each meeting or activity, where revisions have been recognized or made.

# 1.04 SUBMITTAL SCHEDULE

- A. After development and acceptance of the Contractors' construction schedule, each Prime Contractor shall prepare a complete schedule of submittals. Submit the schedule within 10 days from the Pre-Construction Conference.
- B. Coordinate submittal schedule with the list of subcontracts, schedule of values and the list of products as well as the Contractor's construction schedule.
- C. Prepare the schedule in chronological order; include submittals required during the first 30 days of Construction. Provide the following information:
  - 1. Schedule date for the first submittal.
  - 2. Related Section number.
  - 3. Submittal category.
  - 4. Name of subcontractor.
  - 5. Description of the part of the work covered.
  - 6. Scheduled date for resubmittal.
  - 7. Scheduled date for the Architect's final release or approval.
- D. Distribution: Following response to initial submittal, print and distribute copies to the Architect's, Owner, subcontractors, and other parties required to comply with submittal date indicated. Post copies in the Project meeting room and file in office.
  - 1. When revisions are made, distribute to the same parties and post in the same locations. Delete parties from distribution when they have completed their assigned portion of the Work and are no longer involved in construction activities.
- E. Schedule Updating: Revise and reissue the schedule after each meeting or activities, where revisions have been recognized or made.

#### 1.05 SHOP DRAWINGS

- A. Submit newly prepared information, drawn to accurate scale. Highlight, encircle, or otherwise indicate deviations from the Contract Documents. Do not reproduce Contract Documents or copy standard information as the basis of shop Drawings. Standard information prepared without specific reference to the Project is not considered Shop Drawings.
- B. Shop Drawings include fabrication and installation drawings, setting diagrams, schedules, patterns, templates and similar drawings. Include the following information:
  - 1. Dimensions.
  - 2. Identification of products and materials included.
  - 3. Completion with specified standards.
  - 4. Notation of coordination requirements.
  - 5. Notation of dimensions established field measurement.
- C. Sheet Size: Except for templates, patterns and similar full-size Drawings, submit Shop Drawings on sheets at least 8-1/2"x11" but not larger than 30" x 42"
- D. Initial Submittal: To Architect submit one correctable translucent reproducible print and one blueor black-line print for the Architect's review; the reproducible print will be returned.

- E. Final Submittal: To Architect a minimum of blue- or black-line prints; submit 8 prints where required for maintenance manuals. 5 prints will be retained; the remainder will be returned.
  - 1. One of the prints returned shall be marked-up and maintained as a "Record Document".
  - 2. Do not Shop drawings without an appropriate final stamp indicating action taken in connection with construction.

### 1.06 PRODUCT DATA

- A. Collect product Data into a single submittal for each element of construction or system. Product Data included printed information such as manufacturer's installation instructions, catalog cuts, standard color charts, roughing-in diagrams and templates, standard wiring diagrams and performance curves. Where Product Data must be specially prepared because standard printed data is not suitable for use, submit as ' Shop Drawings'.
- B. Mark each copy to show applicable choices and options. Where printed Product Data included information on several products, some of which are not required. Mark copies to indicate the applicable information. Include the following information:
  - 1. Manufacturer's printed recommendations.
  - 2. Compliance with recognized trade association standards.
  - 3. Compliance with recognized testing agency standards.
  - 4. Application of testing agency labels and seals.
  - 5. Notation of dimensions verified by field measurement.
  - 6. Notation of coordination requirements.
- C. Do not submit Product Data until compliance with requirements of the Contract Documents has been confirmed.
- D. Preliminary Submittal: To Architect submit a preliminary single-copy of product Data where selection of options is required.
- E. Submittals: To Architect submit a minimum of 7 copies of each required submittal; submit 8 copies where required for maintenance manuals. The Architect will retain 5 copies. And will return the other marked with action taken and corrections or modifications required.
- F. Distribution: Furnish copies of final submittal to installers, subcontractors, suppliers, manufacturers, fabricators, and other required for performance of construction activities. Show distribution on transmittal form with copy being sent to Architect and Owner.

#### 1.07 SAMPLES

- A. Submit to Architect full-size, fully fabricate Sample cured and finished as specified and physically identical with the material or product proposed. Samples include partial sections of manufactured or fabricate components, cuts or containers of materials; color ranges sets, and swatches showing color, texture and pattern.
- B. Mount, display, or package Samples in the manner specified to facilitate review of qualities indicated. Prepare Samples to match the Architect's Sample. Include the following:
  - 1. Generic description of the Sample.
  - 2. Sample source.
  - 3. Product name or name of manufacturer.
  - 4. Compliance with recognized standards.
  - 5. Availability and delivery time.

- C. Submit to Architect Samples for review of kind, color, pattern, and texture, for a final check of these characteristics with other elements, and for a comparison of these characteristic between the final submittal and the actual component as delivered and installed.
  - 1. Where variation in color, pattern, texture or other characteristic are inherent in the material or product represented, submit multiple units (not less than 3), that show approximate limits of the variations.
  - 2. Refer to other Specification sections for requirements for Samples that illustrate workmanship. Fabrication techniques, details of assembly, connections, operation and similar construction characteristic.
  - 3. Refer to other Sections for Samples to be returned to the Contractor for incorporation in the Work. Such Samples must be undamaged at time of use. On the transmittal of Sample submittals.
- D. Preliminary submittals: Where Samples are for selection of color, pattern, texture or similar characteristics from a range of standard choices, submit a full set of choices for the material or product.
  - 1. Preliminary submittals will be reviewed and returned with the Architect's mark indicating selection and other action.
- E. Submittals: Except for Samples illustrating assembly details, workmanship, fabrication techniques, connections, operation and similar characteristics, submit 3 sets; one will be returned marked with the action taken.
  - 1. Maintain seats of Samples, as returned, at the Project site, for Quality comparisons throughout the course of construction.
  - 2. Unless no completion with Contract Document provisions is observed, the submittal may serve as the final submittal.
  - 3. Sample sets may be used to obtain final acceptance of the construction associate with each set.
- F. Distribution of Samples: Prepare and distribute additional sets to subcontractors, manufacturers, fabricators, supplies, installers, and others as required for performance of the work. Show distribution on transmittal form sent to Architect And Owner.
- G. Filed Samples specified in individual Sections are special types of Samples. Field Samples are full-size examples erected on site to illustrate finish coats, or finishing materials and to establish the standard by which the Work will be judge.
  - 1. Comply with submittal requirements to the fullest extent possible. Process transmittal forms to provide a record of activity.

# 1.08 ARCHITECT'S ACTION

- A. Except for submittals for record, information or similar purposes, here action and return is required or requested, the Architect will review each submittal, mark to indicate action taken, and promptly.
  - 1. Compliance with specified characteristics is the Contractor's responsibility.
- B. Action Stamp: The Architect will stamp each submittal with a uniform, self-explanatory action stamp. The stamp will be appropriately marked, as follows, to indicate the action taken.
  - 1. Final Unrestricted Release: Where submittals are marked "No Exception Taken," that part of the work covered by the submittal may proceed provided it complies with requirements of the Contract Documents; final acceptance will depend upon that compliance.
  - 2. Final-but-Restricted Release: When submittals are marked "Make Corrections Noted," that part of the work covered by the submittal may proceed provided it complies with notations or corrections on the submittal and requirements of the Contract Documents; final acceptance will depend upon that compliance.

- 3. Returned for Resubmittal: When submittal is marked "Revise and Resubmit," do not proceed with that part of the Work covered by the submittal, including purchasing, fabrication, delivery, or other activity. Revise or prepare a new submittal in accordance with the notations; resubmit without delay. Repeat if necessary to obtain a different action mark.
- 4. Do not permit submittals marked "Revise and Resubmit" to be used at the Project site, or elsewhere where Work is in progress.
- 5. Other Action: Where a submittal is primarily for information or record purposes, special processing or other activity, the submittal will be returned.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION - Not Used

### **SECTION 01 35 16**

## ALTERATION PROJECT PROCEDURES

# PART 1 GENERAL

#### 1.01 REQUIREMENTS INCLUDED

- A. Coordinate work of trades and schedule elements of alterations and renovation work by procedures and methods to expedite completion of the Work.
- B. In addition to demolition specified in Section 02 41 19 and that specifically shown, cut, move and remove items as necessary to provide access or to allow alterations and new work to proceed. Include such items as:
  - 1. Repair or removal of hazardous or unsanitary conditions.
  - 2. Removal of abandoned items and items serving no useful purpose, such as abandoned piping, conduit and wiring.
  - 3. Removal of unsuitable or extraneous materials not marked for salvage, such as abandoned furnishings and equipment, and debris such as rotted wood, rusted metals and deteriorated concrete.
  - 4. Cleaning of surfaces, and removal of surface finishes, as needed to install new work and finishes.
- C. Patch, repair and refinish existing items to remain, to the specified conditions for each material, with a workmanlike transition to adjacent new items of construction.
- D. Coordination of power outages and major interruptions of progress of construction work with Owner.

#### 1.02 RELATED REQUIREMENTS

- A. Materials for Renovation Work: Specifications in Divisions 02 through 31.
- B. Use of Premises and Work Restrictions: Section 01 10 00 Summary.
- C. Cutting and Patching of New or Existing Work During Construction: Section 01 73 29 Cutting and Patching.
- D. Use of Existing Utilities: Section 01 50 00 Temporary Facilities and Controls.
- E. Cleaning During Construction: Section 01 50 00 Temporary Facilities and Controls.
- F. Selective Demolition: Section 02 41 19.

#### 1.03 ALTERATIONS, CUTTING AND PROTECTION

- A. Assign the work of moving, removal, cutting and patching to trades qualified to perform the work in a manner to cause least damage to each type of work, and provide means of returning surfaces to appearance of new work.
- B. Perform cutting and removal work to remove minimum necessary, and in a manner to avoid damage to adjacent work.
  - 1. Cut finish surfaces such as masonry, tile, stone flooring, plaster or metals by methods to terminate surfaces in a straight line at a natural point of division.

- C. Protect existing finishes, equipment and, adjacent work that is scheduled to remain, from damage.
  - 1. Protect existing and new work from weather and extremes of temperature.
    - a. Maintain existing interior work above 60 degrees F.
    - b. Provide weather protection, waterproofing, heat and humidity control as needed to prevent damage to remaining existing work and to new work.
- D. Temporary Enclosures:
  - 1. Provide temporary, dustproof enclosures to separate work areas from existing building and from areas occupied by Owner.
- 1.04 COORDINATION WITH OWNER'S USE OF THE FACILITY
  - A. General: Coordinate construction phasing with operation of Owner's existing facility. The Owner intends to occupy portions of the existing building throughout construction.
    - 1. Establish effective communications with the Owner regarding Owner's operation and moving schedule. Give as much advance notice as possible, in addition to the minimums specified, for construction activities that will affect Owner's operations.
  - B. Utility Interruptions: Coordinate with Owner. Notify Owner 48 hours in advance of all necessary utility interruptions, including those scheduled for off hours.
  - C. Sequence of Construction and Remodeling:
    - 1. Coordination: Coordinate construction schedule with Owner's requirements.
    - 2. Phasing: See Phasing Plan and Phasing Notes on Drawings.

# PART 2 PRODUCTS

- 2.01 PRODUCTS FOR PATCHING, EXTENDING AND MATCHING
  - A. General Requirements that Work be Complete:
    - 1. Provide same products or types of construction as that in existing structure, as needed to patch, extend or match existing work.
      - a. Generally Contract Documents will not define products or standards of workmanship present in existing construction; Contractor shall determine products by inspection and any necessary testing, and workmanship by use of the existing as a sample of comparison.
    - 2. Presence of a product, finish, or type of construction, requires that patching, extending or matching shall be performed as necessary to make work complete and consistent.

# PART 3 EXECUTION

- 3.01 LAYING OUT WORK
  - A. Verify dimensions and elevations indicated in layout of existing work. Refer discrepancies between Drawings, Specifications and existing conditions to Architect for adjustment before work affected is performed. Failure to make such notification shall place responsibility upon Contractor to carry out work in satisfactory, workmanlike manner.
  - B. The Contractor shall be held responsible for the location and elevation of the construction contemplated by the Construction Documents.

C. Prior to commencing work, carefully compare and check Architectural, Structural, Mechanical and Electrical Drawings, each with the other that in any way affects the location or elevation of the work to be executed, and should any discrepancy be found, immediately report the same to the Architect for verification and adjustment.

# 3.02 LOCATION OF EQUIPMENT AND PIPING

A. Drawings showing location of equipment, piping, ductwork, etc. are diagrammatic and job conditions shall not always duplicate conditions shown. When this situation occurs, it shall be brought to the Architect's attention immediately and the relocation determined in a joint conference.

# 3.03 PATCHING EXISTING FACILITIES

- A. Existing structures, facilities, etc. that are damaged or removed due to required construction work, shall be patched, repaired or replaced, and be left in their original state of repair by the Contractor, to satisfaction of the Architect.
- 3.04 INTEGRATING EXISTING WORK
  - A. Protect existing improvements from damage.
  - B. Contractor's operations shall be confined to the immediate vicinity of the new work and shall not in any way interfere with or obstruct the ingress or egress to and from adjacent facilities.
  - C. Where new work is to be connected to existing work, special care shall be exercised not to disturb or damage the existing work more than necessary. All damaged work shall be replaced, repaired and restored to its original condition at no cost to the Owner.

# 3.05 ADJUSTING

- A. Where partitions are removed, patch floors, walls and ceilings with finish materials to match existing.
  - 1. Where removal of partitions results in adjacent spaces becoming one, rework floors and ceilings to provide smooth planes without breaks, steps or bulkheads.
  - 2. Where extreme change of plane occurs, request instructions from Architect as to method of making transition.
- B. Trim and refinish existing doors as necessary to clear new floors.

# 3.06 DAMAGED SURFACES

- A. Patch and replace any portion of an existing finished surface which is found to be damaged, lifted, discolored, or shows other imperfections, with matching material.
  - 1. Provide adequate support of substrate prior to patching the finish.
  - 2. Refinish patched portions of painted or coated surfaces in a manner to produce uniform color and texture over entire surface.
  - 3. When existing surface finish cannot be matched, refinish entire surface to nearest intersections.

# 3.07 TRANSITION FROM EXISTING TO NEW WORK

- A. When new work abuts or finishes flush with existing work, make a smooth and workmanlike transition. Patch work shall match existing adjacent work in texture and appearance so that the patch or transition is invisible at a distance of five feet.
  - 1. When finished surfaces are cut in such a way that a smooth transition with new work is not possible, terminate existing surface in a neat manner along a straight line at a natural line of division, and provide trim appropriate to finished surface.

# 3.08 DUST CONTROL

A. Precaution shall be exercised at all times to control dust created as a result of any operations during the construction period. If serious problems arise due to air borne dust, and when directed by Architect, operations causing such problems shall be temporarily discontinued and necessary steps taken to control the dust.

#### 3.09 FIRE PROTECTION

- A. Maintain good housekeeping practices to reduce the risk of fire damage and injury to workmen. All scrap materials, rubbish and trash shall be removed daily from in and about the work area and shall not be permitted to be scattered to adjacent areas.
- B. Suitable storage space shall be provided outside the immediate building area for storing flammable materials and paints; no storage will be permitted in the building. Excess flammable liquids being used inside the building shall be kept in closed metal container and removed from the building during unused periods.
- C. A fire extinguisher shall be available at each location where cutting or welding is being performed. Where electric or gas welding or cutting work is done, interposed shields of incombustible material shall be used to protect against fire damage due to sparks and hot metal. When temporary heating devices are used, a watchman shall be present to cover periods when other workmen are not on the premises.
- D. Provide fire extinguishers in accordance with the recommendations of NFPA Bulletins Nos. 10 and 241. However, in all cases a minimum of four fire extinguishers shall be available for each building.

#### 3.10 CLEANING

- A. Perform periodic and final cleaning as specified in Section 01 74 00, 01 50 00 and as follows:
  - 1. Clean Owner-occupied areas where construction or remodeling is occurring, daily.
    - 2. Clean areas of heavy dust production daily.
    - 3. Clean spillage and overspray immediately.
- B. At completion of work of each trade, clean area and make surfaces ready for work of successive trades.
- C. At completion of work in each area, provide final cleaning and return space to a condition suitable for use by Owner.

### **SECTION 01 41 00**

### REGULATORY REQUIREMENTS

## **PART 1 GENERAL**

### 1.01 RELATED REQUIREMENTS

A. Code and Regulatory Reguirements Data on Sheets A0-00 through A1-02 of the Drawings.

### 1.02 PERMITS AND FEES

- Office of Statewide Health Planning and Development (OSHPD) Requirements: OSHPD is the Α. primary agency having jurisdiction over project design and construction within healthcare facilities.
  - Licensed Contractors Declaration: Prepare and submit through Architect license documents 1. required for OSHPD approval.
  - Allow access to the Project site at any time to OSHPD designated Inspector of Record (IOR) 2. for the Project.
  - File OSHPD Verified Report forms every three months during construction. 3.
  - Office of Statewide Health Planning and Development (OSHPD) Building Permit will be 4. obtained and paid for by Owner.
- Β. Permits, Licenses, and Certificates: See General Conditions. For Owner's records, submit copies of permits, licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipts for fee payments, judgments, correspondence, records, and similar documents, established for compliance with environmental regulations bearing on performance of the Work.

# 1.03 CODES AND ORDINANCES

A. Compliance: All construction shall comply with all applicable codes, ordinances and regulations of federal, state, county, city, and special district agencies and jurisdictions having authority over the Project and in effect on the issue date of the Construction Documents: Applicable codes and regulations include, but are not necessarily limited to, the following:

California Code of Regulations (CCR), Title 8, Chapter 4, Subchapter 6, Elevator Safety Orders California Code of Regulations (CCR), Title 19, Public Safety

California Code of Regulations (CCR), Title 22, Social Security

California Code of Regulations (CCR), Title 24, Building Standards, Including, but not limited to:

Part 1 - 2016 California Building Standards Administrative Code (CAC)

Part 2 - 2016 California Building Code (CBC)

Part 3 - 2016 California Electrical Code (CEC)

Part 4 - 2016 California Mechanical Code (CMC

Part 5 - 2016 California Plumbing Code (CPC)

Part 6 - 2016 California Energy Code

Part 9 - 2016 California Fire Code (CFC)

Part 10 - 2016 California Existing Building Code

Part 11 - 2016 California Green Building Standards Code

Part 12 - 2016 California Referenced Standards Code

# 1.04 ADMINISTRATIVE APPROVALS

A. Compliance: General Contractor and all subcontractors shall comply with requirements of local public utility companies and state and local governmental departments, including but not necessarily limited to following:

Governing fire department requirements Utility company requirements

### 1.05 OTHER REGULATORY REQUIREMENTS

A. Compliance: All contractors shall comply with all other applicable laws and regulations in effect on the issue date of the Construction Documents, including but not necessarily limited to, the following:

All local, state, and federal (EPA) construction stormwater pollution control regulations, and monitoring requirements State and Federal Safety and Health Laws United States Department of Justice – 2010 ADA Standards for Accessible Design, September 15, 2010; available at www.ada.gov/ADAStandards\_index.htm.

### 1.06 DISCREPANCIES

A. If discrepancies occur between Contract Documents, local codes, local utility requirements, etc., most stringent requirements shall apply.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION - Not Used

### **SECTION 01 42 00**

### REFERENCES

# PART 1 GENERAL

## 1.01 DEFINITIONS

- A. General: Basic Contract definitions are included in the General Conditions.
- B. Indicated: The term "indicated " refers to graphic representations, notes, or schedule on the Drawings, other paragraphs or schedule in the Specifications, and similar requirements in the Contract Documents. Where terms such as " shown ", " noted", "scheduled," and "specified" are used it is to help the reader locate the reference; no limitations on location is intended.
- C. Directed: Terms such as "directed," "requested," authorized," "selected", "approved," "required," and "permitted" mean "directed by the Architect," requested by the Architect, and similar phrases.
- D. Approve: The term "approved," where used in conjunction with the Architect's action on the Contractor's submittals, applications, and requirements, is limited to the Architect's duties and responsibilities as stated in General and Supplementary Conditions.
- E. Regulation: The term "Regulations" included laws, ordinances, statutes, and lawful orders issued by authorities having jurisdiction, as well as rules, conventions, and agreements within the construction industry that control performance of the Work.
- F. Furnish: The term "furnish" is used to mean " supply and deliver to the Project site, ready for unloading, unpacking, assembly, installation, and similar operations."
- G. Install: The term "install" is used to describe operations at project site including the actual "unloading, unpacking, assembly, erection, placing, anchoring, applying, working to dimension, finishing, curing, protecting, cleaning, and similar operations."
- H. Provide: The term "provide " means "to furnish and install, complete and ready for the intended use."
- I. Installer: An "installer" is the Contractor or an entity engaged by the Contractor, either as an employee, subcontractor, or sub-subcontractor, for performance of a particular construction activity, including installation, erection, application, and similar operations. Installers are required to be experienced in the operations they are engaged to perform.
  - 1. The term "experienced" when used with the term "Installer" means having a minimum of 5 previous Projects similar in size and scope to this Project, being familiar with the precautions required, and having complied with requirements of the authority having jurisdiction.
- J. Trades: Use of titles such as "carpentry " is not intended to imply that certain construction activities must be performed by accredited or unionized individuals of a corresponding generic name, such as "carpenter." It also does not imply that requirements specified apply exclusively to tradesperson of the corresponding generic name.
- K. Assignment of Specialists: Certain Sections of the Specifications require that specified construction activities shall be performed by specialists who are recognized experts in the operations to be performed. The specialists must be engaged for those activities, and

assignments are requirements over which the Contractor has no choice or option. Nevertheless, the ultimate responsibility for fulfilling Contract requirements remains with the Contractor.

- 1. This requirement shall not be interpreted to conflict with enforcement of building codes and similar regulations governing the Work. It is also not intended to interfere with Local trade union jurisdictional settlements and conventions.
- L. Project Site is the space available to the Contractor for Performance of construction activities, either exclusively or in conjunction with others performing other work as part of the project. The extent of the Project Site is shown on the Drawings and may or may not be identical with the description of the land upon which the Project is to be built.
- M. Testing Laboratories: A "testing laboratory" is an independent entity engaged to perform specific inspections or tests, either at the Project Site or elsewhere, and to report on and, if required, to interpret results of those inspections or tests.
- N. Provide: Except as otherwise defined in greater detail, term "provide" means furnish and install, complete and ready for intended use, as applicable in each instance.
- O. Approved Equals-Equivalents:
  - 1. The words "similar and equal to", "or equal", equivalent" and such other words of similar content and meaning shall for the purposes of this contract be deemed to mean similar and equivalent to one of the named products. For the purpose of this article and for the purpose of the bidding documents, the word "products" shall be deemed to include the words " articles", "materials", "items', " equipment" and "methods". Whenever in the contract documents one or more products are specified, the words "similar and equal to" shall be inserted.
  - 2. Wherever any product is specified in the contract documents by a reference to the name, trade name, or catalog number of any manufacturer or supplier, the intent is not to limit competition, but to establish a standard of quality which the Architect has determined is necessary for the project. The Contractor may at their option use any product other than that specified in the contract documents provided the same is approved by the Architect in accordance with the acceptable procedures. However no substitutions will be allowed after bidding that changes product type or system type, as specified herein unless otherwise noted.
- P. Nothing in the contract documents shall be construed as representing, expressly or impliedly, that the named product is available or that there is or there is not a product similar and equal to any of the name products and the Contractor shall have and make no claim by reason of the availability of lack of availability of the named product or of a product similar and equal to any named product.

# 1.02 TECHNICAL SPECIFICATION FORMAT AND CONTENT EXPLANATION

- A. Technical Specification Format: These Technical Specifications are organized into Divisions and Sections on the basis of the 2014 Update to the Construction Specifications Institute (CSI) MasterFormat.
  - 1. The system of groups, subgroups and Divisions are listed in the Table of Contents of this Project Manual. It consists of 50 Divisions, Division 00 though Division 49, some of which are not used or are reserved for future expansion of the MasterFormat.
- B. Technical Specification Content: This Technical Specification uses certain conventions in the use of language and the intended meaning of certain terms, words, and phrases when used in particular situations or circumstances. These conventions are explained as follows:
  - 1. Abbreviated Language: Language used in Technical Specifications and other Contract Documents is the abbreviated type. Implied words and meaning will be appropriately

interpreted. Singular words will be interpreted as plural and plural words interpreted as singular where applicable and the full context of the Contract Documents so indicates.

- 2. Specification Methods: The techniques or methods of specifying to record requirements varies throughout text, and may include "prescriptive," "open generic descriptive,"" compliance with standards,"" performance," proprietary," or a combination of theses. The method used for specifying one unit of work has no bearing on requirements for another unit of work.
- 3. Overlapping and Conflicting Requirements: Where compliance with 2 or more industry standards or sets of requirements is specified, and overlapping of those different standards or requirements establishes different or conflicting minimum or levels of quality, the most stringent requirement is intended and will be enforced.
- C. Contractor's Options: Except for overlapping or conflicting requirements, where more than one set of requirements are specified for a particular unit of work, option is intended to be Contractor's regardless of whether or not it is specifically indicated as such.
  - 1. Minimum Quality/Quantity: In every instance, the quality level or quantity shown or specified is intended to be the minimum for the work to be performed or proved. Except as otherwise specifically indicated, the actual work may either comply exactly with that minimum (within specified tolerances). Or may exceed that minimum within reasonable limits. In complying with these requirements, indicated numeric values are either minimums or maximums as noted or as appropriate for context of the requirements. Refer instances of uncertainty to Architect/Engineer for decision before proceeding.
  - 2. Specialists, Assignments: In certain instances, specification text requires (or implies) that specific work is to be assigned to specialists or expert entitles, who must be engaged for the performance of that work. Such assignments shall be recognized as special requirements over which the Contractor has no choice or option. These requirements should not be interpreted so as to conflict with the enforcement of building codes and similar regulations governing the work; they are also not intended to interfere with local union jurisdiction settlements and similar Conventions. Such assignments are intended to establish which party or entity involved in a specific unit of work is recognized as "expert " for the indicated construction processes or operations. Nevertheless. The final responsibility for fulfillment of the entire set or requirements remains with the Contractor.
  - 3. Trades: Except as otherwise indicated, the use of titles such as "Carpentry " in specification text, implies neither that the work must be performed by an accredited or unionized tradesperson of corresponding generic name (such as "carpenter"), nor specified requirements apply exclusively to work by tradespersons of that corresponding generic name.

# 1.03 INDUSTRY STANDARDS

- A. Applicability of Standards: Except where the Contract Documents include more stringent requirements, applicable Construction industry standards have the same force and effects as if bound or copied directly into the Contract Documents. Such Standards are made a part of the Contract Documents by reference.
- B. Publication Dates: Where the date of issue of a referenced standard is not specified, comply with the standard in effect as of date of Contract Documents.
- C. Conflicting Requirements: Where compliance with two or more standards specified, and the standards establish different or conflicting requirements for minimum quantities or quality levels, refer requirements that are different, but apparently equal, and uncertainties to the Architect for a decision before proceeding.
  - 1. Minimum Quantity or Quality Levels: The quantity or quality level shown or specified shall be the minimum provided or performed. The actual installation may comply exactly with the minimum quantity or quality specified, or it may exceed the minimum within reasonable

limits. In complying with these requirements, indicated numeric values are minimum or maximum, as appropriate for the context of the requirements. Refer uncertainties to the Architect for a decision before proceeding.

- D. Copies of Standards: Each entity engaged in construction on the Project is required to be familiar with industry standards applicable to that entity's construction activity. Copies of applicable standards are not bound with the Contract Documents.
  - 1. Where copies of documents are needed for performance of a required construction activity, the Contractor shall obtain Copies from the publication source.
  - 2. Although copies of standards needed for enforcement of requirements may be included as part of required submittals, the Architect reserves the right to require the Contractor to submit additional copies as necessary for enforcement of requirements.
- E. Abbreviations and Names: Trade association names and titles of general standards are frequently abbreviated. Where such acronyms or abbreviations are used in the Specifications or other Contract Documents, they mean the recognized name of the trade associations, standards generating organization, authority having jurisdiction, or other entity application to the context of the text provision. Refer to the "Encyclopedia of Associations," published by Gale Research Co., available in, most libraries.

# 1.04 SUBMITTALS

A. Permits, Licenses, and Certificates: For the Owner's records, submit copies of permits, Licenses, certifications, inspection reports, releases, jurisdictional settlements, notices, receipt for fee payments, judgments, and similar documents, correspondence, and records established in conjunction with compliance with standards and regulations bearing upon performance of the Work.

PART 2 PRODUCTS - Not used

PART 3 EXECUTION - Not used

### **SECTION 01 45 20**

### QUALITY CONTROL SERVICES

# PART 1 GENERAL

### 1.01 SUMMARY

- A. This Section specifies administrative and procedural requirements for quality control services.
- B. Quality control services include inspections and tests and related actions including reports, performed by independent agencies, governing authorities, and the Contractor.
- C. Inspection and testing services are required to verify compliance with requirements specified or indicated. These services do no relieve the Contractor of responsibility for compliance with Contract Document requirements.
- D. Specific quality control requirements for individual construction activities are specified in the Sections that specify those activities. Those requirements, including inspections and test, cover production of standard products as well as customized fabrication and installation procedures.
- E. Inspection, test and related actions specified are not intended to limit the Contractor's control procedures that facilitate compliance with Contract Document requirements.
- F. Requirements for the Contractor to provide quality control services required by the Architect, Owner, or authorities having jurisdiction are not limited by provisions of this Section.

## 1.02 DEFINITIONS

- A. Quality Assurance: Administrative and procedural requirements for proactive activities to ensure the quality of construction before and during the execution of the Work.
  - 1. Activities and Requirements Included:
    - a. General qualification requirements for manufacturers, suppliers, installers, fabricators, and delegated designers.
    - b. Administrative and procedural requirements for field services provided by manufacturer's representatives.
    - c. General requirements for mockups and field samples constructed, applied, or assembled at the site for review and use as a quality standard.
  - 2. The term "Quality Assurance" as used in the CBC or in CBC-referenced standards may include "Quality Control" activities as defined by this Specification. Such possible discrepancies in terminology do not modify or eliminate any Quality Assurance or Quality Control requirement in the CBC or in these Project Specifications.
- B. Quality Control: Administrative and procedural requirements for reactive activities to evaluate completed activities and elements for conformance with the specified requirements.
  - 1. Activities and Requirements Included:
    - a. Correction of defective construction.
    - b. Contractor quality control.
    - c. Testing and inspection services.
    - d. Testing laboratory services.
    - e. Code-required special inspections and procedures.
  - 2. Where requirements of the CBC or of CBC-referenced standards are referred to in the code as "Quality Assurance" but meet this definition of "Quality Control," "Quality Control" activities

and requirements of this Project Specification shall be taken to mean the same as "Quality Assurance" as used in the CBC.

# 1.03 RESPONSIBILITIES

- A. Testing Agency: The District will employ and pay an independent agency, subject to approval by the Architect, to perform specified quality control services.
- B. Retesting: The Contractor is responsible for retesting where results of required inspections, tests or similar services prove unsatisfactory and do not indicate compliance with Contract Document requirements.
  - 1. The Contractor is responsible for reimbursing the Owner the costs for retesting of noncomplying work.
- C. Associated Services: The Contractor shall cooperate with agencies performing required inspections, tests and similar services and provide reasonable auxiliary services as requested. Notify the agency sufficiently in advance of operations to permit assignment of personnel. Auxiliary services required include but are not limited to.
  - 1. Providing access to the Work and furnishing incidental labor and facilities necessary to facilitate inspections and test.
  - 2. Taking adequate quantities of representative samples of materials that require testing or assisting the agency in taking samples.
  - 3. Provisions facilities for storage and curing of test samples, and deli every of samples to testing laboratories.
  - 4. Providing the agency with a preliminary design mix proposed fro use for materials mixes that require control by the testing agency.
  - 5. Security and protection of Samples and test equipment at the Project site.
- D. Duties of the Testing Agency: The independent testing agency engaged to perform inspections, sampling and testing of materials and construction Sections shall cooperate with the Architect and Contractor in performance of its duties, and shall provide qualified personnel to perform required inspections and tests.
  - 1. The agency shall notify the Architect and Contractor promptly of irregularities or deficiencies observed in the Work during performance of its services.
  - 2. The agency is not authorized to release, revoke, alter or enlarge requirements of the Contract Documents, or approve or accept any portion of the Work.
  - 3. The agency shall not perform any duties of the Contractor.
- E. Coordination: The Contractor and each agency engaged to perform inspections; tests and similar services shall coordinate the sequence of activities to accommodate required services with a minimum of delay. In addition to Contractor, each agency shall coordinated activities to avoid the necessity of removing and replacing construction to accommodate inspections and tests.
- F. The Contractor is responsible for scheduling time for inspections, tests, taking samples and similar activities

# 1.04 SUBMITTALS

- A. The independent testing agency shall submit a certified written repot of each inspection, test or similar service directly to the Architect, in duplicate, with a copy to the Contractor.
- B. Submit additional copies of each written report directly to the governing authority, when the authority so directs.

- C. Report Data: Written reports of each inspection, test or similar services shall include, but not be limited to:
  - 1. Date of issue.
  - 2. Project title, OSHPD project number, and Architect's project number.
  - 3. Name, address and telephone number of testing agency.
  - 4. Dates and locations of samples and tests or inspections.
  - 5. Names of individuals making the inspection or test.
  - 6. Designation of the Work and test method.
  - 7. Identification of product and specification Section.
  - 8. Complete inspection or test data.
  - 9. Test results and an interpretation of test results.
  - 10. Ambient conditions at the time of sample taking and testing.
  - 11. Comments or professional opinion as to whether inspection or tested Work complies with Contract Document Requirements.
  - 12. Name and signature of laboratory inspector.
  - 13. Recommendations on retesting.

# PART 2 PRODUCTS - Not Used

# PART 3 EXECUTION

- 3.01 REPAIR AND PROTECTION
  - A. General: Upon completion of inspection, testing, sample-taking and similar services, repair damage construction and restore substrates and finishes to eliminate deficiencies, including deficiencies in visual qualities of exposed finishes. Comply with Contract Document requirements for 'Cutting and Patching."
  - B. Protect construction exposed by or for quality control service activities, and protect repaired construction.
  - C. Repair and protection is the Contractor's responsibility, regardless of the assignment of responsibility for inspection, testing or similar services.

### **SECTION 01 50 00**

### **TEMPORARY FACILITIES AND CONTROLS**

## **PART 1 GENERAL**

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Temporary utilities.
  - 2. Construction facilities.
  - 3. Temporary construction.
  - 4. Construction aids.
  - 5. Temporary barriers and enclosures.
  - 6. Temporary controls.
- B. Related Requirements:
  - 1. Utility Usage: General Conditions, Article 56.
  - 2. Work Restrictions: Section 01 10 00 Summary.
  - 3. Alteration Project Procedures: Section 01 35 16.

### PART 2 PRODUCTS - Not Used

# PART 3 EXECUTION

# 3.01 TEMPORARY ELECTRICITY AND LIGHTING

- A. Service and Distribution:
  - 1. Contractor may connect to existing electrical power system for source of temporary electricity and lighting. Coordinate location and means of connection with Owner.
  - 2. Provide temporary electrical service and temporary wiring, outlets, lights, etc. as required for construction power and lighting during construction period.
  - 3. Properly ground service and distribution system in accordance with NEC. Provide ground fault interrupters as required by code.
  - 4. Remove temporary electrical service and wiring upon completion of work.
- B. Temporary Power Distribution:
  - 1. Supplement existing system as required. Provide minimum of one double duplex 120V outlet for every 100 lineal feet of temporary loop.
  - 2. Each Contractor: Furnish extension cords necessary to convey electricity from temporary loop outlets to locations of work.
  - 3. Special Power Required for Welders or Other Special Equipment: Provided by contractor requiring such power.
  - 4. Distribution equipment and wiring devices for temporary power and lighting need not be new, however, installation shall conform to safe general practice as required by OSHA.
- C. Temporary Lighting:
  - 1. Provide one light for every interior room regardless of square footage area except closets and pipe chases. In larger rooms, provide one light for every 750 square feet.
  - 2. Each Contractor: Provide plug-in portable lights as required for task lighting.

- D. Use of Permanent Systems:
  - 1. Existing permanent system and, where applicable, new or modified components of permanent system installed under this Contract, may be used as necessary for power and light.
  - 2. Be responsible for any damage to permanent wiring or fixtures as result of temporary use.
  - Permanent branch circuit wiring may be used to supply pigtail lights if protected by properly sized circuit breaker or fuse. Do not use permanent receptacles for construction power. Replace receptacles and device plates showing wear or abuse.
  - 4. Provide lamps necessary to temporarily light work in permanently installed fixtures.
  - 5. Clean permanently installed light fixtures that are used for temporary lighting during construction using methods and materials recommended by the manufacturer.
  - 6. Remove lamps used temporarily in permanent fixtures and replace with new lamps at completion of work.

### 3.02 TEMPORARY HEAT, VENTILATION AND ENCLOSURES

- A. Temporary Heat: Provide temporary heat necessary for execution of Work. Install, maintain and operate temporary heating apparatus in manner to facilitate work, to comply with ambient environmental limitations for installation of new products and materials required by the specifications and manufacturer's installation instructions, to enable work to continue, and to ensure finished work will not be damaged by cold or freezing.
- B. Enclosures: Provide temporary enclosures necessary for holding temporary heat for masonry and concrete work, and for thawing frozen ground.
- C. Use of Permanent System:
  - 1. In using permanent heating system, assume complete responsibility for its proper operation and for any damage that may occur to heating apparatus or any phase of work except such wear and tear that would ordinarily result from normal usage.
  - 2. At completion and before work is accepted by Owner, clean air vents and coils, clean cleanable filters and replace replacement air filters.
  - 3. If permanent heating system is used during construction, Contractor shall remain responsible for full mechanical guarantee from date of Notice of Acceptance of total Project by Owner.

#### 3.03 TEMPORARY WATER

- A. Existing System: Contractor may connect to existing water distribution system for source of temporary water.
  - 1. Coordinate location and means of connection with Owner.
  - 2. Provide temporary connection, plumbing, piping, etc. necessary to convey same to places needed.

# 3.04 TEMPORARY SANITARY FACILITIES

- A. Temporary Toilet Facilities: Provide and maintain, in neat and sanitary condition, adequate temporary self-contained chemical toilet facilities for use of employees engaged on work, in compliance with requirements of applicable codes, regulations, laws and ordinances. Locate units within fenced/screened area.
  - 1. Toilets in existing buildings shall not be used.

# 3.05 FIELD OFFICE AND OTHER TEMPORARY STRUCTURES

- A. Field Office: Provide and maintain suitable temporary field office.
  - 1. Telephone and Fax Service: Install telephone with answering machine and fax machine in field office. Pay for installation, maintenance, removal and other charges for use of telephone.
    - a. Make office and telephone/fax machine available for use by Owner and Architect.
  - 2. Photocopier: Install at least one photocopying machine in field office.
  - 3. Maintain current set of Drawings at site and make available for use by Architect.
- B. Temporary Structures: Provide temporary structures and storage areas as required.
  - 1. Remove offices and other temporary structures from site upon completion of work.
  - 2. Locate on site in orderly manner as coordinated with Owner.

### 3.06 TEMPORARY PROTECTIVE FACILITIES

- A. Provide and maintain protective devices and facilities for protection of public and general protection of workmen on project.
  - 1. Provide warning signs against hazards created by such features of construction as protruding nails, hoists, well holes, window openings, stairways and falling materials.
  - 2. Provide and maintain fire extinguishers and active fire hydrants where required. Maintain fire lanes to hydrants and other equipment as necessary for proper fire protection during construction.
  - 3. Provide temporary walks, roadways, trench covers, barricades, bulkheads, railings, danger lights and signals, etc. required for work by applicable safety laws and building codes.
  - 4. Maintain temporary protective facilities in good condition throughout term of work. Remove at completion of work. Repair and replace work damaged thereby.

### 3.07 PROTECTION FOR WORK IN PLACE

- A. Work in Place: When subject to injury because of operations being carried on adjacent, cover, board up, or substantially enclose with adequate protection.
  - 1. Block and board heads, jambs and sills of permanent openings used as thoroughfares for introduction of work and materials.
  - 2. Construct forms of protection in manner that, upon completion, entire work will be delivered to Owner in undamaged condition.

# 3.08 ACCESS

- A. Limit access to necessary routes to perform the work.
  - 1. Coordinate access with Owner.
  - 2. See Section 01 10 00 for limitations on access to site.

### 3.09 TEMPORARY CONTROLS

- A. General: Comply with local codes, ordinances and regulations.
- B. Noise Control:
  - 1. Minimize noise at all times. All equipment shall be properly muffled. Do not operate noisy equipment after 10:00 p.m.
  - 2. Noise control, during demolition and construction, shall be of utmost importance. The Owner may order the Contractor to stop a portion of the work which they consider the cause of excessive noise.

- 3. The Owner may order a temporary delay or postponement of certain construction activity if, in their opinion, such activity is detrimental to any patient care procedures or other affected hospital operations.
- 4. Jackhammers: Not allowed.
- C. Dust Control: When construction procedures result in dust which becomes a nuisance to the Owner, private property or traffic, control said dust.
  - 1. Temporary Dust Partitions: Construct dust tight. Minimum construction to 3/8 inch gypsum board on metal studs spaced at 24 inches on center. Provide fiberglass sill seal at floor and tape all joints with duct tape. Provide 3 inch thick mineral fiber sound batt insulation on construction side of partitions.
  - 2. Tacky Mat: First Step as manufactured by Advanced Laminated Material Applications, Inc. Provide at all dust partitions and as indicated.
  - 3. Provide polyethylene sheeting from top of ceiling to underside of deck above during construction.
- D. Debris Control: Continually police the work to prevent collection and scattering of debris uncovered, loosened, or caused by prosecution of the work.
- E. Pollution Control: Take extreme caution to prevent spilling or littering of water polluting substances. Do not dump any foreign materials into any portion of the sewer and storm sewer collection systems. Provide such labor, equipment, and materials as is necessary to remedy such pollution. No burning of debris nor any other air polluting methods or equipment will be allowed.
- F. See Section 01 10 00 Summary for related requirements.

# 3.10 CLEANING OF THE WORK

- A. General: Maintain Project and site in clean and orderly condition. Periodically clean interior areas. Regularly remove waste materials, debris and rubbish from site.
- B. Interior Areas: Clean prior to start of finish work and continue cleaning as required. Control cleaning operations so that dust and other particles will not adhere to newly coated surfaces.

### **SECTION 01 60 00**

# PRODUCT REQUIREMENTS

# PART 1 GENERAL

### 1.01 SUMMARY

- A. This Section specifies administrative, and procedural requirements governing the Contractor's selection of products for use in the Project.
- B. The Contractor's Constructions Schedule and the Schedule of submittals are included under Sections "Submittal Procedures."
- C. Standards: Refer to Section "References" for applicability of industry standards to products specified.

### 1.02 DEFINITIONS

- A. Definitions used in this Article are not intended to change the meaning of other terms used in the Contract Documents, such as "specialties," " systems," "structures," "finishes." " Accessories," and similar. Such terms such are self-explanatory and have well recognized meanings in the construction industry.
  - 1. "Products" are items purchased for incorporation in the Work, whether purchased for the Project or taken from previously purchased stock. The term "product" includes the terms "Material," " equipment," " system," and terms of similar intent.
  - 2. "Named Products "are items identified by manufacture's product name, including make or model designation, indicated in the manufacturer's published product literature, that is current as of the date of the Contract Documents.
  - 3. "Foreign Products", as distinguished from "domestic products," are items substantially manufactured (50 percent or more of value) outside of the United States and its possessions; or produced or supplied by entities substantially owned (more than 50 percent) by persons who are not citizens nor living within the United States and its possessions.
  - 4. "Materials ", are products that substantially shaped, cut, worked, mixed, finished, refined, or otherwise fabricated, processed, or installed to inform a part of the Work.
  - 5. "Equipment", is a product with operational part, whether motorized or manually operated, that requires service connections such as wiring or piping.

# 1.03 QUALITY ASSURANCE

- A. Source Limitations: To the fullest extent possible, provide products of the same kind, from a single source.
  - When specified products are available only form sources that do not or cannot produce a quantity adequate o complete project requirements in a timely manner, consult with the Architect for a determination of the most important product qualities before proceeding. Qualities may include attributes relating to visual appearance, strength, durability, or compatibility. When a determination has been made, select products from sources that produce products that possess these qualities, to the fullest extent possible.
- B. Compatibility of Options: When the Contractor is given the option of selecting between two or more products for use on the Projects, the product selected shall be compatible with products previously selected, even if previously selected products were also options.

- C. Foreign Product Limitations: Except under one or more of the following conditions, provide domestic products, not foreign products, for inclusion in the Work:
  - 1. No available domestic product complies with the Contract Document.
- D. Nameplates: Except for required labels and operating data, do not attach or imprint manufacture's or producer's nameplates or trademarks on exposed surfaces of products that will be exposed to view in occupied spaces or on the exterior.
- E. Labels: Locate required product labels and stamps on a concealed surface or, where required for observation after installation, on an accessible surface that is not conspicuous.
- F. Equipment Nameplates: Provide a permanent nameplate on each item on service-connected or power-operated equipment. Locate on an easily accessible surface, which are inconspicuous occupied spaces. The nameplate shall contain the following information and other essential operating data:
  - 1. Name of product and manufacturer.
  - 2. Model and serial number.
  - 3. Capacity.
  - 4. Speed.
  - 5. Ratings.

### 1.04 PRODUCT DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store and handle products in accordance with the manufacture's recommendations, using meanings and methods that will prevent damage, deterioration and loss, including theft.
- B. Schedule delivery to minimize long-term storage at the site and to prevent overcrowding of construction spaces.
- C. Coordinate delivery with installation time to ensure minimum holding time for items that are flammable, hazardous, easily damage, or sensitive to deterioration, theft and other losses.
- D. Deliver Products to the site in the manufacture's original sealed container or other packaging system, complete with labels and instructions for handling, storing, unpacking, protecting and installing.
- E. Inspect products upon delivery to ensure compliance with the Contract Documents, and to ensure that products are undamaged and properly protected.
- F. Store products at the site in a manner that will facilitate inspection and measurement of quantity or counting of units.
- G. Store heavy materials away from the project structure in a manner that will not endanger the supporting construction.
- H. Store products subjects to damage by the elements above ground, under cover in a weather tight enclosure, with ventilation adequate to prevent condensation. Maintain temperature and humidity within range required by manufacturer's instructions.
# PART 2 PRODUCTS

### 2.01 PRODUCT SELECTION

- A. General Product Requirements: Provide products that comply with the Contract Documents, that are undamaged and, unless otherwise indicated, unused at the time of installation.
  - 1. Provide products complete with an accessories, trim, finish, safety guards and other. Indicates and details needed for a complete installation and for the intended use and effect.
- B. Standard Products: Where available, provide standard products of types that have been produced and used successfully in similar situations on other projects.
- C. Product Selection Procedures: Product selection is governed by the Contract Documents and governing regulations, not by previous Project experience. Procedures governing product selection include the following:
  - 1. Where products or manufactures are specified by name, accompanied by the term "or equal," or " or approved equal " comply with the Contract Document provisions concerning "substitutions" to obtain approval for use of an unnamed product.
  - 2. Descriptive Specification Requirements: Where Specifications describe a product or assembly, listing exact characteristics required, with or without use of a brand or trade name, provide a product or assembly that provides the characteristics and otherwise complies with Contract requirements.
  - 3. Performance Specification Requirements: Where Specifications require compliance with performance requirements, provide products that comply with these requirements, and are recommended by the manufacturer for the application indicated. General overall performance of a product is implied where the product is specified for a specific application.
  - 4. Manufacturer's recommendations may be contained in published product literature, or by the manufacturer's certification of performance.
  - 5. Compliance with Standards, Codes and Regulations: Where the Specification only requires compliance with an imposed code, standard or regulation, select a product that complies with the standards, codes or regulations specified.
  - 6. Visual Matching: Where Specifications require matching and established Sample, the Architect's decision will be final on whether a proposed product matches satisfactorily.
  - 7. Where no product available within the specified category matches satisfactorily and also complies with other specified requirements, comply with provisions of the Contract Documents concerning " substitutions " for selection of a matching product in another product category, or for noncompliance with specified requirements.
  - 8. Visual Selection: Where specified product requirements include the phrase "... as selected from manufacturer's standard colors, patterns, textures..." or a similar phrase, select a product and manufacturer that comply with other specified requirements. The Architect will select the color, patterned and texture from the product line selected.

# PART 3 EXECUTION

# 3.01 INSTALLATION OF PRODUCTS

- A. Comply with manufacturer's instructions and recommendations for installation of products in the applications indicated. Anchor each product securely in place, accurately located and aligned with other Work.
  - 1. Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration until the time of Substantial Completion.

### **SECTION 01 61 65**

### LOW-EMITTING MATERIAL REQUIREMENTS

### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Common VOC requirements for interior adhesives.
  - 2. Common VOC requirements for interior sealants.
  - 3. VOC and formaldehyde limitations for engineered wood and wood-based panel products.
  - 4. Common VOC requirements for flooring.
  - 5. Common VOC requirements for acoustical ceiling tiles and wall systems.
  - 6. Common VOC requirements for insulation.
- B. Related Requirements:
  - 1. Common Product Requirements, General: Section 01 60 00 Product Requirements.
  - 2. Joint Sealants: Section 07 92 00.
  - 3. Acoustical Panel Ceilings: Section 09 51 13.
  - 4. Paints and Coatings: Section 09 90 00 09 91 23 Interior Painting.
  - 5. Sections in Divisions 01 through 49 specify indoor environmental quality requirements specific to the Work of each of those Sections.

## 1.02 REFERENCES

- A. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers."
  - 2. South Coast Air Quality Management District (SCAQMD) Rule No. 1168.

#### B. Definitions:

- 1. Adhesive: Any substance used to bond one surface to another by attachment. Includes adhesive bonding primers.
- 2. Interior: For purposes of this Section, "interior" shall mean inside the weatherproofing system and applied on-site.
- 3. Sealant: Any material with adhesive properties that is formulated primarily to fill, seal, or waterproof gaps or joints between two surfaces. Sealants include sealant primers and caulks.

#### 1.03 SUBMITTALS

- A. Particleboard and MDF: Submit third-party certification that formaldehyde emissions comply with Phase 1 standards of CARB Air Toxic Control Measure (ATCM) for Formaldehyde Emissions from Composite Wood Products, and with ANSI A208.1 or A208.2 as applicable, when tested in accordance with ASTM E1333.
  - 1. Provide documentation that composite wood and agrifiber products contain no ureaformaldehyde resins.

DELTA 4 DESIGN CHANGES 12/11/2017

# PART 2 PRODUCTS

- 2.01 FORMALDEHYDE LIMITS FOR MATERIALS
  - A. Formaldehyde limits shall be as follows:
    - 1. Hardwood Plywood: 0.05 ppm.
    - 2. Particleboard: 0.09 ppm.
    - 3. Medium-Density Fiberboard (MDF): 0.11 ppm.
    - 4. Thin MDF: 0.13 ppm.

### 2.02 ADHESIVES

- A. Provide low VOC types as recommended by the manufacturer of the material being installed. Adhesives shall comply with SCAQMD Rule 1168 and the IgCC.
- B. For interior applications use adhesives that comply with the following limits for VOC content when calculated according to SCAQMD Method 304, 316A or 316B:
  - 1. Indoor Carpet Adhesives: 50 g/L
  - 2. Carpet Pad Adhesives: 50 g/L
  - 3. Outdoor Carpet Adhesives: 150 g/L
  - 4. Wood Flooring Adhesive: 100 g/L
  - 5. Rubber Floor Adhesives: 60 g/L
  - 6. Subfloor Adhesives: 50 g/L
  - 7. Ceramic Tile Adhesives: 65 g/L
  - 8. VCT And Asphalt Tile Adhesives: 50 g/L
  - 9. Dry Wall And Panel Adhesives: 50 g/L
  - 10. Cove Base Adhesives: 50 g/L
  - 11. Multipurpose Construction Adhesives: 70 g/L
  - 12. Structural Glazing Adhesives: 100 g/L
  - 13. Single-Ply Roof Membrane Adhesives: 250 g/L
  - 14. CPVC Solvent Cement: 490 g/L
  - 15. PVC Solvent Cement: 510 g/L
  - 16. ABS Solvent Cement: 325 g/L
  - 17. Plastic Cement Welding: 250 g/L
  - 18. Adhesive Primer For Plastic: 550 g/L
  - 19. Contact Adhesive: 80 g/L
  - Special-Purpose Contact Adhesives (Contact Adhesives That Are Used to Bond Melamine-Covered Board, Metal, Unsupported Vinyl, Rubber, or Wood Veneer 1/16 Inch or Less in Thickness to Any Surface): 250 g/L
  - 21. Structural Wood Member Adhesive: 140 g/L

# 2.03 SEALANTS

- A. For interior applications use sealants that comply with the following limits for VOC content when calculated according to SCAQMD Method 304, 316A or 316B:
  - 1. Architectural Sealants: 250 g/L
  - 2. Architectural Sealant Primer:
    - a. Nonporous: 250 g/L
      - b. Porous: 775 g/L
  - 3. Modified Bituminous Sealant Primer: 500 g/L
  - 4. Other Sealant Primers: 750 g/L

# 2.04 PAINTS AND COATINGS

- A. For interior applications use paints, stains, and coatings that comply with the following limits for VOC content when calculated according to 40 CFR 59, Subpart D (EPA method 24) and the following chemical restrictions:
  - 1. Flat Coatings: 50 g/L.
  - 2. Nonflat Coatings: 100 g/L.
  - 3. Nonflat High Gloss Coatings: 150 g/L.
  - 4. Basement Special Coatings: 400 g/L.
  - 5. Bond Breakers: 350 g/L.
  - 6. Concrete Curing Compounds: 350 g/L.
  - 7. Concrete/Masonry Sealers: 100 g/L.
  - 8. Dry-Fog Coatings: 150 g/L.
  - 9. Faux Finishing Coatings: 350 g/L.
  - 10. Fire-Resistive Coatings: 350 g/L.
  - 11. Floor Coatings: 100 g/L.
  - 12. Form-Release Compounds: 250 g/L.
  - 13. Graphic Arts Coatings (Sign Paints): 500 g/L.
  - 14. High-Temperature Coatings: 420 g/L.
  - 15. Industrial Maintenance Coatings: 250 g/L.
  - 16. Low Solids Coatings: 120 g/L.
  - 17. Magnesite Cement Coatings: 450 g/L.
  - 18. Mastic Texture Coatings: 100 g/L.
  - 19. Metallic Pigmented Coatings: 500 g/L.
  - 20. Multi-Color Coatings: 250 g/L.
  - 21. Pretreatment Wash Primers: 420 g/L.
  - 22. Primers, Sealers, and Undercoaters: 100 g/L.
  - 23. Reactive Penetrating Sealers: 350 g/L.
  - 24. Recycled Coatings: 250 g/L.
  - 25. Rust-Preventive Coatings: 250 g/L.
  - 26. Shellacs, Clear: 730 g/L.
  - 27. Shellacs, Pigmented: 550 g/L.
  - 28. Stains: 250 g/L.
  - 29. Stone Consolidants: 450 g/L.
  - 30. Swimming Pool Coatings: 340 g/L.
  - 31. Tub and Tile Refinish Coatings: 420 g/L.
  - 32. Waterproof Membranes: 250 g/L.
  - 33. Wood Coatings: 275 g/L.
  - 34. Wood Preservatives: 350 g/L.
  - 35. Zinc-Rich Primers: 340 g/L.

# 2.05 FLOORING SYSTEMS

A. Flooring materials shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers." Formaldehyde emissions shall not exceed 16.5 micrograms/cu. m or 13.5 ppb, whichever is less. Where postmanufactured coatings or applications have not been applied, concrete; ceramic and concrete tile; clay and concrete pavers; metal; and organic-free, mineral-based flooring shall be deemed to comply with this requirement.

# 2.06 ACOUSTICAL CEILINGS

A. Acoustic ceilings shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions

from Indoor Sources Using Environmental Chambers." Formaldehyde emissions shall not exceed 16.5 micrograms/cu. m or 13.5 ppb, whichever is less.

# 2.07 WALL SYSTEMS

A. Wall systems shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers." Formaldehyde emissions shall not exceed 16.5 micrograms/cu. m or 13.5 ppb, whichever is less. Where postmanufactured coatings or applications have not been applied, concrete, concrete masonry, clay masonry, gypsum plaster, ceramic and concrete tile, metal, and organic-free, mineral-based materials shall be deemed to comply with this requirement.

#### 2.08 INSULATION

A. Insulation shall comply with the requirements of the California Department of Public Health's "Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers." Formaldehyde emissions shall not exceed 16.5 micrograms/cu. m or 13.5 ppb, whichever is less, except for insulation manufactured without formaldehyde.

### 2.09 COMPOSITE WOOD AND AGRIFIBER PRODUCTS

- A. Do not use composite wood and agrifiber products that contain urea-formaldehyde resin.
- B. Engineered Wood Products:
  - 1. Determine formaldehyde concentrations in air from wood products under test conditions of temperature and relative humidity in accordance with ASTM D6007 or E1333.
  - 2. Determine Volatile Organic Compounds (VOC), excluding formaldehyde, emitted from manufactured wood-based panels in accordance with ASTM D6330.
- C. Composite Panel Products:
  - 1. Determine formaldehyde concentrations in air from wood-based panel products under test conditions of temperature and relative humidity in accordance with ASTM D6007 or E1333.
  - 2. Determine Volatile Organic Compounds (VOC), excluding formaldehyde, emitted from manufactured wood-based panels in accordance with ASTM D6330.
  - 3. Particleboard Manufacturer's, MDF Manufacturer's, and Melamine Laminator's Facility: CPA EPP (Environmentally Preferable Product) Downstream Licensed Facility.

# PART 3 EXECUTION - Not Used

### **SECTION 01 64 00**

### **OWNER-FURNISHED PRODUCTS**

# PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Owner-furnished products for installation by Contractor (O.F.C.I.).
- B. Related Requirements:
  - 1. Owner-Furnished, Owner-Installed (O.F.O.I.) Products: Section 01 10 00 Summary.
  - 2. Common Product Requirements, Transportation, Storage and Handling of Products: Section 01 60 00 Product Requirements.
  - 3. Examination and Acceptance of Substrates and In-Place Construction to Receive Product Installation: Section 01 71 16 Acceptance of Conditions.
  - 4. General Product Installation Requirements: Section 01 73 19 Installation.

### 1.02 TRANSPORTATION AND HANDLING

- A. General: Comply with Section 01 60 00.
- B. Handling: Provide equipment and personnel to handle products by methods to prevent soiling or damage. Comply with manufacturer's written instructions.
- C. Material Safety Data Sheets (MSDS): During product transportation and handling, comply with controls specified on MSDS for each product required by OSHA to have a MSDS.
- D. Delivery: Coordinate delivery schedules with Owner.
- E. Inspection: Inspect shipments to ensure products comply with requirements, quantities are correct, and products are undamaged.
  - 1. Immediately inform Owner of damaged and defective items, if any.

### 1.03 STORAGE AND PROTECTION

A. General: Comply with Section 01 60 00.

# PART 2 PRODUCTS

#### 2.01 OWNER-FURNISHED PRODUCTS

- A. Products Furnished by Owner and Installed by Owner or Owner's Separate Vendor or Contractor: Items listed in Equipment Schedule on Drawings and identified as "O.F.O.I." See also Section 01 10 00.
- B. Products Supplied by Owner for Installation by Contractor Under This Contract: Items listed in Equipment Schedule or elsewhere on Drawings and identified as "O.F.C.I."

# PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Comply with Section 01 73 19 and applicable Sections in Divisions 03 through 31.

### **SECTION 01 71 16**

### ACCEPTANCE OF CONDITIONS

# PART 1 GENERAL

# 1.01 SUMMARY

- A. Section Includes:
  - 1. Procedures and general requirements for examination of existing conditions and verification of acceptable conditions for installation.
- B. Related Requirements:
  - 1. Common Product Requirements: Section 01 60 00 Product Requirements.
  - 2. General Product Installation Requirements: Section 01 73 19 Installation.
  - 3. Cutting and Patching: Section 01 73 29.

#### 1.02 QUALITY ASSURANCE

- A. Manufacturer's Instructions: Where installations include manufactured products, comply with manufacturer's applicable instructions and recommendations for verification of existing conditions to extent that these instructions and recommendations are more explicit or more stringent than requirements specified or indicated.
  - 1. Notify Architect of any conflicts between manufacturer's instructions or recommendations and requirements specified or indicated.
  - 2. Coordinate trades constructing substrate and trades installing products to substrate to ensure that surface preparation required by manufacturer's instructions is performed before product installation. Convene pre-installation conference if necessary and discuss issues relating to acceptance of conditions at conference.

# PART 2 PRODUCTS - Not Used

# PART 3 EXECUTION

#### 3.01 EXAMINATION

- A. Existing Conditions: The existence and location of site improvements, utilities, and other construction indicated as existing are not guaranteed. Before beginning work, investigate and verify the existence and location of mechanical and electrical systems and other construction affecting the Work.
  - 1. Before construction, verify the location and points of connection of utility services.
- B. Existing Utilities: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify the existence and location of underground utilities and other construction affecting the Work.
  - 1. Before construction, verify the location and invert elevation at points of connection of sanitary sewer, storm sewer, and water-service piping; and underground electrical services.
  - 2. Furnish location data for work related to Project that must be performed by public utilities serving Project site.

- C. Inspection of Substrates: Require installer of each major unit of work to inspect substrate to receive work and conditions under which work is to be performed.
  - 1. Verify compatibility with and suitability of substrates, including compatibility with existing finishes or primers.
  - 2. Examine roughing-in for mechanical and electrical systems to verify actual locations of connections before equipment and fixture installation.
  - 3. Examine walls, floors, and roofs for suitable conditions where products and systems are to be installed.
- D. Installer: Report unsatisfactory conditions to General Contractor in writing with copy to Architect. Include recommended corrections.
- E. Proceed with installation only after unsatisfactory conditions have been corrected. Proceeding with the Work indicates acceptance of surfaces and conditions.

# **SECTION 01 73 19**

### INSTALLATION

# PART 1 GENERAL

# 1.01 SUMMARY

- A. Section Includes:
  - 1. Common requirements for installing products and materials.
- B. Related Requirements:
  - 1. Examination and Acceptance of Substrates and In-Place Construction to Receive Product Installation: Section 01 71 16 Acceptance of Conditions.
  - 2. Common Product Requirements, Transportation, Storage and Handling of Products: Section 01 60 00 Product Requirements.
  - 3. Cutting and Patching: Section 01 73 29.

### 1.02 REFERENCES

- A. Reference Standards: Comply with the following as applicable:
  - 1. United States Department of Justice 2010 ADA Standards for Accessible Design, September 15, 2010; available at <u>www.ada.gov/ADAStandards\_index.htm</u>.

# 1.03 QUALITY ASSURANCE

- A. Manufacturer's Instructions: Where installations include manufactured products, comply with manufacturer's applicable instructions and recommendations for installation to extent that these instructions and recommendations are more explicit or more stringent than requirements specified or indicated.
  - 1. Refer to manufacturer's warranty, where applicable, and comply with all installation stipulations necessary to obtain warranty.
  - 2. Compliance with manufacturer's instructions shall include compliance with manufacturer's requirements, if any, for verification of conditions and surface preparation prior to installation, and shall include manufacturer's instructions for protection and cleaning after installation.
  - 3. Notify Architect of any conflicts between manufacturer's instructions or recommendations and requirements specified or indicated.
  - 4. Maintain one copy of each on site from time of product delivery to site until installation and final cleaning of product is complete.

# PART 2 PRODUCTS

#### 2.01 MATERIALS

A. Hazardous Materials: Use products, cleaners, and installation materials that are not considered hazardous.

# PART 3 EXECUTION

# 3.01 INSTALLATION

- A. General: Locate the Work and components of the Work accurately, in correct alignment and elevation, as indicated.
  - 1. Make vertical work plumb and make horizontal work level.
  - 2. Where space is limited, install components to maximize space available for maintenance and ease of removal for replacement.
- B. Attachment: Provide attachment and connection devices and methods for securing work.
  - 1. Secure work true to line and level, and within specified tolerances, or if not specified, industry recognized tolerances.
  - 2. Allow for expansion and building movement.
  - 3. Exposed Joints:
    - a. Provide uniform joint width.
    - b. Arrange joints to obtain best visual effect.
    - c. Refer questionable visual-effect choices to Architect for final decision.
- C. Measurements and Dimensions: Recheck as integral step of starting each installation.
- D. Climatic Conditions and Project Status: Install each unit of work under conditions to ensure best possible results in coordination with entire Project.
  - 1. Isolate each unit of work from incompatible work as necessary to prevent deterioration.
  - 2. Coordinate enclosure of work with required inspections and tests to minimize necessity of uncovering work for those purposes.
- E. Mounting Heights: Where not indicated, mount individual units of work at industry recognized standard mounting heights for particular application indicated.
  - 1. Refer questionable mounting heights choices to Architect for final decision.
  - 2. Comply with ADA Standards as applicable.
- F. Conceal pipes, ducts, and wiring in finished areas, unless otherwise indicated.
- G. Maintain minimum headroom clearance of 8 feet in spaces without a suspended ceiling.

#### 3.02 PROTECTION

A. Conduct construction operations so no part of the Work is subjected to damaging operations or loading in excess of that expected during normal conditions of occupancy.

### **SECTION 01 73 29**

### **CUTTING AND PATCHING**

# PART 1 GENERAL

# 1.01 SUMMARY

- A. Work Results: All cutting, fitting and patching required to complete work and to:
  - 1. Make its parts fit together properly.
  - 2. Uncover portions of work to provide for installation of ill-timed work.
  - 3. Remove and replace defective work.
  - 4. Remove and replace work not conforming to requirements of Contract Documents.
  - 5. Remove samples of installed work as specified for testing.
  - 6. Provide routine penetrations of non-structural surfaces for installation of piping and electrical conduit.
- B. Related Requirements:
  - 1. Selective Demolition: Section 02 41 19.

### 1.02 ADMINISTRATIVE REQUIREMENTS

- A. Notification of Architect: Notify Architect well in advance of executing any cutting or alteration that affects:
  - 1. Work of Owner or any separate contractor.
  - 2. Structural value or integrity of any element of Project.
  - 3. Integrity or effectiveness of weather-exposed or moisture-resistant elements or systems.
  - 4. Efficiency, operational life, maintenance or safety of operational elements.
  - 5. Visual qualities of sight-exposed elements.

# PART 2 PRODUCTS

- 2.01 MATERIALS
  - A. Comply with specifications and standards for each specific product involved.

## PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Existing Conditions:
  - 1. Examine existing conditions of Project, including elements subject to damage or to movement during cutting and patching.
  - 2. After uncovering work, examine conditions affecting installation of products or performance of work.
- B. Notification: Report unsatisfactory or questionable conditions to Architect. Do not proceed with work until Architect has provided further instructions.

# 3.02 PREPARATION

- A. Protection: Provide adequate temporary support as necessary to ensure structural value and integrity of affected portion of work. Provide devices and methods to protect other portions of Project from damage.
  - 1. Provide protection from elements for that portion of Project that may be exposed by cutting and patching work.

# 3.03 CUTTING AND PATCHING

- A. General: Provide openings in construction that are required for later work.
  - 1. Various Contractors: Be responsible to supply in advance, proper and sufficiently detailed information for openings.
  - 2. In event of failure to supply this advance information, required cutting shall be done only after concurrence of Architect and at expense of negligent party.
- B. Cutting:
  - 1. Execute cutting and demolition by methods that will prevent damage to other work, and will provide proper surfaces to receive installation or repairs.
  - 2. Employ the original installer or fabricator to perform cutting and patching for:
    - a. Weather-exposed or moisture-resistant elements.
    - b. Sight-exposed finished surfaces.
  - 3. Employ the original installer or fabricator to perform cutting and patching for:
    - a. Weather-exposed or moisture-resistant elements.
    - b. Sight-exposed finished surfaces.
  - 4. Cut asphalt, concrete or masonry using masonry saw or core drill as applicable. Pneumatic tools will not be allowed unless accepted by Architect.
- C. Fitting: Execute fitting and adjustment of products to provide finished installation to comply with specified products, functions, tolerances and finishes. Fit work airtight to pipes, sleeves, ducts, conduit and other penetrations through surfaces.
- D. Patching: Wherever any pipe, conduit, duct, steel member, bracket, equipment, or other material penetrates or passes through fire-resistant wall, ceiling or floor, completely seal voids in construction with cement grout, plaster, or fire-resistant material, embedding sealing material full thickness of wall, ceiling or floor.
- E. Finishing: Where surfaces are exposed, finish with same materials specified in finish schedule or material that is on constructed surfaces.
  - 1. Work: Accomplish with mechanics skilled in finish trade.
  - 2. Refinish entire surfaces as necessary to provide even finish to match adjacent finishes:
    - a. For continuous surfaces, refinish to nearest intersection.
    - b. For assembly, refinish entire unit.

### **SECTION 01 77 00**

# CLOSEOUT PROCEDURES

# PART 1 GENERAL

#### 1.01 SUMMARY

- A. This Section specifies administrative, and procedural requirements for project closeout, including but not limited to.
  - 1. Inspection procedures.
  - 2. Project record document submittal.
  - 3. Operating and maintenance manual submittal.
  - 4. Submittal of warranties.
  - 5. Final cleaning.
- B. Closeout requirements for specific construction activities are included in the appropriate Sections in Divisions 02 through 49.

### 1.02 SUBSTANTIAL COMPLETION

- A. Preliminary Procedures: Before requesting inspection for Certification of Substantial Completion, complete the following. List exception in the request.
  - 1. In the Application for Payment that coincides with, or first follows, the date Substantial Completion is claimed, show 100 percent completion for the portion of the Work claimed as substantially complete. Include supporting documents for completion as indicated in these Contract Documents and a statement showing an accounting of changes to the Contract Sum.
    - a. If 100 percent completion cannot be shown, include a list of delayed items, the value of delayed construction, and reasons the Work is not complete.
  - 2. Submit specific warranties, workmanship bonds, maintenance agreements, final certifications and similar documents, including the Contractor's written warranty of all work (in place) written on firm's letterhead stationary.
- B. Obtain and submit release enabling the Owner unrestricted use of the Work and access to services and utilities; include occupancy permits, operating certificates and similar releases, including, but not limited to:
  - 1. Affidavit of Releases of Liens on AIA Form G706-A:

From Contractor From Sub Contractor(s) From Major material Supplier(s)

2. Affidavit of Debts and Claims Payment on AIA Form G-706:

From Contractor From Sub Contractor(s)

- 3. Submit Contractor's Guarantee Showing:
  - a. One-year warranty from date of Final Acceptance listing all items, which were unable to be completed.
  - b. Certified and current copy of Power of Attorney.
- 4. Submit record drawings, maintenance manuals, final project photographs, damage or settlement survey, and similar final record information.

- 5. Deliver tools, spare parts, Extra stock, and similar items.
- 6. Advise the Owner's personnel of changeover in security provisions.
- 7. Complete start-up testing of systems, and instruction on the Owner's operating and maintenance personnel. Determined or change over and remove temporary facilities from the site, along with construction tools, mock-ups, and similar elements.

### 1.03 FINAL ACCEPTANCE

- A. Preliminary Procedures: Before requesting final inspection for certification of final acceptance and final payment, complete the following: List exceptions in the request.
  - 1. Submit the final request with release and supporting documentation not previously submitted and accepted. Include certificates of insurance for products and completed operations where required.
  - 2. Submit an updated final statement, accounting for final additional changes to the Contract Sum.
  - 3. Submit a certificated copy of the Architect's final inspection list of items to be completed or corrected, stating that each item has been completed or otherwise resolved for acceptance, and the list has been endorsed and dated by the Architect.
  - 4. Submit consent of surety to final payment.
  - 5. Submit evidence of final, continuing insurance coverage complying with insurance requirements.
- B. Reinspections Procedure: The Architect will reinspect the Work upon receipt of notice that the Work, including inspection list from earlier inspections, has been completed, except items whose completion has been delayed because of circumstances acceptable to the Architect.
- C. Upon completion of reinspections, the Architect will prepare a certificate of final acceptance, or advice the Contractor of Work that is incomplete or of obligations that have not been fulfilled but are required for final acceptance.
- D. If necessary, reinspections will be repeated.

### 1.04 RECORD DOCUMENT SUBMITTALS

- A. General: Do not use record documents for construction purposes; protect from deterioration and loss in a secure, fire-resistive location; provide access documents for the Architect's reference during normal working hours.
- B. Record Drawings: Maintain a clean, undamaged set of blue or black line whiteprints of Contract Drawings and Shop Drawings. Mark the set to show the actual installation where the installation varies substantially from the Work originally shown. Mark whichever drawing is most capable of showing conditions fully and accurately; where Shop Drawings are used, record a cross-reference at the corresponding location on the Contract Drawings. Give particular attention to concealed elements that would be difficult to measure and record at a later date.
  - 1. Mark record sets with red erasable pencil; use other colors to distinguish between variations in separate categories of the Work.
  - 2. Mark new information that is important to the Owner, but was not shown on Contract Drawings or shop Drawings.
  - 3. Note related change Order numbers where applicable
  - 4. Organize record drawing sheets into manageable sets, bind with durable paper cover sheets, and print suitable titles, dates and other identification on the cover of each set.
- C. Record Specifications: Maintain one complete copy of the Project Manual, including addenda, and one of other written constructions issued in printed form during construction. Mark these documents to show substantial variations in actual Work performed in comparison with the text of

the Specifications and modification. Give particular attention to substitutions, selection of options and similar information on elements that re concealed or cannot otherwise be readily discerned later by direct observation. Note related record drawing information and Product Data.

- 1. Upon Completion of the Work, submit record Specifications to the Architect for the Owner's records.
- D. Record Product Data: Maintain one copy of each Product Data submittal. Mark these documents to show significant variations in the actual Work performed in comparison with information submitted. Include variations in products delivered to the site, and from the manufacturer's installation instructions and recommendations. Give particular attention to concealed products and portions of the Work, which cannot otherwise be readily discerned later by direct observation. Note related Change orders and mark-up of record drawings and specifications.
  - 1. Upon completion of mark-up, submit complete set of record Product Data to the Architect for the Owner's records.
- E. Record Sample Submitted: Immediately prior to the date or dates of Substantial Completion, the Contractor will meet at the site with the Architect and the Owner's personnel to determine which of the submitted Samples have been maintained during progress of the Work are to be transmitted to the Owner for record purposes. Comply with delivery to the Owner's Sample storage area.
- F. Miscellaneous Record Submittals: Refer to other Specification Sections for requirements of miscellaneous record keeping and submittals in connection with actual performance of the Work. Immediately prior to the date or dates of Substantial Completion, complete miscellaneous records and place in good order, properly identified and bound or filled, ready for continued use and reference. Submit to the Architect for the Owner's records.
- G. Maintenance Manuals: Organize operation and maintenance data into suitable sets of manageable size. Bind properly indexed data in individual heavy-duty 2-inch, 3-inch vinyl-covered binders, with pocket folders for folded sheet information. Mark appropriate identification on front and spine of each binder. Include the following types of information.
  - 1. Emergency instructions.
  - 2. Spare parts list.
  - 3. Copies of warranties.
  - 4. Wiring diagrams.
  - 5. Recommended "turn around" cycles.
  - 6. Inspection procedures.
  - 7. Shop Drawings and Product Data.
  - 8. Fixture lamping schedule.

# PART 2 PRODUCTS - Not Used

# PART 3 EXECUTION

- 3.01 CLOSEOUT PROCEDURES
  - A. Operating and Maintenance Instructions: Arrange for each installer of equipment that requires regular maintenance to meet with the Owner's personnel to provide instruction in proper operation and maintenance. If installers are not experienced in procedures, provide instruction by manufacturer's representative.

# 3.02 FINAL CLEANING

- A. General: General cleaning during construction is required by the General Conditions and included in Section "Temporary Facilities".
- B. Cleaning: Employ experienced workers or professional cleaners for final cleaning. Clean each surface or unit to the condition excepted in a normal, commercial building cleaning and maintenance program. Comply with manufacturer's instructions.
- C. Complete the following cleaning operations before requesting inspection for certification of Substantial Completion.
  - 1. Remove labels that are not permanent labels.
  - 2. Clean transparent materials, including mirrors and glass in doors and windows. Remove glazing compound and other substances that are noticeable vision obscuring materials. Replace chipped or broken glass and other damaged transparent material.
  - Clean exposed exterior and interior hard-surfaced finishes to dust-free conditions, free of stains, films and similar foreign substances. Restore reflective surfaces to their original reflective condition.
  - 4. Wipe surfaces of mechanical and electrical equipment. Remove excess lubrication and other substances. Clean plumbing fixtures to a sanitary condition. Clean light fixtures.
  - 5. Clean the site, including landscape development areas, of rubbish, litter and foreign substances. Sweep paved areas broom clean; remove stains, spills and other foreign deposits. Rake grounds that are neither paved nor planted, to a smooth even-textured surface.
- D. Removal of Protection: Remove temporary protection and facility installed for protection of the Work during construction.
- E. Compliance: Comply with regulations of authority having jurisdiction and safety standards for cleaning. Do not burn waste materials. Do not bury debris or excess materials on the Owner's property. Do not discharge volatile, harmful or dangerous materials into drainage systems. Remove waste materials from the site and dispose of in a lawful manner.
  - 1. Where extra materials of value remaining after completion of associated Work have become the Owner's property, arrange for disposition of these materials as directed.

### **SECTION 01 78 39**

#### WARRANTIES

# PART 1 GENERAL

#### 1.01 SUMMARY

- A. This Section specifies administrative, and procedural requirements for warranties and bonds required by the Contract Documents, including manufacturers standard by the Contractor's Documents and special warranties.
- B. General closeout requirements are included in Section "Project Closeout.'
- C. Specific requirements for warranties for the Work and products and installation that are specified to be warranted, are included in the individual Sections of Divisions 02 through 49.
- D. Certifications and other commitments and agreements for continuing services to Owner are specified elsewhere in the Contract Documents.
- E. Disclaimers and Limitations: Manufacturer's disclaimers and limitations on product warranties do not relieve the Contractor of the warranty on the Work that incorporates the products, nor does it relieve suppliers, manufacturers, and subcontractors required to countersign special warranties with the Contractor.

### 1.02 DEFINITIONS

- A. Standard Product Warranties are preprinted written warranties published by individual manufacturers for particular products and are specifically endorsed by the manufacturer to the Owner.
- B. Special Warranties are written warranties require by or incorporate in the Contract Documents, either to extend time limit provide by standard warranties or to provide greater rights for the Owner.

### 1.03 WARRANTIES REQUIREMENTS

- A. Related Damages and Losses: When correcting warranted Work that this failed, remove and replace other Work that has been damaged as a result of such failure or that must be removed and replaced to provide access for correction of warranted Work.
- B. Reinstatement of Warranty: When Work covered by a warranty has failed and been corrected by replacement or rebuilding, reinstate the warranty by written endorsement. The reinstated warranty shall be equal to the original warranty with an equitable adjustment for depreciation.
- C. Replacement Cost: Upon determination that Work covered by a warranty has failed, replace or rebuild the Work to an acceptable condition complying with requirements for the cost of replacing or rebuilding defective Work regardless of whether the Owner has benefited from use of the Work through a portion of its anticipated useful service life.
- D. Owner's Recourse: Written warranties made to the Owner are in addition to implied warranties, and shall not limit the duties, obligations, right and remedies otherwise available under the law, nor shall warranty periods be interpreted as limitations on time in which the Owner can enforce such other duties, obligations, rights, or remedies.

- E. Rejection of Warranties: The Owner reserves the right to reject warranties and to limit selections to products with warranties not in conflict with requirements of the Contract Documents.
- F. The Owner reserves the right to refuse to accept Work for the Project where a special warranty, certification, or similar commitment is require on such Work or part of the Work, until evidence is presented that entities required to countersign such commitments are willing to do so.

PART 2 PRODUCTS - Not Used

PART 3 EXECUTION - Not Used

DIVISION 02 – EXISTING CONDITIONS

# **SECTION 02 41 19**

#### SELECTIVE DEMOLITION

# PART 1 GENERAL

#### 1.01 SUMMARY

- A. Work Results:
  - 1. For each phase of construction, erect dustproof enclosures separating occupied from unoccupied areas before beginning demolition. Include infection control partitions as noted on Drawings. Remove enclosures when work is completed and patch surfaces damaged by work.
  - 2. Remove designated existing building components and equipment as noted in Demolition Keynotes on Drawings.
  - 3. Remove designated ceiling grid and tiles, gypsum ceiling, light fixtures, sprinkler heads, HVAC equipment, access panels, and wall brackets as noted in RCP Demolition Keynotes on Drawings.
  - 5. Provide shoring and bracing as necessary to ensure structural safety during demolition and until erection of new construction.
  - 6. Cap and identify exposed utilities.
  - 7. Legally dispose of debris off site.
  - 8. Clean up and leave work areas prepared for new construction.
- B. Related Requirements:
  - 1. Construction Phasing and Use of Premises: Section 01 10 00 Summary and Phasing Plan on Drawings.
  - 2. Alteration Project Procedures: Section 01 35 16.
  - 3. Barricades, Warning Lights and Signs: Section 01 50 00 Temporary Facilities and Controls.
  - 4. Cutting and Patching: Section 01 73 29.
  - 5. Removal and Storage of Construction Materials: Section 02 42 00.
  - 6. Selective Roof Removal: Section 07 02 52 Cutting and Patching of Modified Bituminous Membrane Roofing.

#### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Definitions: Meaning of the following terms as used in these Specifications.
  - 1. Remove: Detach items from existing construction and legally dispose of them off-site unless indicated to be removed and salvaged or removed and reinstalled.
  - 2. Remove and Salvage: Carefully detach from existing construction, in a manner to prevent damage, and store as specified in Section 02 42 00.
  - 3. Remove and Reinstall: Detach items from existing construction, prepare for reuse, and reinstall where indicated under Section 02 42 00.
  - 4. Existing to Remain: Existing items of construction that are not to be permanently removed and that are not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.
- C. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. American National Standards Institute (ANSI) Standards; <u>www.ansi.org</u>.
    - a. ANSI/ASSE A10.6-2006 (R2016) Safety and Health Program Requirements for Demolition Operations.

- 2. National Fire Protection Association (NFPA); www.nfpa.org.
  - a. NFPA 241 Standard for Safeguarding Construction, Alteration, and Demolition Operations, 2013 edition.

#### 1.02 DEFINITIONS

- A. Remove: Detach items from existing construction and legally dispose of them off-site unless indicated to be removed and salvaged or removed and reinstalled.
- B. Existing to Remain: Existing items of construction that are not to be permanently removed and that are not otherwise indicated to be removed, removed and salvaged, or removed and reinstalled.

### 1.03 ADMINISTRATIVE REQUIREMENTS

- A. Existing Utility Services:
  - 1. Capping: Arrange and pay for disconnecting, removing and capping utility services within areas of demolition. Disconnect and stub off. Notify affected utility company in advance and obtain approval before starting this work.
  - 2. Identification: Place markers to indicate location of disconnected services. Identify service lines and capping locations on Project Record Documents.
- B. Materials Ownership:
  - 1. Materials to be Removed by Owner: Items which are removed prior to start of demolition shall remain property of Owner. All other items indicated to be removed but not indicated for reinstallation shall become property of Contractor who shall remove them from site.
    - a. Items to be Removed By Owner: Will be designated with marking prior to pre-bid tour of site.
  - 2. Unless otherwise indicated, demolition waste becomes property of Contractor.
  - 3. Materials called out as salvaged or to be recycled are to be returned to the Owner and are retained as the property of the Owner. See Section 02 42 00.
- C. Coordination with Occupants: Portions of the building will be occupied during construction. See Section 01 10 00 Summary and Section 01 35 16. Do not interfere with use of occupied portions of building. Maintain free and safe passage to and from occupied areas.
- D. Predemolition Conference: Conduct conference at Project site.
  - 1. Inspect and discuss condition of construction to be selectively demolished.
  - 2. Review structural load limitations of existing structure.
  - 3. Review and finalize selective demolition schedule and verify availability of materials, demolition personnel, equipment, and facilities needed to make progress and avoid delays.
  - 4. Review requirements of work performed by other trades that rely on substrates exposed by selective demolition operations.
  - 5. Review areas where existing construction is to remain and requires protection.

#### 1.04 INFORMATIONAL SUBMITTALS

- A. Proposed Protection Measures: Submit report for review and approval, including drawings, that indicates the measures proposed for protecting individuals and property, for dust control, and for weather enclosure of the existing building to remain. Indicate proposed locations and construction of enclosures and barriers.
- B. Schedule of Selective Demolition Activities: Indicate the following:
  - 1. Detailed sequence of selective demolition and removal work, with starting and ending dates for each activity. Ensure Owner's on-site operations are uninterrupted.

- 2. Interruption of utility services. Indicate how long utility services will be interrupted.
- 3. Coordination for shutoff, capping, and continuation of utility services.
- 4. Use of elevator and stairs.
- 5. Coordination of Owner's continuing occupancy of portions of existing building and of Owner's partial occupancy of completed Work.
- C. Predemolition Photographs or Video: Submit before Work begins.

#### 1.05 SITE CONDITIONS

- A. Existing Conditions:
  - 1. Owner will occupy portions of building immediately adjacent to selective demolition area. Conduct selective demolition so Owner's operations will not be disrupted.
  - 2. Asbestos-Containing Materials: This Project is not known to have asbestos-containing materials in area designated for construction.

### PART 2 PRODUCTS

### 2.01 MATERIALS

A. Materials to be Reused: Section 02 42 00.

### 2.02 MATERIALS FOR TEMPORARY INFECTION CONTROL PARTITIONS

- A. Fire Resistive Corrugated Board:
  - 1. Basis of Design Manufacturer and Product:
    - a. Manufacturer: Coroplast LLC; <u>www.coroplast.com</u>.
    - b. Product: Firewall FRB.
  - 2. UL94 Class: 94V-2.
  - 3. Material: Polypropylene copolymer.
- B. Tacky Mat: First Step as manufactured by Advanced Laminated Material Applications, Inc. Provide at all dust partitions and as indicated.

# PART 3 EXECUTION

- 3.01 PREPARATION
  - A. Regulatory Requirements: Comply with governing EPA notification regulations before beginning selective demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
  - B. Review record documents of existing construction provided by Owner. Owner does not guarantee that existing conditions are same as those indicated in record documents.
  - C. Survey existing conditions and correlate with requirements indicated to determine extent of selective demolition required.
  - D. Site Access and Temporary Controls: Conduct selective demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.

- E. Temporary Facilities: Provide temporary barricades and other protection required to prevent injury to people and damage to facilities to remain.
  - 1. Provide protection to ensure safe passage of people around selective demolition area and to and from occupied portions of building.
  - 2. Provide temporary weather protection, during interval between selective demolition of existing construction on exterior surfaces and new construction, to prevent water leakage and damage to structure and interior areas.
  - 3. Protect walls, ceilings, floors, and other existing finish work that are to remain or that are exposed during selective demolition operations.
  - 4. Dust Protection: Erect and maintain dustproof partitions as required to prevent spread of dust, fumes and smoke to other parts of building. Erect and maintain infection control partitions from floor to underside of ceiling with zipper opening as indicated on Drawings. On completion, remove partitions and repair damaged surfaces to match adjacent surfaces.
  - 5. Cover and protect furniture, furnishings, and equipment that have not been removed.
- F. Temporary Shoring: Provide and maintain shoring, bracing, and structural supports as required to preserve stability and prevent movement, settlement, or collapse of construction and finishes to remain, and to prevent unexpected or uncontrolled movement or collapse of construction being demolished.
  - 1. Strengthen or add new supports when required during progress of selective demolition.
- G. Exterior Openings: Erect secure and weatherproof closures for exterior openings where work includes temporary penetration of exterior assemblies.

# 3.02 SELECTIVE DEMOLITION OF BUILDING ASSEMBLIES AND COMPONENTS

- A. Standards: Comply with ANSI/ASSE A10.6 and NFPA 241.
- B. General: Demolish and remove existing construction only to the extent required by new construction and as indicated. Demolish in orderly and careful manner as required to accommodate new work. Protect existing foundations and supporting structural members.
  - 1. Execute demolition in manner to limit unnecessary dust and noise. Burning of materials on site not allowed.
  - 2. Hazardous Materials: If the Contractor suspects that existing hazardous materials have been uncovered during demolition, do not disturb; immediately stop work in the area and notify the Owner. Hazardous materials will be removed by Owner under a separate contract.
  - 3. Neatly cut openings and holes plumb, square, and true to dimensions required. Use cutting methods least likely to damage construction to remain or adjoining construction. Use hand tools or small power tools designed for sawing or grinding, not hammering and chopping, to minimize disturbance of adjacent surfaces. Temporarily cover openings to remain.
  - 4. Cut or drill from the exposed or finished side into concealed surfaces to avoid marring existing finished surfaces.
  - 5. Do not use cutting torches until work area is cleared of flammable materials. At concealed spaces, such as duct and pipe interiors, verify condition and contents of hidden space before starting flame-cutting operations. Maintain fire watch and portable fire-suppression devices during flame-cutting operations.
  - 6. Maintain adequate ventilation when using cutting torches.
  - 7. Remove decayed, vermin-infested, or otherwise dangerous or unsuitable materials and promptly dispose of off-site.
  - 8. Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
  - 9. Locate selective demolition equipment and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.

- C. Protection:
  - 1. Provide necessary temporary shoring and bracing to support and protect portions of existing building during demolition operations. Leave such shoring in place until permanent supports have been installed. Be solely responsible for design, safety and adequacy of temporary shoring and bracing and its ability to carry load for which intended.
  - 2. Protect existing slab to remain. Perform demolition using methods that leave slab surface in optimal condition to receive new construction.
- D. Safety: Cease operations and notify Architect immediately if safety of structure appears to be endangered. Take precautions to properly support structure. Do not resume until safety is restored.
- E. Repair: Repair demolition performed in excess of that required at no cost to Owner.

#### 3.03 EXISTING FLOOR COVERINGS

A. Remove existing floor coverings where indicated or new floor coverings are scheduled. Remove existing mastic and leave floors smooth and clean and ready for new floor coverings.

### 3.04 UTILITY SERVICES AND MECHANICAL/ELECTRICAL SYSTEMS

- A. Existing Services/Systems to Remain: Maintain services/systems indicated to remain and protect them against damage.
- B. Existing Services/Systems to Be Removed, Relocated, or Abandoned: Locate, identify, disconnect, and seal or cap off indicated utility services and mechanical/electrical systems serving areas to be selectively demolished.
  - 1. Owner will arrange to shut off indicated services/systems when requested by Contractor.
  - 2. If services/systems are required to be removed, relocated, or abandoned, provide temporary services/systems that bypass area of selective demolition and that maintain continuity of services/systems to other parts of building.

#### 3.05 CLEANING

A. During demolition operations, keep premises free from accumulations of waste material or rubbish caused by employees or work, and at completion of work remove rubbish, tools and surplus material and leave premises clean and ready for subsequent work.

#### 3.06 WASTE MANAGEMENT

- A. General: Comply with Section 01 74 19.
- B. Promptly remove waste, rubbish or debris from site.
- C. Disposal of Demolished Materials: Except for items or materials indicated to be reused, salvaged, reinstalled, or otherwise indicated to remain Owner's property, remove demolished materials from Project site.
  - 1. Do not allow demolished materials to accumulate on-site.
  - 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.

### **SECTION 02 42 00**

# **REMOVAL AND SALVAGE OF CONSTRUCTION MATERIALS**

### PART 1 GENERAL

# 1.01 SUMMARY

- A. Work Results:
  - 1. Remove and salvage designated building equipment and fixtures indicated to be salvaged and delivered to Owner.
  - 2. Remove and salvage designated building equipment, doors, cabinets and fixtures indicated to be relocated in new construction.
  - 3. Store and protect items noted to be saved or relocated.
- B. Related Requirements:
  - 1. Keynotes on Drawings.
  - 2. Alteration Project Procedures: Section 01 35 16.
  - 3. Selective Demolition: Section 02 41 19.
- 1.02 ADMINISTRATIVE REQUIREMENTS
  - A. Building Occupancy: Carry out removal work to cause as little inconvenience to occupants as possible.
- 1.03 DELIVERY, STORAGE, AND HANDLING
  - A. Salvaged materials shall be handled with care and deposited in identified storage areas in an undamaged condition.
  - B. Maintain salvaged materials, clean and store and preserve materials in existing condition until reuse, delivery to or collection by Owner, or removal from site by Contractor.

# PART 2 PRODUCTS

- 2.01 EXISTING PRODUCTS
  - A. Materials and Products Removed by Owner: Items that are removed prior to start of demolition shall remain property of Owner.
  - B. Products to be Salvaged and Delivered to Owner: See Demolition Notes on Drawings. Items include, but are not necessarily limited to:
    - 1. Equipment to be removed but not to be relocated in the Work.
    - 2. Wall mounted board.
    - 3. Offer all salvageable materials to Owner.
  - C. Products and Materials to be Reused: All existing doors, frames, hardware, equipment and fixtures scheduled or noted to be reused in other portions of work shall be salvaged and stored on site for later reinstallation. Such products include, but are not necessarily limited to, the following:
    - 1. Equipment as indicated.
    - 2. Door operator and push plate.
    - 3. Sprinkler heads as indicated.
    - 4. Paging speakers.

TCMC Pharmacy USP 800 Upgrade Tri-City Medical Center SA Project No. 01667.00

- 5. Door and frame as scheduled on Drawings.
- 6. HVAC grilles.
- 7. Acoustical ceiling grid.

# PART 3 EXECUTION

# 3.01 EXAMINATION

A. Documentation of the original condition of materials to be salvaged for the Owner or for reinstallation shall be the responsibility of the Contractor. Undocumented damage shall become the responsibility of the Contractor and the Contractor shall make necessary repairs to these items before delivery to the Owner or reinstallation in the Project.

# 3.02 REMOVAL OF EQUIPMENT, BUILDING MATERIALS AND COMPONENTS

- A. General: Perform removal in orderly and careful manner as required to accommodate new work. Protect existing supporting structural members.
  - 1. Asbestos Containing Materials: If the Contractor suspects that existing asbestos containing materials have been uncovered during removal, immediately stop work in the area and notify the Owner.
- B. Materials to be Reused: Carefully remove materials, specialty items, equipment, etc. scheduled or noted to be reused in other portions of work and store at site for later reinstallation.

# 3.03 REPAIR

- A. Repair removal performed in excess of that required at no cost to Owner.
- B. Repair any damage caused during removal, storage or reinstallation to satisfaction of Architect.

### 3.04 CLEANING AND WASTE MANAGEMENT

A. During removal operations, keep premises free from accumulations of waste material or rubbish caused by employees or work, and at completion of work remove rubbish, tools and surplus material and leave premises clean and ready for subsequent work. Promptly remove waste, rubbish or debris from site.

### **SECTION 03 20 00**

#### CONCRETE REINFORCING

#### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Reinforcing bars for cast-in-place concrete.
  - 2. Doweling Into existing concrete.

#### 1.02 REFERENCES

- A. Reference Standards: See Section 01 42 00. Comply with listed reference standards except as modified by supplemental requirements on the Drawings or by these Specifications.
  - 1. ACI 117-10 Specification for Tolerances for Concrete Construction and Materials.
  - 2. ACI 301-10 Specifications for Structural Concrete.
  - 3. ACI 548.12-12 Specification for Bonding Hardened Concrete and Steel to Hardened Concrete with an Epoxy Adhesive.
- B. Guide References and Standard Practices:
  - 1. SP-66(04) ACI Detailing Manual 2004.
  - CRSI MSP Manual of Standard Practice of the Concrete Reinforcing Steel Institute, 2009, 28<sup>th</sup> edition.
- 1.03 COORDINATION
  - A. Multi-Section Assembly Coordination Requirements: Coordinate the work of this Section with work under the following Sections to provide complete assemblies indicated on the Drawings.
     1. Patching Slab: Section 03 30 53 Miscellaneous Cast-In-Place Concrete.
- 1.04 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
  - B. Product Data: Submit manufacturer's current product literature for the following.
    1. Epoxy bonding adhesive. Include ICC-ES Report.

# PART 2 PRODUCTS

- 2.01 REINFORCING STEEL
  - A. Reinforcing Bars: ASTM A615, Grade 60, unless otherwise indicated on Structural Drawings.
    1. Dowels to be Adhesively Bonded Into Hardened Concrete: Embedded portions shall be straight and free of mill scale, rust and other coatings that may impair the bond with the adhesive.

### 2.02 ACCESSORIES

- A. Bonding Adhesive for Drilled-In Dowels:
  - 1. Basis of Design Manufacturer and Product: See Structural Drawings.
    - a. Simpson Strong Tie Co.; <u>www.strongtie.com</u> Set-XP Epoxy Adhesive Anchors with two-component epoxy. Refer to ICC ESR-2508.
    - b. Substitution Requests: Required for all proposed adhesive manufacturers and products not named as Acceptable Manufacturer and Product in this Section or on Drawings.
      - 1) Submit in accordance with Section 01 25 00.

# PART 3 EXECUTION

### 3.01 PREPARATION

A. Reinforcement: Clean prior to placing concrete to remove oil, soil, ice or other coatings that will destroy or reduce bond.

### 3.02 PLACEMENT

- A. General: Comply with General Notes on Structural Drawings and ACI 318.
- B. Bending:
  - 1. Bend reinforcement cold.
  - 2. Provide full-length bars, accurately bent to details by fabricator.
  - 3. Do not field-bend bars partially embedded in concrete except as indicated on the Drawings or specifically permitted by the Architect. Do not field-bend dowels adhesively bonded to concrete.
- C. Placing:
  - 1. Place reinforcement accurately and hold firmly in place before and during the placing of concrete.
  - 2. Provide minimum concrete protective cover for reinforcement from the exterior face of members in accordance with ACI 318 and notes on Drawings.
  - 3. Tolerances: Comply with ACI 117.

#### 3.03 DOWELING INTO EXISTING CONCRETE

- A. General: Comply with applicable ICC-ES report (ES-ESR) and ACI 548.12.
- B. Drilling:
  - 1. Drill holes into existing concrete as indicated using drill bit diameter and other tools specified in ICC ES-ESR for applicable reinforcing bar size.
  - 2. Do not drill through existing reinforcement without prior approval of Architect.
- C. Surface Preparation:
  - 1. Holes: Clean out dust, foreign particles and disintegrated materials for full depth of holes.
  - 2. Dowels: Clean to bare metal, free of dust, grease, scale and any other foreign materials on surface of dowel to be bonded.
- D. Adhesive Application and Dowel Insertion:
  - 1. Comply with Manufacturer's instructions, including contact time and temperature limitations.
  - 2. Insert dowels providing full embedment indicated on Drawings and within permitted embedment depth range scheduled in ICC ES-ESR.
  - 3. Fill entire annular space with adhesive.

E. Protection: Maintain within adhesive manufacturer's recommended temperature range and protect bars from disturbances for minimum 24 hours after installation. Do not place new adjacent concrete until adhesive is fully cured.

# 3.04 SITE QUALITY CONTROL

- A. Inspection:
  - 1. Notify Architect and Structural Engineer at least 48 hours before reinforcing steel installation is ready for inspection.
- B. Special Inspection: See General Notes on Structural Drawings and Section 01 45 20 Quality Control. Special Inspection is required for the following work under this Section.
  - 1. Adhesive bonding of dowels into existing concrete.
#### **SECTION 03 30 53**

#### MISCELLANEOUS CAST-IN-PLACE CONCRETE

#### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Work Results:
  - 1. Patching and infilling concrete floor slabs as indicated or required to complete the Work.
- B. Related Requirements:
  - 1. Selective Demolition: Section 02 41 19.
  - 2. Concrete Reinforcing: Section 03 20 00.

#### 1.02 REFERENCES

- A. Reference Standards: Comply with following except as modified by supplementary requirements of this Project Specification.
  - 1. American Concrete Institute (ACI) Standards:
    - a. ACI 301-10 Specifications for Structural Concrete.
    - d. ACI 308.1-11 Standard Specification for Curing Concrete.
  - 2. ASTM International Standards:
    - a. ASTM C94/C94M Ready-Mixed Concrete.
    - b. Other ASTM standards as referenced in this Section
- B. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified in this Project Manual.
  - 1. ACI 211.5R-01 Guide for Submittal of Concrete Proportions.
  - 2. ACI 309R-05 Guide for Consolidation of Concrete.

## 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Design Data:
  - 1. Concrete Mix Designs: Not less than two (2) weeks prior to placing any concrete, submit concrete mixes for acceptance in accordance ACI 211.5R. Separate mix design shall be submitted for each type of concrete to be used in the Project. Submittals shall include all information used in designing the mixes. See Mixes in Part 2 for design requirements.

#### 1.04 DELIVERY, STORAGE, AND HANDLING

- A. Ready-Mixed Concrete: Materials handling and batching shall conform to applicable provisions of ASTM C94.
  - 1. Hauling Time: Discharge concrete transmitted in truck mixer, agitator or other transportation device within 1-1/2 hours after mixing water has been added.
  - 2. Deliver concrete to site in exact proportions required by design mix.
  - 3. Extra Water: Should extra water be required for workability before depositing concrete and water/cementitious material ratio of accepted mix design will not be exceeded thereby, General Contractor's superintendent shall have sole authority to authorize addition of water.
    - a. Additional water added to mix after leaving batch plant shall be indicated on truck ticket and signed by person responsible.

- b. Where extra water is added to concrete it shall be mixed thoroughly for 50 revolutions of drum before depositing.
- c. Water may be added at the site only once for each batch.

# PART 2 PRODUCTS

## 2.01 MATERIALS

- A. Concrete Materials:
  - 1. General: Provide ready-mixed concrete conforming with ANSI/ASTM C94. On-job mixed concrete will not be allowed.
  - 2. Cement: ANSI/ASTM C150, Type I/II.
  - 3. Aggregate: Fine aggregate shall be natural sand and coarse aggregate shall be gravel or crushed stone, all conforming to ASTM C33. Maximum coarse aggregate size shall be determined by the thickness of members, finish required, and spacing of reinforcement and shall be approved by the Architect prior to placing any concrete.
  - 4. Water-Reducing Admixtures: ANSI/ASTM C494.

#### 2.02 MIXES

- A. Design: Proportion ingredients for mixes in accordance with ACI 301. Obtain this information in accordance with the latest ASTM specifications.
- B. Admixtures: No admixtures will be allowed except as specified herein, unless authorized by the Architect. Requests for approval or substitution must be accompanied by sufficient information and test data for evaluation.
- C. Slump: Design mix to provide slumps indicated under mix type.
- D. Mixing: Add aggregate and approximately two-thirds of the required water to the mixer first and mix a minimum of 70 revolutions at mixing speed to insure wetting of all the aggregate particles, at which time the cement, add the air entraining agent and the remaining water and mix a minimum of 30 revolutions of mixing speed.

# 2.03 CONCRETE MIX TYPES

- A. Concrete Design Mix Schedule: In addition to all requirements indicated by General Notes on Structural Drawings, design mix for each concrete component or application to meet the following criteria.
  - Mix For Slab Infill and Miscellaneous Concrete: Minimum compressive strength at 28 days as noted on Structural Drawings. 3/4-inch maximum aggregate size. No air entraining admixture. 4-inch maximum slump. Minimum Cement Content: 5-1/2 sack mix.

# PART 3 EXECUTION

#### 3.01 EXAMINATION

A. Architect's Examination: Provide ample notice to the Architect to allow observation of the preparation and placing of concrete. Do not begin placement until approval of Architect is obtained.

## 3.02 PREPARATION

- A. Do not begin concrete work until operations are complete enough to allow placement to be carried on as a continuous operation for the entire section that is to be placed. Clean equipment for mixing and transporting the concrete.
- B. Protection: Cover masonry walls, glazing, and other finish materials with polyethylene or otherwise protect from damage due to pouring of concrete.

## 3.03 PLACING CONCRETE

- A. General: Comply with ACI 301.
- B. Placement: Chuting in such a manner to separate the aggregates will not be permitted. Concrete shall not be dropped over 4'-0".
- C. Water: Prevent accumulations of water on the surface of the concrete due to water gain, segregation, or other causes, during placement or compacting, as far as possible by adjustments in the mixture. Make provision for removal of such water as may accumulate so that under no circumstances will concrete be placed in such accumulation.
- D. Compaction: Compact concrete during and immediately after placing.

# 3.04 FLATWORK

- A. General: Comply with ACI 301 5.3.4.
- B. Screeding: Screed and consolidate surfaces to shape slabs to indicated grades and elevations. Finish surfaces sparingly forcing coarse aggregate slightly below surface. Finish floor slab patches flush with adjacent concrete surfaces. Dusting of wearing surfaces with dry materials will not be permitted.
- C. Troweling:
  - 1. Floor Slabs: Steel troweled finish in accordance with ACI 301, Paragraph 5.3.4.2.c with two trowelings. Hand-trowel the surface smooth and free of trowel marks. Continue hand-troweling until a ringing sound is produced as the floor is troweled.
- D. Floor Flatness Tolerances: Floor slabs shall be level within following maximum tolerances measured with 10-foot long straightedge, except slope to drains as indicated.
   1. Floor Slabs: 1/4-inch in 10 feet.
- E. Requirements for Slab Finish: Comply with requirements of other Sections for slab tolerances, finishes, curing, etc. Be responsible to repair or replace slabs as required and specified in these Sections to meet requirements.

## 3.05 CURING AND PROTECTION

- A. Horizontal Surfaces: Keep the concrete surfaces continuously wet. Do not allow alternate wetting and drying of concrete surfaces.
- B. Final curing shall commence as soon as free water has disappeared from the concrete surface after placing and finishing.
- C. Moisture Retaining Cover Method:
  - 1. Cover all exposed fresh concrete surfaces and beyond the edge of the concrete surface with a white polyethylene sheeting of a minimum of 6 mil nominal thickness, placed in widest practicable width with sides and ends lapped at least 3 inches and sealed by waterproof tape or adhesive. Immediately repair any holes or tears during curing period using cover material and waterproof tape.
  - 2. Keep the concrete continuously wet under the sheeting.
  - 3. Keep sheeting in place a minimum of 7 days.
- D. Protection: Protect exposed surfaces of concrete from premature drying. Protect the concrete from damaging mechanical disturbances during the curing period. Protect finished surfaces from damage by construction equipment, materials or methods, application of curing procedures, or by running water. Protect concrete surfaces from staining, cracking, chipping, and other damage during progress of the work, and leave in good condition upon completion.

#### 3.06 MISCELLANEOUS CONCRETE REQUIREMENTS

A. Other Concrete Work: Furnish and install other concrete work indicated on the Drawings, even though not specifically mentioned herein to complete the work.

## 3.07 SITE QUALITY CONTROL

A. Record of Work: Keep a record listing the time and date of placement of concrete. Such record shall be kept until the completion of the Project and shall be available to the Architect for examination at any time.

#### **SECTION 03 62 00**

#### **NON-SHRINK GROUTING**

## PART 1 GENERAL

## 1.01 SUMMARY

- A. Section Includes:
  - 1. Shrink-resistant, cementitious, non-metallic grout for patching and infilling abandoned anchor holes in concrete floor slabs
  - 2. Shrink-resistant, cementitious, non-metallic grout elsewhere as indicated or as required to complete the Work.

## 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. ASTM International Standards:
    - a. ASTM C1107/C1107M-14a Packaged Dry, Hydraulic-Cement Grout (Non-Shrink).

## 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's product data sheets for each grout product to be installed under this Section.
- 1.04 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
  - B. Delivery and Acceptance Requirements: Deliver palletized in original sound, dry, unopened containers with manufacturer's source code marking.
  - C. Storage and Handling Requirements:
    - 1. Store under cover in dry area.
    - 2. Storage Temperature: Minimum 40 degrees F, maximum 90 degrees F unless recommended otherwise by manufacturer.
    - 3. Storage Damage: Immediately remove from site any material which becomes damp or otherwise defective during storage.
    - 4. Storage Time: 6 months maximum, or shorter time if so recommended by manufacturer.

# PART 2 PRODUCTS

- 2.01 MANUFACTURERS AND PRODUCTS
  - A. Acceptable Manufacturers and Products:
    - 1. BASF MasterFlow 928, MasterFlow 713 or MasterFlow 100.
    - 2. Dayton Superior Corporation 1107 Advantage Grout.
    - 3. Euclid Chemical Company Euclid NS Grout.

- L&M Construction Chemicals; <u>www.lmcc.com</u>; brand of Laticrete International, Inc. Duragrout.
- 5. Sika Corporation SikaGrout 212.
- 6. US Mix Co.; US Spec division; <u>www.usspec.com</u> US Spec MP Grout or Premium Grout.
- B. Substitution Requests: Required for all manufacturers and products not named as Acceptable.
  1. Submit in accordance with Section 01 25 00.

#### 2.02 DESCRIPTION

A. Grout Description: Packaged dry, non-gas forming, non-metallic, cementitious, non-shrink grout.
 1. Grout shall contain no aluminum powder.

#### 2.03 PERFORMANCE

- A. Grout Performance Requirements:
  - 1. Meet or exceed all performance requirements of ASTM C1107.
  - Compressive Strength: In addition to compressive strength performance requirements of ASTM C1107, grout shall provide the following minimum strengths when tested in accordance with ASTM C1107 at plastic consistency.
    - a. 3 Day Strength: 4,500 psi minimum.
    - b. 7 Day Strength: 6,000 psi minimum.
    - c. 28 Day Strength: 7,500 psi minimum.

# PART 3 EXECUTION

#### 3.01 EXAMINATION

A. Architect's Examination: Provide ample notice to the Architect to allow observation of the preparation and placing of grout. Do not begin placement until approval of Architect is obtained.

## 3.02 PREPARATION

- A. Surface Preparation for Cementitious Grouting:
  - 1. Clean steel and concrete surfaces of dirt, oil, grease, laitance, loose concrete and other contaminants.
  - 2. Remove free-standing water from concrete surfaces before grouting.

#### 3.03 PLACEMENT OF CEMENTITIOUS GROUT

- A. General: Mix and install grout in accordance with manufacturer's recommendations.
  - 1. Mix with minimum water necessary for placement method to be used.
  - 2. Extend grout with gravel for placements greater than 3 inches in depth.
- B. Grouting: Place grout at non-sag, damp pack consistency, completely filling infill space with grout. Manually compact to eliminate air pockets and voids.
- 3.04 FINISHING
  - A. Screeding: Screed and consolidate surfaces. Finish surfaces sparingly forcing coarse aggregate slightly below surface. Finish floor slab patches flush with adjacent concrete surfaces. Dusting of wearing surfaces with dry materials will not be permitted.

- B. Troweling:
  - 1. Floor Slabs Infill: Steel troweled finish in accordance with ACI 301, Paragraph 5.3.4.2.c with two trowelings. Hand-trowel the surface smooth and free of trowel marks. Continue hand-troweling until a ringing sound is produced as the floor is troweled.
- C. Requirements for Slab Finish: Comply with requirements of other Sections for slab tolerances, finishes, curing, etc. Be responsible to repair or replace slabs as required and specified in these Sections to meet requirements.

# 3.05 CURING

- A. Curing Cementitious Grout: Comply with manufacturer's instructions.
  - 1. Maintain grout temperature between 40 degrees F and 90 degrees F for minimum 24 hours following placement.
  - 2. Cover exposed grout surfaces with clean, wet rags and maintain moisture for minimum 6 hours following placement.

## **SECTION 05 05 19**

## **POST-INSTALLED CONCRETE ANCHORS**

## PART 1 GENERAL

## 1.01 SUMMARY

- A. Section Includes:
  - 1. Methods common to multiple sections for fastening metals, fabrications, manufactured products, hangers, and equipment to in-place concrete, precast concrete, or concrete masonry,. including:
    - a. Post-installed mechanical anchors.
    - b. Post-installed adhesive anchors.
- B. Related Requirements:
  - 1. General Notes on Structural Drawings.
  - Mechanical Expansion Anchors for Pipe Hangers and Plumbing Equipment: Section 22 05 29 Hangers and Supports for Plumbing Piping and Equipment.
  - 3. Mechanical Expansion Anchors for HVAC Pipe Hangers and HVAC Equipment: Section 23 05 29 Hangers and Supports for HVAC Piping and Equipment.
  - 4. Mechanical Expansion Anchors for Electrical Items and Supports: Section 26 05 29 Hangers and Supports for Electrical Systems.

# 1.02 REFERENCES

- A. Definitions:
  - 1. Interior Use: For purposes of this Section, "Interior Use" shall mean interior applications in a non-corrosive environment.
  - 2. Exterior Use: For purposes of this Section, "Exterior Use" shall mean applications exposed to weather in service and interior applications in a potentially corrosive environment, including, but not limited to, the interior of parking structures, pool rooms, pool equipment rooms, vehicle service and wash areas, animal holding rooms, shower areas and steam rooms.
- B. Reference Standards: See Section 01 42 00.
  - 1. American Concrete Institute (ACI) Standards:
    - a. ACI 355.2-07 Qualification of Post-Installed Mechanical Anchors in Concrete.
    - b. ACI 355.4-11 Qualification of Post-Installed Adhesive Anchors in Concrete.
  - 2. International Code Council Evaluation Service (ICC-ES) Standards:
    - a. AC193 Acceptance Criteria for Mechanical Anchors in Concrete Elements.
    - b. AC308 Acceptance Criteria for Post-Installed Adhesive Anchors in Concrete Elements.

#### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, action and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's technical data for the following.
  - 1. Post-Installed Anchors: Submit for each type proposed for use on Project. Include statement of proposed applications and locations for each type of anchor.

#### 1.04 INFORMATIONAL SUBMITTALS

- A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
- B. Evaluation Reports: Submit ICC-ES Evaluation Report for each manufactured anchor product proposed for use on the Project.
- C. Test Reports: Submit certified test reports showing compliance with specified performance characteristics and physical properties.
- D. Manufacturer's Instructions:
   1. Submit manufacturer's installation instructions.

#### 1.05 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 65 00 and Section 01 66 00.
  - 1. Protect metals from corrosion.
- B. Storage and Handling Requirements:
  - 1. Storage: Store manufactured anchors in accordance with manufacturer's recommendations.

## PART 2 PRODUCTS

- 2.01 PRODUCT OPTIONS
  - A. Basis of Design Anchor Manufacturer and Model: Where anchor manufacturer and model is indicated on Drawings, provide indicated product.
  - B. Where anchor manufacturer and model is not indicated on Drawings, subject to compliance with other specified requirements, provide one of the products named in this Section for anchor type indicated.
    - 1. Include anchors required to comply with installation instructions and typical details of product manufacturers and equipment suppliers under all divisions of these Specifications, where anchors are not furnished by supplier of the product or equipment to be anchored.
  - C. Substitution Requests: Required for all proposed post-installed anchor manufacturers and products not named in this Section or on Drawings.
    - 1. Submit current ICC-ES report with each proposed anchor substitution request. Report shall include compliance documentation for the proposed:
      - a. Base material to receive anchor;
      - b. Base material condition limitations;
      - c. Applicable loading conditions; and
      - d. Load direction(s).
    - 2. Submittals: Submit in accordance with Section 01 25 00.

# 2.02 REGULATORY REQUIREMENTS

A. Manufactured post-installed anchors shall have published ICC-ES Evaluation Report (ICC-ESR) indicating conformance with current applicable ICC-ES Acceptance Criteria and ICC approval as acceptable method of construction under the IBC. Comply with all limitations on use of anchors stipulated in Evaluation Report.

- B. Post-Installed Anchors for Supporting Fire Sprinkler Systems: Comply with NFPA 13. Anchors shall be qualified in accordance with UL for use with "Pipe Hanger Equipment and Fire Protection Systems."
- 2.03 POST-INSTALLED ANCHOR MATERIALS, GENERAL
  - A. Interior Use: Unless otherwise indicated on the Drawings, provide carbon steel anchors with zinc plating in accordance with ASTM B633, Type III Fe/Zn 5 (SC1) or hot-dip galvanizing in accordance with ASTM A153.
- 2.04 MECHANICAL ANCHORS
  - A. Regulatory Requirements:
    - 1. Mechanical Anchorage to Concrete: Expansion anchors, wedge anchors, sleeve anchors, undercut anchors, and drop-in anchors shall have current ICC-ES report that demonstrates compliance with ACI 355.2 as supplemented by AC193 for use in cracked concrete.
      - a. Structural Anchorages and Safety Related Anchorages in Structures Designed for Seismic Design Category C, D, E, or F: Documentation shall also show that anchor has passed simulated seismic tests in accordance with ACI 355.2.
        - 1) Seismic Design Category: See General Notes on Structural Drawings.
  - B. Wedge Anchors for Anchorage to Solid Concrete:
    - Manufacturers and Products: Where anchor manufacturer and product is not indicated, subject to compliance with requirements, provide the following:

       Hilti Inc.; www.us.hilti.com
       Kwik Bolt TZ (KB-TZ). Refer to ICC ESR-1917.
    - Description: Wedge type expansion anchor, torque-controlled, complete with required nuts and washers.
    - 3. Provide anchors with length identification markings conforming to ICC ES AC193.
    - 4. Type and size as indicated on Drawings or by manufacturer of product to be anchored.

# 2.05 CARTRIDGE INJECTION ADHESIVE ANCHORS

- A. Regulatory Requirements.
  - 1. Adhesive Anchorage to Concrete: Adhesive anchors shall have current ICC-ES report that demonstrates compliance with ACI 355.4 as supplemented by AC308 for use in cracked concrete.
    - a. Structural Anchorages and Safety Related Anchorages in Structures Designed for Seismic Design Category C, D, E, or F: Documentation shall also show that anchor has passed simulated seismic tests in accordance with ACI 355.4.
      - 1) Seismic Design Category: See General Notes on Structural Drawings.
- B. Manufacturers and Products Anchorage to Concrete: Where anchor manufacturer is not indicated, subject to compliance with requirements and acceptance by the Architect, provide one of the following:
  - 1. Hilti Inc.; <u>www.us.hilti.com</u> HIT RE 500-SD Adhesive Anchoring System with twocomponent epoxy with threaded rod anchors. Refer to ICC ESR-2322.
  - ITW Red Head division of Illinois Tool Works; <u>www.itwredhead.com</u> Epcon G5 Adhesive Anchoring System with two-component epoxy and threaded rod anchors. Refer to ICC ESR-1137.
  - 3. Powers Fasteners; <u>www.powers.com</u> PE1000+ Epoxy Adhesive Anchoring System with two-component epoxy and threaded rod anchors. Refer to ICC ESR-2583.
  - Simpson Strong Tie Co.; <u>www.strongtie.com</u> Set-XP Epoxy Adhesive Anchors with twocomponent epoxy and threaded rod anchors. Refer to ICC ESR-2508.

- C. Steel Anchors: Threaded steel rod or inserts, complete with nuts, washers, adhesive injection system. Type and size as indicated on Drawings.
  - Interior Use: Unless otherwise indicated on the Drawings, provide carbon steel threaded rods conforming to ASTM A36, ASTM A 193 Type B7 or ISO 898 Class 5.8 with zinc plating in accordance with ASTM B633, Type III Fe/Zn 5 (SC1) or carbon steel rods conforming to ASTM A510 with chemical composition of AISI 1038.

# PART 3 EXECUTION

# 3.01 INSTALLATION

- A General: Install post-installed anchors and inserts in accordance with applicable ICC-ES Report and with manufacturer's instructions in accurately drilled holes of required diameter and depth.
  - 1. Avoid installing anchors in contact with galvanically dissimilar metals.
- B. Drilling:
  - 1. Base Material Strength: Unless otherwise specified, do not drill holes in concrete or masonry until concrete, mortar, and grout has achieved full design strength.
  - 2. Drill holes with rotary impact hammer drills using carbide-tipped bits and core drills using diamond core bits. Drill bits shall be of diameters as specified by the anchor manufacturer. Unless otherwise shown on the Drawings, all holes shall be drilled perpendicular to the concrete surface.
    - a. Cored Holes: Where anchors are to be installed in cored holes, use core bits with matched tolerances as specified by the manufacturer.
    - b. Embedded Items: Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Exercise care in coring or drilling to avoid damaging existing reinforcing or embedded items. Notify the Architect and Structural Engineer if reinforcing steel or other embedded items are encountered during drilling. Take precautions as necessary to avoid damaging prestressing tendons, electrical and telecommunications conduit, and gas lines.
- C. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in part to be fastened. Set anchors to manufacturer's recommended torque, using a torque wrench. Following attainment of 10 percent of the specified torque, 100 percent of the specified torque shall be reached within 7 or fewer complete turns of the nut. If the specified torque is not achieved within the required number of turns, the anchor shall be removed and replaced unless otherwise directed by the Architect and Structural Engineer.
- D. Cartridge Injection Adhesive Anchors: Clean all holes in accordance with manufacturer instructions to remove loose material and drilling dust prior to installation of adhesive. Holes may be dry, damp or wet. Inject adhesive into holes proceeding from the bottom of the hole and progressing toward the surface in such a manner as to avoid introduction of air pockets in the adhesive. Follow manufacturer recommendations to ensure proper mixing of adhesive components. Sufficient adhesive shall be injected in the hole to ensure that the annular gap is filled to the surface. Remove excess adhesive from the surface. Shim anchors with suitable device to center the anchor in the hole. Do not disturb or load anchors before manufacturer specified cure time has elapsed.
- E. Observe manufacturer recommendations with respect to installation temperatures for cartridge injection adhesive anchors and capsule anchors.

# 3.02 ADJUSTING

A. Remove and replace misplaced or malfunctioning anchors. Fill empty anchor holes and patch failed anchor locations with high-strength non-shrink, nonmetallic grout. Anchors that fail to meet proof load or installation torque requirements shall be regarded as malfunctioning.

## 3.03 SITE QUALITY CONTROL

- A. Special Inspection and Testing, General: See Section 01 45 20. Special Inspection and testing of post-installed anchors will be performed by an independent testing agency engaged by the Owner.
- B. Testing of Post-Installed Anchors: . Quality control testing shall be performed by independent testing agency. A manufacturer's representative shall be available to consult with the testing agency prior to and during the testing.
  - 1. Testing: Comply with Expansion Anchor Bolt Notes on Structural Drawings.
- C. Special Inspection: See Section 01 45 20.
  - 1. Special inspection is required for all post-installed anchor installations.

## **SECTION 05 12 53**

## MISCELLANEOUS STRUCTURAL STEEL

## PART 1 GENERAL

## 1.01 SUMMARY

- A. Section Includes:
  - 1. Structural steel anchorages and support assemblies connecting to existing structure, including, but not necessarily limited to, the following.
    - a. Duct support framing and bracing.
    - b. Edge supports for new roof openings.
    - c. Workstation anchorage.
    - d. Refrigerator anchorage.
- B. Related Requirements:
  - 1. General Notes on Structural Drawings.
  - 2. Post-Installed Concrete Anchors: Section 05 05 19.
  - 3. Bracing: Section 05 40 00 Cold-Formed Metal Framing.
  - 4. Metal Fabrications: Section 05 50 00.

## 1.02 REFERENCES

- A. Reference Standards: See Section 01 42 00. Comply with listed reference standards except as superseded by notes on the Drawings or by these Specifications.
  - 1. Design, Detailing, Fabrication and Erection: ANSI/AISC 360-10 Specification for Structural Steel Buildings, June 22, 2010.
  - 2. AISC 303-10 Code of Standard Practice for Steel Buildings and Bridges, limited to the following:
    - a. Fabrication, Delivery and Erection of Steel: Comply with Sections 5 through 8.
  - 3. American Welding Society (AWS) Standards:
    - a. AWS D1.1/D1.1M:2015 Structural Welding Code Steel.
  - 4. Society for Protective Coatings SSPC-PA 1 Shop, Field and Maintenance Painting of Steel.
- 1.03 ACTION SUBMITTALS
  - A. Procedures: Submit for review, action and return in accordance with Section 01 33 00.
  - B. Shop Drawings: Submit shop and erection drawings for all members and assemblies under this Section.
    - 1. Shop drawings shall be original drawings produced by the subcontractor or supplier and shall not be reproductions of the Contract Documents.
    - 2. Shop drawings shall clearly indicate the following:
      - a. Profiles, sizes, spacing, and locations of structural steel members.
      - b. Connections, attachments, and anchorages.

#### 1.04 INFORMATIONAL SUBMITTALS

- A. Certificates:
  - 1. Mill Test Reports:
    - a. Upon request, furnish for all structural steel supplied.

- b. Furnish mill test reports and load test results of each lot of high strength bolts if requested by Architect.
- 1.05 QUALITY ASSURANCE
  - A. Qualifications:
    - 1. Welder Qualifications: Welding shall be performed only by certified welding operators currently qualified in accordance with the testing procedures of AWS D1.1 for the weld types and positions required for the installations indicated.
      - a. If recertification of welders is required, retesting shall be Contractor's responsibility.
- 1.06 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 66 00.
  - B. Storage and Handling Requirements:
    - 1. Steel: Store members above ground on platforms, skids or other supports and stored upright to prevent twisting. Protect steel from corrosion.

# PART 2 PRODUCTS

- 2.01 STRUCTURAL STEEL SHAPES
  - A. Channels (C and MC) and Angles (L): ASTM A36.
  - B. Bars and Plates: ASTM A36.
  - C. Steel Tubes: ASTM A500, Grade B.
- 2.02 FASTENERS, ANCHORS AND WELDING MATERIALS
  - A. Bolts: ASTM A307.
    - 1. Type: Type N with bolt threads included in shear plane.
  - B. Nuts: ASTM A563.
  - C. Washers: Provide flat circular washers or square or rectangular beveled washers as indicated or required for each bolted connection.
  - D. Welding Materials for Steel:
    - 1. Filler Metals for Welding: Meet requirements of AWS D1.1.
      - a. Strength Level: In accordance with AISC and AWS specifications for base metals joined, weld type, and direction of applied load to weld.
    - 2. Welding Electrodes: AWS 5.1 or A 5.5.

#### 2.03 FABRICATION

- A. General: Fabricate structural steel in accordance with AISC specifications.
- B. Connections: Fabricate structural steel components with shop-welded connections or shopbolted connections as indicated and to provide for field-welded or field-bolted connections as shown or noted on the Drawings.

- C. Finished Work: Finish work in accordance with accepted shop drawings.
  - 1. Work: True and free from twists, kinks, buckles, open joints and other defects.
- D. Welding: Comply with AISC Specifications and AWS D1.1.
  - 1. Weld sizes not indicated on Drawings shall be ¼-inch continuous fillet but not less than AISC specified minimum based on thickness of parts joined.

## 2.04 SHOP FINISHES

- A. General:
  - 1. Structural Steel Surfaces: Clean and shop coat all fabricated items with shop primer in accordance with SSPC-PA 1.
- B. Shop Primer: Comply with OSHA Subpart R. One of the following.
  - 1. Tnemec Series 10 modified alkyd primer.
  - 2. Society for Protective Coatings Specification SSPC-Paint 25 lead and chromate free primer.
- C. Shop Priming:
  - 1. Surface Preparation: After fabrication and shop assembly, clean off all loose rust, loose mill scale and weld spatter, slag or flux deposits in accordance with SSPC procedures as follows:
    - a. Surfaces to be Concealed in the Completed Structure: SSPC-SP 3 Power Tool Cleaning or better.
    - b. Surfaces to be Exposed in the Completed Structure: SSPC-SP 6/NACE No. 3 Commercial Blast Cleaning.
  - 2. Shop Paint Thickness:
    - a. Standard Shop Primer: 2.5 dry film mils.

# PART 3 EXECUTION

#### 3.01 PREPARATION

- A. Protection: Protect adjacent materials or areas below from damage due to weld splatter or sparks during field welding.
- B. Field Measurements: Take measurements on site as required for correct fabrication and installation. Be responsible for errors in fabrication and for correct fit of structural steel.

#### 3.02 INSTALLATION

- A. General: Follow applicable provisions of AISC specifications.
- B. Install structural steel to lines and elevations indicated within specified erection tolerances.
  - 1. Align and adjust accurately before fastening.
  - 2. Splice only where indicated on Drawings.
  - 3. Field correction of fabricated items by gas cutting not allowed.
- C. Field Connections: Make connections between steel members with bolts or field welding as indicated.
  - 1. Clean existing surfaces before welding to existing steel.
  - 2. Tighten bolts to snug tight condition with nut rotation sufficient to bring all plies in joint into firm contact.
  - 3. Drifting or cutting to enlarge unfair holes not allowed.
  - 4. Make minor corrections by reaming.

- D. Field Modification: Using cutting torch for field modification or refabrication of structural steel not allowed without written acceptance of Architect. Be responsible for errors in fabrication and for correct fit in field.
- E. Allowable Tolerances: Comply with requirements of AISC Code of Standard Practice.
  - 1. Deviation of member working point horizontal location and elevation with respect to the supporting member shall not exceed plus-or-minus 1/16-inch from the location and elevation shown on Drawings.

#### **SECTION 05 40 00**

## COLD-FORMED METAL FRAMING

# PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Structural metal stud framing, vertical and horizontal.
  - 2. New sister studs to reinforce existing studs as indicated.
  - 3. Metal stud braces.
  - 4. Deflection tracks.
  - 5. Flat strap connections.
  - 6. Soffit framing.
  - 7. Other structural metal stud framing as indicated.

#### 1.02 REFERENCES

- A. Reference Standards: See Section 01 42 00. Comply with following:
  - 1. ANSI/AISI Standards:
    - a. AISI S100-2012 North American Specification for the Design of Cold-Formed Steel Structural Members.
    - b. AISI S200-12 North American Standard for Cold-Formed Steel Framing General Provisions.
    - c. AISI S201-12 North American Standard for Cold-Formed Steel Framing Product Data.
  - 2. American Welding Society (AWS) Standards:
    - a. AWS D1.3/D1.3M:2008 Structural Welding Code Sheet Steel.
  - 3. ASTM C955 Load-Bearing (Transverse and Axial) Steel Studs, Runners (Tracks), and Bracing or Bridging for Screw Application of Gypsum Board and Metal Plaster Bases.
  - 4. Steel Stud Manufacturers Association (SSMA) Product Technical Information.

## 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, action and return in accordance with Section 01 33 00.
- B. Product Data: Submit two copies of manufacturer's current catalog literature and installation instructions for each product specified under this Section with all materials and accessories plainly identified.

#### PART 2 PRODUCTS

- 2.01 MANUFACTURERS
  - A. Acceptable Manufacturers:
    - 1. Allied Studco; <u>www.studco.com</u>.
    - 2. California Expanded Metal Products Company (CEMCO); <u>www.cemcosteel.com</u>.
    - 3. ClarkDietrich Building Systems LLC, www.clarkdietrich.com.
    - 4. Marino\WARE; <u>www.marinoware.com</u>.
    - 5. Angeles Metal Systems.
  - B. Substitution Requests: In accordance with Section 01 25 00.

# 2.02 MATERIALS

- A. Steel Mechanical Properties: Conform to requirements of AISI Specification, Section A3.
  - 1. Minimum Yield Point for Material 16 Gage to 10 Gage in Thickness: 50,000 psi.
  - 2. Minimum Yield Point for Material 18 Gage and Less in Thickness: 33,000 psi.
- B. Steel Sectional Properties and Design: Computed in accordance with AISI Specification.
- C. Steel Studs, Tracks, Bracing, Bridging and Related Metal: ASTM C955.
  - 1. Sizes and locations as indicated on Drawings.
- D. Blocking: 16 gage by 6-inch, 50 ksi sheet metal, unless heavier gage is indicated on Drawings.
- E. Finish: Corrosion resistant galvanized coating conforming to ASTM A653, G60 minimum.

## 2.03 FASTENERS

A. Self-Drilling, Self-Tapping Screws, Bolts, Nuts and Washers: ASTM A90, hot-dip galvanized.

# PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Connections:
    - 1. Double Studs at Door Jambs: Welded.
    - 2. Other Connections: Screwed as indicated on the Structural Drawings.

#### **SECTION 05 50 00**

#### METAL FABRICATIONS

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Steel support for counters and open front sink cabinet.
  - 2. Stainless steel bumper for duct enclosure.
  - 3. All other miscellaneous angles, channels, tubes and plates as indicated and required, and not indicated and specified as structural steel.
- B. Related Requirements:
  - 1. Post-Installed Concrete Anchors: Section 05 05 19.
  - 2. Miscellaneous Structural Steel: Section 05 12 53.
  - 3. Field Painting: Section 09 91 23 Interior Painting.

#### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. American Institute of Steel Construction (AISC):
    - a. Design, Detailing, and Fabrication: ANSI/AISC 360-10 Specification for Structural Steel Buildings.
    - b. AISC 303-10 Code of Standard Practice for Steel Buildings and Bridges, limited to the following:
      - 1) Fabrication, Delivery and Erection of Steel: Comply with Sections 5 through 8.
      - 2) Fabrication, Erection, and Dimensional Tolerances for Exposed Steel Fabrications: Comply with Section 10.
  - 2. ASTM International Standards; <u>www.astm.org</u>:
    - a. ASTM A240/A240M-16 Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications.
    - b. ASTM A276/A276M-16a Standard Specification for Stainless Steel Bars and Shapes.
  - 2. American Welding Society (AWS) Standards:
    - a. AWS D1.1/D1.1M:2015 Structural Welding Code Steel.
  - Society for Protective Coatings (SSPC):
     a. SSPC-PA 1 Shop, Field and Maintenance Painting of Steel.

#### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit product data for all manufactured stock items specified under this Section, including the following.
  - 1. Anchorage and suspension assembly for CAV box.

- C. Shop Drawings: Submit for all custom fabricated items under this Section.
  - 1. Shop drawings shall clearly indicate the following:
    - a. Profiles, sizes, spacing, and locations of members.
    - b. Connections, attachments, and anchorages.
    - c. Size and type of fasteners.
    - d. Finishes, coatings and shop painting.
  - 2. Include erection drawings, elevations and details where applicable.
  - 3. Indicate weld lengths and sizes.

#### 1.04 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Welder Qualifications: Welding shall be performed only by certified welding operators currently qualified in accordance with the testing procedures of AWS D1.1 for the weld types and positions required for the fabrications and installations indicated.
- 1.05 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 65 00 and Section 01 66 00.
  - B. Storage and Handling Requirements:
    - 1. Store metals above ground on platforms, skids, or other supports. Protect metals from corrosion.
    - 2. Store other materials in weathertight and dry place, until ready for use.

# PART 2 PRODUCTS

- 2.01 CARBON STEEL MATERIALS
  - A. Carbon Steel Shapes, Bars and Plates: ASTM A36.
  - B. Steel Pipe and Tubing: ASTM A53, Grade B, or A500, Grade B, minimum wall thickness 11 gage.
  - C. Threaded Rod: ASTM A36.
  - D. Carbon Steel Fasteners and Anchors:
    - 1. Bolts: ASTM A307.
    - 2. Nuts: ASTM A563.
    - 3. Washers: ASTM F436.
  - E. Welding Materials for Carbon Steel:
    - 1. Filler Metals for Welding: Meet requirements of AWS D1.1.
    - 2. Welding Electrodes: AWS 5.1 or A 5.5.

# 2.02 STAINLESS STEEL MATERIALS

- A. Stainless Steel Plate, Sheet and Strip:
  - 1. Chemistry and Annealed Mechanical Properties: ASTM A240/A240M.
  - 2. Basic Finish, Flatness and Dimensional Tolerances: ASTM A480/A480M.
- B. Hot or Cold Finished Bar and Structural Shapes:
  - 1. Chemistry and Annealed Mechanical Properties: ASTM A276/A276M.
  - 2. Basic Finish, Straightness and Dimensional Tolerances: ASTM A480/A480M.

- C. United Numbering System (UNS) Types:
  - 1. Stainless Steel for Climate-Controlled and Mild Outdoor Applications:
    - a. Up to 1/4-Inch Thickness: Type 304.
- D. Maximum Sulfur Content: 0.005 percent maximum.

## 2.03 FABRICATION

- A. Exposed Steel Fabrications: Interior and exterior steel fabrications and connections which will remain exposed and subject to normal view by the public or occupants of the completed structure shall be subject to all requirements for Architecturally Exposed Structural Steel specified in Section 10 of the AISC Code of Standard Practice.
- B. Shop Assembly: Fabricate custom metal fabrications as indicated, scheduled or listed in Article 1.01.
  - 1. Fabricate in accordance with details and accepted shop drawings.
  - 2. Provide miscellaneous items of metal work indicated or as necessary to complete work.
  - 3. Materials: New stock of types and sizes indicated.
  - 4. Make cuts clean and sharp with wire edges ground smooth. Provide straight, rigid, and tight work, free from defects.
  - 5. Close exposed ends of steel pipe or tubing with welded caps.
  - 6. Verify dimensions on site prior to shop fabrication.
  - 7. Fabricate items with joints neatly fitted and properly secured.
  - 8. Fit and shop assemble, in largest practical sections, for delivery to site.
  - 9. Exposed mechanical fastenings shall be flush, countersunk screws or bolts, unobtrusively located, consistent with design of structure, except where specifically noted otherwise.
  - 10. Make exposed joints flush butt-type, hairline joints where mechanically fastened.
  - 11. Supply components required for proper anchorage of metal fabrications. Fabricate anchorage and related components of same material and finish as metal fabrication, unless otherwise specified or detailed.
  - 12. Welding: AWS D1.1. Miter and cope intersections and weld all around. Remove splatter, grind exposed welds to blend and contour surfaces to match those adjacent.
  - 13. Substitutions: Where exact sizes and weights called for are not available, secure Architect's acceptance of suitable sizes prior to proceeding.

## 2.04 SHOP FINISHES

- A. Shop Painting for Temporary Corrosion Protection of Carbon Steel Fabrications Not Receiving Field-Applied Topcoat: Follow SSPC-PA 1.
  - **1. Surface Preparation:** 
    - a. After fabrication and shop assembly, clean off all oil and grease in accordance with SSPC-SP1 Solvent Cleaning procedures.
    - b. Remove loose rust, loose mill scale and weld spatter, slag or flux deposits in accordance with SSPC-SP2 Hand Tool Cleaning procedures.
  - 2. Shop Painting: Immediately after surface preparation, apply primer according to manufacturer's written instructions and at rate recommended by SSPC to provide a minimum dry film thickness of 1.5 mils. Use priming methods that result in full coverage of joints, corners, edges, and exposed surfaces.
    - a. Shop Paint: Fabricator's standard lead- and chromate-free, nonasphaltic, rustinhibiting primer.

- B. Shop Priming Carbon Steel Fabrications Indicated to Receive Field-Applied Intermediate Coat and Topcoat: Follow SSPC-PA 1.
  - 1. Surface Preparation: After fabrication and shop assembly, clean off all loose rust, loose mill scale and weld spatter, slag or flux deposits in accordance with SSPC-SP 6/NACE No. 3 Commercial Blast Cleaning procedures.
  - 2. Shop Painting: Immediately after surface preparation, apply primer according to manufacturer's written instructions. Use priming methods that result in full coverage of joints, corners, edges, and exposed surfaces.
    - a. Primer:
      - 1) Primer Not Specified Elsewhere: Fast drying, high solids, low VOC, heavy metal free, rust inhibitive, universal, alkyd metal primer compatible with either alkyd or acrylic topcoats.
    - b. Primer Coating Thickness: Where not otherwise specified, provide dry film thickness within range recommended by primer manufacturer's published product data.
- C. Omit shop paint on the following surfaces, as applicable:
  - 1. Omit shop paint on surfaces to be enclosed in concrete, surfaces within two inches of a field weld location, and surfaces to receive welded studs.
- A. Shop Paint:
  - 1. Steel Items to Receive Painted Finish or To Be Concealed in Completed Structure: One of the following.
    - a. Tnemec Series 10 modified alkyd primer.
    - b. Society for Protective Coatings Specification SSPC Paint 25 lead and chromate free primer.
- B. Shop Priming:
  - 1. Surface Preparation: After fabrication and shop assembly, clean off all loose rust, loose mill scale and weld spatter, slag or flux deposits in accordance with SSPC procedures as follows:
    - a. Surfaces to be Concealed in the Completed Structure: SP-3 power tool cleaning.
    - b. Surfaces to be Exposed in the Completed Structure: SP-6 commercial blast cleaning.
  - 2. Paint Application: Shop coat fabricated items with shop paint in accordance with SSPC-PA-1.
    - a. Omit shop paint on surfaces to be enclosed in concrete and surfaces to be field welded.
    - b. Standard Shop Paint Thickness: 2.5 dry film mils.
- D. Stainless Steel Finishes: As selected by Architect from the following.
  - 1. Stainless Steel Plate, Sheet and Strip: ASTM A480, mill finish.
  - 2. Textured or Embossed Sheet or Strip: ASTM A947M-95(2004).
  - 3. Surface Roughness:
    - a. Acceptable Surface Roughness for Smooth Finishes: Ra 0.5 microns or less.

# PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Weld or bolt items securely in place or otherwise fasten as indicated on the Drawings or accepted shop drawings. Include items indicated, scheduled or listed in Article 1.01.
  - B. Install items square and level, accurately fitted and free from distortion or defects.

- C. Field Welds: Perform field welding in accordance with AWS D1.1.
  - 1. Painted Fabrications: Grind smooth and touch up with compatible primer.

# 3.02 ADJUSTMENTS

A. Repair of Defective Work: Remove stained or otherwise defective work. Replace with new material.

DIVISION 06 – WOOD, PLASTICS, AND COMPOSITES

## **SECTION 06 10 53**

## MISCELLANEOUS ROUGH CARPENTRY

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Roofing and flashing blocking.
  - 2. Miscellaneous blocking and supports.
  - 3. Miscellaneous wood sheathing.
  - 4. Preservative treatment.
  - 5. Fire-retardant treatment.
- B. Related Requirements:
  - 1. Cementitious Board: Section 06 16 63 Cementitious Sheathing.
  - 2. Architectural Wood Casework: Section 06 41 00.
  - **3.2.** Cutting and Patching of Modified Bituminous Membrane Roofing: Section 07 02 52.

#### 1.02 REFERENCES

- A. Reference Standards. See Section 01 42 00. Comply with the following:
  - 1. Wood Framing: Comply with requirements of the 2013 California Building Code and ANSI/AF&PA NDS-2012 National Design Specification for Wood Construction, as published by the American Wood Council of the American Forest and Paper Association.
  - 2. Lumber: Grading Rules for Lumber, latest edition, as published by Western Wood Products Association.
  - Plywood: National Institute of Standards and Technology (NIST) Voluntary Product Standard PS 1-09 - Structural Plywood.
  - 4. Performance Rated Wood Sheathing Panels:
    - a. APA PRP-108 Performance Standards and Policies for Structural-Use Panels.
    - b. National Institute of Standards and Technology (NIST) Voluntary Product Standard PS 2-10 Performance Standard for Wood-Based Structural-Use Panels.

#### 5. Treatment:

- a. AWPA C2 Lumber, Timber, Bridge Ties and Mine Ties Preservative Treatment by Pressure Processes.
- b. AWPA C20 Structural Lumber Fire-Retardant Treatment by Pressure Process.
- c. AWPA C27- Plywood Fire-Retardant Treatment by Pressure Process.
- d. AWPA P5 Standard for Waterborne Preservatives.
- e. AWPA Standard P17 Fire Retardant Formulations.
- f. AWPA Use Category System, Appendix H.

## 1.03 QUALITY ASSURANCE

- A. Grade Stamps:
  - 1. Lumber: Each piece shall be WWPA or WCLIB grade stamped.
  - 2. Wood Sheathing: Each panel shall be identified with the grade trademark of the APA.
  - 3. Lumber Specified to be Preservative Treated: Each piece shall be stamped to indicate compliance with AWPA pressure treatment standards.
- B. Treatment Labels: Label each piece of treated lumber.
  - 1. Fire Treated Lumber: UL labels.

## 1.04 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Storage: Stack all materials minimum of 6 inches above ground to ensure proper ventilation and cover with waterproofing covering.

# PART 2 PRODUCTS

- 2.01 WOOD MATERIALS
  - A. General Requirements:
    - 1. Lumber: Sound, thoroughly seasoned, surfaced four sides, well manufactured and free from warp not correctable by bridging, blocking or nailing.
    - 2. Moisture Content: Provide dry lumber as defined by the American Softwood Lumber Standard PS 20, with moisture content limited to maximum 19 percent moisture content, graded S-DRY, KD or KD-HT, as documented by grade stamp.
    - 3. Dimension Lumber Noted on Drawings to be Non-Combustible: Fire retardant treated with chloride salts.
  - B. Blocking, Furring and Miscellaneous Dimension Lumber: Douglas Fir-Larch or Hem-Fir. Standard Grade or Better.
    - 1. Blocking in Contact with Roofing Membrane: Pressure treated with preservative.
  - C. Miscellaneous Panels for Interior Application: APA plywood BDX interior with exterior glue. 3/4inch thickness unless otherwise indicated.
    - 1. Electrical Component Mounting: Fire retardant treated.

# 2.02 TREATMENT

- A. Preservative Treatment of Dimension Lumber: All blocking in contact with roof membrane, exterior plates, posts embedded in concrete, and blocking and plates in contract with concrete or masonry shall be pressure preservative treated.
  - 1. Acceptable Products: Osmose NatureWood Preservative or accepted substitute.
  - 2. Type: Waterborne, alkaline copper quaternary preservative system with co-biocide, registered by EPA as a non-restricted use pesticide.
  - 3. Minimum Preservative Retention:
    - a. Plates and Blocking: 0.40 lbs of preservative per cubic foot of wood.
  - 4. Water Repellent Additive: Required.
  - 5. Treated Wood: Kiln-dried after treatment.
- B. Fire Retardant Treated Plywood: All sheathing required to be fire retardant-treated shall be pressure-treated in accordance with AWPA Standard C27 with an approved low hygroscopic, high temperature Interior Type A-HT fire retardant.
  - 1. Each panel shall be labeled or marked by an approved independent testing agency.
  - 2. After treatment, plywood shall be dried to an average moisture content of 15 percent or less.

#### 2.03 FASTENERS, ANCHORS AND HARDWARE

A. General: Provide necessary bolts, screws, nails, clips, plates, straps, hangers, etc. necessary for completion of rough carpentry. Provide correct material of proper size and strength for purpose intended conforming to specifications, drawings and applicable building codes. Supply anchors to be cast into concrete and masonry for anchorage of wood for installation under other Sections.

- B. Exterior Applications: Provide fasteners hot dip galvanized in accordance with ASTM A153.
- C. Fasteners for Use in Pressure Treated Wood: One of the following:
  - 1. Stainless steel.
  - 2. Steel, hot-dip galvanized to G185 in accordance with ASTM A653.
  - 3. Steel, Batch/Post Hot-Dip Galvanized in accordance with ASTM A153.
  - 4. Steel, mechanically galvanized to Class 55 or greater in accordance with ASTM B695.

# PART 3 EXECUTION

# 3.01 EXAMINATION

A. Verification of Conditions: Verify that surfaces to receive rough carpentry are prepared to required grades and dimensions.

## 3.02 INSTALLATION

- A. General:
  - 1. Perform in substantial manner consistent with accepted standards of carpentry trade.
  - 2. Framing: Erect plumb, level and true and rigidly anchor in place. Cut framing square on bearings, closely fit, accurately set to required lines and levels.
  - 3. Nail or spike members in accordance with IBC and General Structural Notes on Drawings.
  - 4. Framing: 16 inches on center unless otherwise indicated.
  - 5. Shims: Do not use shims for leveling on wood or metal bearings. Use steel shims with full bearing on masonry or concrete.
  - 6. Metal Framing Anchors: Install where required for proper connections in accordance with manufacturer's recommendations.
- B. Anchors: Unless otherwise indicated, bolt plates firmly to concrete or masonry with 3/8-inch by 12 inches (3-inch horizontal leg) anchor bolts, 2'-0" on center or use powder-actuated fastening system.
  - 1. Size and Spacing: Accepted by Architect.

# 3.03 WOOD BLOCKING AND MISCELLANEOUS LUMBER REQUIRED FOR WORK OF OTHER SECTIONS

- A. General: Cooperate with other trades. Provide required grounds, blocking, wood backing and framing. Perform necessary cutting and patching of rough carpentry work as required.
- B. Interior Blocking: Install blocking of size required for support of handrails, toilet and bath accessories, wall-mounted door stops, wall cabinets and other wall-mounted accessory items. Set true to line, level or plumb well secured in stud wall and flush with back of drywall or other wall finish.
- C. Exterior Blocking:
  - 1. Install blocking of size required for roof edge details and other locations as indicated.
  - 2. Roof Blocking: Anchor at 3 feet on center to resist force of 75 lbs. per lineal foot.

#### **SECTION 06 16 63**

## **CEMENTITIOUS SHEATHING**

# PART 1 GENERAL

## 1.01 SUMMARY

- A. Section Includes:1. Cementitious board at new roof curbs and duct penetrations through existing roof.
- B. Related Requirements:1. Miscellaneous Rough Carpentry: Section 06 10 53.

# 1.02 REFERENCES

- A. Abbreviations:
  - 1. CBU: Cementitious Backer Unit.
- B. Reference Standards: See Section 01 42 00. Comply with following:
   1. ANSI A118.9-1999 Test Methods and Specifications for Cementitious Backer Units.

## 1.03 QUALITY ASSURANCE

- A. Regulatory Requirements:
  - 1. Sheathing product shall have a current ICC-ES report finding product to be an acceptable alternative product to those specified in the 2012 (or later) International Building Code.
    - a. Comply with all conditions of use stipulations in ICC-ES report.

## 1.04 DELIVERY, STORAGE, AND HANDLING

- A. General: Comply with Section 01 60 00.
- B. Delivery: Deliver materials in original unopened packages, labeled with identification of manufacturer and brand name.
- C. Storage: Store in an enclosed shelter providing protection from damage and exposure to the elements.
  - 1. Store cementitious backer units flat.

# PART 2 PRODUCTS

#### 2.01 MANUFACTURERS AND PRODUCTS

- A. Acceptable Manufacturers and Products Exterior Cementitious Backer Units:
  - 1. Custom Building Products; <u>www.custombuildingproducts.com</u> WonderBoard.
  - 2. United States Gypsum Company (USG); <u>www.usg.com</u> Durock Brand Exterior Cement Board.
- B. Substitution Requests: In accordance with Section 01 25 00.

## 2.02 EXTERIOR CEMENTITIOUS BOARD

- A. Composition: ANSI A118.9. Composed of stable Portland cement, aggregates, and reinforcements.
  - 1. Non-combustible in accordance with ASTM E136.
  - 2. Unaffected by prolonged exposure to moisture.
- B. Thickness: 1/2 inch unless indicated otherwise.

# 2.03 ACCESSORY PRODUCTS

- A. Fasteners:
  - 1. Screws: Sheathing manufacturer's standard No. 8 steel screws with corrosion resistant coating. Provide type for steel framing.
- B. Joint Tape: Manufacturer's standard alkali-resistant joint tape.

# PART 3 EXECUTION

## 3.01 INSTALLATION

- A. General: Install sheathing in accordance with manufacturer's instructions. Comply with all conditions of use stipulations in ICC-ES report.
- B. Install CBU with smooth side facing out.
- C. Fasten backer board to framing using specified fasteners, beginning in the field of the board and working out to the edges.
  - 1. Space fasteners at maximum 8 inches along each stud or support.
  - 2. Space fasteners a minimum of 3/8 inch from any edge of the board.

#### 3.02 PROTECTION

A. Cementitious Sheathing in Contact with Metals: Coat with asphaltic paint or apply other approved isolation between cementitious sheathing and metal to prevent corrosion.
DIVISION 07 – THERMAL AND MOISTURE PROTECTION

## SECTION 07 02 52

## CUTTING AND PATCHING OF MODIFIED BITUMINOUS MEMBRANE ROOFING

## PART 1 GENERAL

## 1.01 SUMMARY

- A. Section Includes:
  - 1. Selective removal of existing roofing, rigid insulation, and sheet metal flashings down to existing structural concrete deck in areas indicated.
  - 2. Patching and flashing existing modified bituminous membrane roofing and insulation around new roof openings.
- B. Related Sections:
  - 1. Cutting and Patching: Section 01 73 29.
  - 2. Selective Demolition: Section 02 41 19.
  - 3. New Roof Blocking: Section 06 10 53 Miscellaneous Rough Carpentry.
  - 4. Sheet Metal Flashing: Section 07 60 00 Flashing and Sheet Metal.
  - 5. Manufactured Roof Penetration Seals: Section 07 71 41.

#### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Definitions: Accept as otherwise specified, standard roofing terminology as defined by ASTM D1079 applies to this Section.
  - 1. Remove: Detach from existing construction and legally dispose off-site, unless indicated to be removed and reinstalled.
- C. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. ASTM International Standards:
    - a. ASTM C1289-16 Standard Specification for Faced Rigid Cellular Polyisocyanurate Thermal Insulation Board.
  - 2. Factory Mutual Insurance Company Reference Standards:
    - a. FM Approvals LLC; <u>www.fmapprovals.com</u> FM Approval Standards:
      - 1) FMG Approval Guide; <u>www.approvalguide.com</u>.
      - 2) Class Number 4470 Approval Standard for Class 1 Roof Covers.
    - b. FM Global (FMG) Operating Standards: <u>www.fmglobal.com</u>.
      - 1) FMG Property Loss Prevention Data Sheet 1-28 Wind Design, January 2012.
      - 2) FMG Property Loss Prevention Data Sheet 1-28R, 1-29R Roof Systems, September 1998.
      - 3) FMG Property Loss Prevention Data Sheet 1-29 Roof Deck Securement and Above-Deck Roof Components, April 2016.
  - 3. Underwriters Laboratories, Inc. Reference Standards:
    - a. Roofing Materials and Systems Directory.
    - b. UL 55-A Materials for Built-Up Roof Coverings, 2004 edition.
- D. Guide References and Standard Practices:
  - National Roofing Contractors Association (NRCA) The NRCA Roofing Manual: Membrane Roof Systems – 2015.

## 1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
  - 1. Coordinate work activities daily with Owner so Owner can place protective dust or water leakage covers over sensitive equipment or furnishings, shut down HVAC if needed, and evacuate occupants from below the work area if desired. Provide not less than 72 hours' notice of activities that may affect Owner's operations.
  - 2. Coordinate work of this Section with work of other sections. Coordinate placement of wood blockings, inserts, nailing strips, cants, drain pan linings, etc. Coordinate roof penetrations, equipment bases and other conditions as required.
    - a. Roof drains or scuppers that are not at proper level to drain finished roof shall be reset before proceeding by contractors responsible for installation.
- B. Roofing Conference: See Section 01 31 00.
  - 1. Before beginning roofing removal and patching, hold conference with General Contractor's Superintendent, roofing contractor(s), and roofing manufacturer's representatives. Notify Architect and Owner's Representative of meeting at least 10 days in advance.
  - 2. Discuss all matters pertaining to roofing work, including procedures for removal of existing roofing, detailing, preparation, coordination between trades, weather restrictions, structural loading limitations of roof deck during and after roofing, installation techniques and procedures, phasing and scheduling.
    - a. Review temporary protection requirements.
    - b. Review roof drainage during each stage of roofing work, including roof drain plugging and plug removal procedures.
    - c. Review Owner notification requirements.
    - d. Review filtering of HVAC air intakes.
  - 3. Take minutes and distribute to attending parties and Architect.

## 1.04 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Prior to starting the roofing, the applicator shall submit to the Architect through the General Contractor copies of the manufacturer's specifications covering materials he proposes to apply. Submit evidence of certified applicator status with specifications.
- 1.05 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Certificates: Submit evidence of certified applicator status for roofing product proposed for application.

#### 1.06 CLOSEOUT SUBMITTALS

- A. Procedures: Submit for Project Record in accordance with Section 01 78 00.
- B. Warranties: At completion of the Project, submit roofing and flashing warranties as specified.

#### 1.07 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer Qualifications: Employ original roofing subcontractor or other qualified subcontractor authorized to make revisions to existing roofing without affecting or limiting original warranty, guarantee or bond.

#### 1.08 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Delivery and Acceptance Requirements: Deliver materials in manufacturer's original, unopened containers with labels intact and legible.
- C. Storage and Handling Requirements: Handle rolled goods to prevent damage to edges or ends. Store rolled goods on end. Store off the ground and keep covered with waterproof covering. Materials that become wet will be subject to rejection.

## 1.09 AMBIENT CONDITIONS

- A. Comply with manufacturer's recommendations.
- B. Do not apply roofing during wet weather.
- 1.10 WARRANTY
  - A. Existing Roof Warranty: Submit evidence that existing roof warranty has not been voided by patching.
  - B. New Warranty: Roofing subcontractor shall provide and deliver a warranty against defects in materials and workmanship in patched roofing and flashings for a period of two years from completion of work.

## PART 2 PRODUCTS

#### 2.01 MANUFACTURERS

- A. Acceptable Modified Bituminous Membrane Roofing Materials Manufacturers:
  - 1. DERBIGUM Americas, Inc..
  - 2. Firestone Building Products Company; <u>www.firestonebpco.com</u>.
  - 3. GAF Materials Corporation; <u>www.gaf.com</u>.
  - 4. Johns Manville, Inc <u>www.specjm.com</u>.
  - 5. Siplast; <u>www.siplast.com</u>.
  - 6. TAMKO Building Products, Inc.; <u>www.tamko.com</u>.
- B. Substitution Requests: Required for all manufacturers not named as Acceptable Manufacturer.
  1. Submit in accordance with Section 01 25 00.

#### 2.02 TEMPORARY ROOFING

A. Selection of materials and design of temporary roofing is responsibility of Contractor.

#### 2.03 ROOF INSULATION

- A. Insulation Type and Thickness: Match existing. Taper where required to maintain slope from edge to edge of new insulation.
  - 1. Facings: Provide facings as appropriate for torch-applied bitumen roofing system if necessary to match existing roofing type.
  - 2. Fasteners: Provide as recommended by manufacturer to achieve wind resistance rating required by local codes.

### 2.04 ROOF PATCHING SYSTEM

- A. Roof Patching System: Match existing, including minimum number and composition of membrane roofing plies.
  - 1. Add plies if required to provide manufacturer's warranty.
- B. Materials: Match existing.
  - 1. Cold Process Adhesive: Modified bituminous membrane compatible, 80 percent minimum solids content.
  - Asphalt: ASTM D312, Steep Grade, Type III, air blown asphalt manufactured specially for roofing.
  - 3. Emulsion: ASTM D1227, Type I emulsion or fibrated emulsion.
  - 4. Surface Material: Gravel to match existing.
- C. Flashings: Match existing with system compatible with roofing.

## PART 3 EXECUTION

## 3.01 EXAMINATION

- A. General: Verify that work of other trades that penetrates roof deck has been completed. Examine surfaces for inadequate anchorage, drainage, foreign material, moisture and unevenness that would prevent the execution and quality of application of roofing system. Do not proceed with application of roofing system until defects are corrected.
- B. Acceptance: No roofing shall proceed until the surface to be covered is fully acceptable to the applicator.

## 3.02 PREPARATION FOR SELECTIVE ROOF REMOVAL

#### A. Protection:

- 1. Maintain sufficient and suitable materials on-site to facilitate rapid installation of temporary protection in the event of unexpected rain.
- 2. Protect interior spaces from infiltration of dust or debris during demolition of existing roofs and roof patching operations. Include protection of concealed ceiling spaces.
- 3. Protect paving and building walls adjacent to hoist prior to starting work with protective covering.
- 4. Lap suitable protective covering materials at least 6 inches. Secure protective coverings against wind. Leave protective covering in place for duration of roofing work.
- B. Removal of Existing Roofing Gravel: Remove gravel in areas to be patched by spudding down to the top surface of the existing roofing membrane.

## 3.03 SELECTIVE ROOF REMOVAL

- A. Extent of Roof Removal, General: Full roof tear-off at areas indicated. Remove all existing roofing material(s), insulation, cover boards, base flashing, metal flashing, and deteriorated wood blocking and legally dispose of offsite.
  - 1. Except for items or materials indicated to be reused, reinstalled, or otherwise indicated to remain Owner's property, demolished materials shall become Contractor's property and shall be removed from Project site.
- B. Removal of Roofing: Where indicated on Drawings, remove roofing gravel, roofing, insulation, flashing, and other roof components down to existing structural roof deck.

- C. Remove only enough roofing to accommodate the day's work and ensure the exposed area can be made 100 percent watertight at the end of the day or at first sign of inclement weather. Provide temporary roofing when necessary that deck be exposed for extended periods or overnight. Remove temporary roofing membrane before installing new roofing.
- D. Do not damage metal counterflashings that are to remain. Replace metal counterflashings damaged during removal with counterflashings of same metal, weight or thickness, and finish as new metal flashing.
- E. Roof Drains: Maintain in functioning condition. Prevent debris from entering or blocking roof drains and conductors using roof drain plugs specifically designed for this purpose.
- F. Cap and identify exposed utilities, if any.

## 3.04 PREPARATION FOR ROOF PATCHING

- A. Surface Preparation: Dry and broom clean before beginning roof patching.
- B. Inspect deck and substrates behind removed flashings after tear-off of roofing.
  - 1. If deck surface is not suitable to receive new roofing, or if structural integrity of deck is suspect, immediately notify Architect, and do not proceed with installation until directed by Architect.
  - 2. If areas of deck surface are noted to exhibit excessive deflection, to be noticeably out-ofplane, appear to be conducive to water ponding or poor drainage, or otherwise detrimental to proper performance of roofing system, immediately notify Architect of such areas, and do not proceed with installation until directed by Architect.
  - 3. If parapet sheathing, curbs, adjoining walls, roof screen supports, or roof-penetrating items have deteriorated or been damaged, immediately notify Architect.
- C. Concrete Decks:
  - 1. Verify concrete deck to be visibly dry and free from moisture. Test for moisture by plastic sheet method in accordance with ASTM D4263. Do not proceed with roofing work if moisture condenses under plastic sheet.
  - 2. Remove all loose aggregate and debris by power broom and/or vacuum and legally dispose of offsite.
- D. Roof drains or scuppers that are not at the proper level to drain the finished roof shall be reset before proceeding.

## 3.05 APPLICATION

- A. Vapor Barrier: Patch to match existing.
- B. Insulation: Fully adhere new insulation to structural roof deck at areas to be patched. Comply with FM 1-90 wind requirements. Install no more insulation at one time than will be protected from rain or snow by installation of roofing membrane on the same day or prior to storm. Install temporary water cutoffs at completion of each day's work and remove upon resumption of work.
- C. Membrane Roofing: Apply, lap and splice in accordance with approved manufacturer's specifications using roofing torch method for heat welding as recommended.
  - 1. Complete installation of roofing system up to line of termination of day's work.
  - 2. Provide three-inch side laps and four-inch end laps.
  - 3. Take precautions to ensure full adhesion to substrate and full adhesion of laps.

- D. Base Flashing: Install in accordance with approved manufacturer's specifications and as detailed. Extend base flashing a minimum of 8 inches up vertical surface and mop or nail in place.
- E. Aggregate: Install poured flood coat and aggregate surfacing in accordance with requirements of roofing system manufacturer. Pour flood coat uniformly over surface. Apply aggregate uniformly and with complete coverage.
- F. Record of Work: The Contractor shall keep a record indicating temperature and moisture conditions and the type and location of work being done during each day of roofing operation.

# 3.06 CLEANING

A. Upon completion, remove bitumen, asphalt and gravel from roof drains and scuppers and from exposed metal and masonry surfaces, gutters, etc.

## **SECTION 07 26 16**

#### **BELOW-GRADE VAPOR RETARDERS**

#### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Continuous vapor retarder under interior concrete floor slab-on-grade patches.
  - 2. Compactible granular base over and under vapor retarder.
- B. Related Requirements:
  - 1. Concrete Floor Slab Patching: Section 03 30 53 Miscellaneous Cast-in-Place Concrete.
  - 2. Trenching and Backfilling: Section 31 23 33.

#### 1.02 REFERENCES

- A. Reference Standards: Comply with following except as modified by supplementary requirements of this Project Specification.
  - 1. ASTM International Standard Specifications and Test Methods:
    - a. ASTM E154/E154M-08a(2013)e1 Standard Test Methods for Water Vapor Retarders Used in Contact with Earth Under Concrete Slabs, on Walls, or as Ground Cover.
    - b. ASTM E1745-11 Plastic Water Vapor Retarders Used in Contact with Soil or Granular Fill Under Concrete Slabs.
- B. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified in this Project Manual.
  - 1. American Concrete Institute (ACI) Committee Reports, Guides, Standard Practices, and Commentaries:
    - a. ACI 302.1R-15 Guide for Concrete Floor and Slab Construction.
    - b. ACI 302.2R-06 Guide for Concrete Slabs that Receive Moisture-Sensitive Flooring Materials.
  - 2. ASTM International Standard Practices:
    - ASTM E1643-11 Standard Practice for Selection, Design, Installation, and Inspection of Water Vapor Retarders Used in Contact with Earth or Granular Fill Under Concrete Slabs.

## 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit copies of manufacturer's current catalog literature for underslab vapor retarders.
- 1.04 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Manufacturer's Installation/Application Instructions:
    - 1. Submit for underslab vapor retarders before beginning concrete floor slab patching.
      - a. Maintain one copy on site until completion of product application.

### 1.05 QUALITY ASSURANCE

- A. Installer Qualifications:
  - 1. Vapor retarder installer shall have a minimum of two years' experience on equivalent projects.
- 1.06 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
  - B. Storage and Handling Requirements: Comply with Manufacturer's printed instructions.
    - 1. Vapor Retarder: Protect from damage and keep dry.

## PART 2 PRODUCTS

- 2.01 MANUFACTURERS AND PRODUCTS
  - A. Acceptable Manufacturers and Products:
    - 1. Barrier-Bac, Inc., <u>www.barrierbac.com</u> VB-250, 11 mil, three layer, co-extruded biaxially oriented polyethylene membrane.
    - 2. Fortifiber Corporation, <u>www.fortifiber.com</u> Moistop Ultra 10, 10 mil thickness polyolefin membrane.
    - 3. Reef Industries, Inc., <u>www.reefindustries.com</u> Griffolyn 10 mil, co-extruded polyolefin membrane.
    - 4. Stego Industries, LLC, <u>www.stegoindustries.co</u>m Stego Wrap Class A Vapor Retarder, extruded 10 mil thickness polyolefin membrane manufactured with virgin resins.
    - 5. W. R. Meadows, Inc., <u>www.wrmeadows.com</u> Perminator 10 Mil Underslab Vapor Barrier, polyolefin-based membrane.
  - B. Substitution Requests: in accordance with Section 01 25 00.
- 2.02 DESCRIPTION
  - A. Underslab Vapor Retarder: ASTM E1745, Class B or better with ten mil minimum thickness.
  - B. Maximum Allowable Water Vapor Permeance: 0.04 perms when tested in accordance with ASTM E96, ASTM E154, or ASTM F1249.
  - C. Puncture Resistance: Minimum 2200 grams when measured in accordance with ASTM D1709, Method B.

## 2.03 GRANULAR BASE AND BLOTTER LAYER

- A. Compactible Granular Base Material For Placement Over Vapor Retarder: Clean, fine-graded crusher fines or manufactured sand, having a uniform distribution of particle sizes ranging from the No. 4 through the No. 200 sieve, with 10 percent to 30 percent of particles passing a No. 100 sieve, and not contaminated with clay, silt or organic material.
- B. Moisture Content: Dry. Minimum moisture content to meet compaction requirements.

#### 2.04 ACCESSORIES

- A. Vapor Retarding Seam Tape: Manufacturer's standard for vapor retarder product used.
  - 1. Water Vapor Transmission Rate: ASTM E96, 0.3 perms or lower.
  - 2. Color: Contrasting.
- B. Vapor Proofing Mastic.
  - 1. Water Vapor Transmission Rate: ASTM E96, 0.3 perms or lower.
- C. Pipe Boots: Construct pipe boots from vapor barrier material, pressure sensitive tape and/or mastic in accordance with manufacturer's instructions.
- D. Perimeter/Edge Seal: Manufacturer's standard.

## PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Conditions:
    - 1. Layout: Verify layout of work before beginning installation.
    - 2. Subgrade: Inspect subgrade to verify elevation and compaction requirements.
  - B. Notification: Notify General Contractor of unsatisfactory conditions in writing with copy to Architect.
  - C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

#### 3.02 PREPARATION

- A. Subgrade Under Slabs and Vapor Retarder: Fine grade to smooth, level surface.
  - 1. Place approximately 2 inch thickness of fine-graded granular base material over subgrade. Roll or compact to provide smooth and level surface without jagged material protruding which could puncture vapor retarder.

## 3.03 UNDERSLAB VAPOR RETARDER INSTALLATION

- A. General: Place vapor retarder under all interior slab on grade patches.
  - 1. Install in accordance with Manufacturer's recommendations and ASTM E1643.
  - 2. Use widest practical width of film.
  - 3. Install compactible 2-inch granular blotter layer over vapor retarder before placement of concrete.
- B. Laps: Lap new vapor retarder sheet with existing vapor retarder not less than 6 inches around perimeter of all patches. Tape seams in accordance with manufacturer's instructions.
  - 1. Place top lap in direction of spreading of compactible granular base.
- C. Penetrations: Not allowed except for permanent utilities.
  - 1. Carefully fit around service openings.
  - 2. Cut film around pipes and conduit piercing retarder, and apply pressure sensitive tape to ensure maximum barrier effectiveness.
  - 3. Construct pipe boots from vapor retarder material and pressure sensitive tape in accordance with manufacturer's instructions.
- D. Place pipes, conduits, etc. on top of vapor barrier, taking care to prevent film punctures.

- E. Repairs:
  - 1. Repair any damage to film prior to placing granular base.
  - 2. Apply patches of vapor retarder film, lapping damaged area minimum 6 inches and taping all four sides with manufacturer's tape.
- F. Granular Blotter Layer: Immediately prior to placement of concrete, cover vapor barrier with two inch thick uniform compactible granular material. Compact in accordance with requirements of Section 31 23 33 for granular fill under floor slabs. Protect granular layer from excessive moisture beyond minimum required for compaction until concrete is placed.

# 3.04 SITE QUALITY CONTROL

A. Contractor's Quality Control: The Contractor is responsible for quality control, including workmanship and materials furnished by his subcontractors and suppliers. Contractor shall take all other reasonable measures necessary to ensure that underslab moisture is controlled, vapor retarder is complete, intact and undamaged prior to concrete placement, water/cement ratio of slab concrete is not exceeded, fresh concrete contains no more water than required for proper placement and cement hydration, and floor slab concrete is properly cured.

## **SECTION 07 60 00**

### FLASHING AND SHEET METAL

### PART 1 GENERAL

### 1.01 SUMMARY

- A. Sections Includes:
  - 1. Flashing and counterflashing.
  - 2. Flashing at new curbs where ducts penetrate roof.
  - 3. Other new sheet metal flashing related to the above, indicated on the Drawings and not specified elsewhere.
- B. Related Requirements:
  - 1. Wood Blocking and Nailers: Section 06 10 53 Miscellaneous Rough Carpentry.
  - 2. Cutting and Patching of Modified Bituminous Membrane Roofing: Section 07 02 52.
  - 3. Sealants: Section 07 92 00 Joint Sealants.

### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. FM Global (FMG) Operating Standards: <u>www.fmglobal.com</u>.
    - a. FMG Property Loss Prevention Data Sheet 1-28 Wind Design, January 2012.
    - b. FMG Property Loss Prevention Data Sheet 1-29 Roof Deck Securement and Above-Deck Roof Components, April 2016.
    - c. FMG Property Loss Prevention Data Sheet 1-49 Perimeter Flashing, June 1985, Revised September 2000.
  - 2. National Roofing Contractors Association (NRCA):
    - a. NRCA Roofing Manual: Architectural Metal Flashing Condensation and Air Leakage Control, and Reroofing 2014.
  - 3. Sheet Metal and Air Conditioning Contractors National Association (SMACNA):
    - a. Architectural Sheet Metal Manual, 7th Edition, 2012.

## 1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate work of this section with work of other sections.
  - 1. Coordinate placement of wood blockings, inserts, nailing strips, cants, etc.
  - 2. Membrane Roofing and Sheet Metal in Contact with Roofing Membrane: Coordinate with Section 07 02 52.
  - 3. Coordinate with work under Division 23 for welded duct flashing provided with HVAC work.
- B. Pre-Installation Conference: Attend conference with roofing installer, roofing manufacturer's representative, General Contractor and Architect in accordance with Section 01 31 00 and Section 07 02 52.
- 1.04 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.

- B. Shop Drawings: Include:
  - 1. Overall layout of sheet metal work.
  - 2. Type, thickness, and details of sheet metal components.
  - 3. Joints, expansion joints, attachment and anchoring of sheet metal components.

#### 1.05 CLOSEOUT SUBMITTALS

A. Warranty: Submit in accordance with Section 01 78 36.

#### 1.06 WARRANTY

- A. Warranty: Provide two year written warranty covering materials and installation for sheet metal in accordance with Section 01 78 36.
  - 1. Include that system shall be watertight and weatherproof.
  - 2. See Warranty in Section 07 02 52.

## PART 2 PRODUCTS

- 2.01 DESIGN CRITERIA
  - A. Fire/Windstorm Classification: Comply with FMG Class 1-90.

### 2.02 SHEET METAL

- A. Galvanized Iron: ASTM A653 commercial quality sheet steel, G90 commercial hot-dip galvanizing. Provide gages as indicated and specified, 20 gage minimum.
  - 1. Field Finished Galvanized Iron: Mill phosphatized for field painting under Section 09 90 00.
  - 1. Prefinishing: Coil stock coated with PPG Duranar fluoropolymer coating or equivalent finish produced with Kynar 500 resin.

#### 2.03 FABRICATION

A. Field Measurements: Before fabricating sheet metal, verify shapes and dimensions of surfaces to be covered.

#### 2.04 ACCESSORIES

- A. Clips or Cleats: Same material and gage as sheet metal being installed.
- B. Nails and Fasteners: Same metal as metal being installed or other non-corrosive metal as recommended by sheet manufacturer. Match finish of exposed heads with material being fastened.
- C. Screws and Bolts: Round heads
- D. Solder: ASTM B32, composition 50 percent tin and 50 percent lead. Use muriatic acid killed with zinc or soldering flux.
- E. Sealant: Approved type of polyurethane; see Section 07 92 00. Roofers mastic is not acceptable.

## PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Verification of Conditions: Comply with Section 01 71 16:
  - 1. Layout: Verify layout of work before beginning installation.
  - 2. Examine surfaces to receive flashing or sheet metal. Surfaces shall be smooth, sound, clean and dry and fabric flashing in place before work is started.
- B. Notification: Notify General Contractor of unsatisfactory conditions in writing with copy to Architect.
- C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

## 3.02 PREPARATION

A. Protective Coating: Coat contacting dissimilar metals with asphaltic compound.

## 3.03 INSTALLATION

- A. Reference Standards: Unless indicated otherwise on Drawings, workmanship and details shall comply with NRCA Manual, SMACNA Architectural Sheet Metal Manual, and FM Loss Prevention Data Sheet 1-49.
- B. Edges:
  - 1. Edges: Hem all exposed edges, <sup>1</sup>/<sub>2</sub>-inch unless otherwise indicated.
  - 2. Drips: Angle bottom edges of vertical surfaces to form drips.
- C. Joints: Make joints watertight and allow for expansion.
  - 1. Reinforce sheet metal corners as required.
  - 2. Reinforcement: Conceal within finished assembly.
- D. Fastenings: Use concealed hook strips and fasteners. Exposed hook strips and fasteners not acceptable.
- E. Expansion and Contraction:
  - 1. Provide for thermal expansion and contraction and building movement in completed work.
  - 2. Make watertight and weathertight throughout.
  - 3. Unless otherwise indicated, provide expansion joints at maximum of 20 feet and not more than 4 feet from corners. Seal joints with sealant in accordance with Section 07 92 00.

### 3.04 SHEET METAL SCHEDULE

A. Flashing and Counterflashing: As detailed of 20 gage galvanized iron.. Lock and solder joints and hem exposed edges.

## SECTION 07 71 41

## MANUFACTURED ROOF PENETRATION SEALS

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Roof penetration sealing system comprised of manufactured modular polyester curbs, adhesive for installing in existing roofing, and pourable sealant.
- B. Related Requirements:
  - 1. Section 07 02 52 Cutting and Patching of Modified Bituminous Membrane Roofing.

#### 1.02 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate with work under Division 26 Electrical to determine size and location of required roof penetrations and for scheduling of penetration sealing.
- B. Scheduling: Schedule sealing of roof penetrations to occur immediately following installation of conduit through roof.
- 1.03 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
  - B. Product Data: Submit manufacturer's current technical product literature with all selected options clearly indicated.
  - C. Shop Drawings: Submit layout drawing indicating locations and approximate dimensions of roof penetrations. Coordinate with shop drawings prepared under Division 26.
- 1.04 CLOSEOUT SUBMITTALS
  - A. Warranty: Submit in accordance with Section 01 78 36.
- 1.05 WARRANTY
  - A. Provide manufacturer's standard 10-year warranty for system components.
  - B. Installations in Warranted and Inspected Roof Systems: Provide manufacturer's twenty-year warranty.

## PART 2 PRODUCTS

- 2.01 MANUFACTURERS AND PRODUCTS
  - A. Basis of Design Manufacturer and System:
    - 1. Manufacturer: ChemLink, Inc.; <u>www.chemlinkinc.com</u>.
    - 2. System: ChemCurb System, including following components.
      - a. Standard ChemCurbs and/or E-Curbs as appropriate for penetration shapes and sizes required.

- b. Adhesive: M-1.
- c. Sealant: Pro Pack.
- B. Substitution Requests: In accordance with Section 01 25 00.

## 2.02 DESCRIPTION

- A. Curbs: Modular units as appropriate for sealing penetration shapes and sizes required.
  - 1. Standard Curbs:
    - a. Height: 2 inches.
    - b. Unit Shapes:
      - 1) Rounds: Diameter as indicated.
    - c. Color: As selected by Architect from manufacturer's standards.
- B. Adhesive: High-strength, moisture curing, structural adhesive/sealant, zero VOC, that forms an elastic waterproof seal after curing.
- C. Sealant: Self-leveling, non-shrinking sealant that cures to a flexible, long-lasting seal.

## 2.03 MATERIALS

- A. Curbs: Heavy-duty polyester resin.
- B. Sealant: Two-part, 100 percent solids, pourable urethane.

## PART 3 EXECUTION

#### 3.01 EXAMINATION

- A. Verification of Conditions:
  - 1. Verify penetrations through roofing have been formed or cut to proper sizes.
  - 2. Verify piping, conduit, or other construction penetrating roof have been installed and that roof penetrations are ready for sealing.
- B. Notification: Notify General Contractor of unsatisfactory conditions in writing with copy to Architect.
- C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

#### 3.02 PREPARATION

A. Surface Preparation: Remove all previously applied caulk, mastic, cement, asphalt and other contaminants from penetrations with a wire brush to ensure proper bonding. Brush away all gravel and loose granules.

# 3.03 INSTALLATION

- A. General: Follow manufacturer's installation instructions.
- B. Seal the base of each penetration with adhesive by coating the penetrations to three inches above the roofline.

- C. Apply two parallel beads of adhesive over the entire bottom surface of curb units. Tool the adhesive to a 1/8-inch deep coating. Apply excess adhesive to the bonding surface at the roofline to fill in and level all gaps and irregularities.
- D. Place the coated curb section on the roof surface, creating a half form. Press down firmly until adhesive extrudes from the outside edges. Tool adhesive to a 1/8-inch deep coating. Place the remaining section(s) of curb on the roof surface to complete the form. Press firmly in place until excess adhesive extrudes from the outside edge and scarf joints. Tool the joints smooth. Apply a bead of adhesive around the outside base of the installed curb, and tool to form a smooth fillet.
- E. Carefully pour sealer into the curb cavity and tool off to a smooth surface.
- F. Do not disturb the system until fully cured.

## **SECTION 07 84 00**

### FIRESTOPPING

## PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Penetration firestopping, fire-resistant joint sealants, fire safing, and smoke seals as indicated on the Drawings as well as the following areas:
    - a. All openings in fire-rated floors and walls both empty and those accommodating penetrating items such as cables, cable trays, conduits, pipes, ducts, etc.

## B. Related Requirements:

- 1. Joint Sealants: Section 07 92 00.
- 2. Mechanical and Electrical Work: Divisions 21 through 28.

## 1.02 REFERENCES

- A. Guide References and Standard Practices: Comply with recommendations of the following unless otherwise specified.
  - 1. ASTM E2174-14b Standard Practice for On-Site Inspection of Installed Fire Stops.
  - ASTM E2393-10a(2015) Standard Practice for On-Site Inspection of Installed Fire Resistive Joint Systems and Perimeter Fire Barriers.
  - 3. FCIA Firestop Manual of Practice.

#### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit Manufacturer's printed product data indicating product characteristics, performance and limiting criteria for each product proposed for use.
- 1.04 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Installation Instructions: Submit Manufacturer's installation instructions for each type of firestop required by the Project.

## 1.05 CLOSEOUT SUBMITTALS

- A. Procedures: Submit the following in accordance with Section 01 78 00.
- B. Documentation: Compile and submit forms identifying products and technical parameters of each firestop installation performed, including manufacturer's details of the system selected for the application.

### 1.06 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer Qualifications: Firestopping shall be performed by a contractor trained or approved by firestop manufacturer.

- B. Mock-Up: Prepare job mock-up of each system proposed for use in the Project as directed by Architect. Approved mock-ups may be left in place as part of the finished Project and will constitute the standard for remaining work.
- 1.07 DELIVERY, STORAGE, AND HANDLING
  - A. Delivery and Acceptance Requirements: Deliver all materials in original unopened packages fully identified with Manufacturer's name, trade name and UL label.
  - B. Storage and Handling Requirements: Materials shall be stored off the ground and protected from environmental conditions as required by Manufacturer.

## 1.08 AMBIENT CONDITIONS

- A. Conform to Manufacturer's printed instructions for installation and when applicable, curing in accordance with temperature and humidity. Conform to ventilation and safety requirements.
  - 1. Do not install firestopping products when ambient or substrate temperatures are outside limitations recommended by manufacturer.
- B. Do not install firestopping products when substrates are wet due to rain, frost, condensation, or other causes.
- 1.09 WARRANTY
  - A. Firestop Installer shall warrant that firestopping systems used meet firestopping requirements as herein specified.

## PART 2 PRODUCTS

- 2.01 MANUFACTURERS AND PRODUCTS
  - A. Acceptable Firestopping Manufacturers and Systems:
    - 1. 3M Fire Protection Products.
    - 2. A/D Fire Protection Systems; <u>www.adfire.com</u>, division of the Carboline Company A/D Firebarrier,
    - 3. Hilti Corporation; <u>www.us.hilti.com</u> Hilti Firestop Systems.
    - 4. Nelson FireStop Products; <u>www.nelsonfirestop.com</u>.
    - 5. The RectorSeal Corporation; <u>www.rectorseal.com</u> Metacaulk Firestopping Products; <u>www.metacaulk.com</u>..
    - 6. Specified Technologies, Inc. (STI); <u>www.stifirestop.com</u>.
    - 7. Tremco Fire Protection Systems Group of Tremco Incorporated; <u>www.tremcofirestop.com</u>, TREMstop.
  - B. Basis of Design Fire Safing Manufacturer and Product: Thermafiber, Inc.; <u>www.thermafiber.com</u> Owens Corning Thermafiber Safing Insulation.
    - 1. Size: As required by fire rating and conditions.
    - 2. Accessories; Provide Thermafiber Safing Clips as required.
  - C. Substitution Requests: In accordance with Section 01 25 00.

## 2.02 FIRESTOPPING SYSTEMS DESIGN

A. Types of firestop to be used for each condition shall be the responsibility of the installer and shall comply with all specified regulatory requirements.

- B. Provide a Flame (F) and Temperature (T) rating of at least one (1) hour but not less than the fire resistance rating of assembly being penetrated, as tested per ASTM E814.
- C. Firestop contractor shall immediately notify the Architect if the firestopping systems herein specified cannot meet the requirements of the specification.

## 2.03 MATERIALS

- A. Regulatory Requirements: Firestopping materials proposed for use on this Project shall conform to both Flame (F) and Temperature (T) ratings as tested by nationally accepted test agencies per ASTM E814 or UL 1479 fire tests. The F rating and T rating must be a minimum of one (1) hour but not less than the fire resistance rating of the assembly being penetrated. The fire test shall be conducted with a minimum positive pressure differential of 0.03 inches of water column.
- B. General Requirements for Firestopping Materials:
  - 1. Materials shall be free of asbestos.
  - 2. Firestop materials in exposed areas shall be compatible with specified finishes.
  - 3. Materials shall conform to all applicable governing codes.
  - 4. All materials shall be compatible with the material penetrating the fire assembly.
  - 5. Provide products that upon curing, do not re-emulsify, dissolve, leach, breakdown or otherwise deteriorate over time from exposure to atmospheric moisture, sweating pipes, ponding water or other forms of moisture characteristic during and after construction.
  - 6. Provide firestop sealants sufficiently flexible to accommodate motion such as pipe vibration, water hammer, thermal expansion and other normal building movement without damage to the seal.
  - Pipe insulation shall not be removed, cut away or otherwise interrupted through wall or floor openings. Provide products appropriately tested for the thickness and type of insulation utilized.
  - 8. Use sealants that comply with the limits for VOC content according to SCAQMD Rule #1168:
    - a. Sealants: 250 g/L.
    - b. Sealant Primers for Nonporous Substrates: 250 g/L.
    - c. Sealant Primers for Porous Substrates: 775 g/L.

#### 2.04 ACCESSORIES

A. Furnish all accessory materials such as fire safing batts, sleeves, sheet metal, sealants, etc. necessary to complete fire stopping systems unless furnished by others.

## PART 3 EXECUTION

#### 3.01 EXAMINATION

- A. Verification of Existing Conditions: Contractor shall inspect and verify that the surface and condition of the substrates and all sleeves or blockouts furnished by others have no defects or errors that would interfere with the installation of the firestopping materials.
- B. Notification: Notify Architect in writing of any defects or errors in workmanship. Do not proceed with work until all unsatisfactory conditions have been corrected.
- C. Acceptance: Start of installation of firestopping shall constitute the Contractor's acceptance of surfaces and conditions of substrates, sleeves and blockouts.

### 3.02 PREPARATION

- A. Clean surfaces and substrates of dirt, oil, loose materials and other foreign materials that may affect the proper bond or installation of the firestops in strict accordance with Manufacturer's written instructions.
- B. Provide primers as required which conform to Manufacturer's recommendations for various substrates and conditions.
- C. Do not apply firestops to surfaces previously painted or treated with a sealer, curing compound, water repellant or other coating unless tests have been performed to ensure compatibility of materials. Remove coatings as required in compliance with Manufacturer's instructions.
- D. Mask where necessary to protect adjoining surfaces.

## 3.03 INSTALLATION

- A. Install in strict accordance with Manufacturer's printed instructions to provide a Flame (F) and Temperature (T) rating of at least one (1) hour but not less than the fire resistance rating of the assembly being penetrated.
  - 1. Equipment used shall be in accordance with firestop manufacturer's written installation instructions.
- B. Ensure that all accessories such as anchoring devices, back-up materials, clips, sleeves, supports and other materials used in the actual fire test are installed.
- C. Install firestops with sufficient pressure to properly fill and seal openings to ensure an effective smokeseal.
- D. Tool or trowel exposed surfaces. Remove excess firestop material promptly as work progresses and upon completion.
- E. Following each installation, apply a label on or adjacent to each penetration firestop and at regular intervals along each fire-resistive joint sealant application. Label shall identify and document firestopping system installed in accordance with FCIA Firestop Manual of Practice.

## 3.04 SITE QUALITY CONTROL

- A. Firestop contractor shall examine completed firestops to ensure proper installation and full compliance with this specification.
- B. All areas of work must be accessible until inspection by the applicable code authorities.

#### 3.05 ADJUSTMENT

A. Correct unacceptable firestops and provide additional inspection to verify compliance with this specification at no additional cost.

## 3.06 CLEANING

- A. When finished work will be visible, clean adjacent surfaces in accordance with Manufacturer's printed instructions. Remove excess material and stains on surfaces as required.
- B. If visible in the finished work, remove temporary dams after initial cure of firestops.

- C. Correct staining and discoloring on adjacent surfaces.
- D. Remove all debris and excess materials entirely from site and leave work in a neat and clean condition.

## **SECTION 07 92 00**

## JOINT SEALANTS

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. Work Results: Providing all caulking and sealant indicated on Drawings, specified herein, and not specified under other sections. In general, seal all openings indicated on Drawings and at other locations requiring sealant to seal visually and against infiltration from air and water, or to provide acoustical isolation, including but not limited to following:
  - 1. Joints at penetrations of non-fire rated walls, decks and floors by piping and other service and equipment.
  - 2. Joints between items of equipment and other construction.
  - 3. Joints between door frames and adjacent materials.
  - 4. Open joints between similar or dissimilar materials as required to close and conceal jointing of the work.
  - 5. Joints at sound-insulated partitions.
  - 6. Flashing reglet and retainers.
  - 7. Other joints as indicated.
- B. Related Requirements:
  - 1. Sealants Related to Roofing: Section 07 02 52 Cutting and Patching of Modified Bituminous Membrane Roofing.
  - 2. Firestopping: Section 07 84 00.
  - 3. Glazing Sealants: Section 08 80 00 Glazing.
- 1.02 ADMINISTRATIVE REQUIREMENTS
  - A. Coordination:
    - 1. Coordinate installation of sealants with other construction trades.
- 1.03 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
  - B. Product Data: Submit for each material and location of application.
  - C. Samples: Submit for each type of sealant for color selection.

### 1.04 CLOSEOUT SUBMITTALS

A. Warranty: Submit in accordance with Section 01 78 36.

## 1.05 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer: Company specializing in sealant application. Separate subcontractor is required. a. Experience: Continuously installed sealants in State of California for five years.
  - 2. Manufacturer's Technical Representative: Obtain materials only from manufacturers who will, if required, send qualified technical representative to Project site, for purpose of advising installer of proper procedures and precautions for use of materials.

- B. Certifications:
  - 1. Elastomeric Sealants: Listed by SWRI on SWR Institute Validation Program Validated Products List; <u>www.swrionline.org</u>.

### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
  - 1. Protect materials from excessive moisture in shipment, storage, and handling.
- B. Delivery and Acceptance Requirements: Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying material name and manufacturer, production date and/or product code.
- C. Storage and Handling Requirements:
  - 1. Storage: Store materials in a clean, dry area not subject to extreme heat or cold in accordance with manufacturer's instructions.
  - 2. Handling: Protect materials during handling and installation to prevent damage.

## 1.07 AMBIENT CONDITIONS

A. Do not apply exterior sealants during wet weather or when outside temperature is below 40 degrees F or apply interior sealants when inside temperature is below 60 degrees F.

## 1.08 WARRANTY

- A. Warranty: Provide three year written warranty covering materials and installation for sealants in accordance with Section 01 78 00 01 78 36.
  - 1. Warranty: Require installer, at no cost to Owner, to repair or replace sealants which fail to perform as airtight and watertight joints; or fail in joint adhesion, cohesion, abrasion resistance, weather resistance, extrusion resistance, migration resistance, stain resistance, color retention, or general durability; or appear to deteriorate in any manner not clearly specified as inherent quality of material by submitted manufacturer's data.

## PART 2 PRODUCTS

## 2.01 PRODUCT OPTIONS

- A. Substitution Requests: Required for all manufacturers and products not named as Acceptable or as Basis of Design, excepting types for which no manufacturer is named.
  - 1. During Bidding/Negotiation Period: Submit in accordance with Document 00 26 00.
  - 2. During Construction Phase: Submit in accordance with Section 01 25 00.

### 2.02 MATERIALS, GENERAL

- A. Low-Emitting Material Requirements: Use sealants that comply with the following limits for VOC content when calculated according to SCAQMD Rule #1168:
  - 1. Sealants: 250 g/L.
  - 2. Sealant Primers for Nonporous Substrates: 250 g/L.
  - 3. Sealant Primers for Porous Substrates: 775 g/L.

## 2.03 LATEX JOINT SEALANTS

A. Interior Caulk and Sealants for Under Thresholds and Non-Moving Joints: Acrylic latex, ASTM C834-10.

## 2.04 ELASTOMERIC JOINT SEALANTS

- A. Acceptable Manufacturers:
  - 1. Polyurethane Sealants:
    - a. BASF; <u>www.buildingsystems.basf.com</u>, Sonolastic brand.
    - b. Geocel Engineered Polymers.
    - c. Pecora Corporation; <u>www.pecora.com</u>.
    - d. Sika Corporation; www.usa.sika.com.
    - e. Tremco, Inc.; www.tremcosealants.com.
  - 2. General Construction Sealants:
    - a. BASF; <u>www.buildingsystems.basf.com</u>, Sonneborn brand.
    - b. DAP Incorporated.
    - c. Pecora Corporation; <u>www.pecora.com</u>.
    - d. Sika Corporation; <u>www.usa.sika.com</u>.
    - e. Tremco, Inc.; <u>www.tremcosealants.com</u>.
  - 3. Silicone Sealants:
    - a. General Electric.
    - b. Dow Corning; <u>www.dowcorning.com</u>.
    - c. Pecora Corporation; <u>www.pecora.com</u>.
    - d. Tremco, Inc.; www.tremcosealants.com.
  - 4. Fire-Resistant Sealants:
    - a. BASF; www.buildingsystems.basf.com, Sonneborn brand.
    - b. DAP Incorporated.
    - c. Pecora Corporation; <u>www.pecora.com</u>.
    - d. Sika Corporation; <u>www.sikaconstruction.com</u>.
    - e. Tremco, Inc.; <u>www.tremcosealants.com</u>.
- B. Sealant Materials and Applications:
  - 1. Exterior Vertical and Overhead Joints Not Specified Otherwise: Two-component polyurethane, ASTM C920, Type M, Grade NS, non-sag, Class 50, Use NT.
  - 2. Sealant at Lavatories, Tubs and Showers: Silicone tub sealant.
- C. Primer: As recommended by sealant manufacturer.
- D. Colors: As selected by Architect from standard colors.

#### 2.05 ACOUSTICAL JOINT SEALANTS

- A. Acceptable Manufacturers: Following manufacturers are acceptable for applications as specified below.
  - 1. Pecora Corporation; <u>www.pecora.com</u>.
  - 2. Tremco, Inc.; <u>www.tremcosealants.com</u>.
  - 3. United States Gypsum Co; <u>www.usg.com.</u>
- B. Acoustical Sealant for Exposed and Concealed Joints: Nonsag, paintable, nonstaining, latex sealant complying with ASTM C834 that effectively reduces airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing representative assemblies according to ASTM E90.
  - 1. Acceptable Products Non-Fire Rated Partitions and Ceilings:
    - a. Pecora Corp. AC-20 FTR Acoustical and Insulation Sealant. Acrylic latex type.
    - b. Pecora Corp. AIS-919 Acoustical and Insulation Latex Sealant.
    - c. Tremco, Inc. Tremflex 834 Siliconized Interior Acrylic Latex Sealant.
    - d. United States Gypsum Co. SHEETROCK Brand Acoustical Sealant.
  - 2. Acceptable Products –Fire Rated Partitions and Ceilings:
    - a. Pecora Corp. AC-20 FTR Acoustical and Insulation Sealant. Acrylic latex type.

- C. Acoustical Sealant for Concealed Joints: Nondrying, nonhardening, nonskinning, nonstaining, gunnable, synthetic-rubber sealant recommended for sealing interior concealed joints to reduce airborne sound transmission.
  - 1. Acceptable Products:
    - a. Tremco, Inc. Tremco Acoustical Sealant.
- 2.06 NON-RATED JOINT BACKING MATERIAL
  - A. Acceptable Manufacturers:
    - 1. BASF; <u>www.buildingsystems.basf.com</u> Sonolastic.
    - 2. Backer Rod Manufacturing Inc.; <u>www.backerrod.com</u> Denver Foam.
    - 3. Dow Chemical Company Ethafoam.
  - B. Material: Closed cell polyethylene foam.
  - C. Shape: Round rod or semi-circular type.
  - D. Size joint backing material for minimum 30 percent compression when inserted in joint.
- 2.07 FIRE-RATED JOINT BACKING MATERIAL
  - A. Acceptable Manufacturers and Products:
    - 1. Backer Rod Mfg. Inc., Denver, Colorado Ultra Block.
  - B. Size: As required for joint width.
- 2.08 BOND BREAKER TAPE
  - A. Tape: Polyethylene tape or other plastic tape as recommended by sealant manufacturer to be applied to sealant-contact surfaces where bond to substrate or joint filler must be avoided for proper performance of sealant. Provide self-adhesive tape wherever applicable.

## PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Conditions: Comply with Section 01 71 16:1. Inspect joints to be sealed to application of any work under this section.
  - B. Notification: Notify General Contractor of any joints which cannot be put into proper condition to receive sealants in writing with copy to Architect.
  - C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

#### 3.02 PREPARATION

- A. Preparation of Surfaces:
  - 1. Clean surfaces in accordance with manufacturer's recommendations.
  - 2. Mask edges, if required, to protect adjoining surfaces and produce a straight finish line.
  - 3. Clean joint surfaces immediately before installation of sealant. Remove dirt, insecure coatings, moisture and other substances that would interfere with bond of sealant.
  - 4. Do not proceed with installation of sealant over joint surfaces that have been painted, lacquered, waterproofed or treated with water repellent or other treatment of coating. Remove coating or treatment joint surfaces before installing sealant.

- B. Priming: If required, prime surfaces which are to be sealed with manufacturer's recommended or standard primer, after surfaces have been prepared as specified. Before use, check primers for discoloration and dirt pick-up on adjacent surfaces. If staining occurs, after exposure, take adequate measures to prevent primer from being applied over face of adjacent porous materials by masking or other suitable measures.
- C. Joint Backing:
  - 1. Joints: Depth necessary to provide for specified allowable thickness of sealant and also required backing where and as specified. Provide backing of extent and type as specified and required to provide for allowable depth of sealant.
  - 2. Back-up Materials for Sealants: Non-staining, compatible with sealant and primer. resilient nature, and as recommended by manufacturer of sealant.
    - a. Size and Shape: As required by width of joint and specified.
    - b. Do not use materials impregnated with oil, solvents or bituminous materials.
  - 3. Compress backing material minimum of 30 percent when inserted in joint. Backing material for upper portion of joints shall be round rod or semi-circular in cross-section where in contact with sealant.
- D. Bond Breaker Tape: Install where indicated and as required by manufacturer's recommendations to ensure that sealants will deform properly.

## 3.03 APPLICATION

- A. Joint Sealing, General:
  - 1. Apply sealants in continuous beads without open joints, voids or air pockets, using ratchet hand gun or mechanical powered gun.
  - Confine sealants to joint areas with masking tapes or other precautions. Apply compounds in concealed compression joints accurately so that excess compound will not extrude from joints.
  - 3. Remove excess compound or sealant promptly as work progresses, and clean adjoining surfaces.
  - 4. In rough surfaces or joints of uneven widths, install sealant well back into joint. Recess equal to width of joint, or 3/8-inch minimum at masonry.
  - 5. Use anti-tack agent where necessary to protect freshly applied sealant from public traffic and dirt.
  - 6. Slightly recess joints to facilitate painter's line. Handtool and finish joints throughout construction.
  - 7. Comply with manufacturer's specifications and recommendations.
- B. Workmanship: Employ only proven installation techniques, which will ensure that sealants will be deposited in uniform, continuous ribbons without gaps or air pockets, with complete "wetting" of joint bond surfaces equally on opposite sides.
  - 1. Except as otherwise indicated, fill sealant rabbet to slightly concave surface, slightly below adjoining surfaces.
  - 2. Where horizontal joints are between horizontal surface and vertical surface, fill joint to form slight cove, so that joint will not trap moisture and dirt.
- C. Joint Sizes: Install sealants to depths as indicated or, as recommended by sealant manufacturer but within following general limitations:
  - 1. For normal moving joints sealed with elastomeric sealants but not subject to traffic, fill joints to depth equal to 50 percent of joint width, but not more than 1/2-inch deep or less than 1/4-inch deep.
  - 2. For joints sealed with non-elastomeric sealants and calking compounds. fill joints to depth in range of 75 percent to 125 percent of joint width.

- D. Spillage:
  - 1. Do not allow sealants or compounds to overflow or spill onto adjoining surfaces, or to migrate into voids of adjoining surfaces. Use masking tape or other precautionary devices to prevent staining of adjoining surfaces, by either primer/sealer or sealant.
  - 2. Remove excess and spillage of compounds promptly as work progresses. Clean adjoining surfaces by whatever means may be necessary to eliminate evidence of spillage. Do not damage adjoining surfaces or finishes.
- E. Sinks, Lavatories and Showers: Fill joints between dissimilar materials with silicone sealant.
- 3.04 ACOUSTICAL SEALANT APPLICATION
  - A. Comply with manufacturer's instructions for particular conditions of installation in each case.
  - B. Install materials to comply with sound control requirements noted on Drawings.
  - C. Use a caulking-type gun, apply ¼-inch minimum round bead of sealant (1/2-inch maximum) to seal perimeter of each sound-insulated partition.
  - D. Seal sound-insulated partitions on both sides where facings abut dissimilar materials; around perimeter, in the angle formed by panels and abutting dissimilar materials; at all intersections; at all panel terminations in door and window frames; and at control joint locations before attaching the control joint to the panels. Apply continuous beads of sealant around all openings formed for outlets, lights, etc. Completely butter the outside of electrical boxes.
    - 1. Caulk ductwork penetrations.
  - E. Cut gypsum panels with 1/8-inch maximum relief at perimeter to receive sealant. Install before sealant skins.

### 3.05 CURING

- A. Cure sealants and caulking compounds in compliance with manufacturer's instructions and recommendations, to obtain high early bond strength, internal cohesive strength and surface durability.
- 3.06 SITE QUALITY CONTROL
  - A. Field Samples: Where directed by Architect, cut out and remove total of three samples consisting of undisturbed sealant and back-up material from joint. Samples shall be 6 inches in length. Reseal cut out areas with same materials.

## 3.07 CLEANING

- A. Clean soiled surfaces immediately.
- B. Replace any damaged material that cannot be cleaned with new material.

### 3.08 PROTECTION

A. Advise General Contractor of procedures required for protection of sealants during construction period, so that they will be without deterioration or damage (other than normal weathering) at time of acceptance.

## **SECTION 08 11 13**

### HOLLOW METAL DOORS AND FRAMES

## PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Flush hollow metal doors.
  - 2. Hollow metal door frames.
- B. Related Requirements:
  - 1. Hardware: Section 08 71 00 Door Hardware.

#### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. American National Standards Institute (ANSI):
    - a. ANSI A115 Specifications for Door and Frame Preparation for Hardware.
  - 2. National Fire Protection Association (NFPA):
    - a. NFPA 80 Standard for Fire Doors and Other Opening Protectives, 2016 Edition.
- C. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified in this Project Manual.
  - 1. Hollow Metal Manufacturers Association (HMMA), a division of the National Association of Architectural Metal Manufacturers (NAAMM):
    - a. ANSI/HMMA 840-07 –Installation and Storage of Hollow Metal Doors and Frames.
    - b. ANSI/NAAMM HMMA 861-14 Guide Specifications for Commercial Hollow Metal Doors and Frames.
  - 2. Steel Door Institute (SDI): <u>www.steeldoor.org</u>.
    - a. SDI 111-09 Recommended Details for Standard Steel Doors, Frames, Accessories and Related Components.

# 1.03 COORDINATION

A. Templates: Hardware templates for hardware mounted on hollow metal work shall be submitted under Section 08 71 00 directly to hollow metal manufacturer immediately after acceptance of hardware schedule. Report failure to receive templates with reasonable promptness to General Contractor.

## 1.04 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Shop Drawings: Submit drawings indicating dimensions, layout and anchorage details of all hollow metal frames.

#### 1.05 CLOSEOUT SUBMITTALS

- A. Submit the following in accordance with Section 01 77 00.
  - 1. Fire Door and Frame Assemblies: Submit documentation for Owner's records of initial inspection and approval of fire door assemblies by inspector for authority having jurisdiction.

### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00 and with Manufacturer's recommendations.
- B. Storage and Handling Requirements:
  - 1. Store frames in manner to prevent twisting.
  - 2. Doors with dimples or dents will be rejected.

## PART 2 PRODUCTS

#### 2.01 REGULATORY REQUIREMENTS

A. Fire Rating: Provide fire rating label acceptable to local building code authority on doors and frames indicated on the door schedule. If any door or frame scheduled to be fire-rated cannot qualify for appropriate labeling because of its design, hardware or any other reason, advise Architect prior to submission of bids.

## 2.02 HOLLOW METAL FRAMES

- A. General: Frames for hollow metal and wood doors, entrances, windows and borrowed lights, etc. indicated to be hollow metal shall be of design sections as detailed and assembled as indicated.
- B. Gages:
  - 1. Frames on Interior Walls: 16 gage steel.
  - 2. Loose Glazing Beads: Not less than 20 gage steel, corners butted.
- C. Construction: Construct frames encompassing one or more doors with sidelights or transoms, and steel window walls, etc., in rigid units of as large size as practical to reduce to minimum number of job-fabricated joints.
  - 1. Joints and Connections Including Job-Fabricated Joints: Welded and ground and entire assembly reinforced and braced as required to ensure absolute rigidity.
  - 2. Provide expansion joints as indicated or required.
  - 3. Where so indicated or as required, provide channel stiffening within and securely welded to frame member.
  - 4. Do not used exposed screws except where specifically accepted.
- D. Accessories:
  - 1. Reinforcement for Hardware: Machine frames for attachment of hardware, including mortising, reinforcing, drilling and tapping for hinges.
    - a. Butt Hinges: Seven gage, 12 inches long.
    - b. Closers: 10 gage, 12 inches long, full width of frame or equivalent.
    - c. Strikes, Flush Bolts and Other Surface Mounted Hardware: 12 gage or equivalent.
  - 2. Anchors: Furnish anchors of type and number required for anchoring frames to structure, partitions, etc. as follows:
    - a. Three jamb anchors on seven foot high jamb.
    - b. Four jamb anchors on jambs over seven feet.
Wire anchors will not be allowed. Provide such installation instructions as are necessary to ensure proper installation of anchors.

- 3. Silencers: Drill stop of lock jamb of each interior frame for installation of pneumatic rubber door silencers. Silencers shall be furnished under Section 08 71 00, numbers as indicated on schedule.
- 4. Joints: Conceal welded joints in two-sided mullions or similar sections behind glazing stops. Continuous weld and grind smooth exposed joints.
- 5. Glazing Stops: Provide removable metal stops, screwed to frame, at borrowed lights and window walls. See Section 08 84 00 for glazing clearance requirements.
  - a. Unless indicated otherwise, glazing stops shall be 5/8-inch x 3/4-inch or 3/4-inch x 3/4-inch cold-rolled channel, shaped as required or detailed and hand fitted to each opening.
  - b. Butt Joints: Square and true and tightly fitted.
  - c. Fasten to frame with metal screws 18 inches on center, flathead, countersunk. Do not over-tighten to cause indentations or puckering at screws. Use vandalproof screws at exterior stops.
- E. Hinges: Install mortar protection box behind each hinge cut.

# 2.03 HOLLOW METAL DOORS

- A. General: Doors indicated to be hollow metal shall be hollow metal, flush, swing type doors of types indicated.
- B. Construction: Construct hollow metal doors from 16 gage steel, fully welded, ground smooth and completely sound and fire insulated. Manufacture hollow metal doors and panels with flush tops, sides and bottoms. Plastic inserts are not acceptable. All vertical seams shall be fully welded. Lock seams or epoxy filled seams are not acceptable.
- C. Labels: Provide fire rated construction and UL labels where listed in door schedule.
- D. Hardware: Mortise and reinforce doors to receive hardware.
  - 1. Hinges: Seven gage steel plate, 9-inches, welded to continuous 16 gage interior edge channels or equivalent. Drill and tap. Use of coined or extruded holes not acceptable.
  - 2. Locks, Latches, Push/Pulls and Panic Devices: 12 gage steel spot welded to 16 gage interior edge channels or equivalent and designed to provide adequate support and reinforcement for required hardware.
  - 3. Closers: Not less than 12 gage internal reinforcement. Provide special attention to reinforcing doors where closers are to be bolted through door.
- E. Vents: Provide louvers for interior doors, where indicated, which comply with SDI 111, with blades or baffles formed of 0.020-inch-thick, cold-rolled steel sheet set into 0.032-inch-thick steel frame.
  - 1. Form corners of moldings with hairline joints. Provide fixed frame moldings on outside of exterior and on secure side of interior doors and frames.

#### 2.04 FINISH

- A. Cleaning and Primer:
  - 1. Thoroughly clean surfaces of grease, rust and scale to insure paint adherence. Apply filler to doors where required to produce a smooth surface.
  - 2. Apply one coat of baked-on factory primer.

# PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Frames:
    - 1. Set steel frames accurately in accordance with details, straight and free of twist with head level and jambs plumb. Rigidly anchor to walls and partitions and securely brace until surrounding work is completed. Provide deflection clearances at frame heads where indicated.
    - 2. Field Welds: Make welds full length of joints. Remove splatter and grind exposed welds to match adjacent surfaces. Provide Architect with ample notice to review welds before finish operations begin.
    - 3. Wherever possible leave spreader bars in place until frames are securely anchored.
    - 4. Jambs shall be filled with grout where frames occur in concrete or masonry walls.
    - 5. Provide special masonry anchorage devices where required for securing hollow metal frames to in-place masonry construction. Set anchorage devices, opposite each anchor location in accordance with details on accepted shop drawings and anchorage device manufacturer's recommendations.
  - B. Doors: Apply hardware in conformance with hardware manufacturer's templates and instructions. Hang doors to be free of binding with hardware functioning properly.
    - 1. Clearance Tolerances:
      - a. Head: 1/8-inch maximum.
      - b. Jamb: 1/8-inch maximum.
      - c. Between Doors (Pair): 1/8-inch maximum.
      - d. Sill without Threshold: 1/2-inch maximum.
  - C. Fire-Rated Door and Frame Assemblies: Install in compliance with NFPA 80.
    - 1. Install with door clearances within limits listed in NFPA 80.
    - 2. Make no field modifications to door assembly that void the label.
  - D. Miscellaneous Items: Install closures, panels, fillers, etc. as indicated.
- 3.02 ADJUSTING
  - A. At completion of job, adjust doors and hardware as required and leave in proper operating condition. Adjust doors to freely swing, completely close, and positively latch.

END OF SECTION

### **SECTION 08 31 00**

### ACCESS DOORS AND PANELS

# PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Access doors into ceiling spaces.
- B. Related Requirements:
  - 1. Furnishing Access Doors as Specified in This Section for Plumbing Equipment: Division 22 Plumbing.
  - 2. Furnishing Access Doors as Specified in This Section for Mechanical Equipment: Division 23 Heating, Ventilating, and Air Conditioning (HVAC).
  - 3. Furnishing Access Doors as Specified in This Section for Electrical Equipment: Division 26 Electrical.
  - 4. Openings for Access Doors and Finishing After Installation: Applicable sections.

### 1.02 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Manufacturer's current product data sheets describing products to be supplied with all selected options clearly identified, basic uses, components, materials, physical properties, precautions and limitations, applicable standards, approvals, and general installation procedures.
- C. Shop Drawings: Submit layout plan.
- 1.03 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
  - B. Delivery and Acceptance Requirements:
    - 1. Deliver materials in original packages bearing brand name and identification of manufacturer.
  - B. Storage and Handling Requirements:
    - 1. Store doors, frames and panels under cover and in manner to prevent twisting.
    - 2. Doors and panels with dimples or dents will be rejected.

#### PART 2 PRODUCTS

- 2.01 FLUSH-MOUNTED, NON-RATED ACCESS DOORS
  - A. Acceptable Manufacturers and Products Flush-Mounted, Non-Rated Access Doors for Installation in Plaster Walls and Ceilings:
    - 1. Acudor Products, Inc.; <u>www.acudor.com</u> Model PS-5030.
    - 2. J,L. Industries; <u>www.jlindustries.com</u> Model PW.
    - 3. Karp Associates, Inc.; <u>www.karpinc.com</u> Model DSC-214 PL.
    - 4. Milcor; <u>www.milcorinc.com</u> -Style K.
    - 5. Nystrom Building Products; <u>www.nystrom.com</u> Model NP.

- 6. Williams Brothers Corporation of America; <u>www.wbdoors.com</u> WB-PL.
- 7. Substitution Requests: In accordance with Section 01 25 00.
- B. Acceptable Manufacturers and Products Flush-Mounted, Non-Rated Access Doors for Installation in Masonry, Tile, Concrete, or Gypsum Drywall:
  - 1. Acudor Products, Inc.; <u>www.acudor.com</u> Model UF-5000.
  - 2. J.L. Industries; www.jlindustries.com Model TM.
  - 3. Karp Associates, Inc.; <u>www.karpinc.com</u>.- Model DSC-214M.
  - 4. Milcor; <u>www.milcorinc.com</u> Style M.
  - 5. Nystrom Building Products; www.nystrom.com Model NT.
  - 6. Williams Brothers Corporation of America; <u>www.wbdoors.com</u> WB Series.
  - 7. Substitution Requests: In accordance with Section 01 25 00.
- C. Acceptable Manufacturers and Products Flush-Mounted, Non-Rated Ceiling Panels Located in Non-Rated Drywall Ceilings:
  - 1. Karp Associates, Inc. ; <u>www.karpinc.com</u> Model KDW.
  - 2. Substitution Requests: In accordance with Section 01 25 00.
- D. Sizes: As indicated on Drawings or as required to properly service mechanical or electrical equipment.
- E. Material: Stainless steel.
- F. Finish:
  - 1. Stainless Steel: No. 4 satin finish.
- G. Locking Devices: Screwdriver operated cam latch.

### 2.02 RECESSED ACCESS DOORS

- A. Acceptable Manufacturers and Products Recessed, Non-Rated Access Doors for Installation in Plaster Walls and Ceilings:
  - 1. Acudor Products, Inc.; <u>www.acudor.com</u> Model AP-5010.
  - 2. Karp Associates, Inc.; www.karpinc.com Model DSC-210 PL.
  - 3. Williams Brothers Corporation of America; <u>www.wbdoors.com</u> WB-AP.
  - 4. Substitution Requests: In accordance with Section 01 25 00.
- B. Acceptable Manufacturers and Products Non-Rated Access Doors, Recessed for Cladding with Gypsum Drywall Panel, for Installation in Non-Rated Gypsum Board Walls and Ceilings:
  - 1. Acudor Products, Inc.; <u>www.acudor.com</u> Model DW-5015.
  - 2. Karp Associates, Inc.; <u>www.karpinc.com</u> Model RDW.
  - 3. Nystrom Building Products; <u>www.nystrom.com</u> Model RW.
  - 4. Williams Brothers Corporation of America; <u>www.wbdoors.com</u> WB-RDW.
  - 5. Substitution Requests: In accordance with Section 01 25 00.
- C. Acceptable Manufacturers and Products Non-Rated Access Doors, Recessed for Installation of Acoustical Ceiling Tile:
  - 1. Acudor Products, Inc.; <u>www.acudor.com</u> Model AT-5020.
  - 2. Karp Associates, Inc.; <u>www.karpinc.com</u> Model DSC-210.
  - 3. Milcor; <u>www.milcorinc.com</u> Style CT.
  - 4. Nystrom Building Products; <u>www.nystrom.com</u> Model RA.
  - 5. Williams Brothers Corporation of America; <u>www.wbdoors.com</u> WB-AT.
  - 6. Substitution Requests: In accordance with Section 01 25 00.

- D. Acceptable Manufacturers and Products –Fire-Resistive Access Doors, Recessed for Cladding with Double Layer Gypsum Drywall Panel, for Installation in Fire-Rated Gypsum Board Floor/Ceiling Assemblies:
  - 1. Karp Associates, Inc.; <u>www.karpinc.com</u> Model KATR.
  - 2. Substitution Requests: In accordance with Section 01 25 00.
- E. Sizes: As indicated on Drawings or as required to properly service mechanical or electrical equipment.
- F. Material: Stainless steel.
- G. Finish:
  - 1. Stainless Steel: No. 4 satin finish.
- H. Locking Devices: Key operated cam locks.

### 2.03 FIRE-RATED ACCESS DOORS

- A. Acceptable Manufacturers and Products Flush-Mounted Fire-Rated Access Doors:
  - 1. Acudor Products, Inc.; <u>www.acudor.com</u> Model FB-5050.
  - 2. Karp Associates, Inc.; www.karpinc.com Model KRP-150 FR.
  - 3. J.L. Industries; www.jlindustries.com- Model FD.
  - 4. Milcor; <u>www.milcorinc.com</u> Style UFR.
  - 5. Nystrom Building Products; <u>www.nystrom.com</u> Model IT.
  - 6. Williams Brothers Corporation of America; <u>www.wbdoors.com</u> Model WB-FR.
  - 7. Substitution Requests: In accordance with Section 01 25 00.
- B. Fire Rating:
  - 1. Provide fire rating label acceptable to local building code authority on access doors to be installed in fire rated walls and ceilings.
  - 2. Walls: 1-1/2 hour UL "B" label.
  - 3. Ceilings: Approved by Warnock Hersey International for 3 hours.
- C. Sizes: As indicated on Drawings or as required to properly service mechanical or electrical equipment, but not larger than limit for required fire rating.
- D. Material: Stainless steel.
- E. Finish:
  - 1. Stainless Steel: No. 4 satin finish.
- F. Locking Devices: Key operated cam locks.

# PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Access Doors:
    - 1. Mechanical or Electrical Access: Access doors required for access to mechanical or electrical equipment shall be provided under Division 22, Division 23, or Division 26 and installed by the trade responsible for the material in which door is located.
    - 2. General Access: Furnish access door indicated on Drawings for general access to be installed by trade responsible for material in which door is located.

- 3. Type:
  - a. Installation in Non-Rated Walls and Ceilings:
    - 1) In Janitor Rooms, Mechanical and Electrical Rooms, and Other Rooms Generally Accessible to Staff Personnel Only: Flush-mounted, non-rated.
    - 2) Areas and Rooms Accessible to Public: Recessed type, unless flush-mounted is specifically approved by Architect.
  - b. Installation in Fire-Rated Walls and Ceilings: Fire-rated type.
    - Fire Rated Floor/Ceiling Assemblies: Fire-resistive access door with double layer of gypsum board acceptable provided finished door retains fire rating of floor/ceiling assembly.

END OF SECTION

### **SECTION 08 56 19**

### PASS WINDOWS

# PART 1 GENERAL

# 1.01 SUMMARY

- A. Section Includes:1. Interior aluminum frame bi-parting transaction window.
- B. Related Requirements:
  - 1. Glazing: Section 08 80 00 Glazing.

# 1.02 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's current catalog literature for windows, components and accessories proposed for installation. Include printed data with selected options clearly indicated and in sufficient detail to indicate compliance with the Contract Documents.
- C. Shop Drawings: Indicate frame profiles, size, type and spacing of frame anchors, reinforcement size and locations, details of joints and connections, and welding details.
- 1.03 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Manufacturer's Instructions:
    - 1. Submit Manufacturer's instructions for installation of windows and for cleaning glazing material.

### 1.04 CLOSEOUT SUBMITTALS

- A. Submit the following for Project record:
  - 1. Operating and Maintenance Data:
  - 2. Warranties.
- 1.05 DELIVERY, STORAGE AND HANDLING
  - A. General: Comply with Section 01 65 00 and Section 01 66 00. Protect windows during transit, storage and handling to prevent damage, soiling, breakage and deterioration.
  - B. Delivery and Acceptance Requirements: Deliver the materials to the Project with the manufacturer's labels intact and legible.
  - C. Storage and Handling Requirements: Properly store all frames, glazing material, etc. in a dry location and covered to protect them from damage before and after installation.

# PART 2 PRODUCTS

#### 2.01 MANUFACTURERS

- A. Basis of Design Manufacturer: Quickserv Corporation; <u>www.quikserv.com</u>.
- B. Substitution Requests: Required for all manufacturers and products not named as Basis of Design or as Acceptable Manufacturer and Product.
  - 1. Submit in accordance with Section 01 25 00.

### 2.02 DESCRIPTION

- A. Type: Sliding interior self-closing serving window.
- B. Slider Configuration: As indicated.
- C. Glazing: 1/4-inch clear tempered glass.
- D. Frames: Aluminum frame modules shall be constructed of 6063-T5 extruded aluminum.
  - 1. Window glides on top-hung nylon slides.
  - 2. Poly-pile weather stripping and slide locks.
  - 3. Overall frame sizes are to be in accordance with the Drawings.

#### E. Hardware:

1. Keyed lock. Coordinate with Section 08 71 00 Door Hardware.

### 2.03 FINISHES

A. Aluminum Finish: Comply with AAMA 2604. PVDF or FEVE, two-coat.1. Color: White.

#### PART 3 EXECUTION

#### 3.01 INSTALLATION

- A. Pass/Service Windows: Install as indicated and in accordance with manufacturer's instructions and approved shop drawings.
- B. Anchorage: As indicated on accepted shop drawings. All exposed anchor holes shall be used for anchoring.

### 3.02 ADJUSTING

- A. At completion of job, adjust operable windows and hardware as required and leave in proper operating condition.
- B. No field alterations to the construction of the units shall be allowed unless approved by the manufacturer and the Architect.

#### 3.03 CLEANING

A. Upon completion, clean exposed surfaces of frames and glazing products thoroughly in accordance with manufacturer's instructions; remove mastic smears and other unsightly marks.

# 3.04 PROTECTION

- A. Protect installed windows from damage or deterioration until acceptance of entire Project.
- B. Replacement: Repair damaged units prior to completion and acceptance of the Project or replace with new, as directed.

END OF SECTION

### SECTION 08 71 00

# DOOR HARDWARE

### PART 1 - GENERAL

### 1.1 SUMMARY

- A. Section includes:
  - 1. Mechanical and electrified door hardware for:
    - a. Swinging doors.
- B. Exclusions: Unless specifically listed in hardware sets, hardware is not specified in this section for:
  - 1. Windows
  - 2. Cabinets (casework), including locks in cabinets
  - 3. Signage
  - 4. Toilet accessories
  - 5. Overhead doors
- C. Related Sections:
  - 1. Division 01 Section "Alternates" for alternates affecting this section.
  - 2. Division 07 Section "Joint Sealants" for sealant requirements applicable to threshold installation specified in this section.
  - 3. Division 26 sections for connections to electrical power system and for low-voltage wiring.
  - Division 28 sections for coordination with other components of electronic access control system.

#### 1.2 REFERENCES

- A. UL Underwriters Laboratories
  - 1. UL 10B Fire Test of Door Assemblies
  - 2. UL 10C Positive Pressure Test of Fire Door Assemblies
  - 3. UL 1784 Air Leakage Tests of Door Assemblies
  - 4. UL 305 Panic Hardware
- B. DHI Door and Hardware Institute
  - 1. Sequence and Format for the Hardware Schedule
  - 2. Recommended Locations for Builders Hardware
  - 3. Key Systems and Nomenclature
- C. ANSI American National Standards Institute
  - 1. ANSI/BHMA A156.1 A156.29, and ANSI/BHMA A156.31 Standards for Hardware and Specialties

# **1.3 SUBMITTALS**

- A. General:
  - 1. Submit in accordance with Conditions of Contract and Division 01 requirements.
  - 2. Highlight, encircle, or otherwise specifically identify on submittals deviations from Contract Documents, issues of incompatibility or other issues which may detrimentally affect the Work.
  - 3. Prior to forwarding submittal, comply with procedures for verifying existing door and frame compatibility for new hardware, as specified in PART 3, "EXAMINATION" article, herein.
- B. Action Submittals:
  - 1. Product Data: Product data including manufacturers' technical product data for each item of door hardware, installation instructions, maintenance of operating parts and finish, and other information necessary to show compliance with requirements.
  - 2. Riser and Wiring Diagrams: After final approval of hardware schedule, submit details of electrified door hardware, indicating:
    - a. Wiring Diagrams: For power, signal, and control wiring and including:
      - 1) Details of interface of electrified door hardware and building safety and security systems.
      - 2) Schematic diagram of systems that interface with electrified door hardware.
      - 3) Point-to-point wiring.
      - 4) Risers.
  - 3. Samples for Verification: If requested by Architect, submit production sample or sample installations of each type of exposed hardware unit in finish indicated, and tagged with full description for coordination with schedule.
    - a. Samples will be returned to supplier in like-new condition. Units that are acceptable to Architect may, after final check of operations, be incorporated into Work, within limitations of key coordination requirements.
  - 4. Door Hardware Schedule: Submit schedule with hardware sets in vertical format as illustrated by Sequence of Format for the Hardware Schedule as published by the Door and Hardware Institute. Indicate complete designations of each item required for each door or opening, include:
    - a. Door Index; include door number, heading number, and Architects hardware set number.
    - b. Opening Lock Function Spreadsheet: List locking device and function for each opening.
    - c. Type, style, function, size, and finish of each hardware item.
    - d. Name and manufacturer of each item.
    - e. Fastenings and other pertinent information.
    - f. Location of each hardware set cross-referenced to indications on Drawings.
    - g. Explanation of all abbreviations, symbols, and codes contained in schedule.
    - h. Mounting locations for hardware.
    - i. Door and frame sizes and materials.
    - j. Name and phone number for local manufacturer's representative for each product.
    - k. Operational Description of openings with any electrified hardware (locks, exits, electromagnetic locks, electric strikes, automatic operators, door position switches, magnetic holders or closer/holder units, and access control components).

Operational description should include how door will operate on egress, ingress, and fire and smoke alarm connection.

- Submittal Sequence: Submit door hardware schedule concurrent with submissions of Product Data, Samples, and Shop Drawings. Coordinate submission of door hardware schedule with scheduling requirements of other work to facilitate fabrication of other work that is critical in Project construction schedule.
- 5. Key Schedule:
  - a. After Keying Conference, provide keying schedule listing levels of keying as well as explanation of key system's function, key symbols used and door numbers controlled.
  - Use ANSI/BHMA A156.28 "Recommended Practices for Keying Systems" as guideline for nomenclature, definitions, and approach for selecting optimal keying system.
  - c. Provide 3 copies of keying schedule for review prepared and detailed in accordance with referenced DHI publication. Include schematic keying diagram and index each key to unique door designations.
  - d. Index keying schedule by door number, keyset, hardware heading number, cross keying instructions, and special key stamping instructions.
  - e. Provide one complete bitting list of key cuts and one key system schematic illustrating system usage and expansion.
    - 1) Forward bitting list, key cuts and key system schematic directly to Tri-City Medical Center, by means as directed by Tri-City Medical Center.
  - f. Prepare key schedule by or under supervision of supplier, detailing Tri-City Medical Center's final keying instructions for locks.
- 6. Templates: After final approval of hardware schedule, provide templates for doors, frames and other work specified to be factory prepared for door hardware installation.
- C. Informational Submittals:
  - 1. Qualification Data: For Supplier, Installer and Architectural Hardware Consultant.
  - 2. Product Certificates for electrified door hardware, signed by manufacturer:
    - a. Certify that door hardware approved for use on types and sizes of labeled fire-rated doors complies with listed fire-rated door assemblies.
  - 3. Certificates of Compliance:
    - a. Certificates of compliance for fire-rated hardware and installation instructions if requested by Architect or Authority Having Jurisdiction.
    - b. Installer Training Meeting Certification: Letter of compliance, signed by Contractor, attesting to completion of installer training meeting specified in "QUALITY ASSURANCE" article, herein.
    - c. Electrified Hardware Coordination Conference Certification: Letter of compliance, signed by Contractor, attesting to completion of electrified hardware coordination conference, specified in "QUALITY ASSURANCE" article, herein.
  - 4. Product Test Reports: For compliance with accessibility requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by qualified testing agency, for door hardware on doors located in accessible routes.
  - 5. Warranty: Special warranty specified in this Section.
- D. Closeout Submittals:

- 1. Operations and Maintenance Data : Provide in accordance with Division 01 and include:
  - a. Complete information on care, maintenance, and adjustment; data on repair and replacement parts, and information on preservation of finishes.
  - b. Catalog pages for each product.
  - c. Name, address, and phone number of local representative for each manufacturer.
  - d. Parts list for each product.
  - e. Final approved hardware schedule, edited to reflect conditions as-installed.
  - f. Final keying schedule
  - g. Copies of floor plans with keying nomenclature
  - h. As-installed wiring diagrams for each opening connected to power, both low voltage and 110 volts.
  - i. Copy of warranties including appropriate reference numbers for manufacturers to identify project.

### 1.4 QUALITY ASSURANCE

- A. Product Substitutions: Comply with product requirements stated in Division 01 and as specified herein.
  - 1. Where specific manufacturer's product is named and accompanied by "No Substitute," including make or model number or other designation, provide product specified. (Note: Certain products have been selected for their unique characteristics and particular project suitability.)
    - a. Where no additional products or manufacturers are listed in product category, requirements for "No Substitute" govern product selection.
  - 2. Where products indicate "acceptable manufacturers" or "acceptable manufacturers and products", provide product from specified manufacturers, subject to compliance with specified requirements and "Single Source Responsibility" requirements stated herein.
- B. Supplier Qualifications and Responsibilities: Recognized architectural hardware supplier with record of successful in-service performance for supplying door hardware similar in quantity, type, and quality to that indicated for this Project.
  - 1. Warehousing Facilities: In Project's vicinity.
  - 2. Scheduling Responsibility: Preparation of door hardware and keying schedules.
  - 3. Engineering Responsibility: Preparation of data for electrified door hardware, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project.
  - 4. Coordination Responsibility: Coordinate installation of electronic security hardware with Architect and electrical engineers and provide installation and technical data to Architect and other related subcontractors.
    - a. Upon completion of electronic security hardware installation, inspect and verify that all components are working properly.
- C. Installer Qualifications: Qualified tradesmen, skilled in application of commercial grade hardware with record of successful in-service performance for installing door hardware similar in quantity, type, and quality to that indicated for this Project.
- D. Single Source Responsibility: Obtain each type of door hardware from single manufacturer.

- 1. Provide electrified door hardware from same manufacturer as mechanical door hardware, unless otherwise indicated.
- 2. Manufacturers that perform electrical modifications and that are listed by testing and inspecting agency acceptable to authorities having jurisdiction are acceptable.
- E. Fire-Rated Door Openings: Provide door hardware for fire-rated openings that complies with NFPA 80 and requirements of authorities having jurisdiction. Provide only items of door hardware that are listed and are identical to products tested by Underwriters Laboratories, Intertek Testing Services, or other testing and inspecting organizations acceptable to authorities having jurisdiction for use on types and sizes of doors indicated, based on testing at positive pressure and according to NFPA 252 or UL 10C and in compliance with requirements of fire-rated door and door frame labels.
- F. Smoke- and Draft-Control Door Assemblies: Where smoke- and draft-control door assemblies are required, provide door hardware that meets requirements of assemblies tested according to UL 1784 and installed in compliance with NFPA 105.
  - 1. Air Leakage Rate: Maximum air leakage of 0.3 cfm/sq. ft. (3 cu. m per minute/sq. m) at tested pressure differential of 0.3-inch wg (75 Pa) of water.
- G. Electrified Door Hardware: Listed and labeled as defined in NFPA 70, Article 100, by testing agency acceptable to authorities having jurisdiction.
- H. Means of Egress Doors: Latches do not require more than 15 lbf (67 N) to release latch. Locks do not require use of key, tool, or special knowledge for operation.
- I. Accessibility Requirements: For door hardware on doors in an accessible route, comply with governing accessibility regulations cited in "REFERENCES" article, herein.
  - 1. Provide operating devices that do not require tight grasping, pinching, or twisting of wrist and that operate with force of not more than 5 lbf (22.2 N).
  - 2. Maximum opening-force requirements:
    - a. Interior, Non-Fire-Rated Hinged Doors: 5 lbf (22.2 N) applied perpendicular to door.
    - b. Sliding or Folding Doors: 5 lbf (22.2 N) applied parallel to door at latch.
    - c. Fire Doors: Minimum opening force allowable by authorities having jurisdiction.
  - 3. Bevel raised thresholds with slope of not more than 1:2. Provide thresholds not more than 1/2 inch (13 mm) high.
  - 4. Adjust door closer sweep periods so that, from open position of 70 degrees, door will take at least 3 seconds to move to 3 inches (75 mm) from latch, measured to leading edge of door.
- J. Keying Conference: Conduct conference at Project site to comply with requirements in Division 01.
  - 1. Attendees: Tri-City Medical Center, Contractor, Architect, Installer, and Supplier's Architectural Hardware Consultant.
  - 2. Incorporate keying conference decisions into final keying schedule after reviewing door hardware keying system including:
    - a. Function of building, flow of traffic, purpose of each area, degree of security required, and plans for future expansion.
    - b. Preliminary key system schematic diagram.
    - c. Requirements for key control system.
    - d. Requirements for access control.

- e. Address for delivery of keys.
- K. Pre-installation Conference: Conduct conference at Project site
  - 1. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
  - 2. Inspect and discuss preparatory work performed by other trades.
  - 3. Inspect and discuss electrical roughing-in for electrified door hardware.
  - 4. Review sequence of operation for each type of electrified door hardware.
  - 5. Review required testing, inspecting, and certifying procedures.
- L. Coordination Conferences:
  - 1. Installation Coordination Conference: Prior to hardware installation, schedule and hold meeting to review questions or concerns related to proper installation and adjustment of door hardware.
    - a. Attendees: Door hardware supplier, door hardware installer, Contractor.
    - b. After meeting, provide letter of compliance to Architect, indicating when meeting was held and who was in attendance.
  - 2. Electrified Hardware Coordination Conference: Prior to ordering electrified hardware, schedule and hold meeting to coordinate door hardware with security, electrical, doors and frames, and other related suppliers.
    - a. Attendees: electrified door hardware supplier, doors and frames supplier, electrified door hardware installer, electrical subcontractor, Tri-City Medical Center, Architect and Contractor.
    - b. After meeting, provide letter of compliance to Architect, indicating when coordination conference was held and who was in attendance.

# 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up for hardware delivered to Project site.
- B. Tag each item or package separately with identification coordinated with final door hardware schedule, and include installation instructions, templates, and necessary fasteners with each item or package.
  - 1. Deliver each article of hardware in manufacturer's original packaging.
- C. Project Conditions:
  - 1. Maintain manufacturer-recommended environmental conditions throughout storage and installation periods.
  - 2. Provide secure lock-up for door hardware delivered to Project, but not yet installed. Control handling and installation of hardware items so that completion of Work will not be delayed by hardware losses both before and after installation.
- D. Protection and Damage:
  - 1. Promptly replace products damaged during shipping.
  - 2. Handle hardware in manner to avoid damage, marring, or scratching. Correct, replace or repair products damaged during Work.

- 3. Protect products against malfunction due to paint, solvent, cleanser, or any chemical agent.
- E. Deliver keys to manufacturer of key control system for subsequent delivery to Tri-City Medical Center.
- F. Deliver keys and permanent cores to Tri-City Medical Center as directed.

### **1.6 COORDINATION**

- A. Coordinate layout and installation of floor-recessed door hardware with floor construction. Cast anchoring inserts into concrete. Concrete, reinforcement, and formwork requirements are specified in Division 03.
- B. Installation Templates: Distribute for doors, frames, and other work specified to be factory prepared. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.
- C. Security: Coordinate installation of door hardware, keying, and access control with Tri-City Medical Center's security consultant.
- D. Electrical System Roughing-In: Coordinate layout and installation of electrified door hardware with connections to power supplies and building safety and security systems.
- E. Existing Openings: Where hardware components are scheduled for application to existing construction or where modifications to existing door hardware are required, field verify existing conditions and coordinate installation of door hardware to suit opening conditions and to provide proper door operation.
- F. Direct shipments not permitted, unless approved by Contractor.

#### 1.7 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.
  - 1. Warranty Period: Years from date of Substantial Completion, for durations indicated.
    - a. Closers:
      - 1) Mechanical: 30 years.
    - b. Automatic Operators: 2 years.
    - c. Exit Devices:
      - 1) Mechanical: 3 years.
      - 2) Electrified: 1 year.
    - d. Locksets:
      - 1) Mechanical: 3 years.
      - 2) Electrified: 1 year.
    - e. Continuous Hinges: Lifetime warranty
    - f. Key Blanks: Lifetime

2. Warranty does not cover damage or faulty operation due to improper installation, improper use or abuse.

# PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. The Tri-City Medical Center requires use of certain products for their unique characteristics and particular project suitability to insure continuity of existing and future performance and maintenance standards. After investigating available product offerings, the Awarding Authority has elected to prepare proprietary specifications. These products are specified with the notation: "No Substitute."
  - 1. Where "No Substitute" is noted, submittals and substitution requests for other products will not be considered.
- B. Approval of manufacturers and/or products other than those listed as "Scheduled Manufacturer" or "Acceptable Manufacturers" in the individual article for the product category shall be in accordance with QUALITY ASSURANCE article, herein.
- C. Approval of products from manufacturers indicated in "Acceptable Manufacturers" is contingent upon those products providing all functions and features and meeting all requirements of scheduled manufacturer's product.
- D. Hand of Door: Drawings show direction of slide, swing, or hand of each door leaf. Furnish each item of hardware for proper installation and operation of door movement as shown.
- E. Where specified hardware is not adaptable to finished shape or size of members requiring hardware, furnish suitable types having same operation and quality as type specified, subject to Architect's approval.

# 2.2 MATERIALS

#### A. Fasteners

- 1. Provide hardware manufactured to conform to published templates, generally prepared for machine screw installation.
- 2. Furnish screws for installation with each hardware item. Finish exposed (exposed under any condition) screws to match hardware finish, or, if exposed in surfaces of other work, to match finish of this other work including prepared for paint surfaces to receive painted finish.
- 3. Provide concealed fasteners for hardware units exposed when door is closed except when no standard units of type specified are available with concealed fasteners. Do not use thru-bolts for installation where bolt head or nut on opposite face is exposed in other work unless thru-bolts are required to fasten hardware securely. Review door specification and advise Architect if thru-bolts are required.
- 4. Install hardware with fasteners provided by hardware manufacturer.
- B. Provide screws, bolts, expansion shields, drop plates and other devices necessary for hardware installation.
  - 1. Where fasteners are exposed to view: Finish to match adjacent door hardware material.

### 2.3 HINGES

- A. Provide three-knuckle, concealed bearing hinges.
  - 1. Manufacturers and Products:
    - a. Scheduled Manufacturer and Product: Ives 3CB series
    - b. Acceptable Manufacturers and Products: Hager AB series, McKinney TA series
- B. Requirements:
  - 1. 1-3/4 inch (44 mm) thick doors, up to and including 36 inches (914 mm) wide:
    - a. Exterior: Standard weight, bronze or stainless steel, 4-1/2 inches (114 mm) high
    - b. Interior: Standard weight, steel, 4-1/2 inches (114 mm) high
  - 2. 1-3/4 inch (44 mm) thick doors over 36 inches (914 mm) wide:
    - a. Exterior: Heavy weight, bronze/stainless steel, 5 inches (127 mm) high
    - b. Interior: Heavy weight, steel, 5 inches (127 mm) high
  - 3. 2 inches or thicker doors:
    - a. Exterior: Heavy weight, bronze or stainless steel, 5 inches (127 mm) high
    - b. Interior: Heavy weight, steel, 5 inches (127 mm) high
  - 4. Provide three hinges per door leaf for doors 90 inches (2286 mm) or less in height, and one additional hinge for each 30 inches (762 mm) of additional door height.
  - 5. Where new hinges are specified for existing doors or existing frames, provide new hinges of identical size to hinge preparation present in existing door or existing frame.
  - 6. Hinge Pins: Except as otherwise indicated, provide hinge pins as follows:
    - a. Steel Hinges: Steel pins
    - b. Non-Ferrous Hinges: Stainless steel pins
    - c. Out-Swinging Exterior Doors: Non-removable pins
    - d. Out-Swinging Interior Lockable Doors: Non-removable pins
    - e. Interior Non-lockable Doors: Non-rising pins
  - 7. Width of hinges: 4-1/2 inches (114 mm) at 1-3/4 inch (44 mm) thick doors, and 5 inches (127 mm) at 2 inches (51 mm) or thicker doors. Adjust hinge width as required for door, frame, and wall conditions to allow proper degree of opening.
  - 8. Doors 36 inches (914 mm) wide or less furnish hinges 4-1/2 inches (114 mm) high; doors greater than 36 inches (914 mm) wide furnish hinges 5 inches (127 mm) high, heavy weight or standard weight as specified.
  - 9. Provide hinges with electrified options as scheduled in the hardware sets. Provide with sufficient number and wire gage to accommodate electric function of specified hardware. Locate electric hinge at second hinge from bottom or nearest to electrified locking component.
  - 10. Provide mortar guard for each electrified hinge specified.
  - 11. Provide spring hinges where specified. Provide two spring hinges and one bearing hinge per door leaf for doors 90 inches (2286 mm) or less in height. Provide one additional bearing hinge for each 30 inches (762 mm) of additional door height.

# 2.4 CONTINUOUS HINGES

#### A. Stainless Steel

TCMC Pharmacy USP 800 Upgrade Tri-City Medical Center SA Project No. 01667.00

- 1. Manufacturers:
  - a. Scheduled Manufacturer: lves
  - b. Acceptable Manufacturers: Markar, Stanley
- 2. Requirements:
  - a. Provide pin and barrel continuous hinges conforming to ANSI/BHMA A156.26, Grade 2.
  - b. Provide pin and barrel continuous hinges fabricated from 14 gauge, type 304 stainless steel.
  - c. Provide twin self-lubricated nylon bearings at each hinge knuckle, with 0.25-inch (6 mm) diameter stainless steel pin.
  - d. Provide hinges capable of supporting door weights up to 600 pounds, and successfully tested for 1,500,000 cycles.
  - e. On fire-rated doors, provide pin and barrel continuous hinges that are classified for use on rated doors by testing agency acceptable to authority having jurisdiction.
  - f. Provide pin and barrel continuous hinges with electrified options as scheduled in the hardware sets. Provide with sufficient number and wire gage to accommodate electric function of specified hardware.
  - g. Install hinges with fasteners supplied by manufacturer.
  - h. Provide hinges with symmetrical hole pattern.

### 2.5 ELECTRIC POWER TRANSFER

- A. Manufacturers:
  - a. Scheduled Manufacturer: Von Duprin
  - b. Acceptable Manufacturers: Falcon, ABH
- B. Provide power transfer with electrified options as scheduled in the hardware sets. Provide with number and gage of wires sufficient to accommodate electric function of specified hardware.
- C. Locate electric power transfer per manufacturer's template and UL requirements, unless interference with operation of door or other hardware items.

### 2.6 FLUSH BOLTS

- A. Manufacturers:
  - 1. Scheduled Manufacturer: Ives
  - 2. Acceptable Manufacturers: Trimco, Rockwood
- B. Requirements:
  - Provide automatic, constant latching, and manual flush bolts with forged bronze or stainless steel face plates, extruded brass levers, and with wrought brass guides and strikes. Provide 12 inch (305 mm) steel or brass rods at doors up to 90 inches (2286 mm) in height. For doors over 90 inches (2286 mm) in height increase top rods by 6 inches (152 mm) for each additional 6 inches (152 mm) of door height. Provide dustproof strikes at each bottom flush bolt.

# 2.7 COORDINATORS

- A. Manufacturers:
  - 1. Scheduled Manufacturer: Ives
  - 2. Acceptable Manufacturers: Trimco, Rockwood
- B. Requirements:
  - 1. Where pairs of doors are equipped with automatic flush bolts, an astragal, or other hardware that requires synchronized closing of the doors, provide bar-type coordinating device, surface applied to underside of stop at frame head.
  - 2. Provide filler bar of correct length for unit to span entire width of opening, and appropriate brackets for parallel arm door closers and surface vertical rod exit device strikes. Factory-prep coordinators for vertical rod devices if required.

# 2.8 MORTISE LOCKS

- A. Manufacturers and Products:
  - 1. Scheduled Manufacturer and Product: Corbin-Russwin ML2000 series
  - 2. Acceptable Manufacturers and Products: No Substitute
- B. Requirements:
  - Provide mortise locks conforming to ANSI/BHMA A156.13 Series 1000, Grade 1 Operational, Grade 1 Security, and manufactured from heavy gauge steel, containing components of steel with a zinc dichromate plating for corrosion resistance. Provide lock case that is multi-function and field reversible for handing without opening case. Cylinders: Refer to "KEYING" article, herein.
  - Provide locks with standard 2-3/4 inches (70 mm) backset with full 3/4 inch (19 mm) throw stainless steel mechanical anti-friction latchbolt. Provide deadbolt with full 1 inch (25 mm) throw, constructed of stainless steel.
  - 3. Provide standard ASA strikes unless extended lip strikes are necessary to protect trim.
  - 4. Provide electrified options as scheduled in the hardware sets. Where scheduled, provide a request to exit (RX) switch that is actuated with rotation of inside lever.
  - 5. Lever Trim: Solid brass, bronze, or stainless steel, cast or forged in design specified, with wrought roses and external lever spring cages. Provide thru-bolted levers with 2-piece spindles.
    - a. Lever Design: Corbin-Russwin LWA.

# 2.9 EXIT DEVICES

- A. Manufacturer and Product:
  - 1. Scheduled Manufacturer: Von Duprin 98 series
  - 2. Acceptable Manufacturers and Products: No Substitute.
- B. Manufacturers and Products:
  - 1. Scheduled Manufacturer: To establish standard of quality and design intent, exit device specifications have been based on Von Duprin products. Products of other manufacturers meeting or exceeding design and performance requirements specified

herein will be considered for substitution subject to compliance with provisions of Division 01 Section "Product Requirements."

- C. Requirements:
  - Provide exit devices tested to ANSI/BHMA A156.3-2014 Grade 1, UL certified to meet maximum 5 pound requirements according to the California Building Code section 11B-309.4,] and UL listed for Panic Exit or Fire Exit Hardware. Cylinders: Refer to "KEYING" article, herein.
  - 2. Provide touchpad type exit devices, fabricated of brass, bronze, stainless steel, or aluminum, plated to standard architectural finishes to match balance of door hardware.
  - 3. Quiet Operation: Incorporate fluid damper or other device that eliminates noise of exit device operation.
  - 4. Touchpad: Extend minimum of one half of door width, but not the full length of exit device rail. Provide end-cap with two-point attachment to door. Match exit device finish, stainless steel for US26, US26D, US28, US32, and US32D finishes; and for all other finishes, provide compatible finish to exit device. Provide compression springs in devices, latches, and outside trims or controls; tension springs prohibited.
  - 5. Provide rim devices with a dual cylinder or inside thumb turn cylinder option with a visual security indicator that identifies the trims locked/unlocked status of the door from the inside of the room. Indicator in unlocked state presents a 1/2 inch x 1/2 inch white metal flag with black icon at top of device head. Indicator in locked state has no flag present. Provide rim devices without the dual cylinder or inside thumb turn cylinder option capable of being retrofitted with the visual security indicator.
  - 6. Provide exit devices with deadlatching feature for security and for future addition of alarm kits and/or other electrical requirements.
  - 7. Provide exit devices with manufacturer's approved strikes.
  - 8. Provide exit devices cut to door width and height. Locate exit devices at height recommended by exit device manufacturer, allowable by governing building codes, and approved by Architect.
  - 9. Mount mechanism case flush on face of doors, or provide spacers to fill gaps behind devices. Where glass trim or molding projects off face of door, provide glass bead kits.
  - 10. Where lever handles are specified as outside trim for exit devices, provide heavy-duty lever trims with forged or cast escutcheon plates. Provide vandal-resistant levers that will travel to 90-degree down position when more than 35 pounds of torque are applied, and which can easily be re-set.
    - a. Lever Style: Match lever style of locksets.
  - 11. Provide UL labeled fire exit hardware for fire rated openings.
  - 12. Provide electrified options as scheduled in the hardware sets.

# 2.10 POWER SUPPLIES

- A. Manufacturers and Products:
  - 1. Scheduled Manufacturer and Product: Schlage or Von Duprin PS900 series
  - Acceptable Manufacturers and Products: Precision ELR series, Sargent 3500 series, Dynalock 5000 series, Folger Adam FABPS series, Securitron BPS series, Security Door Controls 600 series
- B. Requirements:

- 1. Provide power supplies, recommended and approved by manufacturer of electrified locking component, for operation of electrified locks, electrified exit devices, magnetic locks, electric strikes, and other components requiring power supply.
- Provide appropriate quantity of power supplies necessary for proper operation of electrified locking components as recommended by manufacturer of electrified locking components with consideration for each electrified component using power supply, location of power supply, and approved wiring diagrams. Locate power supplies as directed by Architect.
- 3. Provide regulated and filtered 24 VDC power supply, and UL class 2 listed.
- 4. Options:
  - a. Provide power supply, where specified, with internal capability of charging sealed backup batteries 24 VDC, in addition to operating DC load.
  - b. Provide sealed batteries for battery back-up at each power supply where specified.
  - c. Provide keyed power supply cabinet.
- 5. Provide power supply in an enclosure, complete, and requiring 120VAC to fused input.
- 6. Provide power supply with emergency release terminals, where specified, that allow release of all devices upon activation of fire alarm system complete with fire alarm input for initiating "no delay" exiting mode.

# 2.11 CYLINDERS MATCH EXISTING KEY SYSTEM

- A. Manufacturers:
  - 1. Scheduled Manufacturer: Corbin-Russwin
  - 2. Acceptable Manufacturers: Unknown
- B. Requirements:
  - Provide cylinders/cores, from the same manufacturer of locksets, compliant with ANSI/BHMA A156.5; latest revision, Section 12, Grade 1; permanent cylinders; cylinder face finished to match lockset, manufacturer's series as indicated. Refer to "KEYING" article, herein.
  - 2. Provide cylinders in the below-listed configuration(s), distributed throughout the Project as indicated.
    - a. Conventional cylinder with permanent core with open keyway.
    - b. Keying: Manufacturer-keyed permanent cylinders/cores, configured into keying system per "KEYING" article herein.
    - c. Features: Cylinders/cores shall incorporate the following features.
  - 3. Nickel silver bottom pins.
  - 4. Replaceable Construction Cores.
    - a. Provide temporary construction cores replaceable by permanent cores, furnished in accordance with the following requirements.
      - 1) 12 construction change (day) keys.
    - b. Tri-City Medical Center or Tri-City Medical Center's Representative will replace temporary construction cores with permanent cores.

# 2.12 KEYING MATCH EXISTING KEY SYSTEM

- A. Provide a factory registered keying system, complying with guidelines in ANSI/BHMA A156.28, incorporating decisions made at keying conference.
- B. Requirements:
  - 1. Provide permanent cylinders/cores keyed by the manufacturer according to the following key system.
    - a. Keying system as directed by the Tri-City Medical Center.
  - 2. Forward bitting list and keys separately from cylinders, by means as directed by Tri-City Medical Center. Failure to comply with forwarding requirements shall be cause for replacement of cylinders/cores involved at no additional cost to Tri-City Medical Center.
  - 3. Provide keys with the following features.
    - a. Material: Nickel silver; minimum thickness of .107-inch (2.3mm)
  - 4. Identification:
    - a. Mark permanent cylinders/cores and keys with applicable blind code per DHI publication "Keying Systems and Nomenclature" for identification. Blind code marks shall not include actual key cuts.
    - b. Identification stamping provisions must be approved by the Architect and Tri-City Medical Center.
    - c. Stamp cylinders/cores and keys with Tri-City Medical Center's unique key system facility code as established by the manufacturer; key symbol and embossed or stamped with "DO NOT DUPLICATE" along with the "PATENTED" or patent number to enforce the patent protection.
    - d. Failure to comply with stamping requirements shall be cause for replacement of keys involved at no additional cost to Tri-City Medical Center.
    - e. Forward permanent cylinders/cores to Tri-City Medical Center, separately from keys, by means as directed by Tri-City Medical Center.
  - 5. Quantity: Furnish in the following quantities.
    - a. Change (Day) Keys: 3 per cylinder/core.
    - b. Permanent Control Keys: 3.
    - c. Master Keys: 6.
    - d. Unused balance of key blanks shall be furnished to Tri-City Medical Center with the cut keys.
    - e. Extra Keys:
      - 1) 2 Presentation Keys
      - 2) 2 Construction Keys

# 2.13 DOOR CLOSERS

- A. Manufacturers and Products:
  - 1. Scheduled Manufacturer and Product: LCN 4040XP series
  - 2. Acceptable Manufacturers and Products: Sargent 281/281P10/281TJ series factory assembled (without PRV)
- B. Requirements:

TCMC Pharmacy USP 800 Upgrade Tri-City Medical Center SA Project No. 01667.00

- 1. Provide door closers conforming to ANSI/BHMA A156.4 Grade 1 requirements by BHMA certified independent testing laboratory. Stamp units with date of manufacture code.
- 2. Provide door closers with fully hydraulic, full rack and pinion action with high strength cast iron cylinder, and full complement bearings at shaft.
- 3. Cylinder Body: 1-1/2 inch (38 mm) diameter, with 5/8 inch (16 mm) diameter double heat-treated pinion journal.
- 4. Hydraulic Fluid: Fireproof, passing requirements of UL10C, and requiring no seasonal closer adjustment for temperatures ranging from 120 degrees F to -30 degrees F.
- 5. Spring Power: Continuously adjustable over full range of closer sizes, and providing reduced opening force as required by accessibility codes and standards.
- 6. Hydraulic Regulation: By tamper-proof, non-critical valves with separate adjustment for latch speed, general speed, and backcheck.
- 7. Provide closers with a solid forged steel main arms and factory assembled heavy-duty forged forearms for parallel arm closers.
- 8. Pressure Relief Valve (PRV) Technology: Not permitted.
- 9. Finish for Closer Cylinders, Arms, Adapter Plates, and Metal Covers: Powder coating finish which has been certified to exceed 100 hours salt spray testing as described in ANSI/BHMA Standard A156.4 and ASTM B117, or has special rust inhibitor (SRI).
- 10. Provide special templates, drop plates, mounting brackets, or adapters for arms as required for details, overhead stops, and other door hardware items interfering with closer mounting.

# 2.14 ELECTRO-MECHANICAL AUTOMATIC OPERATORS

- A. Manufacturers and Products:
  - 1. Scheduled Manufacturer and Product: LCN Senior Swing
  - 2. Acceptable Manufacturers and Products: Besam Swingmaster MP, Horton 4000LE series
- B. Requirements:
  - 1. Provide low energy automatic operator units that are electro-mechanical design complying with ANSI/BHMA A156.19.
    - a. Opening: Powered by DC motor working through reduction gears.
    - b. Closing: Spring force.
    - c. Manual, hydraulic, or chain drive closers: Not permitted.
    - d. Operation: Motor is off when door is in closing mode. Door can be manually operated with power on or off without damage to operator. Provide variable adjustments, including opening and closing speed adjustment.
    - e. Cover: Aluminum.
  - 2. Provide units with manual off/auto/hold-open switch, push and go function to activate power operator, vestibule interface delay, electric lock delay, hold-open delay adjustable from 2 to 30 seconds, and logic terminal to interface with accessories, mats, and sensors.
  - 3. Provide drop plates, brackets, or adapters for arms as required to suit details.
  - 4. Provide hard-wired motion sensors and/or actuator switches for operation as specified. Provide weather-resistant actuators at exterior applications.
  - 5. Provide key switches, with LED's, recommended and approved by manufacturer of automatic operator as required for function as described in operation description of hardware sets. Cylinders: Refer to "KEYING" article, herein.
  - 6. Provide complete assemblies of controls, switches, power supplies, relays, and parts/material recommended and approved by manufacturer of automatic operator for each individual leaf. Actuators control both doors simultaneously at pairs. Sequence operation of exterior and vestibule doors with automatic operators to allow ingress or

egress through both sets of openings as directed by Architect. Locate actuators, key switches, and other controls as directed by Architect.

7. Provide units with inputs for smoke evacuation doors, where specified, which allow doors to power open upon fire alarm activation and hold open indefinitely or until fire alarm is reset, presence detector input, which prevents closed door from opening or door that is fully opened from closing, hold open toggle input, which allows remote activation for indefinite hold open and close second time input is activated, vestibule inputs, which allow sequencing operation of two units, and SPDT relay for interfacing with latching or locking devices.

# 2.15 PROTECTION PLATES

- A. Manufacturers:
  - 1. Scheduled Manufacturer: Ives
  - 2. Acceptable Manufacturers: Trimco, Rockwood
- B. Requirements:
  - 1. Provide kick plates, mop plates, and armor plates minimum of 0.050 inch (1 mm) thick, beveled four edges as scheduled. Furnish with sheet metal or wood screws, finished to match plates.
  - 2. Sizes of plates:
    - a. Kick Plates: 10 inches (254 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs
    - b. Mop Plates: 4 inches (102 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs
    - c. Armor Plates: 36 inches (914 mm) high by 2 inches (51 mm) less width of door on single doors, 1 inch (25 mm) less width of door on pairs

# 2.16 DOOR STOPS AND HOLDERS

- A. Manufacturers:
  - 1. Scheduled Manufacturer: Ives
  - 2. Acceptable Manufacturers: Trimco, Rockwood
- B. Provide door stops at each door leaf:
  - 1. Provide wall stops wherever possible. Provide convex type where mortise type locks are used and concave type where cylindrical type locks are used.
  - 2. Where a wall stop cannot be used, provide universal floor stops for low or high rise options.
  - 3. Where wall or floor stop cannot be used, provide medium duty surface mounted overhead stop.

# 2.17 THRESHOLDS, SEALS, DOOR SWEEPS, AUTOMATIC DOOR BOTTOMS, AND GASKETING

- A. Manufacturers:
  - 1. Scheduled Manufacturer: Zero International
  - 2. Acceptable Manufacturers: National Guard, Pemko

- B. Requirements:
  - 1. Provide thresholds, weather-stripping (including door sweeps, seals, and astragals) and gasketing systems (including smoke, sound, and light) as specified and per architectural details. Match finish of other items.
  - 2. Size of thresholds:
    - a. Saddle Thresholds: 1/2 inch (13 mm) high by jamb width by door width
    - b. Bumper Seal Thresholds: 1/2 inch (13 mm) high by 5 inches (127 mm) wide by door width
  - 3. Provide door sweeps, seals, astragals, and auto door bottoms only of type where resilient or flexible seal strip is easily replaceable and readily available.

### 2.18 FINSHES

- A. Finish: BHMA 626/652 (US26D); except:
  - 1. Hinges at Exterior Doors: BHMA 630 (US32D)
  - 2. Continuous Hinges: BHMA 630 (US32D)
  - 3. Push Plates, Pulls, and Push Bars: BHMA 630 (US32D)
  - 4. Protection Plates: BHMA 630 (US32D)
  - 5. Overhead Stops and Holders: BHMA 630 (US32D)
  - 6. Door Closers: Powder Coat to Match
  - 7. Wall Stops: BHMA 630 (US32D)
  - 8. Latch Protectors: BHMA 630 (US32D)
  - 9. Weatherstripping: Clear Anodized Aluminum
  - 10. Thresholds: Mill Finish Aluminum

#### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Prior to installation of hardware, examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire-rated door assembly construction, wall and floor construction, and other conditions affecting performance.
- B. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.2 INSTALLATION

- A. Mounting Heights: Mount door hardware units at heights to comply with the following, unless otherwise indicated or required to comply with governing regulations.
  - 1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
  - 2. Custom Steel Doors and Frames: HMMA 831.
  - 3. Wood Doors: DHI WDHS.3, "Recommended Locations for Architectural Hardware for Wood Flush Doors."

- B. Install each hardware item in compliance with manufacturer's instructions and recommendations, using only fasteners provided by manufacturer.
- C. Do not install surface mounted items until finishes have been completed on substrate. Protect all installed hardware during painting.
- D. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate as necessary for proper installation and operation.
- E. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.
- F. Install operating parts so they move freely and smoothly without binding, sticking, or excessive clearance.
- G. Hinges: Install types and in quantities indicated in door hardware schedule but not fewer than quantity recommended by manufacturer for application indicated or one hinge for every 30 inches (750 mm) of door height, whichever is more stringent, unless other equivalent means of support for door, such as spring hinges or pivots, are provided.
- H. Lock Cylinders: Install construction cores to secure building and areas during construction period.
  - 1. Replace construction cores with permanent cores as indicated in keying section.
- I. Wiring: Coordinate with Division 26, ELECTRICAL sections for:
  - 1. Conduit, junction boxes and wire pulls.
  - 2. Connections to and from power supplies to electrified hardware.
  - 3. Connections to fire/smoke alarm system and smoke evacuation system.
  - 4. Connection of wire to door position switches and wire runs to central room or area, as directed by Architect.
  - 5. Testing and labeling wires with Architect's opening number.
- J. Key Control System: Tag keys and place them on markers and hooks in key control system cabinet, as determined by final keying schedule.
- K. Door Closers: Mount closers on room side of corridor doors, inside of exterior doors, and stair side of stairway doors from corridors. Closers shall not be visible in corridors, lobbies and other public spaces unless approved by Architect.
- L. Power Supplies: Locate power supplies as indicated or, if not indicated, above accessible ceilings or in equipment room, or alternate location as directed by Architect.
  - 1. Configuration: Provide least number of power supplies required to adequately serve doors with electrified door hardware.
- M. Thresholds: Set thresholds in full bed of sealant complying with requirements specified in Division 07 Section "Joint Sealants."
- N. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they may impede traffic or present tripping hazard.
- O. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.

- P. Meeting Stile Gasketing: Fasten to meeting stiles, forming seal when doors are closed.
- Q. Door Bottoms: Apply to bottom of door, forming seal with threshold when door is closed.

# 3.3 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.
  - 1. Door Closers: Adjust sweep period to comply with accessibility requirements and requirements of authorities having jurisdiction.
- B. Occupancy Adjustment: Approximately three months after date of Substantial Completion, Installer's Architectural Hardware Consultant shall examine and readjust each item of door hardware, including adjusting operating forces, as necessary to ensure function of doors, door hardware, and electrified door hardware.

### 3.4 CLEANING AND PROTECTION

- A. Clean adjacent surfaces soiled by door hardware installation.
- B. Clean operating items as necessary to restore proper function and finish.
- C. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of Substantial Completion.

#### 3.5 DEMONSTRATION

A. Provide training for Tri-City Medical Center's maintenance personnel to adjust, operate, and maintain door hardware and door hardware finishes. Refer to Division 01 Section "Demonstration and Training."

#### 3.6 DOOR HARDWARE SCHEDULE

- A. Locksets, exit devices, and other hardware items are referenced in the following hardware sets for series, type and function. Refer to the above-specifications for special features, options, cylinders/keying, and other requirements.
- B. Hardware Sets:

DELTA 3 OSHPD COMMENTS 12/11/2017

Hardware Group 01 - ANTE ROOM Door(s):

031A

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	3CB1HW 4.5 X 4.5	630	IVE
1	EA	PUSH/PULL LATCH	HL6 2 3/4" AS	630	SCH
1	EA	SURFACE CLOSER	4040XP SCUSH MC	MTLPC	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
2	EA	EDGE GUARD	7306B 84" EDGE MS (HINGE/LATCH CUTOUTS AS REQUIRED)	US32D	IVE
1	EA	GASKETING	188S-BK	S-Bk	ZER

Hardware Group 02 - HAZARDOUS/NON-HAZARDOUS PROCESSING ROOMS Door(s):

030A 032
----------

Qty		Description	Catalog Number	Finish	Mfr
3	EA	HW HINGE	3CB1HW 4.5 X 4.5	630	IVE
1	EA	PUSH/PULL LATCH	HL6 2 3/4" AS	630	SCH
1	EA	ELECTRIC STRIKE	6211 FSE	630	VON
1	EA	SURF. AUTO OPERATOR	4631 WMS (CONFIRM EXISTING)	689	LCN
2	EA	ACTUATOR, WALL MOUNT	8310-813 (CONFIRM EXISTING)	BLK	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS	630	IVE
2	EA	EDGE GUARD	7306B 84" EDGE MS (HINGE/LATCH CUTOUTS AS REQUIRED)	US32D	IVE
1	EA	FLOOR STOP	FS439	682	IVE
1	EA	GASKETING	188S-BK	S-Bk	ZER
1	EA	POWER SUPPLY	PS902 900-4RL (IF REQUIRED)	LGR	SCE

End of Section

# **SECTION 08 80 00**

### GLAZING

# PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Glass and Glazing For:
    - a. Flush Wood Doors: Section 08 14 16.
  - 2. Glazing sealants.
- B. Related Requirements:
  - 1. Factory-Glazed Windows: Section 08 56 19 Pass Windows.

### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. American National Standards Institute (ANSI) Standards; <u>www.ansi.org</u>.
    - a. ANSI Z97.1-2015 Safety Glazing Materials Used in Buildings Safety Performance Specifications and Methods of Test.
  - 2. ASTM International Standards; <u>www.astm.org</u>:
    - a. ASTM C1036-11e1 Standard Specification for Flat Glass.
      - d. ASTM C1048-12e1 Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass.
  - 3. Glazing Association of North America (GANA); <u>www.glasswebsite.com</u>:
    - a. GANA Glazing Manual, 50th Anniversary Edition.
    - b. GANA Tempering Division Engineering Standards Manual, 2008 edition.
- C. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified.
  - 1. ASTM International; <u>www.astm.org</u>:
    - a. ASTM E1300-16 Standard Practice for Determining Load Resistance of Glass in Buildings.
  - Glazing Association of North America (GANA); <u>www.glasswebsite.com</u>:
     a. GANA Sealant Manual, 2008 edition.

# 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit for all glass products and accessories supplied under this Section.
  1. Glazing Sealants: Include VOC data.
- C. Samples: Submit samples of each type of glass and mirror.
   1. Cut sizes as requested by Architect.

### 1.04 QUALITY ASSURANCE

- A. Certifications:
  - 1. Each Individual Piece of Glass: Bear label designating type, thickness and quality. Do not remove labels until reviewed by Architect.
- 1.05 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
  - B. Delivery and Acceptance Requirements: Schedule delivery to coincide with glazing schedules so minimum handling of crates is required. Do not open crates except as required for inspection for shipping damage.
  - C. Storage and Handling Requirements:
    - 1. Storage: Store cases according to printed instructions on case, in areas least subject to traffic or falling objects. Keep storage area clean and dry.
    - 2. Handling: Unpack cases following printed instructions on case. Stack individual windows on edge leaned slightly against upright supports with separators between each.

### PART 2 PRODUCTS

#### 2.01 MANUFACTURERS

- A. Acceptable Float Glass Manufacturers:
  - 1. AGC Flat Glass North America; <u>www.na.agc-flatglass.com</u>.
  - 2. Cardinal Glass Industries; <u>www.cardinalcorp.com</u>.
  - 3. Guardian Industries Corporation; www.guardian.com.
  - 4. Pilkington North America Inc.; <u>www.pilkington.com</u>.
  - 5. PPG Industries Corporation; <u>www.ppg.com</u>.
- B. Acceptable Manufacturers Heat Strengthened and Fully Tempered Safety Glass:
  - 1. American Glass Products (AGP) Company.
  - 2. Guardian Industries Corporation; <u>www.guardian.com</u>.
  - 3. Interpane Glass Company.
  - 4. Oldcastle BuildingEnvelope; <u>www.oldcastlebe.com</u>.
  - 5. Pilkington North America Inc.; <u>www.pilkington.com</u>.
  - 6. PPG Industries Corporation; <u>www.ppg.com</u>.
  - 7. Viracon; <u>www.viracon.com</u>.
- C. Acceptable Manufacturers Fire-Rated Safety Glass:
  - 1. SAFTI FIRST, division of O'Keeffe's, Inc.; www.safti.com.
  - 2. Technical Glass Products; <u>www.fireglass.com</u>.
  - 3. Vetrotech Saint-Gobain; <u>www.vetrotech.com</u>.

#### 2.02 SUBSTITUTION LIMITATIONS

- A. Substitution Requests: Required for all manufacturers and products not named as Basis of Design or as Acceptable Manufacturer and Product.
  - 1. Submit in accordance with Section 01 25 00.

### 2.03 REGULATORY REQUIREMENTS

A. Fire-Rated Glass: UL approved.

B. Safety Glass and Glazing: Comply with State Statutes, IBC and ANSI Z97.1.

### 2.04 PERFORMANCE

A. General: Provide glazing systems that are produced, fabricated, and installed to withstand normal thermal movement, wind loading, and impact loading (where applicable), without failure including loss or glass breakage attributable to the following: defective manufacture, fabrication, and installation; failure of sealants or gaskets to remain watertight and airtight; deterioration of glazing materials; and other defects in construction.

### 2.05 GLASS

- A. General: Glass shall be annealed, heat strengthened or tempered as specified and as required by codes or as required to meet thermal stress and wind loads.
- B. Annealed Float Glass: ASTM C1036, Type 1, Class 1, clear, Quality q3.
- C. Fully Tempered Glass: ASTM C1048, Type 1, Class 1, clear, Quality q3, Kind FT.
- E. Fire- and Safety-Rated Laminated Ceramic Glazing: Laminated glass made from two plies of clear, ceramic glass and complying with 16 CFR 1201, Category II.
  - 1. Total Thickness: 5/16-inch.
  - 2. Fire-rating: 20 minutes to 3 hours for doors; 20 minutes to 90 minutes for other applications. See Drawings.
  - 3. Surface Finish: Premium Grade-Ground and polished on both sides.

### 2.06 ACCESSORIES

- A. Setting Blocks, Shims and Glazing Clips: Size and type as recommended by glass manufacturer.
- B. Preshimmed Glazing Tape: Preformed, adhesive, elastomeric butyl/polyisobutylene glazing tape with continuous built-in EPDM shim, designed for pressure sealing of glazing units in framing system.
  - 1. Acceptable Manufacturers and Products:
    - a. Bostik Chem-Tape 60.
    - b. Pecora Shim-Seal Tape.
    - c. Tremco Preshimmed 440 Tape.
  - 2. Sealant Compatibility: Provide tape compatible with silicone glazing sealant.
  - 3. Tape for Fire Rated Glazing: GT-18, 1/8-inch fire rated glazing tape.
- C. Silicone Glazing Compound:
  - 1. Acceptable Manufacturers and Products:
    - a. General Electric Silglaze N.
- D. Cleaners, Primers and Sealers: Type recommended by sealant gasket manufacturer.

# PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Conditions: Comply with Section 01 71 16.
    - 1. Layout: Verify layout of work before beginning installation.

- 2. Existing Conditions:
  - a. Field Measurements: Field measure openings before ordering tempered glass products. Be responsible for proper fit of field measured products.
  - b. Before glazing, verify that frames are plumb and square with metals stops set for proper glass-to-stop face clearance.
- B. Notification: Notify General Contractor of unsatisfactory conditions in writing with copy to Architect.
- C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

# 3.02 PREPARATION

A. Protection: Completely cover glass during spray painting, texturing or other construction operations that might cause damage to glass.

### 3.03 GLAZING

- A. Stops:
  - Hold glass with wood or metal stops as detailed.
     a. Stops: Furnished under other sections.
  - 2. Carefully remove any stop already in place as necessary to permit glazing.
  - 3. Handle stops carefully and install to avoid damage.
- B. Glazing in Wood or Metal Frames:
  - 1. Tape entire opening to prevent glass from touching frame in any direction.
  - 2. Center glass in glazing rabbet to maintain recommended clearances at all four, inside and out.
  - 3. Rest glass on setting blocks as recommended by the glass manufacturer.
  - 4. Install shims or use shim tape as recommended to maintain clearance between stops and face of glass.
  - 5. Install glazing tape and stop in with specified stops.
    - a. Fire Rated Glazing: Apply tape to both sides of glass.
  - 6. Cover top of tape with silicone sealant on both sides of frame.
  - 7. Cut all glass with smooth, straight edges of full size required by the openings. Edge clearances shall comply with GANA standards.
  - 8. Leave sealant smooth and clean. Remove sealant from adjoining surfaces without damaging the finish.
- C. Glazing Tolerances: Maintain glazing tolerances between glass and frame or stops as recommended by GANA.
  - 1. 1/4 Inch Thickness Glass: Maintain 1/8 inch clearance between glass face and metal stops.

# 3.04 ADJUSTMENTS

- A. Upon completion, installation shall be free of scratches and rattles.
- B. Breakage: Unless responsibility can be assessed to another contractor, be responsible for glass broken during shipment, storage and installation.3.05 CLEANING
- C. Leave glass in job clean condition with glazing compound and putty carefully removed from glass and adjoining surfaces.

END OF SECTION
## **SECTION 09 05 61**

## COMMON WORK RESULTS FOR FLOORING PREPARATION

## PART 1 GENERAL

## 1.01 SUMMARY

- A. Work Results:
  - 1. Preparation of concrete slabs to receive finish flooring under flooring sections of Division 09, and testing procedures to verify conditions of concrete subfloor are suitable to receive finish flooring.
    - a. Types of Concrete Slabs Included, Where They Occur:
      - 1) Existing concrete slab-on-grade floor slabs to receive new flooring.
    - b. Concrete slabs to receive finish flooring of the following types are included, where they occur:
      - 1) Resilient Sheet Flooring: Section 09 65 16.
    - c. Concrete slabs to receive the following finishes are excluded, where they occur:
      - 1) Sealed concrete, without other finish.
      - 2) Ceramic, porcelain, glass, and quarry tile installed over cementitious or epoxybased setting materials directly to concrete.
    - d. Testing Included:
      - 1) Moisture vapor emission.
      - 2) Relative humidity.
      - 3) Alkalinity.
    - 4) Bond testing for all interior floor slabs to receive adhered floor finish materials.
  - 2. Concrete slab leveling.
  - 3. Concrete slab cleaning.
  - 4. Vapor emission control treatment, if required.
- B. Related Requirements:

a.

- 1. General Notes on Interior Design Drawings.
- 2. Quality Control and Testing: Section 01 45 20 Quality Control Services.

## 1.02 REFERENCES

- A. Reference Standards: Comply with following except as modified by supplementary requirements of this Project Specification.
  - 1. American National Standards Institute (ANSI) Standards:
    - ANSI A108 American National Standard Specifications for Installation of Ceramic Tile:
       A108.01 General Requirements: Subsurfaces and Preparations by Other Trades 2013 (Revised).
  - 2. ASTM International Standard Specifications and Test Methods:
    - a. ASTM F1869-11 Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride.
    - b. ASTM F2170-11 Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes.
- B. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified in this Project Manual.
  - 1. ASTM International Standard Practices:
    - a. ASTM F710-11 Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring.

b. ASTM F2678-10 – Standard Practice for Preparing Panel Underlayments, Thick Poured Gypsum Concrete Underlayments, Thick Poured Lightweight Cellular Concrete Underlayments, and Concrete Subfloors with Underlayment Patching Compounds to Receive Resilient Flooring.

## 1.03 SCHEDULING

A. Comply with other requirements specific to each flooring type as specified in Division 09 finish flooring specification sections, and with each finish flooring manufacturer's written instructions regarding scheduling limitations, coordination with other trades, and conditions necessary before flooring may be installed.

## 1.04 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data:
  - 1. Vapor Emission Control Treatment: Include data documenting compliance with product performance requirements specified in this section.

## 1.05 INFORMATIONAL SUBMITTALS

- A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
- B. Manufacturer's Installation/Application Instructions.
  - 1. Maintain one copy on site until completion of product application.

## 1.06 CLOSEOUT SUBMITTALS

- A. Procedures: Submit in accordance with Section 01 78 00:
- B. Submit vapor emission control treatment warranty..

## 1.07 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Vapor Emission Control Treatment Installer: Vapor Emission Control Treatment Manufacturer employed or certified personnel.

## 1.08 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Delivery and Acceptance Requirements: Deliver products in original unopened manufacturer's containers with labels intact.
- C. Storage and Handling Requirements: Comply with Manufacturer's printed instructions.
- 1.09 WARRANTY
  - A. Finish Flooring Manufacturers' Warranties: In addition to flooring preparation and testing specified under this Section, comply with additional requirements, if any, specified by finish flooring manufacturers as warranty conditions.

- B. Vapor Emission Treatment Performance and Workmanship Warranty: Manufacturer shall provide, in accordance with Section 01 78 36, an installation workmanship and material performance warranty for a period of ten (10) full years from date of application. In the event of treatment system failure by concrete moisture and alkalinity over slab surfaces, joints or cracks, Manufacturer shall provide materials and installation labor for repair or replacement of damaged flooring system at no charge to the Owner. Warranty shall cover repair or replacement of the flooring system, adhesives, patching compounds, and treatment system.
  - Underwriter Coverage of Manufacturer's Warranty: Provide Owner with a warranty underwritten by a product liability insurance carrier, with a maximum "A" rating from Best or equivalent rating system, in the amount of \$5 million per occurrence, and naming Owner, Architect and General Contractor as co-insured.

# PART 2 PRODUCTS

- 2.01 REGULATORY REQUIREMENTS
  - A. All vapor emission control treatment products shall be certified to be VOC compliant with all applicable federal, state and local regulations.

# 2.02 VAPOR EMISSION CONTROL TREATMENT SYSTEMS

- A. Acceptable Manufacturers and Systems:
  - 1. Ardex Engineered Cements; <u>www.ardex.com</u>. MC Moisture Control System.
    - a. Primer: Ardex P-MC.
    - b. Sealer: Ardex S-MC.
  - Floor Seal Technology, Inc.; <u>www.floorseal.com</u> MES 100 vapor emission control system utilizing all of the following components, unless otherwise recommended by system manufacturer based on Project conditions encountered:
    - a. MES Penetrant water-based modified resinous epoxy.
    - b. MES Coating water-based modified resinous epoxy.
    - c. MES Membrane water-based modified resinous epoxy.
  - Koester American Corporation, 757/425-1206; <u>www.koesterusa.com</u>. VAP I 2000 System, utilizing all of the following components, unless otherwise recommended by system manufacturer based on Project conditions encountered:
    - a. VAP I Primer, water-based primer/curing agent containing epoxy resins.
    - b. VAP I 2000, 100 percent solids modified resinous epoxy.
  - 4. Synthetics International, 866/646-0356; <u>www.syntheticsintl.com</u> Synthetic30, utilizing the following materials:
    - a. Non-porous primer
    - b. Synthetic30 penetrating waterborne polymer.
  - 5. Substitution Requests: Required for all manufacturers and products not named as Acceptable Manufacturer and System.
    - a. Submit in accordance with Section 01 25 00.
- B. Performance Requirements:
  - 1. Application of vapor emission treatment system to concrete floor slabs that initially fail to meet vapor emission performance requirements specified in Article 2.02 "Performance" shall reduce vapor emission to within specified limits.
  - Treatment system shall be certified by independent testing agency to meet the following:

     Water Vapor Transmission Rate: Application shall yield a maximum emission rate of 2.0 lbs/ 24 hours/ 1000 ft<sup>2</sup> when tested in accordance with ASTM E96.
    - Alkali Resistance: Insensitive for long term to pH exposures up to 14 when tested in accordance with ASTM D1308.

- c. Pull-Off Concrete Adhesion: Exceeding 500 psi or reaching concrete cohesive failure when tested in accordance with ASTM D4541.
- C. Vapor Emission Control Treatment Materials:
  - 1. VOC Content: Not greater than 65 g/liter in accordance with EPA Method 24 or SCAQMD 1168.
- D. Cementitious Underlayment: Required over treated slab.
  - 1. Acceptable Manufacturers and Products: Ardex K-15 Self-Leveling Underlayment Concrete or alternate product recommended by treatment system manufacturer and compatible with treatment system materials.

### 2.03 ALKALINITY NEUTRALIZER

- A. Neutralizer for Treating Concrete Floor Slabs with Measured pH Higher Than That Acceptable to Flooring Manufacturer: Use only materials accepted by flooring manufacturer to treat floors to receive flooring manufacturer's products. Obtain manufacturer's written acceptance of proposed treatments.
- B. Available Manufacturers and Products:
  1. Foundation Armor; www.foundatinarmor.com Armor PH Balance.
- C. Prohibited Materials: Acids that, if applied, are detrimental to cement and strength of concrete and/or to flooring adhesives or flooring materials shall not be used.
  - 1. Vinegar shall not be used.
  - 2. Muriatic acid shall not be used.

## PART 3 EXECUTION

#### 3.01 TESTING, GENERAL

- A. Contractor's Quality Control: The Contractor is responsible for quality control, including workmanship and materials furnished by his subcontractors and suppliers. Contractor shall strictly follow concrete floor slab specifications, and shall take all other reasonable measures necessary to ensure that moisture is controlled and floor slabs are properly prepared to receive specified finish flooring systems.
  - 1. Inspection or testing by the Owner does not relieve Contractor of his responsibility to perform the Work in accordance with the Contract Documents.
- B. Testing Agency: Vapor emission and alkalinity testing will be conducted by an approved testing agency in accordance with ASTM F710 and Section 01 45 20.
  - 1. Cooperate fully with those making tests.
  - 2. Test Reports:
    - a. Distribution: Reports of tests shall be distributed by independent testing laboratory in accordance with Section 01 45 20. The General Contractor shall make copies and distribute moisture and bond test reports to each flooring contractor.
    - b. Include testing agency name and primary contact of test performer.
    - c. Include type of testing equipment employed.
    - d. Include floor plan with clearly marked test locations.
    - e. Include written description of test placement quality control practices.
    - f. Vapor Emission Tests:
      - 1). Include estimated building temperature at test location.
      - 2) Include test location, starting date, starting time, beginning weight, stopping date, time and ending weight.

- 3) Indicate computed pounds of emission, including equations.
- g. Alkalinity Tests: Indicate measured pH test results.
- h. Relative Humidity Tests: Report testing results in accordance with ASTM F2170.
- C. Testing by Flooring Contractors: If testing by flooring contractor is required by flooring manufacturer as a condition precedent to providing flooring warranty, such testing shall be performed as required by manufacturer, and shall be in addition to testing by the Owner's agency as specified herein.

## 3.02 SLAB MOISTURE TESTING

- A. General: Before beginning installation of finish flooring materials and floor coatings, concrete floor slabs to receive adhesive-applied floor finish materials, fluid-applied flooring, floor coatings, wood flooring, or that will be in contact with moisture-sensitive equipment or products, shall be tested to measure their moisture vapor emission rate (MVER) and internal relative humidity in order to evaluate the slabs' suitability to receive the proposed flooring installation.
- B. Calcium Chloride Tests: Surfaces of concrete floor slabs shall be tested to measure their moisture vapor emission rate (MVER) using the anhydrous calcium chloride testing procedure in accordance with ASTM F1869.
  - 1. Acceptable Test Results: Vapor emission tests will be considered satisfactory if measured moisture emission does not exceed 3 pounds per 1000 square feet over 24 hours.
    - a. Resilient Flooring: Vapor emission tests will be considered satisfactory if measured moisture emission does not exceed 3 pounds per 1000 square feet over 24 hours.
    - b. Wood Flooring, Fluid-Applied Flooring, and Floor Coatings: Vapor emission tests will be considered satisfactory if measured moisture emission does not exceed 3 pounds per 1000 square feet over 24 hours.
    - c. If flooring manufacturer's warranty stipulates a stricter standard, vapor emission test results will be required to meet manufacturer's standard before that flooring may be installed in the failing area of slab.
    - d. Areas to Receive Finish Flooring Materials Warranted for Vapor Emission Greater Than That Specified: Upon submission of sample warranty documenting flooring manufacturer's higher allowable vapor emission limit, such higher limit may be substituted for specified 3 pound limit, subject to Architect's approval.
  - 2. Slabs failing moisture emission test shall receive additional drying time, or, at Owner's option, may be required to receive vapor emission control treatment as specified herein, until further testing demonstrates slab achieves specified moisture vapor emission rate limit.
  - 3. If, at any given test location, slab passes calcium chloride test, but fails alkalinity (pH) test, and no reasonable explanation is evident for pH test failure other than slab moisture, calcium chloride test shall be repeated at that location to verify original test was not a false positive.
- C. Relative Humidity Tests: Interiors of concrete floor slabs shall be tested using the in situ relative humidity testing procedure specified by ASTM F2170.
  - 1. Acceptable Test Results: Relative humidity shall be measured at 75 percent or less. .
    - a. If flooring manufacturer's warranty stipulates a stricter standard, relative humidity test results will be required to meet manufacturer's standard before that flooring may be installed in the failing area of slab.
    - b. Areas to Receive Finish Flooring Materials Warranted for Relative Humidity Greater Than 75 Percent: Upon submission of sample warranty documenting flooring manufacturer's higher allowable relative humidity limit, such higher limit may be substituted for specified 75 percent limit, subject to Architect's approval.
  - 2. Slabs failing relative humidity test shall receive additional drying time, or, at Owner's option, may be required to receive vapor emission control treatment as specified herein, until further testing demonstrates slab achieves specified moisture vapor emission rate limit.

D. Test Scheduling: No later than two weeks prior to scheduled finish flooring installation, perform final moisture testing, both calcium chloride and relative humidity tests. Testing shall be a minimum of 3 tests for the first 1,000 square feet of floor area, and one test for each additional 1,000 square feet. Include moisture tests around room perimeter, at columns and where moisture may be evident.

### 3.03 SLAB ALKALINITY TESTING

- A. General: Before beginning installation of finish flooring materials and floor coatings, concrete floor slabs to receive adhesive-applied floor finish materials, fluid-applied flooring, floor coatings, wood flooring, or that will be in contact with moisture-sensitive equipment or products, shall be tested to measure their surface pH in accordance with ASTM F710.
- B. Testing Methods:
  - pH Paper Method: Use wide range pH paper, its associated pH chart, and distilled or deionized water. Place several drops of water on a clean surface of concrete, forming a puddle approximately 1 inch (25 mm) in diameter. Allow the puddle to set for 60 plus-orminus 5 seconds, then dip the pH paper into the water. Remove immediately, and compare to chart to determine pH reading.
  - 2. Other pH testing methods such as pH pencils or pH meters, or both, are available and may be used to measure pH.
- C. Testing Scheduling and Locations: Test at same time, rate and near locations of calcium chloride tests, except as follows.
  - 1. Do not test slabs for pH that have been recently bead blasted or otherwise abraded to remove near surface layer. Allow such slabs to remain exposed to air at least 14 days before testing surface for pH.
- D. Acceptable Test Results: Slab alkalinity will be acceptable if measured pH is less than 9.0.
- E. Slabs failing alkalinity test shall receive additional drying time, or, at Owner's option, may be required to receive vapor emission control treatment or pH neutralization treatment as specified herein until further testing demonstrates slab meets this alkalinity limitation.

## 3.04 BOND TESTING FOR RESILIENT FLOORING

- A. General: After cleaning of slab surfaces, and before beginning application of resilient flooring adhesive, resilient flooring contractor(s) shall test adhesive bonding to slab.
- B. Testing Procedures:
  - 1. Using the flooring material and the proposed adhesives, install 3 foot by 3 foot panels spaced approximately 50 feet apart throughout the subfloor area. Select areas next to walls, columns or other light traffic areas.
  - 2. Tape edges of panels to prevent edge drying of adhesive.
  - 3. After 72 hours, check panels in presence of Architect and General Contractor's Superintendent.
- C. Acceptable Test Results: Test will be considered satisfactory if flooring material is found, in the opinion of the Architect, to be securely bonded such that an unusual amount of force is required to lift it from the subfloor.
- D. Slabs failing bond test shall receive additional treatment as specified herein until further testing demonstrates satisfactory bond. Additional treatment may consist of mechanical or chemical cleaning to remove contaminants or vapor emission control treatment of excessively moist concrete subfloor.

### 3.05 PATCHING AND LEVELING

- A. Verification of Conditions: Examine substrate for unevenness which would prevent execution and quality of flooring as specified. Report unsatisfactory conditions to the General Contractor with copy to Architect.
  - 1. Examine subfloors prior to installation to determine that surfaces are free from cracks, holes, ridges, and other defects that might prevent adhesive bond or impair durability or appearance of the flooring material.
  - 2. Levelness: As required by manufacturer of finish flooring material to be installed. In absence of specific criteria from manufacturer, verify subfloor to be level within 3/16 inches in 10 feet.
  - 3. Surface Profile: Verify surface to be smooth troweled finish.
- B. Patching: Thoroughly clean concrete floors before applying floor coverings. Remove rough spots and any foreign matter that might be evident through the floor covering. Patch minor rough areas, voids and defects with compatible leveling compound.
- C. Leveling: Level major uneven concrete floor joints or other irregularities by bush hammering or grinding and filling with latex type underlayment. Leveled areas shall be sanded to provide a surface level plus-or-minus 3/16-inch in 10 feet unless flooring manufacturer stipulates stricter criterion. Leveled areas shall be inspected by the Architect before flooring work may proceed.

### 3.06 VAPOR EMISSION CONTROL TREATMENT

- A. General:
  - 1. Floor Slabs-on-Grade: All floor slabs-on-grade shall receive specified vapor emission control treatment unless testing demonstrates to Owner's satisfaction that treatment may be waived.
- B. Protection: Mask and protect walls and equipment before beginning scarification and application.
- C. Surface Preparation: Shot blast concrete surface to expose uncontaminated, absorptive, and sound concrete. Do not acid etch concrete surface. Grind near wall base and clean all joints for treatment application. Broom-sweep and vacuum slab surfaces to remove dust and debris. Do not use clean sweeping agents.
  - 1. Fill all cracks, control joints, construction joints, and surface irregularities with resin and cementitious filling materials in accordance with system manufacturer's recommendations.
- D. Installation: Manufacturer's personnel or manufacturer-certified applicator shall treat slab surfaces in accordance with manufacturer's standard procedures for system and special instructions for specific test results and slab conditions encountered at this Project.
- E. Finishing: Apply primer and cementitious underlayment over treated slabs, using methods recommended by underlayment and treatment manufacturer.
- F. Vapor Emission Retesting: After application of vapor emission treatment, retest directly over treatment using calcium chloride method.

### 3.07 ALKALINITY NEUTRALIZATION TREATMENT

- A. General:
  - 1. Comply with finish flooring manufacturer's instructions. Treat slab surfaces with high measured pH using methods acceptable to finish flooring manufacturer only, and that will in no way void or compromise finish flooring warranty.

- 2. Coordinate with MVER testing and relative humidity testing. If high pH is measured in concert with high MVER and/or relative humidity, follow procedures specified for slabs failing moisture testing, including, if required, vapor emission control treatment. Neutralization treatment procedures specified in this Article apply only to slabs with acceptable measured moisture vapor emission and relative humidity, but excessive pH at surface.
- B. Water Rinsing: Initial treatment shall consist of neutralizing the slab by rinsing with clean neutral water, using following procedure.
  - 1. Start with a clean, porous concrete.
  - 2. Spray a small area with clean neutral water, rinsing the slab. If in doubt about the water take a pH paper and test the water.
  - 3. Immediately after the application of the water, thoroughly wet vacuum the area rinsed to remove any excess water.
  - 4. Allow it to dry for 24 hours and retest to verify the slab is neutralized.
  - 5. Test pH of neutralized slab again after 7 days to verify pH has not returned to high levels before proceeding with finish flooring installation.
- C. Acid Washing: If water rinsing fails to neutralize slab surface to acceptable pH level, subject to acceptance of finish flooring manufacturer, neutralize slab surface by washing with mild carbonic acid, using following procedure.
  - 1. Spray mild carbonic acid onto the surface of the concrete.
  - 2. Wet vacuum the excess.
  - 3. Immediately rinse the acid with clean neutral water. Do not allow it to dry on the concrete.
  - 4. Wet vacuum the excess water and allow it to dry 24 hours.
  - 5. Test the surface to be verify the pH is neutralized.
  - 6. Test pH of neutralized slab again after 7 days to verify pH has not returned to high levels before proceeding with finish flooring installation.

## 3.08 CLEANING

- A. Before beginning installation of finish flooring materials and floor coatings, floor slabs shall be cleaned of dirt debris, contaminants and other deleterious materials on slab surfaces.
- B. Curing Compound Membranes and Other Coatings:
  - 1. Remove residual curing compound membrane, paint, oils and similar contaminants using shotblasting or other acceptable mechanical cleaning method, or by specified chemical cleaner and stripper in accordance with manufacturer's instructions.
- C. Vacuum or broom-clean surfaces to be covered immediately before the application of flooring.

## 3.09 PROTECTION

- A. During and after flooring preparation, and until commencement of finish flooring installation, protect subfloor slab surfaces from staining, cracking, chipping, and other damage.
- B. Protect freshly placed slabs from weather damage.
- C. Protect slabs from mortar leakage from placing of slabs above.
- D. Take precautions to protect slabs from exposure to significant excess moisture after end of curing period, during drying period, and until commencement of finish flooring installation.
  - 1. Promptly remove snow and standing water from floor slabs.
  - 2. Do not wash construction tools or materials over floor slabs.
- E. Do not permit construction activities such as pipe cutting which could damage or stain floor slabs.

F. Do not store materials on floor slabs that could expose concrete to oil contamination.

END OF SECTION

### **SECTION 09 21 16**

#### GYPSUM BOARD ASSEMBLIES

### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Work Results:
  - 1. New metal stud and gypsum board partitions.
  - 2. Suspended gypsum board ceiling assemblies.
  - 3. Gypsum board ceilings and coves on metal ceiling joist framing.
  - 4. Gypsum board and metal stud wall opening infill.
  - 5. Gypsum board soffits.
  - 6. Patching existing gypsum board walls and ceilings.
- B. Products Installed But Not Supplied Under This Section:
  - 1. Acoustical Blanket Insulation: Section 09 81 16.
- C. Related Requirements:
  - 1. Cold-Formed Framing for Exterior Walls, Structural Metal Stud Framing and Cold-Formed Metal Joist Framing: Section 05 40 00 Cold-Formed Metal Framing.
  - 2. Fire Safing Material for Deflection Channels: Section 07 84 00 Firestopping.
  - 3. Acoustical Sealants: Section 07 92 00 Joint Sealants.
  - 4. Painting: Section 09 91 23 Interior Painting.

## 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Definitions: Meaning of the following terms as used in these Specifications.
  - 1. Gypsum Board Construction Terminology: Refer to ASTM C11 for definitions of terms for gypsum board construction not otherwise defined in this Section or in referenced standards.
  - 2. Drywall: Gypsum board.
- C. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. ANSI/AISI Standards:
    - a. AISI S200-12 North American Standard for Cold-Formed Steel Framing General Provisions, 2012 Edition.
    - b. AISI S201-12 North American Standard for Cold-Formed Steel Framing Product Data, 2012 Edition.
    - c. AISI S212-07 (2012) North American Standard for Cold-Formed Steel Framing Header Design, 2007 Edition (Reaffirmed 2012).
    - d. AISI S220-15 North American Standard for Cold-Formed Steel Framing Nonstructural Members, 2015 Edition.
  - 2. ASTM International Standards: <u>www.astm.org</u>.
    - a. ASTM C645-14e1 Standard Specification for Nonstructural Steel Framing Members.
    - b. ASTM C754-15 Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products.
    - c. ASTM C840-16 Standard Specification for Application and Finishing of Gypsum Board.
    - d. ASTM C1396 / C1396M-14a Standard Specification for Gypsum Board.

- 3. Gypsum Association Standards: <u>www.gypsum.org</u>.
  - a. GA-216-2016 Application and Finishing of Gypsum Panel Products.
- D. Guide References and Standard Practices: Follow recommendations of the following:
  - 1. Gypsum Association Publications: <u>www.gypsum.org</u>.
    - a. GA-214-2015 Recommended Levels of Finish for Gypsum Board, Glass Mat and Fiber-Reinforced Gypsum Panels.

## 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit copies of manufacturer's technical data covering all assembly materials with all options and accessories plainly identified.
  - 1. Submit product data sheets for each type of metal furring channel to be provided.
  - 2. Submit product data sheets for all non-structural metal framing components and accessories to be provided.
    - a. Include tables showing gage, depth and limiting unsupported heights for studs demonstrating that proposed stud systems and gages meet performance requirements specified for all conditions indicated on the Drawings. Highlight applicable lines in tables.

## 1.04 QUALITY ASSURANCE

- A. Mockups:
  - 1. Build mockups of at least 100 square feet in surface area to demonstrate aesthetic effects and to set quality standards for materials and execution for the following:
    - a. Each Level 3, 4, and/or 5 gypsum board finish indicated for use in exposed locations.
    - b. Each texture finish indicated.
  - 2. Use construction methods and materials specified.
  - 3. Prepare mockups to illustrate both pre-decorated and decorated gypsum board finishing for approval.
    - a. If directed by Architect, apply or install final decoration indicated, including painting and wallcoverings, over a portion of exposed mockup surfaces, to allow review of mockups for both pre-decorated and decorated conditions in single review.
    - b. If directed by Architect, obtain approval of pre-decorated gypsum board finish prior to application of final decoration for approval.
  - 4. Simulate finished lighting conditions for review of mockups.
  - 5. For mockups illustrating gypsum board finishing to receive paint, afford opportunity to painting contractor to review and accept gypsum board finishing methods prior to start of painting operations.
  - 6. Accepted Sample Areas: Standard for rest of work. Proceed with work only after sample has been reviewed and approved by Architect.
  - 7. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

## 1.05 DELIVERY, STORAGE, AND HANDLING:

- A. General Requirements: Comply with Section 01 60 00 and with Manufacturer's recommendations.
- B. Delivery and Acceptance Requirements: Deliver materials in original packages, containers or bundles bearing brand name and identification of manufacturer or supplier.

- C. Storage and Handling Requirements:
  - 1. Storage: Store materials inside under cover and keep them dry and protected against damage from weather, direct sunlight, surface contamination, corrosion, construction traffic and other causes.
    - a. Neatly stack gypsum boards flat to prevent sagging.
    - b. Store metals above ground on platforms, skids, or other supports. Protect metals from surface contamination and corrosion.
  - 2. Handling: Handle gypsum boards to prevent damage to edges, ends, and surfaces. Do not bend or otherwise damage metal corner beads and trim.

#### 1.06 AMBIENT CONDITIONS

- A. Comply with ASTM C840 and Manufacturer's recommendations.
- B. During gypsum panel application and finishing, maintain temperatures within building within range of 55 degrees to 70 degrees F.
- C. Provide adequate ventilation to carry off excess moisture.

## PA%RT 2 PRODUCTS

#### 2.01 ASSEMBLIES

- A. Partitions: See Drawings for detailed assembly requirements.
  - 1. Gypsum Board Panels: Unless indicated otherwise, provide panels 5/8 inch thick by 48 inch wide by vertical length to allow for vertical installation without cross joints.
- B. Ceilings and Interior Soffits:
  - 1. Gypsum Board Panels: Provide panels 5/8-inch thick unless specifically indicated otherwise, by 48 inches wide by length to minimize cross joints.
  - 2. Seismic Suspension System Bracing: Ceiling system and connections shall be designed and constructed in accordance with requirements of ICC Evaluation Service Report for ceiling suspension systems in Seismic Design Category adopted by local code.
- C. Fire Rated Assemblies: For fire-resistance-rated assemblies, provide materials and construction identical to those tested in assembly indicated according to ASTM E119 by an independent testing agency.
  - 1. Gypsum Board Partitions: Partitions listed and labeled for fire protective ratings where indicated.
  - 2. Where UL design numbers are referenced on Drawings, assemblies shall comply with the requirements listed by the referenced UL design, in addition to requirements of applicable specification sections. See Drawings and Sections 01 42 00. Products shall be one of those listed in referenced UL assembly.
  - 3. All gypsum board ceilings that are part of a rated roof/ceiling assembly shall comply with all requirements of that assembly.
  - 4. Gypsum board ceilings and soffits that are suspended below rated assemblies are unrated.

### 2.02 PRODUCT OPTIONS

- A. Substitution Requests: Required for all manufacturers and products not named as Basis of Design or as Acceptable Manufacturer and Product.
  - 1. Submit in accordance with Section 01 25 00.

## 2.03 GYPSUM BOARD AND JOINT FINISHING MATERIALS

- A. General:
  - 1. Reference Standard: Each type of gypsum board shall be as defined by, and shall comply with requirements of, ASTM C1396/C1396M.
  - 2. Single Source Responsibility: Obtain each type of gypsum board and related joint treatment materials from a single manufacturer.
  - 3. All gypsum board and gypsum board finishing materials shall be formaldehyde-free and asbestos-free.
- B. Type X Gypsum Board: For all locations not specified otherwise.
  - 1. Acceptable Manufacturers and Products:
    - a. American Gypsum; <u>www.americangypsum.com</u> American Gypsum Firebloc Type X.
    - b. CertainTeed Corporation; <u>www.certainteed.com</u> CertainTeed Type X Gypsum Board.
    - c. Georgia-Pacific Gypsum LLC; <u>www.qp.com</u> ToughRock Fireguard X Gypsum Board.
    - d. National Gypsum Company; <u>www.nationalgypsum.com</u>. Gold Bond Fire-Shield Gypsum Board.
    - e. Pabco Gypsum; <u>www.pabcogypsum.com</u> Pabco Flame Curb Type X Gypsum Board.
    - f. United States Gypsum Company (USG); <u>www.usg.com</u> Sheetrock Brand Firecode X Gypsum Panels.
  - 2. Core: Type X.
  - 3. Surfaces: Paper.
  - 4. Thickness: 5/8-inch.
  - 5. Edge: Tapered.
  - 6. UL Classified as to fire resistance, surface-burning characteristics and noncombustibility.
- C. Joint Finishing Materials: As recommended by gypsum board manufacturer for use with applicable gypsum board product.
  - 1. Joint Tape: Cross-fibered reinforced paper or fiberglass mesh as recommended by manufacturer for use with applicable gypsum board product.
  - 2. Joint Compound for Use With Paper Tape: All-purpose type specifically formulated and manufactured for use with embedding tape at gypsum board joints and as a finishing compound, and compatible with tape, substrate and fasteners.
  - 3. Joint Compound for Use With Fiberglass Tape: Setting type specifically formulated and manufactured for use with fiberglass tape at gypsum board joints, and compatible with tape, substrate and fasteners.
  - 4. Topping Compound: Topping type specifically formulated and manufactured for use for smooth joint finishing in second and third coats. Unthinned

## 2.04 NON-LOAD-BEARING METAL PARTITION STUDS AND RUNNERS

- A. Basis of Design Non-Load-Bearing Metal Partition Stud Manufacturer: California Expanded Metal Products Company (CEMCO); <u>www.cemcosteel.com</u>.
- B. Other Acceptable Non-Load-Bearing Metal Partition Stud Manufacturers:
  - 1. ClarkDietrich Building Systems LLC, www.clarkdietrich.com.
  - 2. Marino\WARE; <u>www.marinoware.com</u>.
  - 3. Studco Building Systems; <u>www.studcosystems.com</u>.
- C. Stud Sizes: As indicated on Drawings.
- D. Steel Stud Gages: As indicated on Drawings.
  - 1. Verify gages required for support of wall-hung equipment with equipment manufacturer's recommendations.

- E. Steel Stud Runners: Manufacturer's standard to match studs. Provide long leg runners for slip joint at structure above where indicated.
- F. Finish for Studs, Runners, Bracing and Accessories: Corrosion resistant galvanized coating conforming to ASTM A653, G40 minimum.
- 2.05 CEILING AND SOFFIT FRAMING
  - A. Non-Accessible Ceiling and Soffit Framing: 16 gauge studs, sizes as indicated, 16 inches on center unless otherwise indicated on Drawings.
    - 1. Spans Greater Than 8 Feet: Joist framing to comply with Section 05 40 00.
  - B. Accessible Ceiling and Soffit Framing: Joist framing to comply with Section 05 40 00.

### 2.06 CEILING SUSPENSION SYSTEMS

- A. Acceptable Manufacturers:
  - 1. Armstrong; <u>www.armstrong.com</u>.
  - 2. Chicago Metallic; www.chicagometallic.com.
  - 3. United States Gypsum Company (USG); <u>www.usg.com</u>.
- B. Hangers: Steel wire or rods, sizes to comply with requirements of ASTM C754 for ceiling or soffit area and loads to be supported.
  - 1. Wire: ASTM A641, minimum No. 9 gage, soft, Class 1 galvanized.
  - 2. Rods and Flats: Mild steel components.
- C. Suspended Framing System Description: Framing system for gypsum board panels consisting of cold-rolled steel members conforming to ASTM C635, including main tees, furring cross channels, furring cross tees, and cross tees.
  - Main Runners: Cold rolled, "C" shaped steel channels, 16 gauge minimum.
     a. Form to required radius at curved ceilings.
  - 2. Cross Furring: Hat shaped steel furring channels, ASTM C645, 7/8 inch high, 25 gauge, galvanized.
  - 3. Finish: Hot dipped galvanized finish, ASTM A653, Type G30 or better.
  - 4. Provide compression posts and other accessories as required to comply with seismic requirements.

#### 2.07 ACOUSTIC INSULATION AND SEALANTS

- A. Sound Attenuation Blankets: See Section 09 81 16.
- B. Acoustical Sealant: See Section 07 92 00.
- 2.08 FINISHES
  - A. Skim Coat Finish: Unthinned topping joint compound formulated for filling, leveling and finishing coats.

### 2.09 ACCESSORIES

- A. Fasteners: ASTM C1002.
  - 1. Fastening to Metal: One-inch Type S gypsum board screws. Use proper type for gage of stud.
- B. Laminating Adhesive: Setting type compound, formaldehyde-free and asbestos-free, and as recommended by gypsum board manufacturer for use with applicable gypsum board product.
- C. Cornerbead and Edge Trim for Interior Installation: Provide corner beads, edge trim and control joints that comply with ASTM C1047 and requirements indicated below:
  - 1. Acceptable Manufacturers:
    - a. California Expanded Metal Products Company (CEMCO); <u>www.cemcosteel.com</u>.
    - b. ClarkDietrich Building Systems LLC, <u>www.clarkdietrich.com</u>.
    - c. Phillips Manufacturing Company; <u>www.phillipsmfg.com</u>.
    - d. United States Gypsum Company (USG); <u>www.usg.com</u> Beadex.
  - 2. Material: Formed metal, or metal combined with paper:
  - 3. Edge Trim: USG Sheetrock No. 103 Dur-A-Bead, 1-1/4-inch by 1-1/4-inch, unless otherwise indicated.
  - 4. One-Piece Control Joint: Formed with vee-shaped slot per Fig. 1 in ASTM C1047, with slot opening covered with removable strip.

## PART 3 EXECUTION

- 3.01 ERECTION OF NON-LOAD-BEARING METAL STUD PARTITIONS
  - A. Reference Standard: Erect steel framing in accordance with ASTM C754.
  - B. Layouts: Align partition studs accurately according to partition layout.
  - C. Anchoring: Anchor runner channels to concrete slabs with concrete stub nails or power-driven anchors at 24 inches on center Anchor runner channels to ceiling grid where applicable with stove bolts. Install headers where required to receive runners where studs extend above ceiling system.
  - D. Studs: Position studs vertically in runners. Anchor studs located adjacent to openings or partition intersections and corners to runners with USG metal lock fastener or with 1/2-inch Type S pan head screws.
    - 1. Space studs 16 inches on center unless otherwise indicated, and not less than that required by referenced steel framing installation standard.
    - 2. Corners and Intersections: Locate studs no more than two inches from abutting partitions, corners, etc.
    - 3. Openings: Frame door openings to comply with details indicated, with GA-219 and with applicable published recommendations of gypsum board manufacturer. Locate studs not more than two inches from opening frames. Anchor studs to frame anchor clips by bolt or screw attachment. Install runner track section (for cripple studs) at head and secure to jamb studs. Install headers over openings as recommended by the manufacturer.
      - a. Wood Doors and Hollow Metal Doors: Provide two studs at jambs.
    - 4. Metal Strap Blocking: See Drawings.
    - 5. Install runners (tracks) at floors, ceilings and structural walls and columns where gypsum board stud system abuts other construction.
      - a. Where studs are installed directly against exterior walls, install asphalt felt strips between studs and wall.

- 6. Installation Tolerances: Install each steel framing and furring member so that fastening surface do not vary more than 1/8 inch from plane of faces of adjacent framing.
- 7. Extend partition framing full height to structural supports or substrates above suspended ceilings, except where partitions are indicated to terminate at suspended ceilings. Continue framing over frames for doors and openings and frame around ducts penetrating partitions above ceiling to provide support for gypsum board.
- 8. Terminate partition framing at suspended ceilings where indicated.
- 9. Install steel studs so that flanges point in the same direction and gypsum boards can be installed in the direction opposite to that of the flange.
- 10. Position studs vertically with open sides facing in same direction and engaging floor and ceiling runners. Begin and end each arc with a stud and space intermediate studs equally along arcs at stud spacing recommended by gypsum board manufacturer for radii indicated.
- 11. Attach studs to runners with 3/8-inch long pan head framing screws. On straight lengths at ends of arcs, place studs 6 inches on center with last stud left free standing.
- E. Bracing: Provide diagonal bracing at head of studs that terminate above the ceiling level. Bracing shall consist of metal studs bent to V-shape and extending at 45 degrees from partition head to structure above. Locate bracing 48 inches maximum on center
- F. Top of Partition Deflection Head Assemblies:
  - 1. Provide long leg runners for slip joint at structure above for partitions where indicated.
  - 2. Fire Rated Partitions:
    - a. Firestopping Installation: Under Section 07 84 00.

## 3.02 CEILING SUSPENSION INSTALLATION

- A. General: Install suspension system in accordance with ASTM C754 and manufacturer's instructions and as required to comply with seismic requirements..
- B. Hangers: Secure hangers to structural support by connecting directly to structure where possible, otherwise connect to cast in concrete inserts or other anchorage devices or fasteners as indicated. Install wire hangers spaced not over 48 inches on center in direction of 1-1/2-inch main runner channels and within 6 inches of ends of main runners or interruptions of ceiling continuity. Hang from structure above. Install hangers 24 inches on center at gypsum drywall ceilings supporting wood or metal ceilings or other secondary ceiling systems.
  - 1. Where spacing of structural members, or width of ducts or other equipment, prevents regular spacing of hangers, provide supplemental hangers and suspension members and reinforce nearest affected hangers to span extra distance.
  - 2. Attach directly to structural elements only. Do not connect or suspend steel framing from ducts, pipes or conduit. Loop hangers and wire tie directly or provide anchors or inserts.
  - 3. Keep hangers and braces 2 inches clear of ducts, pipes and conduits.
- C. At light troffers or other openings, reinforce framing with 3/4-inch cold rolled channels wired atop and parallel to main runner channels.
- D. Provide all necessary framing and suspension for offsets, verticals and decorative recesses, etc. Use drywall studs where indicated or required. See Section 09 22 16 for type.
- E. Install 1-1/2 inch main runner channels 24 inches on center. at ceilings supporting wood or metal ceilings or other secondary ceiling systems.
- F. Seismic Braced System:
  - 1. Install compression posts, splay wires and other accessories as required to comply with seismic requirements.
  - 2. Extend runners to within 6 inches of walls.

- 3. Wire tie or clip furring members to main runners and to other structural supports indicated. In fire resistance rated assemblies, wire tie furring members; do not clip.
- 4. Do not permit furring or runners to contact masonry or concrete walls.
- 5. Provide 1 inch clearance between furring or runners and abutting walls and partitions.
- G. Installation Tolerances:
  - 1. Do not exceed 1/8 inch in 8-foot variation from plumb or level in exposed lines of surface, except at joints between gypsum board units.
  - 2. Do not exceed 1/16 inch variation between planes of abutting edges or ends.
  - 3. Shim as required to comply with specified tolerances.

## 3.03 SOUND TREATMENT

- A. General:
  - 1. Comply with manufacturer's instructions for particular conditions of installation in each case.
  - 2. Install materials to comply with thermal and sound control requirements noted on Drawings.
  - 3. Unfaced Insulation: Not allowed in exposed applications where there is a potential for skin contact and irritation.
- B. Acoustical Blanket Installation in Partitions:
  - 1. Batts: Friction-fit in place until interior gypsum wallboard finish is applied. Install batts to fill entire stud cavity. Place in partitions tight within spaces, around cut openings, behind and around electrical and mechanical items within partitions and tight to items passing through partitions.
    - a. Stud Cavity Heights Up To 8 Feet: Cut lengths to friction-fit against floor and ceiling tracks or plates.
    - b. Stud Cavity Heights Greater Than 8 Feet: Provide supplemental support as required to hold batts in place until the interior finish is applied.
  - 2. Ductwork Penetrations: Provide one inch wide clearance around ductwork and pack with fiberglass ready for caulking.
- C. Acoustical Blanket Installation Over Ceilings: See Section 09 81 16.
- D. Acoustical Sealant: See Section 07 92 00. Apply at perimeter and at all penetrations of gypsum board in single bead.
  - 1. Locations: Apply at partitions with sound attenuation blankets.
  - 2. Caulk ductwork penetrations.
  - 3. Caulk both sides of partitions edges with continuous bead.
- 3.04 INSTALLATION OF GYPSUM BOARD, GENERAL
  - A. Reference Standards: Apply and finish gypsum board in accordance with GA-216 and ASTM C840.
  - B. Fastening: Apply board to studs, furring or framing with gypsum board screws spaced 12 inches on center in field of board and eight inches on center staggered along vertical abutting edges.
     1. Use Type S-12 screws for attaching to structural studs.
  - C. Install exposed gypsum board with face side out. Do not install imperfect, damaged or damp boards. Butt boards together for a light contact at edges and ends with not more than 1/16-inch open space between boards. Do not force into place.
  - D. Position boards so that like edges abut, tapered edges against tapered edges and mill-cut or field-cut ends against mill-cut or field-cut ends. Do not place tapered edges against cut edges or ends.

- E. Trim: Apply as recommended by manufacturer, where gypsum board abuts other materials, and as indicated.
- F. Tolerances: Gypsum board surface plane within plus-or-minus 1/8-inch in 10 feet.

### 3.05 INSTALLATION OF GYPSUM BOARD ON PARTITIONS AND WALLS

- A. Layout: Apply gypsum wallboard panels vertically with abutting ends and edges occurring over stud flanges or furring. Horizontal installation is not allowed.
  - 1. Joints on Opposite Sides of Partitions: Shall not occur over same stud.
  - 2. Two Layer Construction: Stagger joints between layers.
  - 3. Locate exposed end-butt joints as far from center of walls as possible, and stagger not less than 24 inches in alternate courses of board.
  - 4. Install wall/partition boards in manner that minimizes the number of end-butt joints or avoids them entirely where possible.
  - 5. Locate either edge or end joints over supports, except in horizontal applications where intermediate supports or gypsum board back-blocking is provided behind end joints.
- B. Stagger vertical joints over different studs on opposite sides of partitions.
- C. Attach gypsum board to steel studs so that leading edge or end of each board is attached to open (unsupported) edge of stud flange first.
- D. Spot grout hollow metal door frames for solid core wood doors, hollow metal doors and doors over 32 inches wide. Apply spot grout at each jamb anchor clip just before inserting board into frame.
- E. Form control joints and expansion joints at locations indicated, with space between edges of boards, prepared to receive trim accessories.
- F. Cover both faces of steel stud partition framing with gypsum board in concealed spaces (above ceilings, etc.), except in chase walls that are braced internally.
- G. Isolate perimeter of non-load-bearing gypsum board partitions at structural abutments. Provide 1/4-inch to 1/2-inch space and trim edge with "U" bead edge trim. Seal joints with acoustical sealant.
- H. Layers: Install multiple layer gypsum board as indicated.
- I. Corner Bead: Apply as recommended by manufacturer at exposed out corners.

## 3.06 INSTALLATION OF GYPSUM DRYWALL CEILINGS

- A. Install to ceiling framing, to suspended grid framing, or directly to structural framing as indicated.
- B. Apply gypsum board of maximum practical length with long dimensions at right angles to furring channels and fasten with drywall screws spaced 12 inches on center in the field of the board and 8 inches on center along abutting edges. All end and edge joints shall occur over furring channels with end joints staggered. Properly support gypsum board around cutouts and openings.

#### 3.07 FINISHING

A. General: Finish gypsum board in accordance with ASTM C840. Treat gypsum board joints, interior angles, edge trim, control joints, penetrations, fastener heads, surface defects, and

elsewhere as required to prepare gypsum board surfaces for decoration. Promptly remove residual joint compound from adjacent surfaces.

- B. Joint Finishing: Apply joint treatment at side and end joints, corner bead, trim, penetrations and fastener dimples as recommended by manufacturer.
  - 1. Finish panels to following finish levels as defined by ASTM C840 and as recommended by GA-214 where not otherwise specified.
    - a. Level 0: Limited to temporary construction. No taping, finishing or accessories required.
    - b. Level 1: Limited to ceiling plenums and similar concealed areas. Apply tape embedded in joint compound to all joints and interior angles. Excess joint compound, tool marks and ridges are acceptable.
    - c. Level 2: Minimum finish level for gypsum board to receive interior adhered masonry veneer, or bonded acoustical ceiling tile. All joints and interior angles shall have tape embedded in joint compound and wiped with a joint knife leaving a thin coating of joint compound over all joints and interior angles. Cover all fastener heads and accessories with one coat of joint compound. Surface shall be free of excess joint compound. Tool marks and ridges are acceptable.
    - d. Level 3: Minimum finish level for gypsum board to receive ceramic, stone, or glass tile, FRP or other protective wall covering, fixed acoustical panels, or heavy- or mediumtexture finishes before final painting. All joints and interior angles shall have tape embedded in joint compound and shall be immediately wiped with a joint knife leaving a thin coating of joint compound over all joints and interior angles. Cover fastener heads and accessories with two separate coats of joint compound as required by ANSI A108.01-2013 for gypsum board to receive tile. The surface shall be smooth and free of tool marks and ridges.
    - e. Level 4: Minimum finish level for gypsum board to receive light texture, wallcoverings, and for all gypsum board that will be exposed to view but not specified to receive Level 5 finishing. All joints and interior angles shall have tape embedded in joint compound and shall be immediately wiped with a joint knife leaving a thin coating of joint compound over all joints and interior angles. Apply two separate coats of joint compound over all flat joints and one separate coat over interior angles. Cover fastener heads and accessories with three separate coats of joint compound. The surface shall be smooth and free of tool marks and ridges.
    - f. Level 5:
      - 1) Finish gypsum board to Level 5 where so noted on the Drawings and for following applications:
        - a) Gypsum board to receive semigloss or gloss paint or other glossy decorative finish.
        - b) Gypsum board to receive dark or deep tone paint application.
      - 2) Finish joints as specified for Level 4.
      - 3) Apply a skim coat over the entire exposed surface.
  - 2. Prefill open joints and rounded or beveled edges, if any, using setting-type joint compound.
  - 3. Apply joint tape at joints between gypsum boards except at trim accessories.
  - 4. Joint Compound: Sand smooth between coats and after last coat.
    - a. Embedding and first coat: Setting-type joint compound.
    - b. Fill coat: Setting-type joint compound.
    - c. Finish coat: Ready-mix drying-type all-purpose or topping compound.
- C. Skim Coat Application. Skim coat to be troweled on to straight plumb finish prior to final wall painting application or other finish as shown on Drawings.
  - 1. Required for Level 5 finishing.

END OF SECTION

### **SECTION 09 28 13**

### **CEMENTITIOUS BACKING BOARDS**

### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Cementitious backer board for stainless steel countertops.
  - 2. Cementitious backer board at pass window counter.
- B. Related Requirements:
  - 1. Exterior Cement Board: Section 06 16 63 Cementitious Sheathing.
  - 2. Interior Metal Stud Partition Framing and Gypsum Board: Section 09 21 16 Gypsum Board Assemblies.
  - 3. Metal Countertops: Section 12 36 16.

#### 1.02 REFERENCES

- A. Abbreviations:
  - 1. CBU: Cementitious Backer Unit.
- B. Reference Standards: See Section 01 42 00. Comply with following:
  - 1. ANSI A108.11-2005 Interior Installation of Cementitious Backer Units.
  - 2. ANSI A118.9-2005 Test Methods and Specifications for Cementitious Backer Units.
  - 3. ASTM C1325-04 Non-Asbestos Fiber-Mat Reinforced Cement Substrate Sheets.

### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's current data sheets describing all materials and accessories to be supplied under this Section.
- 1.04 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Evaluation Reports: Submit ICC Evaluation Service, Inc. (ICC-ES) report for each CBU product to be provided.
  - C. Manufacturer's Installation Instructions: Submit manufacturer's written recommended installation procedures.
    - 1. Maintain one copy on site until completion of installation.

### 1.05 QUALITY ASSURANCE

- A. Regulatory Requirements:
  - 1. CBU product shall have a current ICC-ES report finding product to be an acceptable alternative product to those specified in the 2003 (or later) International Building Code.
    - a. Comply with all conditions of use stipulations in ICC-ES report.

- 1.06 DELIVERY, STORAGE, AND HANDLING
  - A. General: Comply with Section 01 60 00.
  - Β. Delivery: Deliver materials in original unopened packages, labeled with identification of manufacturer and brand name.
  - C. Storage: Store in an enclosed shelter providing protection from damage and exposure to the elements.
    - Store cementitious backer units flat. 1.

### **PART 2 PRODUCTS**

- 2.01 MANUFACTURERS AND PRODUCTS
  - Α. Acceptable Manufacturers and Products – Interior Cementitious Backer Units:
    - 1. Custom Building Products; www.custombuildingproducts.com WonderBoard backerboard.
    - 2. National Gypsum Company; www.nationalgypsum.com - PermaBase Cement Board.
    - United States Gypsum Company (USG); www.usg.com Durock Brand Cement Board. 3.
  - Substitution Requests: In accordance with Section 01 25 00. Β.

#### 2.02 INTERIOR CEMENTITIOUS BACKER UNITS (CBU)

- Composition: ANSI A118.9 and ASTM C1325. Composed of stable Portland cement, Α. aggregates, and reinforcements.
  - Non-combustible in accordance with ASTM E136. 1.
  - Unaffected by prolonged exposure to moisture. 2.
- Thickness: 1/2 inch unless indicated otherwise. B.
- 2.03 ACCESSORY PRODUCTS
  - Fasteners: Α.
    - Screws: CBU manufacturer's standard No. 8 steel screws with corrosion resistant coating. 1. Provide type for wood framing or steel framing as appropriate to indicated installation.
  - Β. Joint Tape: Manufacturer's standard alkali-resistant joint tape.

### **PART 3 EXECUTION**

#### 3.01 EXAMINATION

1.

- Α. Verification of Conditions: Comply with Section 01 71 16.
  - Existing Conditions: Examine framing to receive sheathing before beginning installation. a.
    - Verify wall framing to be structurally sound and free from excessive bow.
    - Verify spacing of studs and supports does not exceed 16 inches on center. b.
- B. Notification: Notify General Contractor of unsatisfactory conditions in writing with copy to Architect.
- C. Acceptance: Beginning of work means acceptance of existing conditions by applicator.

### 3.02 INSTALLATION, GENERAL

- A. Install cementitious boards in accordance with manufacturer's instructions.
  - 1. CBU to Receive Finish Materials Installed in Mortar: Install CBU with rough side facing out.
  - 2. CBU to Receive Finish Materials Installed in Mastic: Install CBU with smooth side facing out.
- B. Comply with all conditions of use stipulations in ICC-ES report.
- C. Do not install cementitious boards when board is wet.
- D. Fit ends and edges closely but not forced together, leaving 1/8 inch gap.
- E. Install perimeter fasteners a minimum of 3/8 inch and a maximum of 5/8 inch from ends and edges.

#### 3.03 INSTALLATION

- A. Preparation:
  - 1. Double Layer Walls: Apply a vapor-permeable water barrier over gypsum board before installing CBU.
- B. Install backer board with ends over a supporting member. Stagger all end joints in successive courses.
- C. Fasten backer board to framing using specified fasteners.
  - 1. Space fasteners at maximum 8 inches along each stud or support.

## 3.04 JOINT TREATMENT

- A. Joint Treatment for Dry Untiled Areas:
  - 1. Seal board with Type 1 Ceramic Tile Adhesive, mixed with 1 part water to 4 parts adhesive. a. Do not apply ready-mixed or setting-type joint compound over unsealed board.
  - 2. Embed gypsum board joint tape over joints and treat fasteners with gypsum board settingtype joint compound in accordance with Section 09 21 16.30.
  - 3. Flat trowel gypsum board setting-type joint compound over board to cover fasteners and fill voids to a smooth surface. Finish joints with at least two coats of joint compound.

## END OF SECTION

### **SECTION 09 30 00**

### TILING

#### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Ceramic floor tiling.
  - 2. Ceramic wall tiling.
  - 3. Ceramic tile base.
  - 4. Tile mortar and grout.
  - 5. Crack isolation membrane.
  - 6 Other tiling accessories.
- B. Related Requirements:
  - 1. Common Work Results for Flooring Preparation: Section 09 05 61.
  - 2. Concrete Floor Slab Curing and Finishing: Section 03 33 53 Miscellaneous Cast-In-Place Concrete.

#### 1.02 REFERENCES

- A. General Requirements: Refer to Section 01 42 00.
- B. Abbreviations and Acronyms:
  - 1. DCOF: Dynamic Coefficient of Friction as measured by the DCOF AcuTest method of ANSI A137.1 and ANSI A326.3.
- C. Definitions: Meaning of the following terms as used in these Specifications.
  - 1. EGP Mortar: Exterior Grade Plywood (EGP) latex-Portland cement mortar formulated specifically for bonding ceramic, glass, and natural stone tiles to exterior glue plywood.
  - 2. Floor Flatness: For purposes of this Section, a measure of the local variation in amplitude and frequency in height of a floor surface in comparison to a reference straight edge.
  - 3. Floor Levelness: For purposes of this Section, a measure of the total variation in pitch of a floor surface over a given length in comparison to a reference straight edge.
- D. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.

1. American National Standards Institute (ANSI) Standards; <u>www.ansi.org</u>.

a. ANSI A108 – Installation Standards:

ANSI A108.02	General Requirements: Materials, Environmental, and Workmanship - 2016
ANSI A108.5	Ceramic Tile Installed with Dry-Set Portland Cement Mortar or Latex-Portland Cement Mortar – 1999 [Reaffirmed 2010]
ANSI A108.6	Ceramic Tile Installed with Chemical-Resistant, Water- Cleanable Tile-Setting and -Grouting Epoxy. – 1999 [Reaffirmed 2010]
ANSI A108.10 ANSI A108.17	Installation of Grout in Tilework – 1999 [Reaffirmed 2010] Installation of Crack Isolation Membranes for Thin-set Ceramic Tile and Dimension Stone – 2005 [Reaffirmed 2016]

b. ANSI A118 - Material Specifications:

ANSI A118.1	American National Standard Specifications for Dry-Set Cement Mortar - 2012
ANSI A118.3	American National Standard Specifications for Chemical- Resistant, Water-Cleanable, Tile-Setting and -Grouting Epoxy and Water-Cleanable Tile-Setting Epoxy Adhesive - 2013
ANSI A118.4	American National Standard Specifications for Modified Dry- Set Cement Mortar - 2012
ANSI A118.12	American National Standard Specifications for Crack Isolation Membranes for Thin-Set Ceramic Tile and Dimension Stone Installation - 2014
ANSI A118.15	American National Standard Specifications for Improved Modified Dry-Set Cement Mortar - 2012

- c. ANSI A137.1 American National Standard Specifications for Ceramic Tile 2017.
- d. ANSI A326.3 American National Standard Test Method for Measuring Dynamic Coefficient of Friction of Hard Surface Flooring Materials 2017.
- 2. Tile Council of North America, Inc. (TCNA) Standards; www.tcnatile.org:
  - a. TCNA Handbook for Ceramic, Glass, and Stone Tile Installation, 2017 Edition.
- D. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified in this Project Manual.
  - 1. American National Standards Institute (ANSI); <u>www.ansi.org</u>.
    - a. ANSI A108 American National Standard Specifications for Installation of Ceramic Tile:
      - 1) A108.01 General Requirements: Subsurfaces and Preparations by Other Trades 2016.

## 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's current descriptive and technical data for the following:
  1. Factory blended setting mortars.
  - 2. Tile grout.
  - 3. Crack isolation membrane.
  - 4. Tile cleaning agents.
  - 5. Other tiling accessories.
- C. Shop Drawings: Indicate tile patterns, colors, locations, and widths of expansion, contraction, control, and isolation joints in tile substrates and finished tile surfaces.
  - 1. Locate precisely each joint and crack in tile substrates by measuring, record measurements on shop drawings, and coordinate them with tile joint locations.
  - 2. Submit jointing layout based on field dimensions of existing conditions.
- D. Samples: Submit complete samples of tile and grout to Architect for color and texture selection or verification.
  - 1. Each type and composition of tile and for each color and texture required, at least one full size sample for each tile specified.
  - 2. Trim for Ceramic Tile: Full size pieces.
  - 3. Provide samples keyed according to specifications.

## 1.04 INFORMATIONAL SUBMITTALS

A. Procedures: Submit for information and verification in accordance with Section 01 33 00.

- B. Certifications:
  - 1. Submit "Master Grade Certificate" for each type of tile in accordance with requirements of ANSI A137.1.
  - 2. Submit manufacturer's certifications that mortars, adhesives, and grouts are suitable for intended use.
- C. Manufacturer's Site Reports: Submit Manufacturer's Representative's quality control report.

### 1.05 CLOSEOUT SUBMITTALS

- A. Procedures: Submit the following in accordance with Section 01 77 00.
- B. Maintenance Data: Include cleaning methods, cleaning solutions recommended, stain removal methods, and polishes and waxes recommended.
- C. Warranties: Submit in accordance with Section 01 78 36.

## 1.06 MAINTENANCE MATERIALS SUBMITTALS

- A. Extra Stock Materials: Provide the Owner 3 percent of each size and color of tile and grout used at completion of the Project.
- B. Store in location as directed by Owner.
- C. Ensure materials are boxed and identified by manufacturer, type, and color, with use-by date, when applicable.

### 1.07 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer Qualifications: Flooring subcontractor must have at least five (5) years' experience in the installation of ceramic tile flooring projects.
- 1.08 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
    - 1. Protect materials from contamination, dampness, freezing, or overheating in accordance with manufacturer's instructions.
    - 2. Broken, cracked, chipped, stained, or damaged tile will be rejected, whether built-in or not.
    - 3. Protect mortar and grout materials against moisture, soiling, or staining.
  - B. Delivery and Acceptance Requirements:
    - 1. Delivery: Deliver materials in manufacturer's unopened containers, fully identified with name, brand, type, and grade.
    - 2. Labeling: Comply with ANSI A137.1.
  - C. Storage and Handling Requirements:
    - 1. Storage: Store materials in a clean, dry area.
      - a. Store cementitious materials off the ground and under cover.
      - b. Store premixed setting and grouting materials; admixtures, sealers, cleaning agents, and other liquid products; and accessories in original unopened containers.
      - c. Protect liquid and trowelable products, caulks and sealants from freezing.
    - 2. Handling: Handle tile that has temporary protective coating on exposed surfaces to prevent coated surfaces from contacting backs or edges of other units. If coating does contact bonding surfaces of tile, remove coating from bonding surfaces before setting tile.

#### 1.09 AMBIENT CONDITIONS

- A. Comply with requirements of referenced standards and recommendations of material manufacturers for environmental conditions before, during, and after installation.
- B. Do not begin installation until building is completely enclosed and HVAC system is operating and maintaining temperature and humidity conditions consistent with "after occupancy" conditions for a minimum of 2 weeks.
- C. Do not install tile set in Portland cement mortar when the ambient temperature is below 50 degrees F. Comply with minimum temperature requirements of bonding and grouting materials manufacturers.
- D. Maintain continuous and uniform building temperatures of not less than 50 degrees F during installation nor more than 100 degrees F.
- E. Ventilate spaces receiving tile in accordance with material manufacturers' instructions.

#### 1.10 WARRANTIES

A. Crack Isolation Membrane Warranty: Submit manufacturer's standard 10-year warranty against cracking of ceramic and stone tile due to non-structural horizontal movement in substrate or cracks in substrate not greater than 1/8-inch in width.

#### PART 2 PRODUCTS

- 2.01 PRODUCT OPTIONS
  - A. Substitution Requests: Required for all manufacturers and products not named as Basis of Design or as Acceptable Manufacturer and Product.
    - 1. Submit in accordance with Section 01 25 00.
- 2.02 GENERAL REQUIREMENTS FOR TILE
  - A. ANSI Standard for Ceramic Tile: Comply with ANSI A137.1 for types, compositions, and grades of tile indicated.
    - 1. Furnish tile complying with "Standard Grade" requirements unless otherwise indicated.
    - 2. Minimum Dynamic Coefficient of Friction (DCOF) for Interior Floor Tile: 0.42 as measured by the DCOF AcuTest method of ANSI A137.1 and ANSI A326.3.
  - B. Colors, Textures, and Patterns: Where manufacturer's standard products are indicated for tile, grout, and other products requiring selection of colors, surface textures, patterns, and other appearance characteristics, provide specific products or materials complying with the following requirements:
    - 1. Match existing.
  - C. Factory Blending: For tile exhibiting color variations within the ranges selected during sample submittals, blend tile in factory and package accordingly so that tile units taken from one package show the same range in colors as those taken from other packages and match approved samples.
  - D. Provide 3/4-inch bullnose tile pieces at all outside corners, exposed edges and top of wainscot as detailed on the Drawings.

## 2.03 INTERIOR CERAMIC AND PORCELAIN TILE

- A. Acceptable Manufacturers Ceramic Wall and Floor Tile and Base: See Finish Legend on Drawings.
  - 1. American Olean Tile Company; <u>www.aotile.com</u>.
  - 2. Dal-Tile Corporation; www.daltile.com Daltile.
  - 3. Florida Tile, Inc.; <u>www.floridatile.com</u>.
- B. Ceramic Wall Tile: Buff body, approximately 5/16-inch thickness, cushion edges with bright glaze or matte glaze finish as selected.
  - 1. Size: 4-1/4" x 4-1/4"
  - 2. Cove Base: To match floor tile
  - 3. Colors: See Finish Legend on Drawings.
  - 4. Manufacturer and Colors: As selected by Architect.
    - a. Accent Trim: As selected from available tile in all Price Groups.
    - b. Field Tile Colors: As selected from the entire range of colors in Price Group 1 (least expensive).
- C. Ceramic Floor Tile: Approximately 1/4-inch thickness, unglazed, factory mounted sheets.
  - 1. Size: 1" x 1".
  - 2. Cove Base: To match floor tile. Extend up the wall to match existing. Where no wall tile is present, provide bullnose at top of base.
  - 3. Colors: See Finish Legend on Drawings.
- D. Performance:
  - 1. Ceramic Tile Water Absorption Rate: Less than 0.5 percent, ANSI A137.1,
  - 2. Porcelain Tile Water Absorption Rate: Less than 0.1 percent, ANSI A137.1,

### 2.04 TILE SETTING MATERIALS

- A. Acceptable Manufacturers: Unless noted otherwise, tile setting products by the following manufacturers meeting requirements of these specifications, and equivalent to products listed herein or on the Drawings, will be acceptable, subject to product data submittal and approval by the Architect.
  - 1. Ardex; <u>www.ardexamericas.com</u>.
  - 2. Bonsal American, Inc. ProSpec brand; <u>www.prospec.com</u>.
  - 3. Bostik, Inc.; <u>www.bostik-us.com</u> Hydroment brand.
  - 4. C-Cure Chemical Co., Inc.; <u>www.c-cure.com</u>.
  - 5. Custom Building Products; <u>www.custombuildingproducts.com</u>.
  - 6. Laticrete International, Inc.; <u>www.laticrete.com</u>.
  - 7. MAPEI Corporation; <u>www.mapei.us</u>.
  - 8. Mer-Krete Systems, division of ParexLahabra, Inc.; <u>www.merkrete.com</u>.
  - 9. Specialty Construction Brands, Inc. TEC brand; <u>www.tecspecialty.com</u>.
- B. Sand: ASTM C144.
- C. Portland Cement: ASTM C150.
- D. High performance Portland Cement Mortar: ANSI A118.4 and/or A118.15. Required for all porcelain tile installations and elsewhere as specified.
  - For Thin-Set Installation on Slab-on-Grade Floors:
  - a. C-Cure Pro M-Bond Ultra 918.
  - b. Laticrete 254 Platinum.
  - c. MAPEI Ultraflex 2.

1.

- 2. For Thin-Set Installation on Interior Walls and Other Vertical Surfaces: Non-sag formulation.
  - a. C-Cure PermaBond NonSag 903 mixed with C-Cure CureMix 937.
  - b. Laticrete 254 Platinum.
  - c. MAPEI Ultraflex 2.
- E. Organic Adhesives and Mastics: Not acceptable for setting of tile.

## 2.05 TILE GROUTING MATERIALS

- A. Acceptable Manufacturers: Unless noted otherwise, tile grouting products by the following manufacturers meeting requirements of these specifications, and equivalent to products listed herein or on the Drawings, will be acceptable, subject to product data submittal and approval by the Architect.
  - 1. Ardex; <u>www.ardexamericas.com</u>.
  - 2. Bonsal American, Inc. ProSpec brand; <u>www.prospec.com</u>.
  - 3. Bostik, Inc.; <u>www.bostik-us.com</u> Hydroment brand.
  - 4. C-Cure Chemical Co., Inc.; <u>www.c-cure.com</u>.
  - 5. Custom Building Products; <u>www.custombuildingproducts.com</u>.
  - 6. Laticrete International, Inc.; <u>www.laticrete.com</u>.
  - 7. MAPEI Corporation; <u>www.mapei.us</u>.
  - 8. Mer-Krete Systems, division of ParexLahabra, Inc.; <u>www.merkrete.com</u>.
  - 9. Specialty Construction Brands, Inc. TEC brand; <u>www.tecspecialty.com</u>.
- B. Epoxy Grout: ANSI A118.3.
  - 1. Acceptable Products:
    - a. Colored Epoxy Grout:
      - 1) Ardex WA.
      - 2) C-Cure ColorSet Epoxy 931.
      - 3) Laticrete SpectraLOCK Pro Premium Grout.
      - 4) MAPEI Kerapoxy Epoxy Grout.
    - b. White Epoxy Grout:
      - 1) C-Cure EverWhite Epoxy 932.
  - 2. Mixes as recommended by manufacturer.
  - 3. Locations: Epoxy grout required at following locations, and elsewhere as indicated, scheduled, or specified.
    - a. Restroom floors and walls.

## 2.06 EXPANSION JOINT SEALANT

- A. Joint Sealant:
  - 1. Floors: Two component polyurethane sealant, ASTM C920, Type M (self-leveling) for horizontal joints, Type II (nonsag) for vertical joints as specified in Section 07 92 00.
  - 2. Walls: Silicone to match grout.
  - 3. Color: Match grout.
  - 4. Ensure sealant is chemically compatible with tile, mortar, and grout.
    - a. A silicone sealer product may be used with natural stone tile only if compatibility with the type of stone tile to be installed has been verified by accelerated laboratory testing.
  - 5. Ensure sealant can physically and chemically withstand environmental conditions normally expected at installation areas.
- B. Joint Backing: Closed cell foam polyethylene.
- C. Comply with applicable regulations including SCAQMD Rule #1168.

- D. Expansion and Control Joints for Thin-Set Applications: Extruded rigid PVC profiles joined by a soft CPE movement joint material, with integral perforated anchoring legs for setting the joint into the setting bed.
  - 1. Height: As required to suit application.
  - 2. Color As selected by Architect.
  - 3. Acceptable Products: Subject to compliance with requirements herein, provide one of the following:
    - a. Schlüter Systems, L.P.; www.schluter.com DILEX-BWB
    - b. Schlüter Systems, L.P.; www.schluter.com DILEX-BWS
    - c. Schlüter Systems, L.P.; <u>www.schluter.com</u> DILEX-BWA

#### 2.07 CRACK ISOLATION MEMBRANE

- A. Acceptable Manufacturers and Products:
  - 1. The Noble Company; <u>www.noblecompany.com</u>. NobleSeal CIS.
- B. Performance:
  - 1. Meet Extra Heavy Service performance requirements of ASTM C627.
  - 2. System Crack Resistance: Exceed High Performance criteria of ANSI A118.12.
  - 3. Waterproof Sheet: Comply with waterproofing requirements of ANSI A118.10.
- C. Material: Composite sheet membrane consisting of non-plasticized chlorinated polyethylene (CPE) thermoplastic sheet, laminated with fabric on both surfaces.
- D. Nominal Thickness: 30-mils.
- E. Accessories:
  - 1. Bond Coat: One of the following.
    - a. Membrane manufacturer's standard latex-based adhesive.
    - b. Acrylic or polymer-modified, rapid-curing type, thin-set mortar meeting ANSI A118.4 or A118.15, as recommended by membrane manufacturer for this application.

#### 2.08 MISCELLANEOUS ACCESSORY MATERIALS

A. Tile Cleaner: A neutral cleaner capable of removing soil and residue without harming tile and grout surfaces, specifically approved for materials and installations indicated by tile and grout manufacturers.

#### PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Conditions: Before proceeding, examine surfaces to receive tile, setting beds or accessories for defects or conditions adversely affecting quality and execution of the installation.
    - 1. Verify floor surface to be dry, structurally sound, and free of wax, curing compound, and other coatings.
    - 2. Verify floors to receive tile are level and flat within specified tolerances.
    - 3. Verify locations of all expansion and control joints in substrate for compliance with Article "Expansion And Control Joint Installation".

- B. Floor Levelness Tolerances: Floor slabs shall be level within following maximum tolerances measured with 10-foot long straightedge, except slope to drains as indicated.
  - 1. Floors to Receive Thin-Set Ceramic, Porcelain or Stone Tile: ANSI A108.01 and as follows. a. Permissible Levelness Variation for Ceramic or Porcelain Tile With All Edges Shorter
    - Than 15 Inches:
      - 1) With 1/4-Inch Grout Joints and Larger: 1/4-inch in 10 feet.
      - 2) With 3/16-Inch Grout Joints: 3/16-inch in 10 feet.
      - 3) With 1/8-Inch Grout Joints: 1/8-inch in 10 feet.
- C. Floor Flatness Tolerances: Floor slabs shall be flat within following maximum tolerances measured by straightedge, except slope to drains as indicated.
  - 1. Floors to Receive Thin-Set Ceramic, Porcelain or Stone Tile: ANSI A108.01 and as follows.
    - a. Permissible Flatness Variation for Ceramic and Porcelain Tile With All Edges Shorter Than 15 Inches: No more than 1/4-inch in 10 feet with variations of no more than 1/16inch in any single foot of length when measured from the high points in the surface.
- D. Report unsatisfactory conditions to the General Contractor in writing with copy to Architect.
- E. Acceptance: Beginning of installation means acceptance of substrates.

### 3.02 PREPARATION

- A. Blending: For tile exhibiting color variations within the ranges selected during sample submittals, verify that tile has been blended in factory and packaged accordingly so that tile units taken from one package show the same range in colors as those taken from other packages and match approved samples. If not factory blended, either return to manufacturer or blend tiles at Project site before installing.
- B. Cleaning and Surface Preparation: Clean substrates. Prepare surfaces in strict accordance with instructions of tile setting material manufacturer and membrane manufacturer, as applicable.
  - 1. Clean concrete base slab to remove dust, dirt and loose material.
    - a. Acid Based Cleaners: Use not permitted.
  - 2. Mechanically scarify concrete substrates if necessary to completely remove curing compounds, form-release compound, paint, efflorescence, loose material, or other substances that would interfere with proper bond of tile or waterproofing materials.
  - 3. Do not seal substrate unless required by manufacturer.
  - 4. Mechanically grind and level substrate or level with self-leveling underlayment as required to meet flatness tolerance of floor tile to be set.
- C. Crack Isolation Membrane: Install in strict accordance with ANSI A108.17 and manufacturer's printed instructions.
  - 1. Protect membrane from pedestrian or vehicular traffic and prolonged exposure to sunlight.
  - 2. Cracks Larger Than 1/8-Inch in Width: Treat as a movement joint in accordance with TCNA EJ-171.
  - 3. Partial Coverage: Where full coverage crack isolation membrane is not specified, extend crack isolation membrane a minimum of the diagonal measurement of the tile on each side of the crack.

## 3.03 TILE INSTALLATION, GENERAL

A. Install tile materials in accordance with ANSI A137.1, other referenced ANSI and TCNA specifications, and TCNA "Handbook for Ceramic, Glass, and Stone Tile Installation", except for more stringent requirements of manufacturer or these Specifications.

- B. Cut and fit tile tight to protrusions and vertical interruptions and treat with a compatible sealant as specified in Section 07 92 00. Form corners and bases neatly.
- C. Work tile joints uniform in width, subject to variance in tolerance allowed in tile size. Make joint watertight, without voids, cracks, excess mortar, or grout.
- D. Prepare surface, fit, set, bond, grout and clean in accordance with applicable requirements of ANSI standards and Tile Council of North America.
- E. Layout:
  - 1. Lay out work to pattern indicated so that full tile or joint is centered on each wall and no tile of less than half width need be used. Do not interrupt pattern through openings. Lay out tile to minimize cutting and to avoid tile less than half size.
  - 2. For heights stated in feet and inches, use courses of full tile to produce nearest attainable heights without cutting tile.
  - 3. No staggered joints will be permitted.
  - 4. Align joints in tile in both directions.
  - 5. Align joints between floor and base tile.
  - 6. File edges of cut tile smooth and even.
  - 7. Cut and fit tile at penetrations through tile. Do not damage visible surfaces. Carefully grind edges of tile abutting built-in items. Fit tile at outlets, piping and other penetrations so that plates, collars, or covers overlap tile.
  - 8. Extend tile work into recesses and under or behind equipment and fixtures, to form complete covering without interruptions, except as otherwise indicated. Terminate work neatly at obstructions, edges and corners without disrupting pattern or joint alignments.
  - 9. Accurately form intersections and returns.
- F. Grout Joint Sizes:
  - 1. Standard Joint Widths for Tile Installation if Joint Width is Not Noted on Drawings: Subject to meeting other specified requirements, install with joints sized as follows:
    - a. Glazed Wall Tile: 1/8-inch.
    - b. Mosaic Tile: 1/8-inch.
  - Minimum Requirement to Accommodate Building Movement, Differential Thermal Expansion, and Normal Variations in Tile Dimensions in Fabrication or Manufacturing: Grout joints shall not be less than 1/16-inch in width.
    - a. Butt Joints: Allowable only at areas of limited size where specifically detailed on Drawings. Lippage limitations will be waived for butt joint applications required by the Drawings.
  - 3. Ensure joint width is at least 3 times the maximum variance in tile dimension. Report discrepancies, if any, between specified joint width and tile warp and dimensional variance to the Architect.
- H. Allowable Lippage:
  - 1. Glazed Wall Tile: 1/32-inch.
  - 2. Mosaic Tile: 1/32-inch.

#### 3.04 INTERIOR CERAMIC FLOOR TILE INSTALLATION OVER CONCRETE

- A. Ceramic Tile Floors Thin Set Installation On Interior Concrete Slabs-on-Grade: Install, grout, clean, protect and cure in conformance with TCNA Handbook Method F115-17 and ANSI A108.5 using latex-Portland cement mortar and epoxy grout with the addition of full coverage crack isolation membrane in conformance with TCNA Handbook Method F125-Full-17. Slab shall be free of curing compound or other contaminates before proceeding.
  - 1. Crack Isolation Membrane: Bond to substrate in accordance with membrane manufacturer's recommendations and ANSI A108.17.

- 2. Provide soft joints in tile on each side of crack or joint as recommended by crack isolation membrane manufacturer.
  - a. Subject to recommendations and approval of crack isolation membrane manufacturer, soft joints may be omitted at movement joints installed in compliance with EJ171.
- 3. Install epoxy grout in accordance with ANSI A108.6.
- 3.05 INTERIOR CERAMIC WALL TILE INSTALLATION OVER STUD-FRAMED WALLS AND SIMILAR VERTICAL SURFACES
  - A. Ceramic Wall Tile and Base Installation Over Moisture Resistant Gypsum Board: Install wall tile using the thin set method. Install, grout, clean, protect and cure in conformance with TCNA Handbook Method W243-17 and ANSI A108.5 using latex-Portland cement mortar and epoxy grout.
    - 1. Install epoxy grout in accordance with ANSI A108.6.
  - B. Ceramic Wall Tile and Base Installation Over Interior Cementitious Backer Board: Install wall tile using the thin set method. Install, grout, clean, protect and cure in conformance with TCNA Handbook Method W244C-17 and ANSI A108.5 using latex-Portland cement mortar and epoxy grout.
    - 1. Install epoxy grout in accordance with ANSI A108.6.

### 3.06 MOVEMENT JOINT TREATMENT

- A. General: Comply with all requirements of TCNA Handbook Method EJ171.
- B. Locations:
  - 1. Ceramic Floor Tile: At intersection of all ceramic floor tile and cove base, install and caulk ¼-inch wide expansion joint.
  - 2. Other Locations: Directly over all expansion and control joints in concrete slab below and all other locations required by EJ171.

#### 3.07 CLEANING AND SEALING

- A. Not less than 28 days following installation of tile grout, and just prior to occupancy of the building, clean unglazed ceramic tile with sulfamic acid and flush with clean water. Do not apply sealer to floor tile or epoxy grout.
- B. Clean all other floor and wall tile according to tile manufacturer's recommendations.

## 3.08 PROTECTION

- A. Protection of Completed Work from Physical Damage: Protect all finished work from soiling or damage caused by traffic, other trades, etc.
  - 1. Protect all flooring after setting by suitable covering.
  - 2. Replace any work showing damage or disfiguration during the progress of work in its entirety. No patching or hiding of defects will be permitted.

## END OF SECTION

### **SECTION 09 51 13**

### ACOUSTICAL PANEL CEILINGS

### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Work Results:
  - 1. Acoustical grid and suspension system for CBC seismic Category D.
  - 2. Lay-in panels.
  - 3. Replace existing lay-in panels with new panels in existing ceiling grid where indicated.
- B. Related Requirements:
  - 1. Gypsum Board Ceilings: Section 09 21 16 Gypsum Board Assemblies.
  - 2. Interior Painting: Section 09 91 23.

#### 1.02 REFERENCES

- A. Reference Standards: See Section 01 42 00. Comply with the following.
  - 1. ASTM International References:
    - a. ASTM C635/C635M-13a Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings.
    - b. ASTM C636/C636M-13 Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels.
    - c. ASTM E580/E580M-14 Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions.
    - d. ASTM E1264-14 Standard Classification for Acoustical Ceiling Products.

### 1.03 SEQUENCING

- A. Do not install acoustical ceilings until dust-generating activities are completed, wet work has dried and overhead mechanical work is completed.
- 1.04 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
  - B. Product Data: Submit manufacturer's catalog data indicating all systems proposed for installation. Include details of light fixture protection (if any) required to comply with Article "Performance." If Fixture protection is not required, submit manufacturer's written data so indicating. Also submit specific requirements for holddown clips (if any).
  - C. Samples: Submit samples of each type of lay-in panel meeting the requirements of this specification to the Architect.

#### 1.05 INFORMATIONAL SUBMITTALS

- A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
- B. Test and Evaluation Reports:
  - 1. Submit current ICC-ES Evaluation Report (ESR) showing compliance with ICC-acceptance criteria.

- C. Manufacturer's Instructions:
  - 1. Submit Manufacturer's installation instructions.
    - a. Maintain one additional copy on site until completion of installation.

### 1.06 MAINTENANCE MATERIALS SUBMITTALS

- A. Extra Materials: Provide Owner with 1 percent of gross area installed, maximum of two cases, of each type of ceiling panel used.
- 1.07 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
  - B. Deliver in manufacturer's original unopened containers and store in a clean, dry area until ready for use.
- 1.08 AMBIENT CONDITIONS
  - A. Maintain minimum of 60 degrees F during and after installation of acoustical ceilings.

## PART 2 PRODUCTS

### 2.01 PRODUCT OPTIONS

- A. Substitution Requests: Required for all manufacturers and products not named as Basis of Design or as Acceptable Manufacturer and Product.
  - 1. Submit in accordance with Section 01 25 00.
- 2.02 REGULATORY REQUIREMENTS
  - A. Seismic Design Compliance: Metal suspension systems and lay-in panel ceilings provided under this Section shall meet the requirements of the CBC for Seismic Design Category D. Systems shall be designed and installed in accordance with ASTM C635, ASTM C636, and ASTM E580, Section 4 – Seismic Design Category D.
    - Systems with a current ICC-ES report recognizing the system as a code-compliant alternative method for installation in Seismic Design Category D construction will be deemed to meet this requirement. Comply with all stipulations and conditions of use stated in the ICC-ESR.

## 2.03 PERFORMANCE

- A. Acoustical Performance:
  - Lay-in panels shall have a minimum noise reduction coefficient (NRC) as of .55 in accordance with ASTM C423 and a CAC rating of the ceiling assembly of 35 in accordance with ASTM E1414.
- B. Fire Resistance:
  - 1. Flame Spread: Do not exceed flame spread classifications in CBC Table 803.9.
  - 2. System fire rating not required.
- 2.04 ACOUSTICAL LAY-IN CEILING PANELS
  - A. Acoustical Lay-In Panels: Match existing.
### 2.05 SUSPENSION SYSTEMS

- A. Ceiling Suspension System: Match existing.
- B. Edge Molding: Standard angle molding for seismic suspension system, color to match grid.
  - 1. Minimum Horizontal Flange Dimension: 7/8-inch.
  - 2. Minimum Vertical Flange Dimension: 7/8-inch.
- C. Spacer Bars: Provide system as required to prevent perimeter components from spreading apart.
- D. Suspension Wire: Minimum No. 12 gauge galvanized, soft-annealed, mild steel wire.

## PART 3 EXECUTION

## 3.01 INSTALLATION OF SUSPENSION SYSTEMS

- A. General: Install suspension systems in accordance with Drawings, ASTM C636, ASTM E580, and manufacturer's instructions.
  - 1. Reflected Ceiling Plan: Follow reflected ceiling plan on Drawings in layout of grid. Deviations must receive prior acceptance by Architect.
  - 2. Install metal edge molding wherever the suspended grid abuts walls, columns and other vertical surfaces.
  - 3. Frame around openings as required.
  - 4. Suspend grid with hanger wires from structure above. Install hanger wires at 4 feet on center along each main runner, at all four corners of lay-in light fixtures and as required to provide maximum deflection of 1/360 of span and level within 1/8-inch in 12 feet.
    - a. Suspension wires shall not hang more than one in six out of plumb unless countersloping wires are provided.
  - 5. Provide a minimum 3/8-inch clearance from the wall on all sides at terminal ends of suspension members. Overlap metal edge molding angles a minimum of 3/8-inch. Do not fasten terminal ends to wall or to metal edge molding angle. Fasten to prevent terminal ends of main runners and cross runners from spreading.
- B. Exposed Grid Suspension System:
  - 1. Install main T-runner on 48-inch centers.
  - 2. To complete a 24-inch by 48-inch grid, install 48-inch cross T-splines 24 inches on center at right angles to main T-runners.
    - a. Install additional cross T-splines to form 24-inch grid.
  - 3. Lock T-spline intersecting moldings in place. All main T-runners and cross T-splines shall be straight in alignment and flush at intersections.
  - 4. Avoid use of less than half width units at borders.
  - 5. Install edge molding at all intersections with dissimilar vertical surfaces. End joints for edge moldings shall occur only at T-Runners or Cross T-splines and shall have riveted connections.

## 3.02 INSTALLATION OF LAY-IN PANELS

- A. Panels: Install panels in accordance with manufacturer's instructions and recommendations. Where required, cut units to fit.
  - 1. Install square edge panels flush in grid and beveled and tegular edge panels so that grid is recessed behind face of panels. Ensure each panel to be well supported on all four edges.
  - 2. Where panels run continuous over tops of partitions or where required for specified fire rating, provide holddown clips so panels fit tight to tops of partitions.

B. Hurricane Clips: Install at all open areas and within 20 feet of entrances.

# 3.03 LIGHTING FIXTURE INSTALLATION AND PROTECTION

- A. Mechanically attach all lighting fixtures to ceiling suspension system in accordance with the NEC and ASTM E580 unless fixtures are independently supported.
- B. If required for fire resistance assembly specified and by manufacturer's design number install box, tent or flat cover fixture protection as applicable to the assembly being installed.

## 3.04 SITE QUALITY CONTROL

A. Special Inspection: Special inspection is required for the suspension system, anchoring and bracing of the system. See Section 01 45 20.

# 3.05 FINAL APPEARANCE

- A. On completion, acoustical panels shall be free from defects, clean and lying flat in metal grid.
- B. Remove and replace dirty, defaced, scarred or otherwise defective panels. Touch up of scarred panels not acceptable.

### **SECTION 09 65 13**

## **RESILIENT BASE AND ACCESSORIES**

## PART 1 GENERAL

### 1.01 SUMMARY

A. Section Includes:1. Rubber base.

## 1.02 REFERENCES

A. Reference Standards: See Section 01 42 00.
 1. ASTM F1861-08 - Resilient Wall Base.

### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's catalog data for all products proposed for installation.
- C. Samples: Submit samples for verification of each brand of base specified.

# 1.04 MAINTENANCE MATERIALS SUBMITTALS

A. Provide the Owner at the completion of the Project the following items:1. One gallon of each type of adhesive used.

### 1.05 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Temperature: Store materials in original containers at not less than 70 deg F for not less than 24 hours immediately before installation.

### 1.06 AMBIENT CONDITIONS

A. Maintain temperature in space to receive base between 70 degrees F and 90 degrees F for not less than 24 hours before and 48 hours after installation.

# PART 2 PRODUCTS

- 2.01 RESILIENT BASE
  - A. Rubber Cove Base: ASTM F1861, Group 1. Type TS, thermoset vulcanized extruded rubber cove.
    - 1. Height: 6 inches.
  - B. Provide pre-formed external corners. Job-formed internal corners may be used at Contractor's option.
  - C. Colors: Match existing..

- D. Fire Resistance:
  - 1. Flame Spread: Do not exceed flame spread classifications in CBC Table 803.9.
- 2.02 ADHESIVE
  - A. Adhesive: As recommended by the manufacturer of the material being installed. Adhesive shall be a type not affected by heat.
    - 1. Low-Emitting Material Requirements: Use adhesives that comply with the limits for VOC content of SCAQMD Rule #1168:

## PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Conditions: Examine substrate for unevenness that would prevent execution and quality of resilient base as specified. Report unsatisfactory conditions to the General Contractor.
  - B. Acceptance: Do not proceed with installation of resilient base until defects have been corrected. Beginning of installation means acceptance of existing substrate.
- 3.02 APPLICATION OF ADHESIVES
  - A. General: Mix and apply adhesives in accordance with manufacturer's instruction. Provide safety precautions during mixing and applications as recommended by adhesive manufacturer. Cover only that amount of area that can be covered by base within the recommended working time of the adhesive.
  - B. Application: Apply adhesive uniformly over surfaces with notched trowel or other suitable tool. Clean trowel and rework notches as necessary to insure proper application of adhesive.
  - C. Cleaning: Remove any adhesive that dries or films over. Do not soil walls or adjacent areas with adhesives. Promptly remove spillage.
- 3.03 INSTALLATION
  - A. Base: Tightly cement base to wall with butt joints 1/16-inch or less in width.

### 3.04 CLEANING

A. Upon completion, remove loose, cracked, chipped, stained or otherwise defective base and replace in a satisfactory manner. Clean surfaces using only cleaners approved by the manufacturer. Remove mastic cement from adjoining work with particular care to not damage such work.

### **SECTION 09 65 16**

## **RESILIENT SHEET FLOORING**

## PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Sheet vinyl flooring with integral cove base.
- B. Related Requirements:
  - 1. Finish Legend on Drawings.
  - 2. Concrete Floor Slab Moisture Testing: Section 09 05 61 Common Work Results for Flooring Preparation.
- 1.02 REFERENCES
  - A. Reference Standards: See Section 01 42 00. Comply with the following.
    - 1. ASTM International (ASTM):
      - a. ASTM F1869-16 Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride.
      - b. ASTM F1303-04(2014) Standard Specification for Sheet Vinyl Floor Covering with Backing.
      - c. ASTM F2170-16a Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes.
    - 2. Resilient Floor Covering Institute (RFCI):
      - a. RFCI Standard Slab Moisture Test Method (Calcium Chloride Method).
  - B. Guide References and Standard Practices: Comply with recommendations of the following except as otherwise specified in this Project Manual.
    - 1. ASTM International Standard Practices:
      - a. ASTM F710-11 Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring.

## 1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
  - 1. Concrete Subfloor Vapor Emission, Alkalinity and Bond Testing and Acceptance: Coordinate with Section 09 05 61.
    - a. Notwithstanding testing by others, it is the responsibility of the flooring installer to determine whether the subfloor is sufficiently dry for covering.
- B. Sequencing:
  - 1. Finishing Operations: Install flooring after finishing operations, including painting and ceiling operations, have been completed.
- C. Scheduling:
  - 1. Material shall not be delivered or installed until all concrete, masonry and painting work are completed and all mechanical work, lighting and other overhead equipment are installed.

### 1.04 ACTION SUBMITTALS

A. Submittals for Review: Submit the following in accordance with Section 01 33 00:

- B. Product Data: Submit manufacturer's current printed product literature and specifications for all products proposed for installation.
- C. Shop Drawings: Submit shop drawings to indicate materials, details, and accessories including but not limited to the following:
  - 1. Submit a cut diagram indicating seam locations and roll direction. Use mitered seam layouts for corners when changing directions 180 degrees (e.g. when running material down corridors which bisect at a right angle), unless approved otherwise.
- D. Samples: Submit for verification the brand and color of sheet vinyl to be used.
  - 1. Samples shall be complete and up to date.
  - 2. Submit duplicate 12 inch by 12 inch sample pieces of sheet material, 12 inch long gulley edge, cap strip, joint cover strip, or cove former as applicable.
- 1.05 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Manufacturer's Instructions:
    - 1. Manufacturer's Installation Instructions:
      - a. Maintain one copy on site until completion of installation.

## 1.06 CLOSEOUT SUBMITTALS

- A. Submittals for Project Record: Submit the following in accordance with Section 01 78 00.
- B. Operation and Maintenance Data: Submit manufacturer's maintenance instructions.
  - 1. Include recommended cleaning and maintenance methods and materials and frequency of cleaning.
  - 2. Include precautions against cleaning materials and methods detrimental to finishes and performance.
- 1.07 MAINTENANCE MATERIALS SUBMITTALS
  - A. Extra Materials: Upon completion of the Project, deliver the following materials to the Owner for future maintenance and repair:
    - 1. Sheet flooring pieces over 4 sq. ft.
    - 2. One gallon of each type of adhesive used.
- 1.08 DELIVERY, STORAGE, AND HANDLING
  - A. General Requirements: Comply with Section 01 60 00.
  - B. Delivery and Acceptance Requirements: Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact.
  - C. Storage and Handling Requirements: Store materials protected from exposure to harmful weather conditions and at temperature and humidity conditions recommended by manufacturer.
    - 1. Maintain area where materials are to be stored at 55 degrees F and less than 50 percent relative humidity.
    - 2. Store rolls in dry locations. Stand rolls on end. Protect and secure rolls from falling.

### 1.09 AMBIENT CONDITIONS

A. General: Comply with manufacturer's recommendations.

- B. Before beginning work, building shall be warm, dry and well ventilated.
- C. Temperature Requirements: Maintain temperature in space to receive base between 70 degrees F and 90 degrees F for not less than 24 hours before and 48 hours after installation. Following 48 hour period maintain minimum temperature of 55 deg F until completion of Work.

### PART 2 PRODUCTS

- 2.01 MANUFACTURERS AND PRODUCTS
  - A. Basis of Design Manufacturer and Products: See Finish Legend on Drawings.
    1. Manufacturer: Mannington Resilient Floors; <u>www.mannington.com</u>.
  - B. Substitution Requests: In accordance with Section 01 25 00.

#### 2.02 PERFORMANCE

- A. HUD/FHA Requirements: Exceed.
- B. Flooring Radiant Panel Test (ASTM-E648): 0.45 watts/ cm<sup>2</sup>, Pass Class 1.
- C. N.B.S. Smoke Chamber Test (ASTM-E-662): Less than 450 Pass.
- D. Fire Resistance:
  - 1. Flame Spread: Do not exceed flame spread classifications in CBC Table 803.9.

### 2.03 SHEET VINYL FLOORING (SV) MATERIALS

- A. Heterogeneous Sheet Vinyl Flooring With Backing: ASTM F1303, Type 2, Grade 1, Class A.1. Gauge:
  - a. Overall Nominal Thickness: 0.080 inch
  - b. Wearlayer Thickness: 0.080 inch.

### 2.04 ACCESSORIES

- A. Adhesives: As recommended by the flooring manufacturer of the material being installed. Adhesive for vinyl edging and base shall be a type not affected by heat.
  - 1. Low-Emitting Material Requirements: Use adhesives that comply with the limits for VOC content of SCAQMD Rule #1168:
- B. Heat Welding Rod: Color matched or multi-color welding rod as supplied by the flooring manufacturer.
- C. Leveling Compound: Ardex Feather Finish or accepted substitute.
- D. Edge Strips: Metal type.
- E. Sealer and Wax: Type recommended by flooring manufacturer.

# PART 3 EXECUTION

## 3.01 EXAMINATION

- A. Verification of Conditions: Examine substrate for excessive moisture content and unevenness which would prevent execution and quality of resilient flooring as specified. Report unsatisfactory conditions to the General Contractor with copy to Architect.
  - 1. Test moisture content of concrete before installation. Coordinate with vapor emission testing requirements of Section 03 32 00. If moisture is above level acceptable to flooring or adhesive manufacturer, seal concrete surface as recommended by flooring manufacturer.
  - 2. Verify concrete subfloor to be clean, level, sound and fully cured.
- B. Acceptance: Do not proceed with installation of resilient flooring until defects have been corrected except where correction is indicated under Preparation. Beginning of installation means acceptance of existing substrate.

### 3.02 PREPARATION

- A. Adjacent Surfaces Protection: Protect adjacent work areas and finish surfaces from damage during product installation.
- B. Subfloor Preparation:
  - 1. General: Prepare floor substrate in accordance with manufacturer's instructions.
  - 2. Concrete Subfloor:
    - a. Reference Standard: Comply with ASTM F710.
    - b. Cleaning, Patching and Priming: Thoroughly clean concrete floors before applying floor coverings. Remove rough spots and any foreign matter that might be evident through the floor covering. Patch minor rough areas, voids and defects with compatible leveling compound. Prime concrete floors as recommended by the manufacturer of the flooring.
    - c. Leveling: Level major uneven concrete floor joints or other irregularities by bush hammering or grinding and filling with latex type underlayment. Leveled areas shall be sanded to provide a surface level within 1/4-inch in 10 feet. Leveled areas shall be inspected by the Architect before flooring work may proceed.
- C. Subfloor Testing:
  - 1. Concrete Moisture Test: Coordinate with Section 03 32 00. Perform moisture tests on concrete floors regardless of the age or grade level. Verify concrete substrate is dry in accordance with the RFCI Industry Standards Slab Moisture Test Method (Calcium Chloride Method), in strict accordance with instructions.
    - a. Perform moisture condition test in each major area. A minimum of 1 test per 93 m<sup>2</sup> (1000 sq.ft), prior to installation. Moisture emissions from concrete subfloors must not exceed 3 lbs per 1000sf per 24 hours (1.4 kg H<sub>2</sub>O/24 hr/93 m<sup>2</sup>) for acrylic adhesive and 5lbs for polyurethane adhesive via the Calcium Chloride Test Method (ASTM F1869).
    - b. Conduct moisture tests around room perimeter, at columns and where moisture may be evident.
  - 2. Concrete pH Test: Perform alkali tests to ensure pH levels of concrete subfloor surface do not exceed pH 9.9. Concrete must be neutralized if above pH 9.9.
  - 3. Do not proceed with work until results of moisture condition and/or pH tests are acceptable.

# 3.03 APPLICATION OF ADHESIVES

A. General: Mix and apply adhesives in accordance with manufacturer's instruction. Provide safety precautions during mixing and applications as recommended by adhesive manufacturer. Cover

only that amount of area which can be covered by flooring material within the recommended working time of the adhesive.

- B. Application: Apply adhesive uniformly over surfaces with notched trowel or other suitable tool. Clean trowel and rework notches as necessary to insure proper application of adhesive.
- C. Cleaning: Remove any adhesive which dries or films over. Do not soil walls. bases, or adjacent areas with adhesives. Promptly remove spillage.

### 3.04 INSTALLATION

- A. General: Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions, and product carton instructions for installation.
- B. Sheet Vinyl Flooring: Install according to manufacturer's recommendations. Rout seams with a hand router or electric router and heat weld seams using matching vinyl welding thread. Install fillet cove filler at all walls. Turn sheet flooring up wall to form integral cove base and install aluminum trim at exposed top edge.

## 3.05 CLEANING

- A. General:
  - 1. Remove temporary coverings and protection of adjacent work areas.
  - 2. Repair or replace damaged installed products.
  - 3. Clean installed products in accordance with manufacturer's instructions prior to owner's acceptance.
  - 4. Remove construction debris from Project site and legally dispose of debris.
- B. Remove visible adhesive and other surface blemishes using cleaning methods recommended by floor manufacturer. Remove mastic cement from adjoining work with particular care to not damage such work.
- C. Sweep and vacuum floor after installation.
- D Clean surfaces using only cleaners approved by the manufacturer.
- E. Buffing: Dry mop and buff flooring.
- F. Final Cleaning: Mop with warm water and mild detergent as recommended by manufacturer of flooring, then thoroughly machine buff.

# 3.06 PROTECTION

- A. Protect finished work from damage by subsequent construction operations.
- B. After flooring is installed, the room shall be kept locked to allow curing time for adhesive. No other trades shall be allowed on the floor until it is accepted by the Architect.
- C. Protect the newly installed flooring from foot traffic for 24 hours and heavy rolling traffic for 72 hours.

### **SECTION 09 81 16**

## ACOUSTIC BLANKET INSULATION

## PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Acoustical insulation in partitions as indicated.
  - 2. Acoustical insulation over ceilings as indicated.
- B. Related Requirements:
  - 1. Acoustical Joint Sealants: Section 07 92 00 Joint Sealants.

### 1.02 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's current product literature.
- C. Samples: Submit manufacturer's sample, minimum 6 inches square.

## 1.03 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
  - 1. Protect acoustical materials from excessive moisture in shipment, storage, and handling.
- B. Delivery and Acceptance Requirements:
  - 1. Deliver materials to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying material name and manufacturer, production date and/or product code.
- C. Storage and Handling Requirements:
  - 1. Storage: Store materials in a clean, dry area in accordance with manufacturer's instructions.
  - 2. Handling: Protect materials during handling and installation to prevent damage.

## PART 2 PRODUCTS

- 2.01 FIBER GLASS ACOUSTICAL BLANKET INSULATION
  - A. Acceptable Manufacturers:
    - 1. Johns-Manville, 800/654-3103; <u>www.jm.com</u>.
    - 2. Knauf Fiber Glass; 800/825-4434; <u>www.knaufinsulation.us</u>.
    - 3. Owens-Corning, 800/GET-PINK; <u>www.owenscorning.com</u>.
    - 4. Accepted substitute in accordance with Section 01 25 00.
  - B. Sound Control Blankets for Partitions: ASTM C665, Type 1, unfaced.
    - 1. Acceptable Products:
      - a. Knauf EcoBatt; <u>www.ecobatt.us</u>.
      - b. Manville Sound Control Batts.
      - c. Accepted substitute in accordance with Section 01 25 00.
    - 2. Material: Formaldehyde-free inorganic fiber glass bonded with thermoset resin.

- 3. Thickness: 3<sup>1</sup>/<sub>2</sub> inches thick unless otherwise indicated.
- 4. Width: 16 inches or 24 inches to match partition wall stud spacing or joist spacing as applicable and as indicated.
- 5. Surface Burning Characteristics: ASTM E84.
  - a. Flame Spread: Maximum 25.
  - b. Smoke Developed: Maximum 50.
- C. Acoustical Batts for Ceilings: ASTM C665, Type 1, unfaced.
  - 1. Acceptable Manufacturers and Products:
    - a. Owens Corning Sonobatts Insulation.
    - b. Accepted substitute in accordance with Section 01 25 00.
  - 2. Size: Sized to fit 2 foot by 4 foot ceiling panel system.
  - 3. Thickness: 6¼ inches.
  - 4. Surface Burning Characteristics: ASTM E84.
    - a. Flame Spread: Maximum 10.
    - b. Smoke Developed: Maximum 10.

## PART 3 EXECUTION

### 3.01 INSTALLATION, GENERAL

- A. Comply with manufacturer's instructions for particular conditions of installation in each case.
- B. Install materials to comply with thermal and sound control requirements noted on Drawings.
- C. Unfaced Insulation: Not allowed in exposed applications where there is a potential for skin contact and irritation.

### 3.02 ACOUSTICAL BLANKET INSTALLATION IN PARTITIONS

- A. Batts: Friction-fit in place until interior finish is applied. Install batts to fill entire stud cavity. Place in partitions tight within spaces, around cut openings, behind and around electrical and mechanical items within partitions and tight to items passing through partitions.
  - 1. Stud Cavity Heights Up To 8 Feet: Cut lengths to friction-fit against floor and ceiling tracks or plates.
  - 2. Stud Cavity Heights Greater Than 8 Feet: Provide supplemental support as required to hold batts in place until the interior finish is applied.

# 3.03 ACOUSTICAL BLANKET INSULATION INSTALLATION OVER CEILINGS

- A. Sound Attenuation Blankets Over Ceilings:
  - 1. Cover ceiling panels for 2 feet each side of acoustically insulated partitions.
- B. Sound Attenuation Blankets Over Acoustical Ceilings: Lay batts on top of the ceiling panel and suspension system between tees. Fit batts tightly together.
  - Blankets at Light Fixtures: Comply with National Electrical Code. Do not install insulation over or within 3 inches (76 mm) of recessed light fixtures, unless approved insulated ceiling (IC) lighting fixtures are used.

## SECTION 09 91 23

### **INTERIOR PAINTING**

## PART 1 GENERAL

## 1.01 SUMMARY

- A. Section Includes:
  - 1. Paint all new or patched interior surfaces.
  - 2. Interior painting.
  - 3. Touch up painting of existing surfaces abraded or otherwise damaged by construction operations.
  - 4. Painting acoustical ceiling grid where noted on Drawings.
  - 5. Includes:
    - a. Surface preparation, priming and field application of finish coat(s) to all exterior surfaces not specifically excluded.
    - b. Surface preparation, priming and field application of finish coat(s) to all interior surfaces not specifically excluded.
    - c. Painting includes field painting of exposed bare and covered pipes and ducts (including color coding), hangers, exposed steel and iron supports, and surfaces of mechanical and electrical equipment that do not have a factory-applied final finish.
- B. Exclusions: In addition to material obviously not requiring paint such as glass, floor, tile, etc. do not paint or finish:
  - 1. Surfaces indicated by the Finish Schedule to remain unfinished.
  - 2. Factory finished surfaces unless otherwise specified.
  - 3. Concealed surfaces.
  - 4. Operating parts.
  - 5. Labels.
  - 6. Existing surfaces not included in the Work.
- C. Related Requirements:
  - 1. Primer for Structural Steel: Section 05 12 53 Miscellaneous Structural Steel.
  - 2. Primer for Metal Fabrications: Section 05 50 00 Metal Fabrications.
  - 3. Piping Identification: Section 22 05 53 Identification For Plumbing Piping And Equipment.

# 1.02 REFERENCES

- A. Definitions:
  - 1. Terminology: ASTM D16-12 Standard Terminology for Paint, Related Coatings, Materials, and Applications.
  - 2. Coat: An application of paint or coating that is allowed to dry prior to subsequent application.
  - 3. Sheen Terms:
    - a. Flat: Lusterless or matte finish with a gloss range below 15 when measured at an a85degree meter.
    - b. Eggshell: Low-sheen finish with a gloss range between 20 and 35 when measured at a 60-degree meter.
    - c. Semigloss: Medium-sheen finish with a gloss range between 35 and 70 when measured at a 60-degree meter.
    - d. Full Gloss: High-sheen finish with a gloss range more than 70 when measured at a 60-degree meter.

### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Material List: Immediately after award of the contract submit a letter listing the manufacturer and product name of each different paint and coating material for use on the Project. Do not order materials before Material List has been accepted by the Architect.
- C. Paint Samples: If requested by Architect, prepare and submit paint samples. Remake samples until accepted.

#### 1.04 MAINTENANCE MATERIALS SUBMITTALS

- A. Extra Paint: At the completion of painting, deliver to the Owner one full gallon of each paint color and type used along with the color number or formula for each type.
  - 1. Epoxy and high performance coatings are not included.

### 1.05 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Applicator Qualifications: Applicator shall have minimum 5 years' experience and shall have successfully completed commercial work of similar scale to this Project.

### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Delivery and Acceptance Requirements: Deliver materials required for painting in unbroken packages bearing the brand and name of manufacturer. Order materials sufficiently in advance to be on the job when needed and deliver at the building in sufficient quantities so the work will not be delayed. No claim by the Contractor concerning unsuitability of any material specified or his inability to produce first-class work with the same, will be entertained unless such claim is made, in writing, with the material list submittal.
- C. Storage and Mixing: Painter will be assigned a room or space in which to mix or store material. Provide galvanized mixing pans for this paint room or space in which paints shall be mixed. No mixing of paint shall be done except in these pans. Empty containers bearing the name or brand of any manufacturer shall not be brought upon the premises for mixing of paint unless labels are canceled and containers are closely marked as to contents.
  - 1. Inspection: The paint storage area shall be open for periodic inspection by the Architect to ensure only approved materials are being used.

### 1.07 AMBIENT CONDITIONS

- A. Apply coating under following conditions only.
  - 1. Temperature of Air: Between 50 and 100 degrees F.
  - 2. Temperature of Substrate: Between 50 and 100 degrees F and above dew point.
  - 3. Lighting: Maintain 80 foot candles minimum on surfaces to be finished.

# PART 2 PRODUCTS

- 2.01 MANUFACTURERS
  - A. Basis of Design Paint Manufacturer: See Finish Legend on Drawings.
    - 1. Sherwin-Williams Company; <u>www.sherwin-williams.com</u>.
  - B. Other Acceptable Manufacturers: The best quality materials as manufactured by any of the following manufacturers will be acceptable: (Paint Only):
    - 1. For Brush, Roller or Spray Work:
      - a. Benjamin Moore & Co.; <u>www.benjaminmoore.com</u>. .
      - b. Dunn-Edwards Corporation; <u>www.dunnedwards.com</u>.
      - c. Frazee Paint, division of the Comex Group; <u>www.frazeepaint.com</u>.
      - d. Glidden Professional Brand of PPG Architectural Coatings; <u>www.gliddenprofessional.com</u>.
      - e. Kelly-Moore Paint Company; <u>www.kellymoore.com</u>.
      - f. PPG Pittsburgh Paints; <u>www.ppgpittsburghpaints.com</u>.
      - g. Pratt & Lambert, Inc.; www.prattandlambert.com.
    - 2. Touch-up Paint for Acoustical Tile and Panel Ceilings:
      - a. Armstrong World Industries; <u>www.armstrong.com</u> SuperCoat.
  - B. Substitution Requests: Required for all manufacturers and products not named as Basis of Design or as Acceptable Manufacturer.
    - 1. Requests for substitutions must be on company letterhead and signed by an authorized representative of the manufacturer. Letters from sales representatives or retailers will not be acceptable.
    - 2. Submissions: Submit in accordance with Section 01 25 00.

## 2.02 REGULATORY REQUIREMENTS

- A. Regulatory Requirements: Product shall be certified to meet the following.
  - 1. Volatile Organic Content (VOC): Paint and coating materials shall not exceed VOC content limitations of all applicable regulations, when thinned to manufacturer's maximum recommendation.

## 2.03 MATERIALS

- A. Quality: All products not specified by name shall be "best grade" or "first line" products or acceptable manufacturers. See Part 3 Execution for materials required for this Project. Where possible, materials shall be of a single manufacturer.
- B. Volatile Organic Content (VOC): In addition to meeting all applicable regulations, paint and coating materials shall be certified to not exceed following VOC content limitations when thinned to manufacturer's maximum recommendation.
  - 1. Architectural Paints, Coatings, and Primers Applied to Interior Walls and Ceilings:
    - a. Flat: VOC content less than 50 grams/liter.
    - b. Non-Flats: VOC content less than 150 grams/liter.
    - c. Eggshell Interior Finish Coat: VOC content less than 150 grams/liter.
  - 2. Anti-Corrosive and Anti Rust Paints Applied to Interior Ferrous Metal Substrates: VOC content less than 250 grams/liter.
  - 3. Epoxy: Waterborne epoxy; maximum VOC content 200 grams/liter.
  - 4. Clear Wood Finishes, Floor Coatings, Stains, Sealers, and Shellacs Applied to Interior Elements:
    - a. Clear Wood Finishes: Varnish VOC content less than 350 grams/liter; lacquer VOC content less than 550 grams/liter.

- b. Floor Coatings: VOC content less than 100 grams/liter.
- c. Sealers: Waterproofing sealers VOC content less than 250 grams/liter; sanding sealers VOC content less than 275 grams/liter; all other sealers VOC content less than 200 grams/liter.
- d. Stains: VOC content less than 250 grams/liter.
- 5. Paint Strippers Low-Emitting: Shall not contain methylene chloride. Avoid products containing methanol and trichloroethane.
- C. Colors: See Finish Legend on Drawings. If materials of other manufacturers are used, colors must match those selected.

## PART 3 EXECUTION

#### 3.01 EXAMINATION

- A. Verification of Conditions: Examine surfaces scheduled to receive paint and finishes for conditions that will adversely affect execution, permanence or quality of work and which cannot be put into an acceptable condition through preparatory work as included under Preparation.
- B. Report unsatisfactory conditions to the General Contractor in writing with copy to the Architect.
- C. Acceptance: Beginning of application means acceptance of existing surfaces.

## 3.02 PREPARATION

- A. General:
  - 1. Spaces: Clean before finishing is started. Do not finish rooms or spaces where rubbish has accumulated or while rubbish is being removed. Finishing not allowed in dusty rooms.
  - Sand finishes on wood and metal surfaces between coats to ensure smoothness and adhesion of subsequent coats. Use extra fine sandpaper to avoid cutting the edges when sanding. Apply putty or spackling compound after surfaces are primed and primer is dry. Bring material flush with adjoining surfaces.
  - 3. Existing Surfaces: If the surfaces are not in proper shape for painting or finishing, repair, rebuild or refinish before proceeding with the work. Be responsible for any poor work caused by improper surfaces. Surfaces shall be dry, clean and smooth before starting work. Fill cracks, holes or checks full and make smooth before finish is applied to surfaces. Fill any cracks, etc., which occur after walls are sized.
- B. Metals:
  - 1. Ferrous Metal: Remove foreign material, rust and mill scale from unprimed metal.
    - a. Wire brush or sand damaged or rusted areas to bright metal.
    - b. Remove grease and other foreign materials with mineral spirits.
    - c. Dust clean.
  - 2. Shop Primed Metals: Touch-up shop primed metals with a primer similar to the existing. Sand shop primer on hollow metal work immediately before painting to remove grease and dirt film from surfaces.
  - 3. Zinc Coated Metal (Galvanized Surfaces): Solvent clean with mineral spirits or other acceptable solvent in accordance with SSPC-SP1 to remove all residue oil, grease or other contamination. Prime as specified.
  - 4. Non-ferrous Metals: Clean with lacquer thinner.
- C. Gypsum Board: Verify surfaces are clean and dry, with all nail heads set and embedded in joint compound, and with joints sanded smooth. Remove all dust prior to painting.

- D. Protection:
  - 1. Furnish and lay drop cloths or mask off areas where finishing is being done to protect floors and other work from damage during the execution of work.
  - 2. Remove items which are not to be coated from surfaces which are to be coated. Reinstall items after completion of coating application. Include mechanical grilles and factory finished items.
  - 3. Where it becomes necessary to remove temporary coverings placed by others, replace same in proper manner.
  - 4. Remove empty cans, oily rags and waste from the building every night. Do not allow to accumulate.
  - 5. Damage to Work of Others: Be responsible for any damage done to the work of other trades, repairing same to the satisfaction of the Architect. Replace any materials damaged to such an extent that they cannot be restored to their original condition.

### 3.03 APPLICATION

- A. Painting and Staining, General: Apply primer and two finish coats unless otherwise noted.
  - 1. The application of the first coat does not relieve the applicator of responsibility for the base.
  - 2. Do not apply any coats on either damp or wet surfaces and in no case until the preceding coat is dry and hard.
- B. Primer: Apply as many coats as necessary to produce a uniform substrate appearance. Do not exceed manufacturer's recommended coverage rate.
  - 1. Tint primers to match finish coat.
  - 2. Allow to dry prior to application of subsequent coats.
  - 3. Sand primer with 100 grit or finer sandpaper. Remove dust.
- C. Application of Finish Coats: Spread materials evenly without runs or sagging of materials and thoroughly brush out.
  - 1. Second and third coats shall not be applied until preceding coat is dry.
  - 2. Sand work between coats.
  - 3. Colors: Each finish coat shall be color as selected by Architect.
- D. Roller Application: Where paint or enamel is rolled on, use fine nap roller so nearly flat or orange peel texture is obtained.
  - 1. Painting Existing Acoustical Ceiling Suspension Grid: Paint exposed surfaces of grid by spray, brush or roll coating. If necessary to achieve complete hiding and finish, apply in two coats.
- E. Spray Application:
  - 1. Metals: Apply paint to all metals by spray application method.
  - 2. Acoustical Tiles and Panels: Apply paint to acoustical tiles and panels by spray application.
    - a. Existing Surfaces: Do not apply any coats on either damp or wet surfaces and in no case until the preceding coat is dry and hard.
    - b. Apply paint with a stream directed perpendicularly to the surface of the material. Apply to produce uniform coating that does not close the perforations or fissures in the material.
    - c. Apply in single coat unless second coat is required to hide stains. Each coat of paint shall be applied so dry film shall be of uniform thickness and free from runs, drops, ridges, waves, pinholes or other voids, laps, brush marks, and variations in color, texture, and finish. Hiding shall be complete.

### 3.04 MISCELLANEOUS REQUIREMENTS

- A. Mechanical Piping and Ductwork: Wherever insulated pipe or ductwork occurs in rooms where walls are finished, cover canvas jacket with one coat sealer and two coats flat wall paint. Wherever uninsulated piping or ductwork occurs in rooms where walls are finished or elsewhere as called for, finish pipes as called for under ferrous zinc coated, or factory primed metals. See Division 22 for identification markings.
- B. Electrical Wiremold: Paint to match wall on which installed.

## 3.05 CLEANING

- A. Do not remove rubbish while finish is fresh. Surfaces: Dry and clean.
- B. Clean-up Materials: Non-abrasive mild detergent, cellulose sponge and potable water.
- C. Clean up overspray and spills.
- D. Remove masking.
- E. Allow at least 7 days after application before washing.
- F. Final Cleaning: At the completion of work, remove all surplus materials, staging, rubbish; clean off all paint, varnish, stains from floors, glass, walls, hardware; and leave the premises in clean condition.

## 3.06 PROTECTION

- A. Protect coating from damage.
- B. Touch up and repair coatings damaged by Work.

## 3.07 COATING SYSTEM - INTERIOR

### A. General:

- 1. Paint and coating systems shall meet following scheduled requirements as a minimum.
- 2. Delete primer when re-coating existing surfaces.
- B. Ferrous, Zinc Coated or Factory-Primed Metals Painted:

First Coat	Factory Primer Coat or Suitable Primer
Second Coat	Enamel Undercoat
Third Coat	Semi-Gloss Enamel

C. Hollow Metal Frames - Painted:

First Coat	Factory-Prime Coat (Sanded)
Second Coat	Enamel Undercoat
Third Coat	Semi-Gloss Enamel

D. Gypsum Board Walls - Painted:

First Coat	Suitable Primer
Second Coat	Latex Enamel, EggshellSemi-gloss
Third Coat	Latex Enamel, EggshellSemi-gloss

E. Gypsum Board Ceilings and Soffits - Painted:

First Coat	Suitable Primer
Second Coat	Latex Enamel, Gloss
Third Coat	Latex Enamel, Gloss

## **SECTION 10 14 10**

#### **INTERIOR SIGNAGE**

### PART 1 GENERAL

### 1.01 SUMMARY

- Section Includes:
  - 1. Sanitary facilities signage.
- B. Related Requirements:
  - 1. Lighted Exit Signs: Division 26 Electrical.

## 1.02 ACTION SUBMITTALS

- A. Procedures: Submit for review, action and return in accordance with Section 01 33 00.
- B. Product Data: Submit product data for specified products. Include material details for each sign specified.
- C. Shop Drawings: Submit shop drawings showing layout, profiles, and product components, including dimensions, mounting methods, and accessories.
- D. Samples: Submit supplier's standard color chart for selection purposes and selected colors for verification purposes.

## 1.03 CLOSEOUT SUBMITTALS

- A. Procedures: Submit the following in accordance with Section 01 77 00.
- B. Submit operation and maintenance data for installed products, including precautions against harmful cleaning materials and methods.

## 1.04 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer Qualifications: Installation shall be performed by installer specialized and experienced in work similar to that required for this Project.

### 1.05 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Delivery and Acceptance Requirements: Deliver products in manufacturer's original, unopened, undamaged containers with identification labels intact.
- C. Storage and Handling Requirements;
  - 1. Storage: Store products protected from weather, temperature, and other harmful conditions as recommended by supplier.
  - 2. Handling: Handle products in accordance with manufacturer's instructions.

## PART 2 PRODUCTS

- 2.01 REGULATORY REQUIREMENTS
  - A. Comply with requirements of all regulatory agencies having jurisdiction. See Section 01 41 00 and notes on Drawings.
  - B. Provisions for Users with Disabilities: All room numbers, restroom identification, and other permanent identifying devices shall have tactile type and symbols integral with signage complying with the requirements of the CBC Title 24 incorporating California Contracted Grade 2 Braille.
- 2.02 SANITARY FACILITIES SIGNAGE
  - A. Sign Types, Tactile Graphics, Symbols, Colors, Sizes and Shapes: As indicated on Drawings and in accordance with the CBC.
  - B. Sign Materials and Colors: Match existing signs of same type within the facility.
  - C. Installation Methods:
    - 1. To Painted Gypsum Board, Doors, Concrete, or Concrete Block: 3M VHB double-sided vinyl tape.
    - 2. To Vinyl Wallcovering: 3M VHB double-sided vinyl tape and liquid silicone adhesive recommended by the sign manufacturer to attach sign units to irregular, porous, or vinyl covered surfaces.
    - 3. Concealed Mechanical Fasteners: Provide concealed mechanical fasteners recommended by the sign manufacturer to attach heavier sign units to the walls. Fasteners must not be corrosive to sign materials or mounting surface.

### 2.03 FABRICATION

- A. General: Comply with requirements indicated for materials, thicknesses, finishes, colors, designs, shapes, sizes, and details of construction.
- B. Preassemble signs in the shop to the greatest extent possible to minimize field assembly. Disassemble signs only as necessary for shipping and handling limitations. Clearly mark units for reassembly and installation, in a location not exposed to view after final assembly.
- C. Conceal fasteners if possible; otherwise, locate fasteners to appear inconspicuous.
- D. Form panels to required size and shape. Comply with requirements indicated for design, dimensions, finish, color, and details of construction.
- E. Coordinate dimensions and attachment methods to produce message panels with closely fitting joints. Align edges and surfaces with one another in the relationship indicated.

## PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Site Verification of Conditions: Verify installation conditions previously established under other sections are acceptable for product installation in accordance with manufacturer's instructions.
  - B. Proceeding with installation implies installer's acceptance of substrate and conditions.

### 3.02 INSTALLATION

- A. General: Install in strict accordance with the manufacturer's instructions and with CBC standards, using only the mounting materials and methods recommended by the manufacturer for the surface upon which the items are to be mounted.
- B. Mount at locations indicated or as directed by the Architect and where required by applicable codes.
- C. Install signs firmly in position, level and plumb, with sign surfaces free from distortion, warp, or defect adversely affecting appearance.
  - 1. Foam Tape Mounting: Use double sided foam tape, of thickness indicated to mount signs to smooth, nonporous surfaces. Do not use this method alone for vinyl covered or rough surfaces.
  - 2. Silicone Adhesive Mounting: Use liquid silicone adhesive to attach sign units to irregular, porous, or vinyl covered surfaces. Use double sided foam tape to hold the sign in place until the adhesive has fully cured.
  - 3. Concealed Mechanical Fasteners: Use hidden fasteners to attach heavier sign units to the walls.
- D. Mount permanent signage on walls at heights indicated on Drawings and in accordance with applicable local amendments and regulations.
- E. Install signs within the following tolerances and in accordance with manufacturer's recommendations:
  - 1. Interior Signs: Within 1/4 inch vertically and horizontally of intended location.

### 3.03 ADJUSTING

A. Repair scratches and other damage which might have occurred during installation. Replace components where repairs were made but are still visible to the unaided eye from a distance of 5 feet.

### 3.04 CLEANING

A. Remove temporary coverings and protection to adjacent work areas. Clean installed products in accordance with manufacturer's instructions prior to Owner's acceptance. Remove construction debris from Project in accordance with provisions in Division 01.

## **SECTION 10 26 13**

### **CORNER GUARDS**

## PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Vinyl corner guards.

### 1.02 COORDINATION

- A. Coordinate installation with wall construction, including concealed blocking or anchoring devices, installation of wall base, and painting.
- 1.03 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
  - B. Product Data: Submit manufacturer's current product literature.
  - C. Shop Drawings: Submit shop drawings indicating dimensions, locations, types, sizes, and finishes.
  - D. Samples: Submit two 24 inch sections of corner guards illustrating component design, configuration, color, and finish.

### PART 2 PRODUCTS

## 2.01 MANUFACTURERS AND PRODUCTS

- A. Basis of Design Manufacturer and Product:
  - 1. Manufacturer: Koroseal Wall Protection Systems, division of RJF International Corporation; <u>www.korogard.com</u>.
  - 2. Product: Korogard Lexan Series J200.
- B. Substitution Requests: In accordance with Section 01 25 00.

## 2.02 DESCRIPTION

- A. Type: Clear Lexan, surface mounted.
- B. Exposed surfaces shall be free of wrinkling, chipping, discoloration, or other imperfections.
- C. Size: 2-inches by 2-inches by 4 feet high.
- D. Angle: 90 degrees.
- E. Profile: High-impact Lexan polycarbonate extrusion.
- F. Class A fire rating, tested in accordance with ASTM E84.

## 2.03 ACCESSORIES

A. Provide attachment accessories as recommended by corner guard manufacturer.

# PART 3 EXECUTION

## 3.01 EXAMINATION

- A. Verification of Conditions: Verify of existing conditions before starting work. Verify that field measurements, surfaces, substrates and conditions are as required, and ready to receive Work.
- B. Report in writing to Architect prevailing conditions that will adversely affect satisfactory execution of the Work of this Section. Do not proceed with Work until unsatisfactory conditions have been corrected.
- C. By beginning Work, Contractor accepts conditions and assumes responsibility for correcting unsuitable conditions encountered at no additional cost to the Owner.

# 3.02 INSTALLATION

- A. Install over corners in accordance with manufacturer's published instructions, square and plumb, secured rigidly in position.
- B. Butt bottom of corner guard to top of base; top of corner guard 4 feet above finish floor.

### **SECTION 10 26 23**

### PROTECTIVE WALL COVERING

## PART 1 GENERAL

### 1.01 SUMMARY

A. Section Includes:1. Plastic, impact-resistant, wall protection panels for wainscot.

## 1.02 SEQUENCING

- A. Apply panels to gypsum board substrate before adjacent gypsum board is painted.
- 1.03 ACTION SUBMITTALS
  - A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
  - B. Product Data: Submit manufacturer's current catalog literature and technical data for each product supplied under this Section.
  - C. Shop Drawings: Submit detail drawings indicating mounting details with the appropriate fasteners for indicated substrate materials.
  - D. Samples: Submit 8 inch long samples in full size profile for verification of each product type and color indicated.
- 1.04 INFORMATIONAL SUBMITTALS
  - A. Procedures: Submit for information and verification in accordance with Section 01 33 00.
  - B. Test Reports: Include product test data demonstrating compliance with specified standards.

### 1.05 CLOSEOUT SUBMITTALS

- A. Submit the following in accordance with Section 01 78 00.
  - 1. Submit cleaning and maintenance instructions for Owner's information.
  - 2. Warranty.

### 1.06 QUALITY ASSURANCE

- A. Regulatory Requirements:
  - 1. Fire Performance: Wall panels shall meet requirements for NFPA Class A fire rating.
  - 2. Wall Panels: UL labeled.

### 1.07 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
- B. Delivery: Deliver sheets in cartons. Deliver adhesive in sealed containers.
- C. Storage: Store products in original packaging in climate controlled area away from direct sunlight.

D. Handling: Protect surface of panels during handling and installation.

### 1.08 SITE CONDITIONS

- A. Ambient Conditions: During installation and for not less than 48 hours before installation, maintain room temperature required for adhesive being used.
- B. Protection: Provide ventilation to disperse fumes during application of adhesive. Allow no containers of adhesive to be opened until all potential sources of flame or spark have been shut down or extinguished and until warning signs have been posted.

## PART 2 PRODUCTS

# 2.01 MANUFACTURERS AND PRODUCTS

- A. Basis of Design Manufacturer and Product: See Finish Legend on Drawings.
  - 1. Construction Specialties, Inc. Acrovyn.
  - 2. Color, Texture and Joint Detail: As indicated on Finish Legend.
- B. Substitution Requests: In accordance with Section 01 25 00.

## 2.02 MATERIALS

- A. Wall Protection Panels: Vinyl/acrylic panels of gage indicated on Finish Legend.
  - 1. Size: Height as indicated by length required in one piece.
- B. Adhesive: Contact type as recommended by the manufacturer and complying with Southern California VOC regulations.
- C. Accessories and Trim: Manufacturer's standard vinyl/acrylic alloy moldings and trim.

## PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Existing Conditions: Examine surfaces scheduled to receive panels for conditions that will adversely affect execution, permanence or quality of work. Report unsatisfactory conditions to the General Contractor in writing with copy to Architect.
  - B. Acceptance: Beginning of application means acceptance of existing surfaces.

### 3.02 PREPARATION

A. All wall surfaces to be smooth, level, clean, dry and free of any irregularities to provide a good adhesive grip and smooth application of wall panels.

## 3.03 INSTALLATION

- A. General: Install panels in accordance with the manufacturer's recommendations.
- B. Adhesive: Comply with manufacturer's instructions regarding method of application, spread rate, drying time, open time and temperature and humidity limitations.

- C. Panels: Align and plumb the first sheet before allowing the glue lines to come together, then apply the sheet slowly from one side to the other to expel air. Roll uniformly with hard rubber roller.
- D. Install rigid sheets beveled at seams and chemically sealed. Butt adjoining panels tight, in straight, even line. Install panels without top cap, vertical divider bars, inside corner trim, or other joint accessories and trim unless otherwise detailed on Interior Design Drawings.
- E. Trim: Install trim at all exposed edges and outside corners.

# 3.04 CLEANING

A. Immediately remove any adhesive from face of panels using solvent recommended by panel manufacturer. Keep faces clean during application.

### **SECTION 10 28 13**

#### **TOILET ACCESSORIES**

#### PART 1 GENERAL

### 1.01 SUMMARY

- A. Section Includes:
  - 1. Toilet room accessories as indicated and specified.

#### 1.02 REFERENCES

- A. Reference Standards: Comply with the following as applicable:
  - 1. United States Department of Justice 2010 ADA Standards for Accessible Design, September 15, 2010; available at <u>www.ada.gov/ADAStandards\_index.htm</u>.

### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Product Data: Submit manufacturer's current product literature.

## PART 2 PRODUCTS

- 2.01 TOILET ACCESSORIES
  - A. Basis of Design Manufacturers and Products: See Toilet Accessories Schedule on the Drawings.
     1. Bobrick Washroom Equipment, Inc.; <u>www.bobrick.com</u>.

### **PART 3 EXECUTION**

#### 3.01 EXAMINATION

- A. Verification of Conditions: Comply with Section 01 71 16.
  - 1. Existing Conditions:
    - a. Verify solid blocking in partitions and walls as required for proper support of toilet accessories.
- B. Notification: Notify General Contractor of unsatisfactory conditions in writing with copy to Architect.
- C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

#### 3.02 INSTALLATION

- A. Fasten accessories rigidly and securely to walls using methods and materials recommended by manufacturer.
- B. Locate and mount at heights complying with local, state and ADA Standards.

DELTA 3 OSHPD COMMENTS 12/11/2017

# 3.03 ADJUSTMENT

A. Before final inspection, inspect each accessory installation for rigid and secure installation. Take action necessary for rigid and secure installations.
# **SECTION 11 00 00**

# EQUIPMENT

# PART 1 GENERAL

### 1.01 SUMMARY

- A. Products Installed But Not Furnished Under This Section:
  - 1. Contractor shall install Owner-furnished equipment where indicated in the Equipment Schedule on Drawings.
- B. Related Requirements:
  - 1. Equipment Schedule and Drawings apply to Work of this Section.
  - 2. Plumbing Connections: Division 22 Plumbing.
  - 3. Electrical Connections: Division 26 Electrical.

# 1.02 PRE-INSTALLATION CONFERENCE

- A. Conduct pre-installation conference in accordance with Section 01 31 00.
- B. Convene pre-installation conference one week prior to commencing work of this Section when specified under product description.
- C. Attendance Required: Contractor, manufacturer's representative, and installer.
- D. Agenda: Discuss and agree upon acceptable substrate and mounting conditions, preparatory work, utility connections, and methods of installation.

### 1.03 SEQUENCING

- A. General: Sequence work in accordance with Section 01 10 00.
- B. Prior to fabrication of mounting plates, furnish mounting plate templates to trades installing structure to support mounting plates.
- C. Install mounting plates to structural supports prior to covering-up by subsequent construction operations.

# 1.04 DATA TO BE FURNISHED BY SEPARATE VENDORS FOR COORDINATION

- A. Product Data: See Appendix 1, Equipment Cut Sheets.
  - 1. Include data to indicate standard mounting and utility connection details.
  - 2. Include information for factory finishes, hardware, glass, sealants, accessories and other required components.
  - 3. Include wiring diagrams and rough-in requirements for items requiring electrical connections.
- B. Shop Drawings: Furnished by Owner for non-standard custom-fabricated items to be installed by Contractor.
  - 1. Will indicate typical layout including dimensions, mounting locations and sizes, service accesses, utility connections, mounting sequences, and division of installation responsibilities.
  - 2. Will include detail drawings of non-standard mounting details and utility connections.

- 3. Will include detail drawings of special accessory components not included in manufacturer's product data.
- C. Informational Submittals: Submit following packaged separately from other submittals:
  - 1. Manufacturer's Instructions: Manufacturer's printed installation instructions will be furnished by Owner.

# 1.05 CLOSEOUT SUBMITTALS

- A. Submit following in accordance with Section 01 77 00.
  - 1. Operation and Maintenance Data: Manufacturer's printed, recommended operation and maintenance data when furnished with equipment.

# 1.06 QUALITY ASSURANCE

- A. Qualifications:
  - 1. Installer Qualifications: Acceptable to manufacturer with experience on at least five projects of similar nature in past five years.
    - a. Where required by manufacturer, Contractor shall provide factory-trained installers.

# 1.07 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00.
  - 1. Protect all equipment from dust and damage during storage, installation and subsequent construction operations.
- B. Delivery and Acceptance Requirements:
  - 1. Contractor shall become responsible for safety and protection of Owner-furnished equipment upon delivery.

# PART 2 PRODUCTS

- 2.01 OWNER-FURNISHED PRODUCTS
  - A. See Equipment Schedule on Drawings and cut sheets in Appendix No. 1.

# PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Verification of Conditions: Examine conditions in accordance with Section 01 73 19.
  - 1. Verify utility connections are installed.
  - 2. Verify mounting brackets, plates, and supports are installed.

### 3.02 INSTALLATION

- A. Install in accordance with manufacturer's printed instructions.
- B. Install equipment plumb, level, square, and free from warp or twist while maintaining dimensional tolerances and alignment with surrounding construction.

- C. Refer to Drawings for:
  - 1. Mounting heights.
  - 2. Mounting and anchoring details.

# 3.03 ADJUSTING

- A. Adjust parts for smooth, uniform operation.
- B. Touch-up minor surface coating damaged during installation; replace damaged units as directed by Architect.

# 3.04 CLEANING

- A. Remove protective covering from pre-finished items.
- B. Clean as recommended by manufacturer. Do not use materials or methods that may damage finish or surrounding construction.

# 3.05 PROTECTION

A. Protect finished work until Substantial Completion.

END OF SECTION

# **SECTION 12 31 00**

# MANUFACTURED METAL CASEWORK

# PART 1 GENERAL

### 1.01 SUMMARY

- A. Work Results:
  - 1. Furnish and install all new custom stainless steel full height, base and overhead cabinets and casework, including tops, shelves, ledges, supporting structures. Include delivery to the building, set in place, level, and scribe and anchor to walls and floors as required. Furnish and install all filler panels, knee space panels and scribes as shown on Drawings.

#### B. Related Requirements:

- 1. Blocking: Section 06 10 53 Miscellaneous Rough Carpentry.
- 2. Stainless Steel Countertops: Section 12 36 16 Metal Countertops.

#### 1.02 COORDINATION

A. Casework must interface closely with casework and equipment which may be installed by another subcontractor. If separate subcontractors are involved, the General Contractor shall coordinate and schedule their work to ensure that casework is installed in an expeditious manner, fit properly together and tightly fits in the space provided.

### 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, acceptance and return in accordance with Section 01 33 00.
- B. Shop Drawings: Submit shop drawings for casework assemblies showing plans, elevations, ends, and cross-sections.
  - 1. Coordinate shop drawings with other work involved.

#### 1.04 CLOSEOUT SUBMITTALS

- A. Submit the following for Project record in accordance with Section 01 78 00:
  - 1. Operation and Maintenance Data: At completion of work submit parts lists, operating instructions and maintenance recommendations in two (2) copies through the General Contractor to the Architect.

### 1.05 DELIVERY, STORAGE, AND HANDLING

- A. General Requirements: Comply with Section 01 60 00 and with Manufacturer's instructions. Protect casework and equipment from damage during delivery, storage, installation and subsequent building operations.
- B. Delivery and Acceptance Requirements: Cabinets shall not be delivered until the building or storage area is enclosed and sufficiently dry to prevent damage from moisture.

# PART 2 PRODUCTS

# 2.01 DESCRIPTION

- A. Metal Casework: Provide high quality stainless steel cabinets and casework with all standard hardware and all other hardware or accessories indicated on the Drawings. Provide all necessary fillers and removable backs.
  - 1. Cabinet Style and Material: Cabinet bodies, drawer bodies, shelves, drawer heads and door assemblies shall be fabricated from stainless steel.
  - 2. Drawer and Door Style: As indicated on Drawings.

# 2.02 PERFORMANCE

- A. Casework Construction Performance:
  - 1. Base cabinets shall be constructed to support at least a uniformly distributed load 200 lbs. per square foot of cabinet top area, including working surface without objectionable distortion of interference with door and drawer operation.
  - 2. Base cabinet corner gussets with leveling bolts shall support 500 lbs. per corner, at 1-1/2 inch projection of the leveling bolt below the gusset.
  - 3. Each adjustable and fixed shelf 4 feet or shorter in length shall support an evenly distributed load of 40 lbs. per square ft. up to a maximum of 200 lbs., with nominal temporary deflection, but without permanent set.
  - 4. Drawer construction and performance shall allow 13-5/8 inches clear when in an extended position and suspension system shall prevent friction contact with any other drawer or door during opening or closing. All drawers shall operate smoothly, a minimum of 10,000 cycles with an evenly distributed load of 150 lbs.
  - 5. Swinging doors on floor-mounted casework shall support 200 lbs. suspended at a point 12 inches from hinged side, with door swung through an arc of 160 degrees. Weight load test shall allow only a temporary deflection, without permanent distortion or twist. Door shall operate freely after test and assume a flat plane in a closed position.

# 2.03 MATERIALS

A. Stainless Steel: Stainless Steel shall be Type 304; 12, 14, 16, 18 and 20 gauge U.S. Standard. Stainless steel shall be supplied with a #4 finish free of burrs, weld marks, or other imperfections.

# 2.04 FABRICATION

- A. Field Measurements: Verify all measurements of the building before beginning final fabrication. All casework must conform to building lines and other casework and must be neatly fitted around openings, pipes or obstructions.
- B. Base Cabinet Construction:
  - 1. General:
    - a. All cabinet bodies shall be flush front construction with intersection of vertical and horizontal case members, such as end panels, top rails, bottoms and vertical posts in same plane without overlap. Exterior corners shall be spot welded with heavy back up reinforcement at exterior corners. All face joints shall be welded and ground smooth to provide a continuous flat plane.
    - b. Each cabinet shall be complete so that units can be relocated at any subsequent time without requiring field application of finished ends or other such parts.
    - c. Case openings shall be rabbeted on all four sides for both hinged and sliding doors to provide a dust resistant case.
    - d. All cabinets shall have a cleanable smooth interior. Bottom edges shall be formed down on sides and back to create easily cleanable corners with no burrs or sharp edges, and

front edge shall be offset to create a seamless drawer and door recess rabbet for dust stop.

- 2. Gauges: Gauges of stainless steel used in construction of cases shall be 18 gauge, except as follows:
  - a. Corner gussets for leveling bolts and apron corner braces, 12 gauge.
  - b. Case and drawer suspension channels, 14 gauge.
  - c. Top and intermediate front horizontal rails, table aprons, hinge reinforcements, and reinforcement gussets, 16 gauge.
  - d. Drawer assemblies, door assemblies, bottom, bottom back rail, toe space rail, and adjustable shelves, 20 gauge.
- 3. Base Cabinets:
  - a. End uprights shall be formed into not less than a channel formation at top, bottom, back and front. The front edge shall further offset to form a strike for doors and drawers, and shall be perforated for the support of drawer channels, intermediate rails and hinge screws. An upright filler shall be screwed in place in all cupboard units to close the back of the channel at front of the upright and to provide a smooth interior for the cupboard to facilitate cleaning. The upright filler shall be perforated with shelf adjustment holes at not more than 2-inch centers painted prior to assembly. The inside front of the upright shall be further reinforced with a full height 16 gauge hinge reinforcement angle.
  - b. Top horizontal rail on base cabinets shall interlock within the flange at top of end panels for strength, but shall be flush as face of unit. Top rail shall have a full width rabbet for swinging doors and drawers. Reinforcements shall be provided at all front corners for additional welded strength between vertical and horizontal case members.
  - c. Intermediate rails shall be provided between doors and drawers, but shall not be provided between drawers unless made necessary by locks in drawers. When required, intermediate rails shall be recessed behind doors and drawer fronts, and designed so that security panels may be added as required.
  - d. Intermediate vertical uprights shall be furnished to enclose cupboards when used in a unit in combination with a half width bank of drawers. However, to allow storage of large or bulky objects, no upright of any type shall be used at the center of double door cupboard units.
  - e. Cabinet bottom, and bottom rail shall be formed of one piece of stainless steel except in corner units and shall be formed down on sides and back to create a square edge transition welded to cabinet end panels, and front edge shall be offset to create a seamless drawer and door recess rabbet for dust stop.
  - f. Toe space rail shall extend up and forward to engage bottom rail to form a smooth surfaced fully enclosed toe space.
  - g. Back construction shall consist of a top and bottom rail, channel formed for maximum strength and welded to back and top flange of end uprights, open for access to plumbing lines. Cupboard units only shall be provided with removable back panels.
  - h. Die formed gussets, with multiple ends for strength, shall be furnished in each bottom corner of base units to ensure rigidity, and a leveling bolt, 3 inches long, shall engage a clinch nut in each gusset. Each leveling bolt and gusset shall be capable of supporting 500 pounds.
  - i. Adjustable shelves shall be formed down 3/4-inch, returned back 7/8-inch and up 1/4inch into a channel formation front and rear; formed down 3/4-inch at each end, shelves over 42 inches long shall be further reinforced with a channel formation welded to underside of shelf.
  - j. Drawer bodies shall be made in one piece construction including the bottom, two sides, back and front. They shall be fully coved at interior bottom on all four sides for easy cleaning. The top front of the inner drawer body shall be offset to interlock with the channel formation in drawer head providing a 3/4-inch thick drawer head.
  - k. Drawer suspension assembly shall consist of 2 sections providing a quiet, smooth operation on ball bearing nylon rollers. All drawers shall be self-closing from a point 5 inches open. Cabinet channels shall maintain alignment of drawer and provide an

integral drawer stop, but the drawer shall be removable without the use of tools. Drawers shall provide 13 5/8 inches front to back clearance when fully extended. Drawers shall rise when opened thus avoiding friction with lower drawers and/or doors. Drawer suspension system shall incorporate a double stop, lock open feature. Drawer suspension channels on Stainless Steel Cabinets shall be zinc plated after they are formed.

- I. Door assembly (two piece) for solid pan swinging doors shall consist of an inner and outer door pan. Outer door pan shall be formed at all four sides. The corners on the pull side of the outer door pan shall be welded and ground smooth to prevent exposure of sharp edges of steel at these critical points. Inner door pan shall be flanged at all four sides with hinge reinforcements welded in place. The door assembly shall be 3/4-inch thick and contains sound deadening material.
- m. Drawer/door assemblies shall be painted prior to assembly. Both shall be punched for attaching drawer pulls. Likewise, inner pan formation of door and drawer body shall be indented for in field installation of locks when required.
- n. Doors shall be readily removable and hinges easily replaceable. Hinges shall be applied to the cabinet and door with screws. Welding of hinges to either cabinet or door will not be acceptable.
- o. Knee space panels, where shown or specified, shall be 20 gauge, finished same as casework cabinets, and easily removable for access to mechanical service areas.
- C. Swinging Door Upper Cabinet Construction:
  - 1. Swinging door storage cabinets shall have a completely finished interior same as exterior.
  - End uprights shall be formed at the front in a 1-inch channel formation with the inside flange formed to provide a 31/32-inch x 1/2-inch door recess. The back of the upright shall be formed to a 2-1/2-inch formation. A 16 gauge hinge reinforcement, same as specified for BASE CABINETS, shall be welded to inner side of front uprights.
  - 3. Cabinet tops shall be formed into a 1-inch x 1-3/16-inch channel shape at front, with a 31/32-inch x 1/2-inch offset for door recess, and with flange at rear and sides for electro-welding cabinet top to cabinet back and ends.
  - 4. Cabinet flush bottoms shall be formed with a 1-inch wide front fascia and a 13/16-inch channel shape formation at front edge flanged back and up to create a door recess rabbet for dust stop.
  - 5. Cabinet backs shall be welded to the top, bottom and ends. Backs shall be perforated for shelf adjustment holes on not more than 1-inch centers. Holes shall be set in a channel formation in cabinet back and enclosed by end uprights.
  - 6. Adjustable shelves shall be formed down 3/4-inch, returned back 7/8-inch and up 1/4-inch into a channel formation front and rear, formed down 3/4-inch at each end, shelves over 42 inches long shall be further reinforced with a channel formation welded to underside of shelf.
  - 7. Door assembly (two piece) for solid panel swinging doors shall consist of an inner and outer door pan. Outer door pan shall be formed into a channel or flanged shape at all four sides. The corners on the pull side of the outer door pan shall be welded and ground smooth to prevent exposure of sharp edges of steel at these critical points. Inner door pan shall be flanged at all four sides with hinge reinforcements welded in place. The door assembly shall be 3/4-inch thick and contains sound deadening material.

# 2.05 HARDWARE AND TRIM

- A. Drawer and Door Pulls:
  - 1. Pull shall be of modern design, offering a comfortable handgrip, and be securely fastened to doors and drawers with screws.
  - 2. Two pulls shall be required on all drawers over 24 inches long.
  - 3. Material and Finish: Stainless steel wire.

- B. Sliding Door Pulls: Flush pulls for sliding doors shall be stainless steel, providing a recessed finger grip. Finger holes or slots machined into doors will not be acceptable.
- C. Hinges: Hinges shall be made of Type 304 stainless steel .089 thick, 2-1/2 inches high, with brushed satin finish, and shall be the institutional type with a five-knuckle bullet-type barrel.
  - 1. Hinges shall be attached to both door and case with two screws through each leaf. Welding of hinges to door or case will not be accepted.
  - 2. Doors under 36 inches in height shall be hung on one pair of hinges, and doors over 36 inches high shall be hung on 3 hinges.
- D. Locks:
  - 1. Disk Tumbler: Locks when shown or called for shall be a 5-disc tumbler with heavy duty interchangeable cylinder. Exposed lock noses shall be dull nickel (satin) plated and stamped with identifying numbers. Locks shall have capacity for 2000 primary key changes. Master key one level with the potential of 10 different, non-interchangeable master key groups.
  - Pin Tumbler: Locks when shown or called for shall be a pin tumbler with heavy duty interchangeable cylinder. Exposed lock noses shall be dull nickel (satin) plated and stamped with identifying numbers. Locks shall have capacity of at least 1000 primary key changes, and the capacity to be Masterkeyed, Grand-masterkeyed, Sub-masterkeyed, and Mason Keyed.
- E. Positive Catch: A two-piece heavy-duty cam action positive catch shall be provided on all base cupboard doors and shall be positioned near the pivoting edge of door to provide a clean unobstructed opening. Main body of the catch shall be confined within an integral cabinet divider rail, while latching post shall be mounted on the hinge side of door. Nylon roller type catches are not acceptable.
- F. Shelf Adjustment Clips: Shelf adjustment clips shall be nickel-plated steel.

# PART 3 EXECUTION

#### 3.01 EXAMINATION

- A. Verification of Conditions: Comply with Section 01 71 16:
  - 1. Verify location of all mechanical and electrical rough-ins to ensure proper match with installed equipment.
  - 2. Prior to beginning installation of casework, check and verify that no irregularities exist that would affect quality of execution of work specified.
- B. Notification: Report any unsatisfactory installed equipment. Report any unsatisfactory conditions immediately to the General Contractor.
- C. Acceptance: Beginning of work means acceptance of existing conditions by installer.

# 3.03 INSTALLATION

- A. Casework:
  - 1. Set casework components plumb, square, and straight with no distortion and securely anchor to building structure. Shim as required using concealed shims.
  - 2. Bolt continuous cabinets together with joints flush, tight and uniform, and with alignment of adjacent units within 1/16-inch tolerance.
  - 3. Secure wall cabinets to solid supporting material, not to plaster, lath or gypsum board.
  - 4. Abut top edge surfaces in one true plane. Provide flush joints not to exceed 1/8-inch.

- B. Work Surfaces:
  - 1. Where required due to field conditions, scribe to abutting surfaces.
  - 2. Only factory prepared field joints, located per approved shop drawings, shall be permitted. Secure the joints in the field, where practical, in the same manner as in the factory.
  - 3. Secure work surfaces to casework and equipment components with materials and procedures recommended by the manufacturer.
- C. Provide connecting and attaching devices, closures and trim members as required. Install items complete and adjust moving parts to operate smoothly.

# 3.04 ADJUSTING

- A. Repair or remove and replace defective work, as directed by Owner's representative upon completion of installation.
- B. Adjust doors, drawers and other moving or operating parts to function smoothly.

# 3.05 CLEANING

- A. Clean shop finished casework; touch up as required.
- B. Clean work surfaces and leave them free of all grease and streaks.
- C. Casework to be left broom clean and orderly.

# 3.06 PROTECTION

A. Provide reasonable protective measures to prevent casework and equipment from being exposed to other construction activity.

# END OF SECTION

# **SECTION 12 36 16**

### **METAL COUNTERTOPS**

# PART 1 GENERAL

# 1.01 SUMMARY

- A. Section Includes:
  - 1. Stainless steel countertops as indicated and specified.
- B. Related Requirements:
  - Work Under Division 22 Plumbing:
  - a. Plumbing rough-in and final connections from rough-in points to various pieces of equipment.
  - b. Traps, grease trays, valves, stops, shut-offs, and fittings necessary.

# 1.02 REFERENCES

1.

- A. Reference Standards: Comply with:
  - 1. National Sanitation Foundation (NSF).
  - 2. Underwriter's Laboratories, Inc. (UL).

# 1.03 ACTION SUBMITTALS

- A. Procedures: Submit for review, action and return in accordance with Section 01 33 00.
- B. Shop Drawings: Indicate the exact location of each water and drain connection required. Provide a drawing indicating fabrication details for stainless steel work as well as sizes and locations of sinks.
- C. Samples: Include samples of stainless steel materials proposed for use on this Project showing gauges and finishes if requested.

# 1.04 CLOSEOUT SUBMITTALS

- A. Procedures: Submit the following in accordance with Section 01 78 00.
- B. Warranty.

#### 1.05 QUALITY ASSURANCE

- A. Manufacturer's Qualifications:
  - 1. Manufacturers: Have personnel and plant facilities to design, detail and fabricate stainless steel countertops of type and size used on this project and shall have been continuously active in the fabrication of stainless steel countertops for a minimum of five years. Owner and Architect shall have free access to fabrication shop during construction of equipment.

#### 1.06 DELIVERY, STORAGE, AND HANDLING

A. Delivery and Storage of Products: In accordance with Section 01 60 00. Store indoors with waterproof covers to protect equipment. Protect tops, exposed surfaces and plumbing fixtures from damage during and after installation.

# 1.07 SITE CONDITIONS

A. Field Measurement: Field measure spaces to receive equipment before beginning final fabrication.

### 1.08 WARRANTY

A. Provide one year written warranty for material and installation in accordance with Section 01 78 36. Warranty shall cover repair or replace any defective equipment, material or workmanship that occurs within the guarantee period. The Owner shall have continued use of defective equipment until replacement is installed unless such use shall further damage the equipment.

# PART 2 PRODUCTS

# 2.01 MATERIALS

- A. Metals: Non-corrodible alloy, or stainless steel Type 302 stainless steel, having a standard analysis of 18 percent chrome and 8 percent nickel.
  - 1. Gauges: United States standard gauges.
  - 2. Give exposed surfaces a finish equal to No. 4 or 150 grit. Where manufacturing process and welding disturb original finish, carefully regrind, polish and restore to match balance of surface.
- B. Welded Parts: Non-porous and free of imperfections, pits, cracks and discolorations. Tinning of welds will not be acceptable. Grind and polish welds of stainless steel to match original finish.

### 2.02 COMPONENTS

A. Hardware: Stainless steel or heavy-duty chrome plated brass unless otherwise specified, studded securely to metal bodies, or welded. Grind smooth and polish.

# 2.03 FABRICATION

- A. Mechanical and Electrical Access to Equipment: Do necessary drilling and cutting of holes in equipment for hot and cold water, and electrical connections, and furnish heavy-turned brass threaded IPS connection on equipment that must be connected to soil or waste lines. Whenever possible cut or drill at the time of fabrication with such work indicated on the shop drawings.
- B. Stainless Steel Welds: Arc-weld using stainless steel electrodes.
  - 1. Welds: Free of pits, flaws and cleaned to remove flux and other impurities. Grind welds smooth and polish to original finish of the metal with the grain uniform to the grain of the original sheet. Where grinding and polishing have destroyed the grain, restore and blend to remove all traces of welding. Acetylene welding will not be acceptable.
  - 2. Welds, whether concealed or exposed, shall be background to the surface of the original metal to remove impurities from welds. Welds on exposed joints shall be continuous for the full length of the joints. Knuckle type or similar intermittent welds with openings or gaps will not be acceptable on any exposed seams of joints. Silver solder may be used only with the specified approval of the Architect.
- C. Tops: Have shop seams and corners welded, ground smooth and polished. Reinforce working tops with 1-1/2-inch x 1/8-inch galvanized angles. Place cross-angle members at each pair of legs. Provide one angle runner, running lengthwise, on tops up to 30 inches wide; provide two on

all tops over 30 inches. Reinforce tops to eliminate deflection and stud-weld all reinforcements to underside of top.

- 1. Spray underside of tops fully and smoothly with an approved hard, drying sound deadening, mastic material and spray with aluminum bronze lacquer after drying.
- Finish exposed edges as specified. Turn edges abutting walls up 6 inches and back 1-inch on a 45 degree angle and down 1/2-inch unless otherwise specified. Enclose ends of backsplashes. Free corners of tops shall be spherical.
- D. Sinks: Construct of #14 gauge stainless steel, No. 4 finish, inside and outside. Form backs, bottoms and fronts of one continuous sheet with ends welded into place. Partitions for compartment sinks of same material, electrically welded in place. Fully sound deaden underside of drain boards.
  - 1. Cove corners, both vertical and horizontal, on not less than 5/8-inch radius. Electrically weld and grind smooth and polish. Solder filleted corners will not be acceptable.
  - 2. Finish top sink edges at front and ends, except where fitted with integral type drain boards, with a minimum 2-1/2-inch die formed integral sanitary semi-rolled rim. Across the back of sinks, unless otherwise specified, provide 12 inches high integral backsplash coved back 2 inches on a 45 degree angle and down 1/2-inch across the top, ends enclosed.
  - 3. Provide two faucet holes on 8-inch centers over center line in each single compartment sink or center line of each partition in multiple compartment sinks and 2-1/2 inches down from the 45 degree break at top splash, unless otherwise noted. Height of backsplash shall be determined from front working edge of sink.
  - 4. Construct drainboards of same material as sinks and weld integrally to same. Provide 2-inch high rims with die formed integrally rolled edges to match sink edges. Cove front, ends and corner on no less than 5/8-inch radius, electrically weld, grind smooth, and polish. Solder filleting of corners will not be acceptable. Drainboards will be tested for flooding. Fabricator shall do necessary corrective work required to remove low spots.
- E. Field Joints: Locate for practical construction consistent with sizes convenient for shipping and accessibility into building.
  - 1. Carefully shear field joints in tops so they can be tightly butted and welded on job.
  - 2. Indicate and detail field joint locations on shop drawings.

# PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Verification of Conditions: Before beginning installation inspect grounds, blocking and supports for proper location and support of equipment. Verify location of mechanical and electrical roughins to assure proper match with installed equipment. Report any unsatisfactory conditions immediately to the General Contractor.
  - B. Acceptance: Beginning of installation means acceptance of existing conditions.

#### 3.02 PREPARATION

- A. Protection: Be liable and responsible for any patching or repairs required by reason of work. Make repairs or replacement to the satisfaction of the Architect.
- B. Coordination: Coordinate mechanical and electrical work to be certain that openings of sufficient size are available to accommodate traps and other fittings required for final connections to equipment specified herein. Coordinate work with other contractors so that all final connecting work is performed for each piece of equipment in accordance with instructions of the equipment manufacturer.

# 3.03 INSTALLATION

- A. General:
  - 1. Furnish, set in place, level and adjust all items specified in this Section.
  - 2. Make items ready for final mechanical and electrical connections as specified under Divisions 22 and 26.
  - 3. Install necessary scribe fillers, trim strips and seal to walls where required.
  - 4. Finished Installation: Conform to National Sanitation Foundation (NSF) standards as specified herein and to applicable state and local public health codes.
  - 5. Install equipment items in accordance with manufacturer's instructions.
- B. Wall Joints: Joints between counter and wall shall not exceed 1/4-inch. Fill all joints between 1/16-inch and 1/4-inch with clear silicone sealant, compressing surface slightly concave. Use polyethylene backer rod where a calking base is necessary.
- C. Accessories:
  - 1. Furnish equipment with accessories and appurtenances necessary to put each item into satisfactory operating condition.
  - 2. Deliver, for installation under Divisions 22 and 26, plumbing and electrical parts and fittings that are furnished loose and as part of equipment and give necessary instructions for their proper installation.
- 3.04 CLEANING AND TESTING
  - A. Cleaning: Throughout the progress of the work, keep working area free from debris.
  - B. Final Cleaning: Before final inspection, remove protective covering from work and give all parts of equipment a thorough cleaning and servicing, leaving all items free from defects and completely ready for operation. At the completion of the work, leave the premises in a clean and finished condition.

END OF SECTION

#### SECTION 22 05 00

#### COMMON WORK RESULTS FOR PLUMBING

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Piping materials and installation instructions common to most piping systems.
  - 2. Transition fittings.
  - 3. Dielectric fittings.
  - 4. Mechanical sleeve seals.
  - 5. Sleeves.
  - 6. Escutcheons.
  - 7. Grout.
  - 8. Plumbing demolition.
  - 9. Equipment installation requirements common to equipment sections.
  - 10. Painting and finishing.
  - 11. Concrete bases.
  - 12. Supports and anchorages.

#### 1.03 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe chases, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and in chases.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.
- F. The following are industry abbreviations for plastic materials:
  - 1. ABS: Acrylonitrile-butadiene-styrene plastic.
  - 2. CPVC: Chlorinated polyvinyl chloride plastic.
  - 3. PE: Polyethylene plastic.
  - 4. PVC: Polyvinyl chloride plastic.
- G. The following are industry abbreviations for rubber materials:
  - 1. EPDM: Ethylene-propylene-diene terpolymer rubber.

2. NBR: Acrylonitrile-butadiene rubber.

# 1.04 SUBMITTALS

- A. Product Data: For the following:
  - 1. Transition fittings.
  - 2. Dielectric fittings.
  - 3. Mechanical sleeve seals.
  - 4. Escutcheons.
- B. Welding certificates.

# 1.05 QUALITY ASSURANCE

- A. Steel Support Welding: Qualify processes and operators according to AWS D1.1, "Structural Welding Code--Steel."
- B. Steel Pipe Welding: Qualify processes and operators according to ASME Boiler and Pressure Vessel Code: Section IX, "Welding and Brazing Qualifications."
  - 1. Comply with provisions in ASME B31 Series, "Code for Pressure Piping."
  - 2. Certify that each welder has passed AWS qualification tests for welding processes involved and that certification is current.
- C. Electrical Characteristics for Plumbing Equipment: Equipment of higher electrical characteristics may be furnished provided such proposed equipment is approved in writing and connecting electrical services, circuit breakers, and conduit sizes are appropriately modified. If minimum energy ratings or efficiencies are specified, equipment shall comply with requirements.
- 1.06 DELIVERY, STORAGE, AND HANDLING
  - A. Deliver pipes and tubes with factory-applied end caps. Maintain end caps through shipping, storage, and handling to prevent pipe end damage and to prevent entrance of dirt, debris, and moisture.
  - B. Store plastic pipes protected from direct sunlight. Support to prevent sagging and bending.

# 1.07 COORDINATION

- A. Arrange for pipe spaces, chases, slots, and openings in building structure during progress of construction, to allow for plumbing installations.
- B. Coordinate installation of required supporting devices and set sleeves in poured-in-place concrete and other structural components as they are constructed.
- C. Coordinate requirements for access panels and doors for plumbing items requiring access that are concealed behind finished surfaces. Access panels and doors are specified in Division 08 Section "Access Doors and Frames."

# PART 2 PRODUCTS

#### 2.01 MANUFACTURERS

- A. In other Part 2 articles where subparagraph titles below introduce lists, the following requirements apply for product selection:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the manufacturers specified.
  - 2. Manufacturers: Subject to compliance with requirements, provide products by the manufacturers specified.

#### 2.02 PIPE, TUBE, AND FITTINGS

- A. Refer to individual Division 22 piping Sections for pipe, tube, and fitting materials and joining methods.
- B. Pipe Threads: ASME B1.20.1 for factory-threaded pipe and pipe fittings.

# 2.03 JOINING MATERIALS

- A. Refer to individual Division 22 piping Sections for special joining materials not listed below.
- B. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.
  - 1. ASME B16.21, nonmetallic, flat, asbestos-free, 1/8-inch maximum thickness unless thickness or specific material is indicated.
    - a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.
    - b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.
  - 2. AWWA C110, rubber, flat face, 1/8 inch thick, unless otherwise indicated; and full-face or ring type, unless otherwise indicated.
- C. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.
- D. Plastic, Pipe-Flange Gasket, Bolts, and Nuts: Type and material recommended by piping system manufacturer, unless otherwise indicated.
- E. Solder Filler Metals: ASTM B 32, lead-free alloys. Include water-flushable flux according to ASTM B 813.
- F. Brazing Filler Metals: AWS A5.8, BCuP Series, copper-phosphorus alloys for general-duty brazing, unless otherwise indicated; and AWS A5.8, BAg1, silver alloy for refrigerant piping, unless otherwise indicated.
- G. Welding Filler Metals: Comply with AWS D10.12 for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- H. Solvent Cements for Joining Plastic Piping:
  - 1. ABS Piping: ASTM D 2235.
  - 2. CPVC Piping: ASTM F 493.
  - 3. PVC Piping: ASTM D 2564. Include primer according to ASTM F 656.
  - 4. PVC to ABS Piping Transition: ASTM D 3138.
- I. Fiberglass Pipe Adhesive: As furnished or recommended by pipe manufacturer.

### 2.04 DIELECTRIC FITTINGS

- A. Description: Combination fitting of copper alloy and ferrous materials with threaded, solderjoint, plain, or weld-neck end connections that match piping system materials.
- B. Insulating Material: Suitable for system fluid, pressure, and temperature.
- C. Dielectric Unions: Factory-fabricated, union assembly, for 250-psig minimum working pressure at 180 deg F.
  - 1. Available Manufacturers:
    - a. Capitol Manufacturing Co.
    - b. Central Plastics Company.
    - c. Eclipse, Inc.
    - d. Epco Sales, Inc.
    - e. Hart Industries, International, Inc.
    - f. Watts Industries, Inc.; Water Products Div.
    - g. Zurn Industries, Inc.; Wilkins Div.
- D. Dielectric Flanges: Factory-fabricated, companion-flange assembly, for 150- or 300-psig minimum working pressure as required to suit system pressures.
  - 1. Available Manufacturers:
    - a. Capitol Manufacturing Co.
    - b. Central Plastics Company.
    - c. Epco Sales, Inc.
    - d. Watts Industries, Inc.; Water Products Div.
- E. Dielectric-Flange Kits: Companion-flange assembly for field assembly. Include flanges, fullface- or ring-type neoprene or phenolic gasket, phenolic or polyethylene bolt sleeves, phenolic washers, and steel backing washers.
  - 1. Available Manufacturers:
    - a. Advance Products & Systems, Inc.
    - b. Calpico, Inc.
    - c. Central Plastics Company.
    - d. Pipeline Seal and Insulator, Inc.
  - 2. Separate companion flanges and steel bolts and nuts shall have 150- or 300-psig minimum working pressure where required to suit system pressures.
- F. Dielectric Couplings: Galvanized-steel coupling with inert and noncorrosive, thermoplastic lining; threaded ends; and 300-psig minimum working pressure at 225 deg F.
  - 1. Available Manufacturers:
    - a. Calpico, Inc.
    - b. Lochinvar Corp.
- G. Dielectric Nipples: Electroplated steel nipple with inert and noncorrosive, thermoplastic lining; plain, threaded, or grooved ends; and 300-psig minimum working pressure at 225 deg F.
  - 1. Available Manufacturers:
    - a. Perfection Corp.
    - b. Precision Plumbing Products, Inc.
    - c. Sioux Chief Manufacturing Co., Inc.
    - d. Victaulic Co. of America.

#### 2.05 MECHANICAL SLEEVE SEALS

A. Description: Modular sealing element unit, designed for field assembly, to fill annular space between pipe and sleeve.

- 1. Available Manufacturers:
  - a. Advance Products & Systems, Inc.
  - b. Calpico, Inc.
  - c. Metraflex Co.
  - d. Pipeline Seal and Insulator, Inc.
- 2. Sealing Elements: EPDM interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
- 3. Pressure Plates: Carbon steel. Include two for each sealing element.
- 4. Connecting Bolts and Nuts: Carbon steel with corrosion-resistant coating of length required to secure pressure plates to sealing elements. Include one for each sealing element.

# 2.06 SLEEVES

- A. Galvanized-Steel Sheet: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.
- B. Steel Pipe: ASTM A 53, Type E, Grade B, Schedule 40, galvanized, plain ends.
- C. Cast Iron: Cast or fabricated "wall pipe" equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.
- D. Stack Sleeve Fittings: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring and bolts and nuts for membrane flashing.
  1. Underdeck Clamp: Clamping ring with set screws.
- E. Molded PVC: Permanent, with nailing flange for attaching to wooden forms.
- F. PVC Pipe: ASTM D 1785, Schedule 40.
- G. Molded PE: Reusable, PE, tapered-cup shaped, and smooth-outer surface with nailing flange for attaching to wooden forms.

#### 2.07 ESCUTCHEONS

- A. Description: Manufactured wall and ceiling escutcheons and floor plates, with an ID to closely fit around pipe, tube, and insulation of insulated piping and an OD that completely covers opening.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished chrome-plated finish.
- C. One-Piece, Cast-Brass Type: With set screw.
  - 1. Finish: Polished chrome-plated.
- D. Split-Casting, Cast-Brass Type: With concealed hinge and set screw.1. Finish: Polished chrome-plated.
- E. One-Piece, Stamped-Steel Type: With set screw and chrome-plated finish.
- F. Split-Plate, Stamped-Steel Type: With exposed-rivet hinge, set screw or spring clips, and chrome-plated finish.
- G. One-Piece, Floor-Plate Type: Cast-iron floor plate.

H. Split-Casting, Floor-Plate Type: Cast brass with concealed hinge and set screw.

# 2.08 GROUT

- A. Description: ASTM C 1107, Grade B, nonshrink and nonmetallic, dry hydraulic-cement grout.
  - 1. Characteristics: Post-hardening, volume-adjusting, nonstaining, noncorrosive, nongaseous, and recommended for interior and exterior applications.
  - 2. Design Mix: 5000-psi, 28-day compressive strength.
  - 3. Packaging: Premixed and factory packaged.

#### PART 3 EXECUTION

- 3.01 PLUMBING DEMOLITION
  - A. Refer to Division 01 Section "Cutting and Patching" and Division 02 Section "Selective Structure Demolition" for general demolition requirements and procedures.
  - B. Disconnect, demolish, and remove plumbing systems, equipment, and components indicated to be removed.
    - 1. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
    - 2. Piping to Be Abandoned in Place: Drain piping and cap or plug piping with same or compatible piping material.
    - 3. Equipment to Be Removed: Disconnect and cap services and remove equipment.
    - 4. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
    - 5. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
  - C. If pipe, insulation, or equipment to remain is damaged in appearance or is unserviceable, remove damaged or unserviceable portions and replace with new products of equal capacity and quality.

### 3.02 PIPING SYSTEMS - COMMON REQUIREMENTS

- A. Install piping according to the following requirements and Division 22 Sections specifying piping systems.
- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- C. Install piping in concealed locations, unless otherwise indicated and except in equipment rooms and service areas.
- D. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- E. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- F. Install piping to permit valve servicing.

- G. Install piping at indicated slopes.
- H. Install piping free of sags and bends.
- I. Install fittings for changes in direction and branch connections.
- J. Install piping to allow application of insulation.
- K. Select system components with pressure rating equal to or greater than system operating pressure.
- L. Install escutcheons for penetrations of walls, ceilings, and floors according to the following:
  - 1. New Piping:
    - a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep-pattern type.
    - b. Chrome-Plated Piping: One-piece, cast-brass type with polished chrome-plated finish.
    - c. Insulated Piping: One-piece, stamped-steel type with spring clips.
    - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, castbrass type with polished chrome-plated finish.
    - e. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, stamped-steel type.
    - f. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, cast-brass type with polished chrome-plated finish.
    - g. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, stamped-steel type and set screw.
    - h. Bare Piping in Unfinished Service Spaces: One-piece, cast-brass type with polished chrome-plated finish.
    - i. Bare Piping in Unfinished Service Spaces: One-piece, stamped-steel type with exposed-rivet hinge and set screw set screw or spring clips.
    - j. Bare Piping in Equipment Rooms: One-piece, cast-brass type.
    - k. Bare Piping in Equipment Rooms: One-piece, stamped-steel type with set screw or spring clips.
    - I. Bare Piping at Floor Penetrations in Equipment Rooms: One-piece, floor-plate type.
- M. Sleeves are not required for core-drilled holes.
- N. Permanent sleeves are not required for holes formed by removable PE sleeves.
- O. Install sleeves for pipes passing through concrete and masonry walls and concrete floor and roof slabs.
- P. Install sleeves for pipes passing through concrete and masonry walls, gypsum-board partitions, and concrete floor and roof slabs.
  - 1. Cut sleeves to length for mounting flush with both surfaces.
    - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
  - 2. Install sleeves in new walls and slabs as new walls and slabs are constructed.
  - 3. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation. Use the following sleeve materials:
    - a. Steel Pipe Sleeves: For pipes smaller than NPS 6.
    - b. Steel Sheet Sleeves: For pipes NPS 6 and larger, penetrating gypsum-board partitions.
    - c. Stack Sleeve Fittings: For pipes penetrating floors with membrane waterproofing. Secure flashing between clamping flanges. Install section of cast-iron soil pipe to

extend sleeve to 2 inches above finished floor level. Refer to Division 07 Section "Sheet Metal Flashing and Trim" for flashing.

- 1) Seal space outside of sleeve fittings with grout.
- 4. Except for underground wall penetrations, seal annular space between sleeve and pipe or pipe insulation, using joint sealants appropriate for size, depth, and location of joint. Refer to Division 07 Section "Joint Sealants" for materials and installation.
- Q. Aboveground, Exterior-Wall Pipe Penetrations: Seal penetrations using sleeves and mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
  - 1. Install steel pipe for sleeves smaller than 6 inches in diameter.
  - 2. Install cast-iron "wall pipes" for sleeves 6 inches and larger in diameter.
  - 3. Mechanical Sleeve Seal Installation: Select type and number of sealing elements required for pipe material and size. Position pipe in center of sleeve. Assemble mechanical sleeve seals and install in annular space between pipe and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.
- R. Underground, Exterior-Wall Pipe Penetrations: Install cast-iron "wall pipes" for sleeves. Seal pipe penetrations using mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
  - 1. Mechanical Sleeve Seal Installation: Select type and number of sealing elements required for pipe material and size. Position pipe in center of sleeve. Assemble mechanical sleeve seals and install in annular space between pipe and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.
- S. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Refer to Division 07 Section "Penetration Firestopping" for materials.
- T. Verify final equipment locations for roughing-in.
- U. Refer to equipment specifications in other Sections of these Specifications for roughing-in requirements.

### 3.03 PIPING JOINT CONSTRUCTION

- A. Join pipe and fittings according to the following requirements and Division 22 Sections specifying piping systems.
- B. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- C. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- D. Soldered Joints: Apply ASTM B 813, water-flushable flux, unless otherwise indicated, to tube end. Construct joints according to ASTM B 828 or CDA's "Copper Tube Handbook," using lead-free solder alloy complying with ASTM B 32.
- E. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," "Pipe and Tube" Chapter, using copper-phosphorus brazing filler metal complying with AWS A5.8.

- F. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- G. Welded Joints: Construct joints according to AWS D10.12, using qualified processes and welding operators according to Part 1 "Quality Assurance" Article.
- H. Flanged Joints: Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.
- I. Plastic Piping Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
  - 1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements.
  - 2. ABS Piping: Join according to ASTM D 2235 and ASTM D 2661 Appendixes.
  - 3. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.
  - 4. PVC Pressure Piping: Join schedule number ASTM D 1785, PVC pipe and PVC socket fittings according to ASTM D 2672. Join other-than-schedule-number PVC pipe and socket fittings according to ASTM D 2855.
  - 5. PVC Nonpressure Piping: Join according to ASTM D 2855.
  - 6. PVC to ABS Nonpressure Transition Fittings: Join according to ASTM D 3138 Appendix.
- J. Plastic Pressure Piping Gasketed Joints: Join according to ASTM D 3139.
- K. Plastic Nonpressure Piping Gasketed Joints: Join according to ASTM D 3212.
- L. PE Piping Heat-Fusion Joints: Clean and dry joining surfaces by wiping with clean cloth or paper towels. Join according to ASTM D 2657.
  - 1. Plain-End Pipe and Fittings: Use butt fusion.
  - 2. Plain-End Pipe and Socket Fittings: Use socket fusion.
- M. Fiberglass Bonded Joints: Prepare pipe ends and fittings, apply adhesive, and join according to pipe manufacturer's written instructions.

### 3.04 PIPING CONNECTIONS

- A. Make connections according to the following, unless otherwise indicated:
  - 1. Install unions, in piping NPS 2 and smaller, adjacent to each valve and at final connection to each piece of equipment.
  - 2. Install flanges, in piping NPS 2-1/2 and larger, adjacent to flanged valves and at final connection to each piece of equipment.
  - 3. Dry Piping Systems: Install dielectric unions and flanges to connect piping materials of dissimilar metals.
  - 4. Wet Piping Systems: Install dielectric coupling and nipple fittings to connect piping materials of dissimilar metals.

#### 3.05 EQUIPMENT INSTALLATION - COMMON REQUIREMENTS

A. Install equipment to allow maximum possible headroom unless specific mounting heights are not indicated.

- B. Install equipment level and plumb, parallel and perpendicular to other building systems and components in exposed interior spaces, unless otherwise indicated.
- C. Install plumbing equipment to facilitate service, maintenance, and repair or replacement of components. Connect equipment for ease of disconnecting, with minimum interference to other installations. Extend grease fittings to accessible locations.
- D. Install equipment to allow right of way for piping installed at required slope.

### 3.06 PAINTING

- A. Painting of plumbing systems, equipment, and components is specified in Division 09 Sections "Interior Painting" and "Exterior Painting."
- B. Damage and Touchup: Repair marred and damaged factory-painted finishes with materials and procedures to match original factory finish.

#### 3.07 CONCRETE BASES

- A. Concrete Bases: Anchor equipment to concrete base according to equipment manufacturer's written instructions and according to seismic codes at Project.
  - 1. Construct concrete bases of dimensions indicated, but not less than 4 inches larger in both directions than supported unit.
  - 2. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 18-inch centers around the full perimeter of the base.
  - 3. Install epoxy-coated anchor bolts for supported equipment that extend through concrete base, and anchor into structural concrete floor.
  - 4. Place and secure anchorage devices. Use supported equipment manufacturer's setting drawings, templates, diagrams, instructions, and directions furnished with items to be embedded.
  - 5. Install anchor bolts to elevations required for proper attachment to supported equipment.
  - 6. Install anchor bolts according to anchor-bolt manufacturer's written instructions.
  - 7. Use 3000-psi, 28-day compressive-strength concrete and reinforcement as specified in Division 03 Section "Cast-in-Place Concrete."

# 3.08 ERECTION OF METAL SUPPORTS AND ANCHORAGES

- A. Refer to Division 05 Section "Metal Fabrications" for structural steel.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor plumbing materials and equipment.
- C. Field Welding: Comply with AWS D1.1.

# 3.09 ERECTION OF WOOD SUPPORTS AND ANCHORAGES

- A. Cut, fit, and place wood grounds, nailers, blocking, and anchorages to support, and anchor plumbing materials and equipment.
- B. Select fastener sizes that will not penetrate members if opposite side will be exposed to view or will receive finish materials. Tighten connections between members. Install fasteners without splitting wood members.
- C. Attach to substrates as required to support applied loads.

# 3.10 GROUTING

- A. Mix and install grout for plumbing equipment base bearing surfaces, pump and other equipment base plates, and anchors.
- B. Clean surfaces that will come into contact with grout.
- C. Provide forms as required for placement of grout.
- D. Avoid air entrapment during placement of grout.
- E. Place grout, completely filling equipment bases.
- F. Place grout on concrete bases and provide smooth bearing surface for equipment.
- G. Place grout around anchors.
- H. Cure placed grout.

# END OF SECTION

### SECTION 22 05 23

### **GENERAL-DUTY VALVES FOR PLUMBING PIPING**

# PART 1 GENERAL

# 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section Includes:
  - 1. Bronze angle valves.
  - 2. Bronze ball valves.
  - 3. Iron ball valves.
  - 4. Iron, single-flange butterfly valves.
  - 5. Iron, grooved-end butterfly valves.
  - 6. Bronze lift check valves.
  - 7. Bronze swing check valves.
  - 8. Iron swing check valves.
  - 9. Iron swing check valves with closure control.
  - 10. Iron, grooved-end swing check valves.
  - 11. Iron, center-guided check valves.
  - 12. Iron, plate-type check valves.
  - 13. Bronze gate valves.
  - 14. Iron gate valves.
  - 15. Bronze globe valves.
  - 16. Iron globe valves.
- B. Related Sections:
  - 1. Division 22 plumbing piping Sections for specialty valves applicable to those Sections only.
  - 2. Division 22 Section "Identification for Plumbing Piping and Equipment" for valve tags and schedules.
  - 3. Division 33 water distribution piping Sections for general-duty and specialty valves for site construction piping.

### 1.03 DEFINITIONS

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene copolymer rubber.
- C. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- D. NRS: Nonrising stem.
- E. OS&Y: Outside screw and yoke.
- F. RS: Rising stem.
- G. SWP: Steam working pressure.

# 1.04 SUBMITTALS

A. Product Data: For each type of valve indicated.

# 1.05 QUALITY ASSURANCE

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
  - 1. ASME B16.10 and ASME B16.34 for ferrous valve dimensions and design criteria.
  - 2. ASME B31.1 for power piping valves.
  - 3. ASME B31.9 for building services piping valves.
- C. NSF Compliance: NSF 61 for valve materials for potable-water service.

### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.
  - 2. Protect threads, flange faces, grooves, and weld ends.
  - 3. Set angle, gate, and globe valves closed to prevent rattling.
  - 4. Set ball and plug valves open to minimize exposure of functional surfaces.
  - 5. Set butterfly valves closed or slightly open.
  - 6. Block check valves in either closed or open position.
- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.
  - 2. Store valves indoors and maintain at higher than ambient dew point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.

C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

# PART 2 PRODUCTS

- 2.01 GENERAL REQUIREMENTS FOR VALVES
  - A. Refer to valve schedule articles for applications of valves.
  - B. Valve Pressure and Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
  - C. Valve Sizes: Same as upstream piping unless otherwise indicated.
  - D. Valve Actuator Types:
    - 1. Gear Actuator: For quarter-turn valves NPS 8 and larger.
    - 2. Handwheel: For valves other than quarter-turn types.
    - 3. Handlever: For quarter-turn valves NPS 6 and smaller except plug valves.
    - 4. Wrench: For plug valves with square heads. Furnish Owner with 1 wrench for every 5 plug valves, for each size square plug-valve head.
    - 5. Chainwheel: Device for attachment to valve handwheel, stem, or other actuator; of size and with chain for mounting height, as indicated in the "Valve Installation" Article.
  - E. Valves in Insulated Piping: With 2-inch stem extensions and the following features:
    - 1. Gate Valves: With rising stem.
    - 2. Ball Valves: With extended operating handle of non-thermal-conductive material, and protective sleeve that allows operation of valve without breaking the vapor seal or disturbing insulation.
    - 3. Butterfly Valves: With extended neck.
  - F. Valve-End Connections:
    - 1. Flanged: With flanges according to ASME B16.1 for iron valves.
    - 2. Grooved: With grooves according to AWWA C606.
    - 3. Solder Joint: With sockets according to ASME B16.18.
    - 4. Threaded: With threads according to ASME B1.20.1.
  - G. Valve Bypass and Drain Connections: MSS SP-45.

#### 2.02 BRONZE ANGLE VALVES

- A. Class 125, Bronze Angle Valves with Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Hammond Valve.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 1.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and screw-in bonnet.
    - d. Ends: Threaded.
    - e. Stem and Disc: Bronze.
    - f. Packing: Asbestos free.

- g. Handwheel: Malleable iron.
- B. Class 125, Bronze Angle Valves with Nonmetallic Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. American Valve, Inc.
    - b. NIBCO INC.
    - c. Milwaukee Valve Company.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 2.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and screw-in bonnet.
    - d. Ends: Threaded.
    - e. Stem: Bronze.
    - f. Disc: PTFE or TFE.
    - g. Packing: Asbestos free.
    - h. Handwheel: Malleable iron.
- C. Class 150, Bronze Angle Valves with Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Division.
    - b. Kitz Corporation.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 1.
    - b. CWP Rating: 300 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and union-ring bonnet.
    - d. Ends: Threaded.
    - e. Stem and Disc: Bronze.
    - f. Packing: Asbestos free.
    - g. Handwheel: Malleable iron.
- D. Class 150, Bronze Angle Valves with Nonmetallic Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Division.
    - b. Hammond Valve.
    - c. Milwaukee Valve Company.
    - d. NIBCO INC.
    - e. Powell Valves.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 2.
    - b. CWP Rating: 300 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and union-ring bonnet.
    - d. Ends: Threaded.
    - e. Stem: Bronze.
    - f. Disc: PTFE or TFE.
    - g. Packing: Asbestos free.
    - h. Handwheel: Malleable iron.

### 2.03 BRONZE BALL VALVES

- A. Two-Piece, Full-Port, Bronze Ball Valves with Bronze Trim:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Conbraco Industries, Inc.; Apollo Valves.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-110.
    - b. SWP Rating: 150 psig.
    - c. CWP Rating: 600 psig.
    - d. Body Design: Two piece.
    - e. Body Material: Bronze.
    - f. Ends: Threaded.
    - g. Seats: PTFE or TFE.
    - h. Stem: Bronze.
    - i. Ball: Chrome-plated brass.
    - j. Port: Full.
- B. Two-Piece, Full-Port, Bronze Ball Valves with Stainless-Steel Trim:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Conbraco Industries, Inc.; Apollo Valves.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-110.
    - b. SWP Rating: 150 psig.
    - c. CWP Rating: 600 psig.
    - d. Body Design: Two piece.
    - e. Body Material: Bronze.
    - f. Ends: Threaded.
    - g. Seats: PTFE or TFE.
    - h. Stem: Stainless steel.
    - i. Ball: Stainless steel, vented.
    - j. Port: Full.

# 2.04 IRON BALL VALVES

- A. Class 125, Iron Ball Valves:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Conbraco Industries, Inc.; Apollo Valves.
    - b. Kitz Corporation.
    - c. Sure Flow Equipment Inc.
    - d. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - 2. Description:
    - a. Standard: MSS SP-72.
    - b. CWP Rating: 200 psig.
    - c. Body Design: Split body.
    - d. Body Material: ASTM A 126, gray iron.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- e. Ends: Flanged.
- f. Seats: PTFE or TFE.
- g. Stem: Stainless steel.
- h. Ball: Stainless steel.
- i. Port: Full.

# 2.05 IRON, SINGLE-FLANGE BUTTERFLY VALVES

- A. 200 CWP, Iron, Single-Flange Butterfly Valves with EPDM Seat and Aluminum-Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Conbraco Industries, Inc.; Apollo Valves.
    - b. Cooper Cameron Valves; a division of Cooper Cameron Corporation.
    - c. Crane Co.; Crane Valve Group; Jenkins Valves.
    - d. Crane Co.; Crane Valve Group; Stockham Division.
    - e. Hammond Valve.
    - f. Milwaukee Valve Company.
    - g. NIBCO INC.
    - h. Red-White Valve Corporation.
  - 2. Description:
    - a. Standard: MSS SP-67, Type I.
    - b. CWP Rating: 200 psig.
    - c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
    - d. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
    - e. Seat: EPDM.
    - f. Stem: One- or two-piece stainless steel.
    - g. Disc: Aluminum bronze.

# 2.06 BRONZE LIFT CHECK VALVES

- A. Class 125, Lift Check Valves with Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Crane Valves.
    - b. Crane Co.; Crane Valve Group; Jenkins Valves.
    - c. Crane Co.; Crane Valve Group; Stockham Division.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 1.
    - b. CWP Rating: 200 psig.
    - c. Body Design: Vertical flow.
    - d. Body Material: ASTM B 61 or ASTM B 62, bronze.
    - e. Ends: Threaded.
    - f. Disc: Bronze.
- B. Class 125, Lift Check Valves with Nonmetallic Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Flo Fab Inc.
    - b. Hammond Valve.
    - c. Kitz Corporation.
    - d. Milwaukee Valve Company.
- e. Mueller Steam Specialty; a division of SPX Corporation.
- f. NIBCO INC.
- g. Red-White Valve Corporation.
- h. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
- 2. Description:
  - a. Standard: MSS SP-80, Type 2.
  - b. CWP Rating: 200 psig.
  - c. Body Design: Vertical flow.
  - d. Body Material: ASTM B 61 or ASTM B 62, bronze.
  - e. Ends: Threaded.
  - f. Disc: NBR, PTFE, or TFE.
- 2.07 BRONZE SWING CHECK VALVES
  - A. Class 125, Bronze Swing Check Valves with Bronze Disc:
    - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
      - a. American Valve, Inc.
      - b. Crane Co.; Crane Valve Group; Crane Valves.
      - c. Crane Co.; Crane Valve Group; Jenkins Valves.
      - d. Crane Co.; Crane Valve Group; Stockham Division.
      - e. Hammond Valve.
      - f. Kitz Corporation.
      - g. Milwaukee Valve Company.
      - h. NIBCO INC.
      - i. Powell Valves.
      - j. Red-White Valve Corporation.
      - k. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
      - I. Zy-Tech Global Industries, Inc.
    - 2. Description:
      - a. Standard: MSS SP-80, Type 3.
      - b. CWP Rating: 200 psig.
      - c. Body Design: Horizontal flow.
      - d. Body Material: ASTM B 62, bronze.
      - e. Ends: Threaded.
      - f. Disc: Bronze.
  - B. Class 125, Bronze Swing Check Valves with Nonmetallic Disc:
    - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
      - a. Crane Co.; Crane Valve Group; Stockham Division.
      - b. Milwaukee Valve Company.
      - c. NIBCO INC.
    - 2. Description:
      - a. Standard: MSS SP-80, Type 4.
      - b. CWP Rating: 200 psig.
      - c. Body Design: Horizontal flow.
      - d. Body Material: ASTM B 62, bronze.
      - e. Ends: Threaded.
      - f. Disc: PTFE or TFE.

- C. Class 150, Bronze Swing Check Valves with Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Division.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 3.
    - b. CWP Rating: 300 psig.
    - c. Body Design: Horizontal flow.
    - d. Body Material: ASTM B 62, bronze.
    - e. Ends: Threaded.
    - f. Disc: Bronze.
- D. Class 150, Bronze Swing Check Valves with Nonmetallic Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Valves.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 4.
    - b. CWP Rating: 300 psig.
    - c. Body Design: Horizontal flow.
    - d. Body Material: ASTM B 62, bronze.
    - e. Ends: Threaded.
    - f. Disc: PTFE or TFE.
- E. Class 125, Iron, Compact-Wafer, Center-Guided Check Valves with Resilient Seat:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Milwaukee Valve Company.
    - b. NIBCO INC.
    - c. Sure Flow Equipment Inc.
  - 2. Description:
    - a. Standard: MSS SP-125.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM A 126, gray iron.
    - d. Style: Compact wafer.
    - e. Seat: EPDM.
- F. Class 125, Iron, Globe, Center-Guided Check Valves with Resilient Seat:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Milwaukee Valve Company.
    - b. NIBCO INC.
    - c. Sure Flow Equipment Inc.
  - 2. Description:
    - a. Standard: MSS SP-125.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM A 126, gray iron.

- d. Style: Globe, spring loaded.
- e. Ends: Flanged.
- f. Seat: EPDM.
- G. Class 150, Iron, Compact-Wafer, Center-Guided Check Valves with Resilient Seat:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. APCO Willamette Valve and Primer Corporation.
    - b. Crispin Valve.
    - c. Val-Matic Valve & Manufacturing Corp.
  - 2. Description:
    - a. Standard: MSS SP-125.
    - b. CWP Rating: 300 psig.
    - c. Body Material: ASTM A 395/A 395M or ASTM A 536, ductile iron.
    - d. Style: Compact wafer.
    - e. Seat: EPDM.

# 2.08 BRONZE GATE VALVES

- A. Class 125, NRS Bronze Gate Valves:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Division.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 1.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and screw-in bonnet.
    - d. Ends: Threaded or solder joint.
    - e. Stem: Bronze.
    - f. Disc: Solid wedge; bronze.
    - g. Packing: Asbestos free.
    - h. Handwheel: Malleable iron, bronze, or aluminum.
- B. Class 125, RS Bronze Gate Valves:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Division.
    - b. Milwaukee Valve Company.
    - c. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 2.
    - b. CWP Rating: 200 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and screw-in bonnet.
    - d. Ends: Threaded or solder joint.
    - e. Stem: Bronze.
    - f. Disc: Solid wedge; bronze.
    - g. Packing: Asbestos free.
    - h. Handwheel: Malleable iron, bronze, or aluminum.

- C. Class 150, NRS Bronze Gate Valves:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Milwaukee Valve Company.
    - b. NIBCO INC.
    - c. Red-White Valve Corporation.
    - Description:

2.

- a. Standard: MSS SP-80, Type 1.
- b. CWP Rating: 300 psig.
- c. Body Material: ASTM B 62, bronze with integral seat and union-ring bonnet.
- d. Ends: Threaded.
- e. Stem: Bronze.
- f. Disc: Solid wedge; bronze.
- g. Packing: Asbestos free.
- h. Handwheel: Malleable iron, bronze, or aluminum.
- D. Class 150, RS Bronze Gate Valves:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Crane Co.; Crane Valve Group; Stockham Division.
    - b. Kitz Corporation.
    - c. Milwaukee Valve Company.
    - d. NIBCO INC.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 2.
    - b. CWP Rating: 300 psig.
    - c. Body Material: ASTM B 62, bronze with integral seat and union-ring bonnet.
    - d. Ends: Threaded.
    - e. Stem: Bronze.
    - f. Disc: Solid wedge; bronze.
    - g. Packing: Asbestos free.
    - h. Handwheel: Malleable iron, bronze, or aluminum.

# **PART 3 EXECUTION**

### 3.01 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

## 3.02 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install chainwheels on operators for ball butterfly gate and plug valves NPS 4 and larger and more than 96 inches above floor. Extend chains to 60 inches above finished floor.
- F. Install check valves for proper direction of flow and as follows:
  - 1. Swing Check Valves: In horizontal position with hinge pin level.
  - 2. Center-Guided and Plate-Type Check Valves: In horizontal or vertical position, between flanges.
  - 3. Lift Check Valves: With stem upright and plumb.

## 3.03 ADJUSTING

A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

### 3.04 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS

- A. If valve applications are not indicated, use the following:
  - 1. Shutoff Service: Ball, butterfly, or gate, gate, or plug valves.
  - 2. Butterfly Valve Dead-End Service: Single-flange (lug) type.
  - 3. Throttling Service: Globe Globe or angle or ball or butterfly, ball, or butterfly valves.
  - 4. Pump-Discharge Check Valves:
    - a. NPS 2 and Smaller: Bronze swing check valves with bronze disc.
    - b. NPS 2-1/2 and Larger for Domestic Water: Iron swing check valves with lever and weight or with spring or iron, center-guided, metal or resilient-seat check valves.

- c. NPS 2-1/2 and Larger for Sanitary Waste and Storm Drainage: Iron swing check valves with lever and weight or spring.
- B. If valves with specified SWP classes or CWP ratings are not available, the same types of valves with higher SWP classes or CWP ratings may be substituted.
- C. Select valves, except wafer types, with the following end connections:
  - 1. For Copper Tubing, NPS 2 and Smaller: Threaded ends except where solder-joint valve-end option is indicated in valve schedules below.
  - 2. For Copper Tubing, NPS 2-1/2 to NPS 4: Flanged ends except where threaded valveend option is indicated in valve schedules below.
  - 3. For Copper Tubing, NPS 5 and Larger: Flanged ends.
  - 4. For Steel Piping, NPS 2 and Smaller: Threaded ends.
  - 5. For Steel Piping, NPS 2-1/2 to NPS 4: Flanged ends except where threaded valve-end option is indicated in valve schedules below.
  - 6. For Steel Piping, NPS 5 and Larger: Flanged ends.
  - 7. For Grooved-End Copper Tubing: Valve ends may be grooved.

## 3.05 LOW-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 PSIG OR LESS)

- A. Pipe NPS 2 and Smaller:
  - 1. Bronze and Brass Valves: May be provided with solder-joint ends instead of threaded ends.
  - 2. Ball Valves: One Two Three piece, full regular port, brass or bronze with brass bronze trim.
  - 3. Bronze Lift Check Valves: Class 125, bronze disc.
  - 4. Bronze Swing Check Valves: Class 125, bronze disc.
  - 5. Bronze Gate Valves: Class 125, NRS.
- B. Pipe NPS 2-1/2 and Larger:
  - 1. Iron Valves, NPS 2-1/2 to NPS 4: May be provided with threaded ends instead of flanged ends.
  - 2. Iron, Single-Flange Butterfly Valves: 200 CWP, NBR seat, aluminum-bronze stainlesssteel disc.
  - 3. Iron, Grooved-End Butterfly Valves: 175 CWP.
  - 4. Iron Swing Check Valves: Class 125, metal seats.
  - 5. Iron, Grooved-End Swing Check Valves: 300 CWP.
  - 6. Iron, Center-Guided Check Valves: Class 125 Class 150, compact-wafer, metal seat.
  - 7. Iron, Plate-Type Check Valves: Class 125 Class 150; single plate; metal seat.
  - 8. Iron Gate Valves: Class 125, NRS.

### 3.06 HIGH-PRESSURE, COMPRESSED-AIR VALVE SCHEDULE (150 TO 200 PSIG)

- A. Pipe NPS 2 and Smaller:
  - 1. Bronze Valves: May be provided with solder-joint ends instead of threaded ends.
  - 2. Ball Valves: One Two piece, full port, brass or bronze with bronze trim.
  - 3. Bronze Lift Check Valves: Class 125, bronze disc.
  - 4. Bronze Swing Check Valves: Class 125, disc.
  - 5. Bronze Gate Valves: Class 125,.
- B. Pipe NPS 2-1/2 and Larger:
  - 1. Iron Valves, NPS 2-1/2 to NPS 4: May be provided with threaded ends instead of flanged ends.
  - 2. Iron, Single-Flange Butterfly Valves: 200 CWP, NBR seat, disc.

# 3.07 DOMESTIC, HOT- AND COLD-WATER VALVE SCHEDULE

- A. Pipe NPS 2 and Smaller:
  - 1. Bronze Valves: May be provided with solder-joint ends instead of threaded ends.
  - 2. Bronze Angle Valves: Class 125, bronze disc.
  - 3. Ball Valves: One Two piece, full regular port, bronze with bronze trim.
  - 4. Bronze Swing Check Valves: Class 125, bronze disc.
  - 5. Bronze Gate Valves: Class 125,.
  - 6. Bronze Globe Valves: Class 125, bronze disc.
- B. Pipe NPS 2-1/2 and Larger:
  - 1. Iron Valves, NPS 2-1/2 to NPS 4: May be provided with threaded ends instead of flanged ends.
  - 2. Iron Ball Valves: Class 150.
  - 3. Iron, Single-Flange Butterfly Valves: 200 CWP, EPDM NBR seat, aluminum-bronze disc.

# END OF SECTION

## SECTION 22 05 29

## HANGERS AND SUPPORTS FOR PLUMBING PIPING AND EQUIPMENT

## PART 1 GENERAL

# 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section Includes:
  - 1. Metal pipe hangers and supports.
  - 2. Trapeze pipe hangers.
  - 3. Metal framing systems.
  - 4. Thermal-hanger shield inserts.
  - 5. Fastener systems.
  - 6. Pipe stands.
  - 7. Pipe positioning systems.
  - 8. Equipment supports.
- B. Related Sections:
  - 1. Division 05 Section "Metal Fabrications" for structural-steel shapes and plates for trapeze hangers for pipe and equipment supports.
  - 2. Division 22 Section "Vibration and Seismic Controls for Plumbing Piping and Equipment" for vibration isolation devices.

### 1.03 DEFINITIONS

A. MSS: Manufacturers Standardization Society of The Valve and Fittings Industry Inc.

### 1.04 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Design trapeze pipe hangers and equipment supports, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- B. Structural Performance: Hangers and supports for plumbing piping and equipment shall withstand the effects of gravity loads and stresses within limits and under conditions indicated according to ASCE/SEI 7.
  - 1. Design supports for multiple pipes, including pipe stands, capable of supporting combined weight of supported systems, system contents, and test water.
  - 2. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
  - 3. Design seismic-restraint hangers and supports for piping and equipment and obtain approval from authorities having jurisdiction.

## 1.05 SUBMITTALS

A. Product Data: For each type of product indicated.

- B. Shop Drawings: Signed and sealed by a qualified professional engineer. Show fabrication and installation details and include calculations for the following; include Product Data for components:
  - 1. Trapeze pipe hangers.
  - 2. Metal framing systems.
  - 3. Fiberglass strut systems.
  - 4. Pipe stands.
  - 5. Equipment supports.
- C. Delegated-Design Submittal: For trapeze hangers indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Detail fabrication and assembly of trapeze hangers.
  - 2. Design Calculations: Calculate requirements for designing trapeze hangers.
- D. Welding certificates.
- 1.06 QUALITY ASSURANCE
  - A. Structural Steel Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code Steel."
  - B. Pipe Welding Qualifications: Qualify procedures and operators according to ASME Boiler and Pressure Vessel Code.

# PART 2 PRODUCTS

# 2.01 METAL PIPE HANGERS AND SUPPORTS

- A. Carbon-Steel Pipe Hangers and Supports:
  - 1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
  - 2. Galvanized Metallic Coatings: Pregalvanized or hot dipped.
  - 3. Nonmetallic Coatings: Plastic coating, jacket, or liner.
  - 4. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
  - 5. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
- B. Stainless-Steel Pipe Hangers and Supports:
  - 1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
  - 2. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
  - 3. Hanger Rods: Continuous-thread rod, nuts, and washer made of stainless steel.
- C. Copper Pipe Hangers:
  - 1. Description: MSS SP-58, Types 1 through 58, copper-coated-steel, factory-fabricated components.
  - 2. Hanger Rods: Continuous-thread rod, nuts, and washer made of copper-coated steel.

## 2.02 TRAPEZE PIPE HANGERS

A. Description: MSS SP-69, Type 59, shop- or field-fabricated pipe-support assembly made from structural carbon-steel shapes with MSS SP-58 carbon-steel hanger rods, nuts, saddles, and U-bolts.

## 2.03 METAL FRAMING SYSTEMS

- A. MFMA Manufacturer Metal Framing Systems:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
    - a. B-Line, an Eaton Company.
    - b. Flex-Strut Inc.
    - c. Unistrut Corporation; Part of Atkore International.
    - d. Wesanco, Inc.
  - 3. Description: Shop- or field-fabricated pipe-support assembly for supporting multiple parallel pipes.
  - 4. Standard: MFMA-4.
  - 5. Channels: Continuous slotted steel channel with inturned lips.
  - 6. Channel Nuts: Formed or stamped steel nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
  - 7. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
  - 8. Metallic Coating: Electroplated zinc.
  - 9. Paint Coating: Vinyl.
  - 10. Plastic Coating: Epoxy.
  - 11. Combination Coating: None.
- B. Non-MFMA Manufacturer Metal Framing Systems:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
    - a. Anvil International.
    - b. Haydon Corporation.
    - c. PHD Manufacturing, Inc.
  - 3. Description: Shop- or field-fabricated pipe-support assembly made of steel channels, accessories, fittings, and other components for supporting multiple parallel pipes.
  - 4. Standard: Comply with MFMA-4.
  - 5. Channels: Continuous slotted steel channel with inturned lips.
  - 6. Channel Nuts: Formed or stamped steel nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
  - 7. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
  - 8. Coating: Paint.

# 2.04 THERMAL-HANGER SHIELD INSERTS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Basis-of-Design Product: Subject to compliance with requirements, provide or comparable product by one of the following:
  - 1. Pipe Shields, Inc.; a subsidiary of Piping Technology & Products, Inc.
  - 2. Piping Technology & Products, Inc.
  - 3. Rilco Manufacturing Co., Inc.
  - 4. Value Engineered Products, Inc.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- C. Insulation-Insert Material for Cold Piping: ASTM C 552, Type II cellular glass with 100-psig minimum compressive strength and vapor barrier.
- D. Insulation-Insert Material for Hot Piping: Water-repellent treated, ASTM C 533, Type I calcium silicate with 100-psig minimum compressive strength.
- E. For Trapeze or Clamped Systems: Insert and shield shall cover entire circumference of pipe.
- F. For Clevis or Band Hangers: Insert and shield shall cover lower 180 degrees of pipe.
- G. Insert Length: Extend 2 inches beyond sheet metal shield for piping operating below ambient air temperature.

#### 2.05 FASTENER SYSTEMS

A. Mechanical-Expansion Anchors: Insert-wedge-type, zinc-coated steel anchors, for use in hardened portland cement concrete; with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

### 2.06 PIPE STANDS

- A. General Requirements for Pipe Stands: Shop- or field-fabricated assemblies made of manufactured corrosion-resistant components to support roof-mounted piping.
- B. Compact Pipe Stand: One-piece plastic unit with integral-rod roller, pipe clamps, or V-shaped cradle to support pipe, for roof installation without membrane penetration.
- C. Low-Type, Single-Pipe Stand: One-piece stainless-steel base unit with plastic roller, for roof installation without membrane penetration.
- D. High-Type, Single-Pipe Stand:
  - 1. Description: Assembly of base, vertical and horizontal members, and pipe support, for roof installation without membrane penetration.
  - 2. Base: Stainless steel.
  - 3. Vertical Members: Two or more cadmium-plated-steel or stainless-steel, continuous-thread rods.
  - 4. Horizontal Member: Cadmium-plated-steel or stainless-steel rod with plastic or stainlesssteel, roller-type pipe support.
- E. High-Type, Multiple-Pipe Stand:
  - 1. Description: Assembly of bases, vertical and horizontal members, and pipe supports, for roof installation without membrane penetration.
  - 2. Bases: One or more; plastic.
  - 3. Vertical Members: Two or more protective-coated-steel channels.
  - 4. Horizontal Member: Protective-coated-steel channel.
  - 5. Pipe Supports: Galvanized-steel, clevis-type pipe hangers.
- F. Curb-Mounting-Type Pipe Stands: Shop- or field-fabricated pipe supports made from structural-steel shapes, continuous-thread rods, and rollers, for mounting on permanent stationary roof curb.

# 2.07 PIPE POSITIONING SYSTEMS

A. Description: IAPMO PS 42, positioning system of metal brackets, clips, and straps for positioning piping in pipe spaces; for plumbing fixtures in commercial applications.

### 2.08 EQUIPMENT SUPPORTS

A. Description: Welded, shop- or field-fabricated equipment support made from structural carbon-steel shapes.

### 2.09 MISCELLANEOUS MATERIALS

- A. Structural Steel: ASTM A 36/A 36M, carbon-steel plates, shapes, and bars; black and galvanized.
- B. Grout: ASTM C 1107, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout; suitable for interior and exterior applications.
  - 1. Properties: Nonstaining, noncorrosive, and nongaseous.
  - 2. Design Mix: 5000-psi, 28-day compressive strength.

## PART 3 EXECUTION

### 3.01 HANGER AND SUPPORT INSTALLATION

- A. Metal Pipe-Hanger Installation: Comply with MSS SP-69 and MSS SP-89. Install hangers, supports, clamps, and attachments as required to properly support piping from the building structure.
- B. Metal Trapeze Pipe-Hanger Installation: Comply with MSS SP-69 and MSS SP-89. Arrange for grouping of parallel runs of horizontal piping, and support together on field-fabricated trapeze pipe hangers.
  - 1. Pipes of Various Sizes: Support together and space trapezes for smallest pipe size or install intermediate supports for smaller diameter pipes as specified for individual pipe hangers.
  - 2. Field fabricate from ASTM A 36/A 36M, carbon-steel shapes selected for loads being supported. Weld steel according to AWS D1.1/D1.1M.
- C. Fiberglass Pipe-Hanger Installation: Comply with applicable portions of MSS SP-69 and MSS SP-89. Install hangers and attachments as required to properly support piping from building structure.
- D. Metal Framing System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled metal framing systems.
- E. Fiberglass Strut System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled fiberglass struts.
- F. Thermal-Hanger Shield Installation: Install in pipe hanger or shield for insulated piping.
- G. Fastener System Installation:
  - 1. Install powder-actuated fasteners for use in lightweight concrete or concrete slabs less than 4 inches thick in concrete after concrete is placed and completely cured. Use operators that are licensed by powder-actuated tool manufacturer. Install fasteners according to powder-actuated tool manufacturer's operating manual.
  - 2. Install mechanical-expansion anchors in concrete after concrete is placed and completely cured. Install fasteners according to manufacturer's written instructions.
- H. Pipe Stand Installation:

- 1. Pipe Stand Types except Curb-Mounted Type: Assemble components and mount on smooth roof surface. Do not penetrate roof membrane.
- Curb-Mounted-Type Pipe Stands: Assemble components or fabricate pipe stand and mount on permanent, stationary roof curb. See Division 07 Section "Roof Accessories" for curbs.
- I. Pipe Positioning-System Installation: Install support devices to make rigid supply and waste piping connections to each plumbing fixture. See Division 22 plumbing fixture Sections for requirements for pipe positioning systems for plumbing fixtures.
- J. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.
- K. Equipment Support Installation: Fabricate from welded-structural-steel shapes.
- L. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- M. Install lateral bracing with pipe hangers and supports to prevent swaying.
- N. Install building attachments within concrete slabs or attach to structural steel. Install additional attachments at concentrated loads, including valves, flanges, and strainers, NPS 2-1/2 and larger and at changes in direction of piping. Install concrete inserts before concrete is placed; fasten inserts to forms and install reinforcing bars through openings at top of inserts.
- O. Load Distribution: Install hangers and supports so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- P. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.
- Q. Insulated Piping:
  - 1. Attach clamps and spacers to piping.
    - a. Piping Operating above Ambient Air Temperature: Clamp may project through insulation.
    - b. Piping Operating below Ambient Air Temperature: Use thermal-hanger shield insert with clamp sized to match OD of insert.
    - c. Do not exceed pipe stress limits allowed by ASME B31.9 for building services piping.
  - 2. Install MSS SP-58, Type 39, protection saddles if insulation without vapor barrier is indicated. Fill interior voids with insulation that matches adjoining insulation.
    - a. Option: Thermal-hanger shield inserts may be used. Include steel weightdistribution plate for pipe NPS 4 and larger if pipe is installed on rollers.
  - 3. Install MSS SP-58, Type 40, protective shields on cold piping with vapor barrier. Shields shall span an arc of 180 degrees.
    - a. Option: Thermal-hanger shield inserts may be used. Include steel weightdistribution plate for pipe NPS 4 and larger if pipe is installed on rollers.
  - 4. Shield Dimensions for Pipe: Not less than the following:
    - a. NPS 1/4 to NPS 3-1/2: 12 inches long and 0.048 inch thick.
    - b. NPS 4: 12 inches long and 0.06 inch thick.
    - c. NPS 5 and NPS 6: 18 inches long and 0.06 inch thick.
    - d. NPS 8 to NPS 14: 24 inches long and 0.075 inch thick.
    - e. NPS 16 to NPS 24: 24 inches long and 0.105 inch thick.

- 5. Pipes NPS 8 and Larger: Include wood or reinforced calcium-silicate-insulation inserts of length at least as long as protective shield.
- 6. Thermal-Hanger Shields: Install with insulation same thickness as piping insulation.

# 3.02 EQUIPMENT SUPPORTS

- A. Fabricate structural-steel stands to suspend equipment from structure overhead or to support equipment above floor.
- B. Grouting: Place grout under supports for equipment and make bearing surface smooth.
- C. Provide lateral bracing, to prevent swaying, for equipment supports.

## 3.03 METAL FABRICATIONS

- A. Cut, drill, and fit miscellaneous metal fabrications for trapeze pipe hangers and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.
- C. Field Welding: Comply with AWS D1.1/D1.1M procedures for shielded, metal arc welding; appearance and quality of welds; and methods used in correcting welding work; and with the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. Finish welds at exposed connections so no roughness shows after finishing and so contours of welded surfaces match adjacent contours.

### 3.04 ADJUSTING

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.
- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches.

### 3.05 PAINTING

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
  1. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils.
- B. Touchup: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint on miscellaneous metal are specified in Division 09 painting Sections.
- C. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A 780.

# 3.06 HANGER AND SUPPORT SCHEDULE

A. Specific hanger and support requirements are in Sections specifying piping systems and equipment.

- B. Comply with MSS SP-69 for pipe-hanger selections and applications that are not specified in piping system Sections.
- C. Use hangers and supports with galvanized metallic coatings for piping and equipment that will not have field-applied finish.
- D. Use nonmetallic coatings on attachments for electrolytic protection where attachments are in direct contact with copper tubing.
- E. Use carbon-steel pipe hangers and supports metal trapeze pipe hangers and metal framing systems and attachments for general service applications.
- F. Use stainless-steel pipe hangers and fiberglass pipe hangers and fiberglass strut systems and stainless-steel or corrosion-resistant attachments for hostile environment applications.
- G. Use copper-plated pipe hangers and copper or stainless-steel attachments for copper piping and tubing.
- H. Use padded hangers for piping that is subject to scratching.
- I. Use thermal-hanger shield inserts for insulated piping and tubing.
- J. Horizontal-Piping Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Adjustable, Steel Clevis Hangers (MSS Type 1): For suspension of noninsulated or insulated, stationary pipes NPS 1/2 to NPS 30.
  - 2. Yoke-Type Pipe Clamps (MSS Type 2): For suspension of up to 1050 deg F, pipes NPS 4 to NPS 24, requiring up to 4 inches of insulation.
  - 3. Carbon- or Alloy-Steel, Double-Bolt Pipe Clamps (MSS Type 3): For suspension of pipes NPS 3/4 to NPS 36, requiring clamp flexibility and up to 4 inches of insulation.
  - 4. Steel Pipe Clamps (MSS Type 4): For suspension of cold and hot pipes NPS 1/2 to NPS 24 if little or no insulation is required.
  - 5. Pipe Hangers (MSS Type 5): For suspension of pipes NPS 1/2 to NPS 4, to allow offcenter closure for hanger installation before pipe erection.
  - 6. Adjustable, Swivel Split- or Solid-Ring Hangers (MSS Type 6): For suspension of noninsulated, stationary pipes NPS 3/4 to NPS 8.
  - 7. Adjustable, Steel Band Hangers (MSS Type 7): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  - 8. Adjustable Band Hangers (MSS Type 9): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  - 9. Adjustable, Swivel-Ring Band Hangers (MSS Type 10): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
  - 10. Split Pipe Ring with or without Turnbuckle Hangers (MSS Type 11): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 8.
  - 11. Extension Hinged or Two-Bolt Split Pipe Clamps (MSS Type 12): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 3.
  - 12. U-Bolts (MSS Type 24): For support of heavy pipes NPS 1/2 to NPS 30.
  - 13. Clips (MSS Type 26): For support of insulated pipes not subject to expansion or contraction.
  - 14. Pipe Saddle Supports (MSS Type 36): For support of pipes NPS 4 to NPS 36, with steelpipe base stanchion support and cast-iron floor flange or carbon-steel plate.
  - 15. Pipe Stanchion Saddles (MSS Type 37): For support of pipes NPS 4 to NPS 36, with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate, and with U-bolt to retain pipe.

- 16. Adjustable Pipe Saddle Supports (MSS Type 38): For stanchion-type support for pipes NPS 2-1/2 to NPS 36 if vertical adjustment is required, with steel-pipe base stanchion support and cast-iron floor flange.
- 17. Single-Pipe Rolls (MSS Type 41): For suspension of pipes NPS 1 to NPS 30, from two rods if longitudinal movement caused by expansion and contraction might occur.
- Adjustable Roller Hangers (MSS Type 43): For suspension of pipes NPS 2-1/2 to NPS 24, from single rod if horizontal movement caused by expansion and contraction might occur.
- 19. Complete Pipe Rolls (MSS Type 44): For support of pipes NPS 2 to NPS 42 if longitudinal movement caused by expansion and contraction might occur but vertical adjustment is not necessary.
- 20. Pipe Roll and Plate Units (MSS Type 45): For support of pipes NPS 2 to NPS 24 if small horizontal movement caused by expansion and contraction might occur and vertical adjustment is not necessary.
- 21. Adjustable Pipe Roll and Base Units (MSS Type 46): For support of pipes NPS 2 to NPS 30 if vertical and lateral adjustment during installation might be required in addition to expansion and contraction.
- K. Vertical-Piping Clamps: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Extension Pipe or Riser Clamps (MSS Type 8): For support of pipe risers NPS 3/4 to NPS 24.
  - 2. Carbon- or Alloy-Steel Riser Clamps (MSS Type 42): For support of pipe risers NPS 3/4 to NPS 24 if longer ends are required for riser clamps.
- L. Hanger-Rod Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Steel Turnbuckles (MSS Type 13): For adjustment up to 6 inches for heavy loads.
  - 2. Steel Clevises (MSS Type 14): For 120 to 450 deg F piping installations.
  - 3. Swivel Turnbuckles (MSS Type 15): For use with MSS Type 11, split pipe rings.
  - 4. Malleable-Iron Sockets (MSS Type 16): For attaching hanger rods to various types of building attachments.
  - 5. Steel Weldless Eye Nuts (MSS Type 17): For 120 to 450 deg F piping installations.
- M. Building Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Steel or Malleable Concrete Inserts (MSS Type 18): For upper attachment to suspend pipe hangers from concrete ceiling.
  - 2. Top-Beam C-Clamps (MSS Type 19): For use under roof installations with bar-joist construction, to attach to top flange of structural shape.
  - 3. Side-Beam or Channel Clamps (MSS Type 20): For attaching to bottom flange of beams, channels, or angles.
  - 4. Center-Beam Clamps (MSS Type 21): For attaching to center of bottom flange of beams.
  - 5. Welded Beam Attachments (MSS Type 22): For attaching to bottom of beams if loads are considerable and rod sizes are large.
  - 6. C-Clamps (MSS Type 23): For structural shapes.
  - 7. Top-Beam Clamps (MSS Type 25): For top of beams if hanger rod is required tangent to flange edge.
  - 8. Side-Beam Clamps (MSS Type 27): For bottom of steel I-beams.
  - 9. Steel-Beam Clamps with Eye Nuts (MSS Type 28): For attaching to bottom of steel Ibeams for heavy loads.
  - 10. Linked-Steel Clamps with Eye Nuts (MSS Type 29): For attaching to bottom of steel Ibeams for heavy loads, with link extensions.
  - 11. Malleable-Beam Clamps with Extension Pieces (MSS Type 30): For attaching to structural steel.

- 12. Welded-Steel Brackets: For support of pipes from below or for suspending from above by using clip and rod. Use one of the following for indicated loads:
  - a. Light (MSS Type 31): 750 lb.
  - b. Medium (MSS Type 32): 1500 lb.
  - c. Heavy (MSS Type 33); 3000 lb.
- 13. Side-Beam Brackets (MSS Type 34): For sides of steel or wooden beams.
- 14. Plate Lugs (MSS Type 57): For attaching to steel beams if flexibility at beam is required.
- 15. Horizontal Travelers (MSS Type 58): For supporting piping systems subject to linear horizontal movement where headroom is limited.
- N. Saddles and Shields: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Steel-Pipe-Covering Protection Saddles (MSS Type 39): To fill interior voids with insulation that matches adjoining insulation.
  - 2. Protection Shields (MSS Type 40): Of length recommended in writing by manufacturer to prevent crushing insulation.
  - 3. Thermal-Hanger Shield Inserts: For supporting insulated pipe.
- O. Spring Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Restraint-Control Devices (MSS Type 47): Where indicated to control piping movement.
  - 2. Spring Cushions (MSS Type 48): For light loads if vertical movement does not exceed 1-1/4 inches.
  - 3. Spring-Cushion Roll Hangers (MSS Type 49): For equipping Type 41, roll hanger with springs.
  - 4. Spring Sway Braces (MSS Type 50): To retard sway, shock, vibration, or thermal expansion in piping systems.
  - 5. Variable-Spring Hangers (MSS Type 51): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from hanger.
  - 6. Variable-Spring Base Supports (MSS Type 52): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from base support.
  - 7. Variable-Spring Trapeze Hangers (MSS Type 53): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from trapeze support.
  - 8. Constant Supports: For critical piping stress and if necessary to avoid transfer of stress from one support to another support, critical terminal, or connected equipment. Include auxiliary stops for erection, hydrostatic test, and load-adjustment capability. These supports include the following types:
    - a. Horizontal (MSS Type 54): Mounted horizontally.
    - b. Vertical (MSS Type 55): Mounted vertically.
    - c. Trapeze (MSS Type 56): Two vertical-type supports and one trapeze member.
- P. Comply with MSS SP-69 for trapeze pipe-hanger selections and applications that are not specified in piping system Sections.
- Q. Comply with MFMA-103 for metal framing system selections and applications that are not specified in piping system Sections.
- R. Use mechanical-expansion anchors instead of building attachments where required in concrete construction.
- S. Use pipe positioning systems in pipe spaces behind plumbing fixtures to support supply and waste piping for plumbing fixtures.

END OF SECTION

### SECTION 22 05 53

### **IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT**

### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Equipment labels.
  - 2. Warning signs and labels.
  - 3. Pipe labels.
  - 4. Stencils.
  - 5. Valve tags.
  - 6. Warning tags.

#### 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples: For color, letter style, and graphic representation required for each identification material and device.
- C. Equipment Label Schedule: Include a listing of all equipment to be labeled with the proposed content for each label.
- D. Valve numbering scheme.
- E. Valve Schedules: For each piping system to include in maintenance manuals.

#### 1.04 COORDINATION

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.

# PART 2 PRODUCTS

- 2.01 EQUIPMENT LABELS
  - A. Metal Labels for Equipment:
    - 1. Material and Thickness: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
    - 2. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 3. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- 4. Fasteners: Stainless-steel rivets or self-tapping screws.
- 5. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- B. Plastic Labels for Equipment:
  - 1. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/16 inch 1/8 inch thick, and having predrilled holes for attachment hardware.
  - 2. Letter Color: Black Yellow.
  - 3. Background Color: White.
  - 4. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
  - 5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  - 6. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
  - 7. Fasteners: Stainless-steel rivets or self-tapping screws.
  - 8. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- C. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), plus the Specification Section number and title where equipment is specified.
- D. Equipment Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch bond paper. Tabulate equipment identification number and identify Drawing numbers where equipment is indicated (plans, details, and schedules), plus the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

# 2.02 WARNING SIGNS AND LABELS

- A. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/16 inch 1/8 inch thick, and having predrilled holes for attachment hardware.
- B. Letter Color: Black, White.
- C. Background Color: Yellow.
- D. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- E. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- F. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- G. Fasteners: Stainless-steel rivets or self-tapping screws.
- H. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.

I. Label Content: Include caution and warning information, plus emergency notification instructions.

# 2.03 PIPE LABELS

- A. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service, and showing flow direction.
- B. Pretensioned Pipe Labels: Precoiled, semirigid plastic formed to cover full circumference of pipe and to attach to pipe without fasteners or adhesive.
- C. Self-Adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- D. Pipe Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings, pipe size, and an arrow indicating flow direction.
  - 1. Flow-Direction Arrows: Integral with piping system service lettering to accommodate both directions, or as separate unit on each pipe label to indicate flow direction.
  - 2. Lettering Size: At least 1-1/2 inches high.

# 2.04 STENCILS

- A. Stencils: Prepared with letter sizes according to ASME A13.1 for piping; and minimum letter height of 3/4 inch for access panel and door labels, equipment labels, and similar operational instructions.
  - 1. Stencil Material: Aluminum.
  - 2. Stencil Paint: Exterior, gloss, alkyd enamel black unless otherwise indicated. Paint may be in pressurized spray-can form.
  - 3. Identification Paint: Exterior, alkyd enamel in colors according to ASME A13.1 unless otherwise indicated.

### 2.05 VALVE TAGS

- A. Valve Tags: Stamped or engraved with 1/4-inch letters for piping system abbreviation and 1/2-inch numbers.
  - 1. Tag Material: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
  - 2. Fasteners: Brass wire-link chain.
- B. Valve Schedules: For each piping system, on 8-1/2-by-11-inch bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses.
  - 1. Valve-tag schedule shall be included in operation and maintenance data.

### 2.06 WARNING TAGS

- A. Warning Tags: Preprinted or partially preprinted, accident-prevention tags, of plasticized card stock with matte finish suitable for writing.
  - 1. Size: 3 by 5-1/4 inches minimum.
  - 2. Fasteners: Brass grommet and wire.
  - 3. Nomenclature: Large-size primary caption such as "DANGER," "CAUTION," or "DO NOT OPERATE."
  - 4. Color: Yellow background with black lettering.

# PART 3 EXECUTION

## 3.01 PREPARATION

A. Clean piping and equipment surfaces of substances that could impair bond of identification devices, including dirt, oil, grease, release agents, and incompatible primers, paints, and encapsulants.

## 3.02 EQUIPMENT LABEL INSTALLATION

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

# 3.03 PIPE LABEL INSTALLATION

- A. Piping Color-Coding: Painting of piping is specified in Division 09 Section "Interior Painting."
- B. Stenciled Pipe Label Option: Stenciled labels may be provided instead of manufactured pipe labels, at Installer's option. Install stenciled pipe labels with painted, color-coded bands or rectangles on each piping system.
  - 1. Identification Paint: Use for contrasting background.
  - 2. Stencil Paint: Use for pipe marking.
- C. Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:
  - 1. Near each valve and control device.
  - 2. Near each branch connection, excluding short takeoffs for fixtures and terminal units. Where flow pattern is not obvious, mark each pipe at branch.
  - 3. Near penetrations through walls, floors, ceilings, and inaccessible enclosures.
  - 4. At access doors, manholes, and similar access points that permit view of concealed piping.
  - 5. Near major equipment items and other points of origination and termination.
  - 6. Spaced at maximum intervals of 50 feet along each run. Reduce intervals to 25 feet in areas of congested piping and equipment.
  - 7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.
- D. Pipe Label Color Schedule:
  - 1. Low-Pressure, Compressed-Air Piping:
    - a. Background Color: Green.
    - b. Letter Color: Black.
  - 2. Medium-Pressure, Compressed-Air Piping:
    - a. Background Color: Green .
    - b. Letter Color: Black.
  - 3. Domestic Water Piping:
    - a. Background Color: Yellow.
    - b. Letter Color: Black.
  - 4. Sanitary Waste and Storm Drainage Piping:
    - a. Background Color: Green.
    - b. Letter Color: Black.

## 3.04 VALVE-TAG INSTALLATION

- A. Install tags on valves and control devices in piping systems, except check valves; valves within factory-fabricated equipment units; shutoff valves; faucets; convenience and lawn-watering hose connections; and similar roughing-in connections of end-use fixtures and units. List tagged valves in a valve schedule.
- B. Valve-Tag Application Schedule: Tag valves according to size, shape, and color scheme and with captions similar to those indicated in the following subparagraphs:
  - 1. Valve-Tag Size and Shape:
    - a. Cold Water: 1-1/2 inches 2 inches, square.
    - b. Hot Water: 1-1/2 inches 2 inches, round.
    - c. Low-Pressure Compressed Air: 2 inches, round.
    - d. High-Pressure Compressed Air: 2 inches, round.
  - 2. Valve-Tag Color:
    - a. Cold Water: Green.
    - b. Hot Water: Green.
    - c. Low-Pressure Compressed Air: Green.
    - d. High-Pressure Compressed Air: Green.
  - 3. Letter Color:
    - a. Cold Water: Black.
    - b. Hot Water: Black.
    - c. Low-Pressure Compressed Air: Black.
    - d. High-Pressure Compressed Air: Black.

# 3.05 WARNING-TAG INSTALLATION

A. Write required message on, and attach warning tags to, equipment and other items where required.

# END OF SECTION

## SECTION 22 07 00

## PLUMBING INSULATION

## PART 1 GENERAL

# 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section Includes:
  - 1. Insulation Materials:
    - a. Calcium silicate.
    - b. Flexible elastomeric.
    - c. Mineral fiber.
    - d. Phenolic.
    - e. Polyisocyanurate.
    - f. Polyolefin.
    - g. Polystyrene.
  - 2. Insulating cements.
  - 3. Adhesives.
  - 4. Mastics.
  - 5. Lagging adhesives.
  - 6. Sealants.
  - 7. Factory-applied jackets.
  - 8. Field-applied fabric-reinforcing mesh.
  - 9. Field-applied cloths.
  - 10. Field-applied jackets.
  - 11. Tapes.
  - 12. Securements.
  - 13. Corner angles.
- B. Related Sections include the following:
  - 1. Division 21 Section "Fire-Suppression Systems Insulation."
  - 2. Division 23 Section "HVAC Insulation."

# 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated. Include thermal conductivity, thickness, and jackets (both factory and field applied, if any).
- B. Shop Drawings:
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail attachment and covering of heat tracing inside insulation.
  - 3. Detail insulation application at pipe expansion joints for each type of insulation.
  - 4. Detail insulation application at elbows, fittings, flanges, valves, and specialties for each type of insulation.
  - 5. Detail removable insulation at piping specialties, equipment connections, and access panels.
  - 6. Detail application of field-applied jackets.

- 7. Detail application at linkages of control devices.
- 8. Detail field application for each equipment type.
- C. Samples: For each type of insulation and jacket indicated. Identify each Sample, describing product and intended use. Sample sizes are as follows:
  - 1. Sample Sizes:
    - a. Preformed Pipe Insulation Materials: 12 inches long by NPS 2.
    - b. Sheet Form Insulation Materials: 12 inches square.
    - c. Jacket Materials for Pipe: 12 inches long by NPS 2.
    - d. Sheet Jacket Materials: 12 inches square.
    - e. Manufacturer's Color Charts: For products where color is specified, show the full range of colors available for each type of finish material.
- D. Qualification Data: For qualified Installer.
- E. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.
- F. Field quality-control reports.

# 1.04 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Fire-Test-Response Characteristics: Insulation and related materials shall have fire-test-response characteristics indicated, as determined by testing identical products per ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing and inspecting agency.
  - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
  - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.
- C. Mockups: Before installing insulation, build mockups for each type of insulation and finish listed below to demonstrate quality of insulation application and finishes. Build mockups in the location indicated or, if not indicated, as directed by Architect. Use materials indicated for the completed Work.
  - 1. Piping Mockups:
    - a. One 10-foot section of NPS 2 straight pipe.
    - b. One each of a 90-degree threaded, welded, and flanged elbow.
    - c. One each of a threaded, welded, and flanged tee fitting.
    - d. One NPS 2 or smaller valve, and one NPS 2-1/2 or larger valve.
    - e. Four support hangers including hanger shield and insert.
    - f. One threaded strainer and one flanged strainer with removable portion of insulation.
    - g. One threaded reducer and one welded reducer.
    - h. One pressure temperature tap.
    - i. One mechanical coupling.
  - 2. Equipment Mockups: One tank or vessel.
  - 3. For each mockup, fabricate cutaway sections to allow observation of application details for insulation materials, adhesives, mastics, attachments, and jackets.

- 4. Notify Architect seven days in advance of dates and times when mockups will be constructed.
- 5. Obtain Architect's approval of mockups before starting insulation application.
- 6. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
- 7. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed Work.
- 8. Demolish and remove mockups when directed.

## 1.05 DELIVERY, STORAGE, AND HANDLING

A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

## 1.06 COORDINATION

- A. Coordinate size and location of supports, hangers, and insulation shields specified in Division 22 Section "Hangers and Supports for Plumbing Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application and equipment Installer for equipment insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.
- C. Coordinate installation and testing of heat tracing.

## 1.07 SCHEDULING

- A. Schedule insulation application after pressure testing systems and, where required, after installing and testing heat tracing. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

# PART 2 PRODUCTS

### 2.01 INSULATION MATERIALS

- A. Comply with requirements in Part 3 schedule articles for where insulating materials shall be applied.
- B. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- C. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- D. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- F. Calcium Silicate:
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Industrial Insulation Group (The); Thermo-12 Gold.
  - 2. Preformed Pipe Sections: Flat-, curved-, and grooved-block sections of noncombustible, inorganic, hydrous calcium silicate with a non-asbestos fibrous reinforcement. Comply with ASTM C 533, Type I.
  - 3. Flat-, curved-, and grooved-block sections of noncombustible, inorganic, hydrous calcium silicate with a non-asbestos fibrous reinforcement. Comply with ASTM C 533, Type I.

- 4. Prefabricated Fitting Covers: Comply with ASTM C 450 and ASTM C 585 for dimensions used in preforming insulation to cover valves, elbows, tees, and flanges.
- G. Flexible Elastomeric: Closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I for tubular materials and Type II for sheet materials.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Aeroflex USA Inc.; Aerocel.
    - b. Armacell LLC; AP Armaflex.
    - c. RBX Corporation; Insul-Sheet 1800 and Insul-Tube 180.
- H. Mineral-Fiber Blanket Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type II and ASTM C 1290, Type I. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. CertainTeed Corp.; Duct Wrap.
    - b. Johns Manville; Microlite.
    - c. Knauf Insulation; Duct Wrap.
    - d. Manson Insulation Inc.; Alley Wrap.
    - e. Owens Corning; All-Service Duct Wrap.
- I. High-Temperature, Mineral-Fiber Blanket Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type V, without factory-applied jacket.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Johns Manville; HTB 23 Spin-Glas.
    - b. Owens Corning; High Temperature Flexible Batt Insulations.
- J. Phenolic:
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:

a. Kingspan Corp.; Koolphen K.

- 2. Preformed pipe insulation of rigid, expanded, closed-cell structure. Comply with ASTM C 1126, Type III, Grade 1.
- 3. Block insulation of rigid, expanded, closed-cell structure. Comply with ASTM C 1126, Type II, Grade 1.
- 4. Factory fabricate shapes according to ASTM C 450 and ASTM C 585.
- 5. Factory-Applied Jacket: Requirements are specified in "Factory-Applied Jackets" Article. a. Preformed Pipe Insulation: ASJ.
  - b. Board for Equipment Applications: ASJ.
- K. Polyisocyanurate: Unfaced, preformed, rigid cellular polyisocyanurate material intended for use as thermal insulation.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Apache Products Company; ISO-25.
    - b. Dow Chemical Company (The); Trymer.
    - c. Duna USA Inc.; Corafoam.
    - d. Elliott Company; Elfoam.

- 2. Comply with ASTM C 591, Type I or Type IV, except thermal conductivity (k-value) shall not exceed 0.19 Btu x in./h x sq. ft. x deg F at 75 deg F after 180 days of aging.
- 3. Flame-spread index shall be 25 or less and smoke-developed index shall be 50 or less for thickness up to 1-1/2 inches as tested by ASTM E 84.
- 4. Fabricate shapes according to ASTM C 450 and ASTM C 585.
- 5. Factory-Applied Jacket: Requirements are specified in "Factory-Applied Jackets" Article.
  - a. Pipe Applications: ASJ.
  - b. Equipment Applications: ASJ.
- L. Polyolefin: Unicellular, polyethylene thermal plastic insulation. Comply with ASTM C 534 or ASTM C 1427, Type I, Grade 1 for tubular materials and Type II, Grade 1 for sheet materials.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Armacell LLC; Tubolit.
    - b. Nomaco Inc.; IMCOLOCK, IMCOSHEET, NOMALOCK, and NOMAPLY.
    - c. RBX Corporation; Therma-cell.
- M. Polystyrene: Rigid, extruded cellular polystyrene intended for use as thermal insulation. Comply with ASTM C 578, Type IV or Type XIII, except thermal conductivity (k-value) shall not exceed 0.26 Btu x in./h x sq. ft. x deg F after 180 days of aging. Fabricate shapes according to ASTM C 450 and ASTM C 585.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Dow Chemical Company (The); Styrofoam.
    - b. Knauf Insulation; Knauf Polystyrene.

# 2.02 INSULATING CEMENTS

- A. Mineral-Fiber Insulating Cement: Comply with ASTM C 195.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Insulco, Division of MFS, Inc.; Triple I.
    - b. P. K. Insulation Mfg. Co., Inc.; Super-Stik.

# 2.03 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated, unless otherwise indicated.
- B. Calcium Silicate Adhesive: Fibrous, sodium-silicate-based adhesive with a service temperature range of 50 to 800 deg F.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-97.
    - b. Foster Products Corporation, H. B. Fuller Company; 81-27/81-93.
    - c. Marathon Industries, Inc.; 290.
    - d. Mon-Eco Industries, Inc.; 22-30.
    - e. Vimasco Corporation; 760.
  - 2. For indoor applications, use adhesive that has a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

- C. Flexible Elastomeric and Polyolefin Adhesive: Comply with MIL-A-24179A, Type II, Class I.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Aeroflex USA Inc.; Aeroseal.
    - b. Armacell LCC; 520 Adhesive.
    - c. Foster Products Corporation, H. B. Fuller Company; 85-75.
    - d. RBX Corporation; Rubatex Contact Adhesive.
  - 2. For indoor applications, use adhesive that has a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- D. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-82.
    - b. Foster Products Corporation, H. B. Fuller Company; 85-20.
    - c. ITW TACC, Division of Illinois Tool Works; S-90/80.
    - d. Marathon Industries, Inc.; 225.
    - e. Mon-Eco Industries, Inc.; 22-25.
  - 2. For indoor applications, use adhesive that has a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- E. Polystyrene Adhesive: Solvent- or water-based, synthetic resin adhesive with a service temperature range of minus 20 to plus 140 deg F.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-96.
    - b. Foster Products Corporation, H. B. Fuller Company; 97-13.
- F. ASJ Adhesive, and FSK and PVDC Jacket Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-82.
    - b. Foster Products Corporation, H. B. Fuller Company; 85-20.
    - c. ITW TACC, Division of Illinois Tool Works; S-90/80.
    - d. Marathon Industries, Inc.; 225.
    - e. Mon-Eco Industries, Inc.; 22-25.
  - 2. For indoor applications, use adhesive that has a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- G. PVC Jacket Adhesive: Compatible with PVC jacket.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Dow Chemical Company (The); 739, Dow Silicone.
    - b. Johns-Manville; Zeston Perma-Weld, CEEL-TITE Solvent Welding Adhesive.
    - c. P.I.C. Plastics, Inc.; Welding Adhesive.
    - d. Speedline Corporation; Speedline Vinyl Adhesive.
  - 2. For indoor applications, use adhesive that has a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

## 2.04 LAGGING ADHESIVES

- A. Description: Comply with MIL-A-3316C, Class I, Grade A, and shall be compatible with insulation materials, jackets, and substrates.
  - 1. For indoor applications, use lagging adhesives that have a VOC content of g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-52.
    - b. Foster Products Corporation, H. B. Fuller Company; 81-42.
    - c. Marathon Industries, Inc.; 130.
    - d. Mon-Eco Industries, Inc.; 11-30.
    - e. Vimasco Corporation; 136.
  - 3. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fireresistant lagging cloths over equipment and pipe insulation.
  - 4. Service Temperature Range: Minus 50 to plus 180 deg F.
  - 5. Color: White.

## 2.05 SEALANTS

- A. Joint Sealants:
  - 1. Joint Sealants for Cellular-Glass, Phenolic, and Polyisocyanurate Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-76.
    - b. Foster Products Corporation, H. B. Fuller Company; 30-45.
    - c. Marathon Industries, Inc.; 405.
    - d. Mon-Eco Industries, Inc.; 44-05.
    - e. Pittsburgh Corning Corporation; Pittseal 444.
    - f. Vimasco Corporation; 750.
  - 2. Joint Sealants for Polystyrene Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-70.
    - b. Foster Products Corporation, H. B. Fuller Company; 30-45/30-46.
    - c. Marathon Industries, Inc.; 405.
    - d. Mon-Eco Industries, Inc.; 44-05.
    - e. Vimasco Corporation; 750.
  - 3. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 4. Permanently flexible, elastomeric sealant.
  - 5. Service Temperature Range: Minus 100 to plus 300 deg F.
  - 6. Color: White or gray.
  - 7. For indoor applications, use sealants that have a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. FSK and Metal Jacket Flashing Sealants:
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-76-8.
    - b. Foster Products Corporation, H. B. Fuller Company; 95-44.
    - c. Marathon Industries, Inc.; 405.
    - d. Mon-Eco Industries, Inc.; 44-05.
    - e. Vimasco Corporation; 750.

- 2. Materials shall be compatible with insulation materials, jackets, and substrates.
- 3. Fire- and water-resistant, flexible, elastomeric sealant.
- 4. Service Temperature Range: Minus 40 to plus 250 deg F.
- 5. Color: Aluminum.
- 6. For indoor applications, use sealants that have a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- C. ASJ Flashing Sealants, and Vinyl, PVDC, and PVC Jacket Flashing Sealants:
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-76.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 3. Fire- and water-resistant, flexible, elastomeric sealant.
  - 4. Service Temperature Range: Minus 40 to plus 250 deg F.
  - 5. Color: White.
  - 6. For indoor applications, use sealants that have a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

# 2.06 FACTORY-APPLIED JACKETS

- A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:
  - 1. ASJ: White, kraft-paper, fiberglass-reinforced scrim with aluminum-foil backing; complying with ASTM C 1136, Type I.
  - 2. ASJ-SSL: ASJ with self-sealing, pressure-sensitive, acrylic-based adhesive covered by a removable protective strip; complying with ASTM C 1136, Type I.
  - 3. FSK Jacket: Aluminum-foil, fiberglass-reinforced scrim with kraft-paper backing; complying with ASTM C 1136, Type II.
  - 4. PVDC Jacket for Indoor Applications: 4-mil-thick, white PVDC biaxially oriented barrier film with a permeance at 0.02 perms when tested according to ASTM E 96 and with a flame-spread index of 5 and a smoke-developed index of 20 when tested according to ASTM E 84.
    - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) Dow Chemical Company (The); Saran 540 Vapor Retarder Film and Saran 560 Vapor Retarder Film.
  - PVDC Jacket for Outdoor Applications: 6-mil-thick, white PVDC biaxially oriented barrier film with a permeance at 0.01 perms when tested according to ASTM E 96 and with a flame-spread index of 5 and a smoke-developed index of 25 when tested according to ASTM E 84.
    - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) Dow Chemical Company (The); Saran 540 Vapor Retarder Film and Saran 560 Vapor Retarder Film.
  - 6. PVDC-SSL Jacket: PVDC jacket with a self-sealing, pressure-sensitive, acrylic-based adhesive covered by a removable protective strip.
    - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) Dow Chemical Company (The); Saran 540 Vapor Retarder Film and Saran 560 Vapor Retarder Film.

## 2.07 FIELD-APPLIED JACKETS

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
- B. PVC Jacket: High-impact-resistant, UV-resistant PVC complying with ASTM D 1784, Class 16354-C; thickness as scheduled; roll stock ready for shop or field cutting and forming. Thickness is indicated in field-applied jacket schedules.
  - 1. Products: Subject to compliance with requirements, provide the following provide one of the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Johns Manville; Zeston.
    - b. P.I.C. Plastics, Inc.; FG Series.
    - c. Proto PVC Corporation; LoSmoke.
    - d. Speedline Corporation; SmokeSafe.
  - 2. Adhesive: As recommended by jacket material manufacturer.
  - 3. Color: White.
  - 4. Factory-fabricated fitting covers to match jacket if available; otherwise, field fabricate.
    - a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, unions, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories.
  - 5. Factory-fabricated tank heads and tank side panels.
- C. Metal Jacket:
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; Metal Jacketing Systems.
    - b. PABCO Metals Corporation; Surefit.
    - c. RPR Products, Inc.; Insul-Mate.
  - 2. Aluminum Jacket: Comply with ASTM B 209, Alloy 3003, 3005, 3105 or 5005, Temper H-14.
    - a. Sheet and roll stock ready for shop or field sizing.
    - b. Finish and thickness are indicated in field-applied jacket schedules.
    - c. Moisture Barrier for Indoor Applications: 1-mil-thick, heat-bonded polyethylene and kraft paper.
    - d. Moisture Barrier for Outdoor Applications: 3-mil-thick, heat-bonded polyethylene and kraft paper.
    - e. Factory-Fabricated Fitting Covers:
      - 1) Same material, finish, and thickness as jacket.
      - 2) Preformed 2-piece or gore, 45- and 90-degree, short- and long-radius elbows.
      - 3) Tee covers.
      - 4) Flange and union covers.
      - 5) End caps.
      - 6) Beveled collars.
      - 7) Valve covers.
      - 8) Field fabricate fitting covers only if factory-fabricated fitting covers are not available.
- D. Underground Direct-Buried Jacket: 125-mil-thick vapor barrier and waterproofing membrane consisting of a rubberized bituminous resin reinforced with a woven-glass fiber or polyester scrim and laminated aluminum foil.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Pittsburgh Corning Corporation; Pittwrap.
b. Polyguard; Insulrap No Torch 125.

# 2.08 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0835.
    - b. Compac Corp.; 104 and 105.
    - c. Ideal Tape Co., Inc., an American Biltrite Company; 428 AWF ASJ.
    - d. Venture Tape; 1540 CW Plus, 1542 CW Plus, and 1542 CW Plus/SQ.
  - 2. Width: 3 inches.
  - 3. Thickness: 11.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. FSK Tape: Foil-face, vapor-retarder tape matching factory-applied jacket with acrylic adhesive; complying with ASTM C 1136.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0827.
    - b. Compac Corp.; 110 and 111.
    - c. Ideal Tape Co., Inc., an American Biltrite Company; 491 AWF FSK.
    - d. Venture Tape; 1525 CW, 1528 CW, and 1528 CW/SQ.
  - 2. Width: 3 inches.
  - 3. Thickness: 6.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. FSK Tape Disks and Squares: Precut disks or squares of FSK tape.
- C. PVC Tape: White vapor-retarder tape matching field-applied PVC jacket with acrylic adhesive. Suitable for indoor and outdoor applications.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0555.
    - b. Compac Corp.; 130.
    - c. Ideal Tape Co., Inc., an American Biltrite Company; 370 White PVC tape.
    - d. Venture Tape; 1506 CW NS.
  - 2. Width: 2 inches.
  - 3. Thickness: 6 mils.
  - 4. Adhesion: 64 ounces force/inch in width.
  - 5. Elongation: 500 percent.
  - 6. Tensile Strength: 18 lbf/inch in width.
- D. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:

- a. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0800.
- b. Compac Corp.; 120.
- c. Ideal Tape Co., Inc., an American Biltrite Company; 488 AWF.
- d. Venture Tape; 3520 CW.
- 2. Width: 2 inches.
- 3. Thickness: 3.7 mils.
- 4. Adhesion: 100 ounces force/inch in width.
- 5. Elongation: 5 percent.
- 6. Tensile Strength: 34 lbf/inch in width.
- E. PVDC Tape: White vapor-retarder PVDC tape with acrylic adhesive.
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Dow Chemical Company (The); Saran 540 Vapor Retarder Tape.
  - 2. Width: 3 inches.
  - 3. Film Thickness: 4 mils.
  - 4. Adhesive Thickness: 1.5 mils.
  - 5. Elongation at Break: 145 percent.
  - 6. Tensile Strength: 55 lbf/inch in width.

### 2.09 SECUREMENTS

- A. Bands:
  - 1. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products; Bands.
    - b. PABCO Metals Corporation; Bands.
    - c. RPR Products, Inc.; Bands.
  - 2. Stainless Steel: ASTM A 167 or ASTM A 240/A 240M, Type 304; 0.015 inch thick, 1/2 inch wide with wing seal.
  - 3. Aluminum: ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch thick, 1/2 inch wide with wing seal.
  - 4. Springs: Twin spring set constructed of stainless steel with ends flat and slotted to accept metal bands. Spring size determined by manufacturer for application.
- B. Insulation Pins and Hangers:
  - 1. Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.106-inch-diameter shank, length to suit depth of insulation indicated.
    - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) AGM Industries, Inc.; CWP-1.
      - 2) GEMCO; CD.
      - 3) Midwest Fasteners, Inc.; CD.
      - 4) Nelson Stud Welding; TPA, TPC, and TPS.
  - 2. Cupped-Head, Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.106-inch-diameter shank, length to suit depth of insulation indicated with integral 1-1/2-inch galvanized carbon-steel washer.
    - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) AGM Industries, Inc.; CWP-1.

- 2) GEMCO; Cupped Head Weld Pin.
- 3) Midwest Fasteners, Inc.; Cupped Head.
- 4) Nelson Stud Welding; CHP.
- 3. Metal, Adhesively Attached, Perforated-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
  - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - 1) AGM Industries, Inc.; Tactoo Insul-Hangers, Series T.
    - 2) GEMCO; Perforated Base.
    - 3) Midwest Fasteners, Inc.; Spindle.
  - b. Baseplate: Perforated, galvanized carbon-steel sheet, 0.030 inch thick by 2 inches square.
  - c. Spindle: Copper- or zinc-coated, low carbon steel, fully annealed, 0.106-inchdiameter shank, length to suit depth of insulation indicated.
  - d. Adhesive: Recommended by hanger manufacturer. Product with demonstrated capability to bond insulation hanger securely to substrates indicated without damaging insulation, hangers, and substrates.
- 4. Nonmetal, Adhesively Attached, Perforated-Base Insulation Hangers: Baseplate fastened to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
  - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - 1) GEMCO; Nylon Hangers.
    - 2) Midwest Fasteners, Inc.; Nylon Insulation Hangers.
  - b. Baseplate: Perforated, nylon sheet, 0.030 inch thick by 1-1/2 inches in diameter.
  - c. Spindle: Nylon, 0.106-inch-diameter shank, length to suit depth of insulation indicated, up to 2-1/2 inches.
  - d. Adhesive: Recommended by hanger manufacturer. Product with demonstrated capability to bond insulation hanger securely to substrates indicated without damaging insulation, hangers, and substrates.
- 5. Self-Sticking-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
  - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - 1) AGM Industries, Inc.; Tactoo Insul-Hangers, Series TSA.
    - 2) GEMCO; Press and Peel.
    - 3) Midwest Fasteners, Inc.; Self Stick.
  - b. Baseplate: Galvanized carbon-steel sheet, 0.030 inch thick by 2 inches square.
  - c. Spindle: Copper- or zinc-coated, low carbon steel, fully annealed, 0.106-inchdiameter shank, length to suit depth of insulation indicated.
  - d. Adhesive-backed base with a peel-off protective cover.
- 6. Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch-thick, galvanized-steel sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
  - a. Products: Subject to compliance with requirements, provide the following available products that may be incorporated into the Work include, but are not limited to, the following:
    - 1) AGM Industries, Inc.; RC-150.

- 2) GEMCO; R-150.
- 3) Midwest Fasteners, Inc.; WA-150.
- 4) Nelson Stud Welding; Speed Clips.
- b. Protect ends with capped self-locking washers incorporating a spring steel insert to ensure permanent retention of cap in exposed locations.
- 7. Nonmetal Insulation-Retaining Washers: Self-locking washers formed from 0.016-inchthick nylon sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
  - a. Products: Subject to compliance with requirements, provide the following:
    - 1) GEMCO.
    - 2) Midwest Fasteners, Inc.
- C. Staples: Outward-clinching insulation staples, nominal 3/4-inch-wide, stainless steel or Monel.
- D. Wire: 0.080-inch nickel-copper alloy.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. C & F Wire.
    - b. Childers Products.
    - c. PABCO Metals Corporation.
    - d. RPR Products, Inc.

### 2.10 CORNER ANGLES

- A. PVC Corner Angles: 30 mils thick, minimum 1 by 1 inch, PVC according to ASTM D 1784, Class 16354-C. White or color-coded to match adjacent surface.
- B. Aluminum Corner Angles: 0.040 inch thick, minimum 1 by 1 inch, aluminum according to ASTM B 209, Alloy 3003, 3005, 3105 or 5005; Temper H-14.
- C. Stainless-Steel Corner Angles: 0.024 inch thick, minimum 1 by 1 inch, stainless steel according to ASTM A 167 or ASTM A 240/A 240M, Type 304.

# PART 3 EXECUTION

#### 3.01 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation and other conditions affecting performance of insulation application.
  - 1. Verify that systems and equipment to be insulated have been tested and are free of defects.
  - 2. Verify that surfaces to be insulated are clean and dry.
  - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

# 3.02 PREPARATION

- A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.
- B. Surface Preparation: Clean and prepare surfaces to be insulated. Before insulating, apply a corrosion coating to insulated surfaces as follows:
  - 1. Stainless Steel: Coat 300 series stainless steel with an epoxy primer 5 mils thick and an epoxy finish 5 mils thick if operating in a temperature range between 140 and 300 deg F.

Consult coating manufacturer for appropriate coating materials and application methods for operating temperature range.

- 2. Carbon Steel: Coat carbon steel operating at a service temperature between 32 and 300 deg F with an epoxy coating. Consult coating manufacturer for appropriate coating materials and application methods for operating temperature range.
- C. Coordinate insulation installation with the trade installing heat tracing. Comply with requirements for heat tracing that apply to insulation.
- D. Mix insulating cements with clean potable water; if insulating cements are to be in contact with stainless-steel surfaces, use demineralized water.

### 3.03 GENERAL INSTALLATION REQUIREMENTS

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of equipment and piping including fittings, valves, and specialties.
- B. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of equipment and pipe system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- G. Keep insulation materials dry during application and finishing.
- H. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- I. Install insulation with least number of joints practical.
- J. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  - 1. Install insulation continuously through hangers and around anchor attachments.
  - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
  - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
  - 4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.

- K. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- L. Install insulation with factory-applied jackets as follows:
  - 1. Draw jacket tight and smooth.
  - 2. Cover circumferential joints with 3-inch-wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
  - 3. Overlap jacket longitudinal seams at least 1-1/2 inches. Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches o.c.
    - a. For below ambient services, apply vapor-barrier mastic over staples.
  - 4. Cover joints and seams with tape as recommended by insulation material manufacturer to maintain vapor seal.
  - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to pipe flanges and fittings.
- M. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- N. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- O. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.
- P. For above ambient services, do not install insulation to the following:
  - 1. Vibration-control devices.
  - 2. Testing agency labels and stamps.
  - 3. Nameplates and data plates.
  - 4. Manholes.
  - 5. Handholes.
  - 6. Cleanouts.

# 3.04 PENETRATIONS

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
  - 1. Seal penetrations with flashing sealant.
  - 2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
  - 3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches below top of roof flashing.
  - 4. Seal jacket to roof flashing with flashing sealant.
- B. Insulation Installation at Underground Exterior Wall Penetrations: Terminate insulation flush with sleeve seal. Seal terminations with flashing sealant.
- C. Insulation Installation at Aboveground Exterior Wall Penetrations: Install insulation continuously through wall penetrations.
  - 1. Seal penetrations with flashing sealant.

- 2. For applications requiring only indoor insulation, terminate insulation inside wall surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
- 3. Extend jacket of outdoor insulation outside wall flashing and overlap wall flashing at least 2 inches.
- 4. Seal jacket to wall flashing with flashing sealant.
- D. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.
- E. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Install insulation continuously through penetrations of fire-rated walls and partitions.
  - 1. Comply with requirements in Division 07 Section "Penetration Firestopping" irestopping and fire-resistive joint sealers.
- F. Insulation Installation at Floor Penetrations:
  - 1. Pipe: Install insulation continuously through floor penetrations.
  - 2. Seal penetrations through fire-rated assemblies. Comply with requirements in Division 07 Section "Penetration Firestopping."

### 3.05 GENERAL PIPE INSULATION INSTALLATION

- A. Requirements in this article generally apply to all insulation materials except where more specific requirements are specified in various pipe insulation material installation articles.
- B. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:
  - 1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity, unless otherwise indicated.
  - 2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
  - 3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
  - 4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.
  - 5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below ambient services, provide a design that maintains vapor barrier.
  - 6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.

- 7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below ambient services and a breather mastic for above ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
- 8. For services not specified to receive a field-applied jacket except for flexible elastomeric and polyolefin, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
- 9. Stencil or label the outside insulation jacket of each union with the word "UNION." Match size and color of pipe labels.
- C. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes, vessels, and equipment. Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.
- D. Install removable insulation covers at locations indicated. Installation shall conform to the following:
  - 1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
  - 2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
  - 3. Construct removable valve insulation covers in same manner as for flanges except divide the two-part section on the vertical center line of valve body.
  - 4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches over adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.
  - 5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

# 3.06 CALCIUM SILICATE INSULATION INSTALLATION

- A. Insulation Installation on Domestic Water Boiler Breechings:
  - 1. Secure single-layer insulation with stainless-steel bands at 12-inch intervals and tighten bands without deforming insulation material.
  - 2. Install 2-layer insulation with joints tightly butted and staggered at least 3 inches. Secure inner layer with wire spaced at 12-inch intervals. Secure outer layer with stainless-steel bands at 12-inch intervals.
  - 3. On exposed applications without metal jacket, finish insulation surface with a skim coat of mineral-fiber, hydraulic-setting cement. When cement is dry, apply flood coat of lagging adhesive and press on one layer of glass cloth. Overlap edges at least 1 inch. Apply finish coat of lagging adhesive over glass cloth. Thin finish coat to achieve smooth, uniform finish.
- B. Insulation Installation on Straight Pipes and Tubes:
  - 1. Secure single-layer insulation with stainless-steel bands at 12-inch intervals and tighten bands without deforming insulation materials.

- 2. Install 2-layer insulation with joints tightly butted and staggered at least 3 inches. Secure inner layer with wire spaced at 12-inch intervals. Secure outer layer with stainless-steel bands at 12-inch intervals.
- 3. Apply a skim coat of mineral-fiber, hydraulic-setting cement to insulation surface. When cement is dry, apply flood coat of lagging adhesive and press on one layer of glass cloth or tape. Overlap edges at least 1 inch. Apply finish coat of lagging adhesive over glass cloth or tape. Thin finish coat to achieve smooth, uniform finish.
- C. Insulation Installation on Pipe Flanges:
  - 1. Install preformed pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of block insulation of same material and thickness as pipe insulation.
  - 4. Finish flange insulation same as pipe insulation.
- D. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install preformed sections of same material as straight segments of pipe insulation when available. Secure according to manufacturer's written instructions.
  - 2. When preformed insulation sections of insulation are not available, install mitered sections of calcium silicate insulation. Secure insulation materials with wire or bands.
  - 3. Finish fittings insulation same as pipe insulation.
- E. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install mitered segments of calcium silicate insulation to valve body. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 2. Install insulation to flanges as specified for flange insulation application.
  - 3. Finish valve and specialty insulation same as pipe insulation.

# 3.07 FLEXIBLE ELASTOMERIC INSULATION INSTALLATION

- A. Seal longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- B. Insulation Installation on Pipe Flanges:
  - 1. Install pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of sheet insulation of same thickness as pipe insulation.
  - 4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- C. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install mitered sections of pipe insulation.
  - 2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- D. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install preformed valve covers manufactured of same material as pipe insulation when available.

- 2. When preformed valve covers are not available, install cut sections of pipe and sheet insulation to valve body. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
- 3. Install insulation to flanges as specified for flange insulation application.
- 4. Secure insulation to valves and specialties and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

# 3.08 MINERAL-FIBER INSULATION INSTALLATION

- A. Insulation Installation on Straight Pipes and Tubes:
  - 1. Secure each layer of preformed pipe insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
  - 2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
  - 3. For insulation with factory-applied jackets on above ambient surfaces, secure laps with outward clinched staples at 6 inches o.c.
  - 4. For insulation with factory-applied jackets on below ambient surfaces, do not staple longitudinal tabs but secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.
- B. Insulation Installation on Pipe Flanges:
  - 1. Install preformed pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with mineral-fiber blanket insulation.
  - 4. Install jacket material with manufacturer's recommended adhesive, overlap seams at least 1 inch, and seal joints with flashing sealant.
- C. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install preformed sections of same material as straight segments of pipe insulation when available.
  - 2. When preformed insulation elbows and fittings are not available, install mitered sections of pipe insulation, to a thickness equal to adjoining pipe insulation. Secure insulation materials with wire or bands.
- D. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install preformed sections of same material as straight segments of pipe insulation when available.
  - 2. When preformed sections are not available, install mitered sections of pipe insulation to valve body.
  - 3. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 4. Install insulation to flanges as specified for flange insulation application.

# 3.09 PHENOLIC INSULATION INSTALLATION

- A. General Installation Requirements:
  - 1. Secure single-layer insulation with stainless-steel bands at 12-inch intervals and tighten bands without deforming insulation materials.
  - 2. Install 2-layer insulation with joints tightly butted and staggered at least 3 inches. Secure inner layer with 0.062-inch wire spaced at 12-inch intervals. Secure outer layer with stainless-steel bands at 12-inch intervals.

- B. Insulation Installation on Straight Pipes and Tubes:
  - 1. Secure each layer of insulation to pipe with wire or bands and tighten bands without deforming insulation materials.
  - 2. Where vapor barriers are indicated, seal longitudinal seams, end joints, and protrusions with vapor-barrier mastic and joint sealant.
  - 3. For insulation with factory-applied jackets on above ambient services, secure laps with outward clinched staples at 6 inches o.c.
  - 4. For insulation with factory-applied jackets with vapor retarders on below ambient services, do not staple longitudinal tabs but secure tabs with additional adhesive as recommended by insulation material manufacturer and seal with vapor-barrier mastic and flashing sealant.
- C. Insulation Installation on Pipe Flanges:
  - 1. Install preformed pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of block insulation of same material and thickness as pipe insulation.
- D. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install preformed insulation sections of same material as straight segments of pipe insulation. Secure according to manufacturer's written instructions.
- E. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install preformed insulation sections of same material as straight segments of pipe insulation. Secure according to manufacturer's written instructions.
  - 2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 3. Install insulation to flanges as specified for flange insulation application.

# 3.10 POLYISOCYANURATE INSULATION INSTALLATION

- A. Insulation Installation on Straight Pipes and Tubes:
  - 1. Secure each layer of insulation to pipe with tape or bands and tighten without deforming insulation materials. Orient longitudinal joints between half sections in 3 and 9 o'clock positions on the pipe.
  - 2. For insulation with factory-applied jackets with vapor barriers, do not staple longitudinal tabs but secure tabs with additional adhesive or tape as recommended by insulation material manufacturer and seal with vapor-barrier mastic.
  - 3. All insulation shall be tightly butted and free of voids and gaps at all joints. Vapor barrier must be continuous. Before installing jacket material, install vapor-barrier system.
- B. Insulation Installation on Pipe Flanges:
  - 1. Install preformed pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, same thickness of adjacent pipe insulation, not to exceed 1-1/2-inch thickness.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of polyisocyanurate block insulation of same thickness as pipe insulation.
- C. Insulation Installation on Fittings and Elbows:
  - 1. Install preformed sections of same material as straight segments of pipe insulation. Secure according to manufacturer's written instructions.

- D. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install preformed sections of polyisocyanurate insulation to valve body.
  - 2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 3. Install insulation to flanges as specified for flange insulation application.

### 3.11 POLYOLEFIN INSULATION INSTALLATION

- A. Insulation Installation on Straight Pipes and Tubes:
  - 1. Seal split-tube longitudinal seams and end joints with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- B. Insulation Installation on Pipe Flanges:
  - 1. Install pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, plus twice the thickness of pipe insulation.
  - 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of polyolefin sheet insulation of same thickness as pipe insulation.
  - 4. Secure insulation to flanges and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- C. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install mitered sections of polyolefin pipe insulation.
  - 2. Secure insulation materials and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.
- D. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install cut sections of polyolefin pipe and sheet insulation to valve body.
  - 2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 3. Install insulation to flanges as specified for flange insulation application.
  - 4. Secure insulation to valves and specialties, and seal seams with manufacturer's recommended adhesive to eliminate openings in insulation that allow passage of air to surface being insulated.

# 3.12 POLYSTYRENE INSULATION INSTALLATION

- A. Insulation Installation on Straight Pipes and Tubes:
  - 1. Secure each layer of insulation with tape or bands and tighten bands without deforming insulation materials. Orient longitudinal joints between half sections in 3 and 9 o'clock positions on the pipe.
  - 2. For insulation with factory-applied jackets with vapor barriers, do not staple longitudinal tabs but secure tabs with additional adhesive or tape as recommended by insulation material manufacturer and seal with vapor-barrier mastic.
  - 3. All insulation shall be tightly butted and free of voids and gaps at all joints. Vapor barrier must be continuous. Before installing jacket material, install vapor-barrier system.
- B. Insulation Installation on Pipe Flanges:
  - 1. Install preformed pipe insulation to outer diameter of pipe flange.
  - 2. Make width of insulation section same as overall width of flange and bolts, same thickness of adjacent pipe insulation, not to exceed 1-1/2-inch thickness.

- 3. Fill voids between inner circumference of flange insulation and outer circumference of adjacent straight pipe segments with cut sections of polystyrene block insulation of same thickness as pipe insulation.
- C. Insulation Installation on Pipe Fittings and Elbows:
  - 1. Install preformed insulation sections of same material as straight segments of pipe insulation. Secure according to manufacturer's written instructions.
- D. Insulation Installation on Valves and Pipe Specialties:
  - 1. Install preformed section of polystyrene insulation to valve body.
  - 2. Arrange insulation to permit access to packing and to allow valve operation without disturbing insulation.
  - 3. Install insulation to flanges as specified for flange insulation application.

# 3.13 FIELD-APPLIED JACKET INSTALLATION

- A. Where glass-cloth jackets are indicated, install directly over bare insulation or insulation with factory-applied jackets.
  - 1. Draw jacket smooth and tight to surface with 2-inch overlap at seams and joints.
  - 2. Embed glass cloth between two 0.062-inch-thick coats of lagging adhesive.
  - 3. Completely encapsulate insulation with coating, leaving no exposed insulation.
- B. Where FSK jackets are indicated, install as follows:
  - 1. Draw jacket material smooth and tight.
  - 2. Install lap or joint strips with same material as jacket.
  - 3. Secure jacket to insulation with manufacturer's recommended adhesive.
  - 4. Install jacket with 1-1/2-inch laps at longitudinal seams and 3-inch-wide joint strips at end joints.
  - 5. Seal openings, punctures, and breaks in vapor-retarder jackets and exposed insulation with vapor-barrier mastic.
- C. Where PVC jackets are indicated, install with 1-inch overlap at longitudinal seams and end joints; for horizontal applications, install with longitudinal seams along top and bottom of tanks and vessels. Seal with manufacturer's recommended adhesive.
  - 1. Apply two continuous beads of adhesive to seams and joints, one bead under lap and the finish bead along seam and joint edge.
- D. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches o.c. and at end joints.
- E. Where PVDC jackets are indicated, install as follows:
  - 1. Apply three separate wraps of filament tape per insulation section to secure pipe insulation to pipe prior to installation of PVDC jacket.
  - 2. Wrap factory-presized jackets around individual pipe insulation sections with one end overlapping the previously installed sheet. Install presized jacket with an approximate overlap at butt joint of 2 inches over the previous section. Adhere lap seal using adhesive or SSL, and then apply 1-1/4 circumferences of appropriate PVDC tape around overlapped butt joint.
  - 3. Continuous jacket can be spiral wrapped around a length of pipe insulation. Apply adhesive or PVDC tape at overlapped spiral edge. When electing to use adhesives, refer to manufacturer's written instructions for application of adhesives along this spiral edge to maintain a permanent bond.

- 4. Jacket can be wrapped in cigarette fashion along length of roll for insulation systems with an outer circumference of 33-1/2 inches or less. The 33-1/2-inch-circumference limit allows for 2-inch-overlap seal. Using the length of roll allows for longer sections of jacket to be installed at one time. Use adhesive on the lap seal. Visually inspect lap seal for "fishmouthing," and use PVDC tape along lap seal to secure joint.
- 5. Repair holes or tears in PVDC jacket by placing PVDC tape over the hole or tear and wrapping a minimum of 1-1/4 circumferences to avoid damage to tape edges.

# 3.14 FINISHES

- A. Equipment and Pipe Insulation with ASJ, Glass-Cloth, or Other Paintable Jacket Material: Paint jacket with paint system identified below and as specified in Division 09 painting Sections.
  - 1. Flat Acrylic Finish: Two finish coats over a primer that is compatible with jacket material and finish coat paint. Add fungicidal agent to render fabric mildew proof.
    - a. Finish Coat Material: Interior, flat, latex-emulsion size.
- B. Flexible Elastomeric Thermal Insulation: After adhesive has fully cured, apply two coats of insulation manufacturer's recommended protective coating.
- C. Color: Final color as selected by Architect. Vary first and second coats to allow visual inspection of the completed Work.
- D. Do not field paint aluminum or stainless-steel jackets.

# 3.15 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
  - Inspect field-insulated equipment, randomly selected by Architect, by removing fieldapplied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to one location(s) for each type of equipment defined in the "Equipment Insulation Schedule" Article. For large equipment, remove only a portion adequate to determine compliance.
  - 2. Inspect pipe, fittings, strainers, and valves, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to three locations of straight pipe, three locations of threaded fittings, three locations of welded fittings, two locations of threaded strainers, two locations of welded strainers, three locations of threaded valves, and three locations of flanged valves for each pipe service defined in the "Piping Insulation Schedule, General" Article.
- D. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

# 3.16 DOMESTIC WATER BOILER BREECHING INSULATION SCHEDULE

- A. Round, exposed breeching and connector insulation shall be one of the following:
  - 1. Calcium Silicate: 4 inches thick.
  - 2. High-Temperature Mineral-Fiber Blanket: 3 inches thick and 3-lb/cu. ft. nominal density.
  - 3. High-Temperature Mineral-Fiber Board: 3 inches thick and 3-lb/cu. ft. nominal density.

- B. Round, concealed breeching and connector insulation shall be one of the following:
  - 1. Calcium Silicate: 4 inches thick.
  - 2. High-Temperature Mineral-Fiber Blanket: 3 inches thick and 3-lb/cu. ft. nominal density.
  - 3. High-Temperature Mineral-Fiber Board: 3 inches thick and 3-lb/cu. ft. nominal density.
- C. Rectangular, exposed breeching and connector insulation shall be one of the following:
  - 1. Calcium Silicate: 4 inches thick.
  - 2. High-Temperature Mineral-Fiber Blanket: 3 inches thick and 3-lb/cu. ft. nominal density.
  - 3. High-Temperature Mineral-Fiber Board: 3 inches thick and 3-lb/cu. ft. nominal density.
- D. Rectangular, concealed breeching and connector insulation shall be one of the following:
  - 1. Calcium Silicate: 4 inches thick.
  - 2. High-Temperature Mineral-Fiber Blanket: 3 inches thick and 3-lb/cu. ft. nominal density.
  - 3. High-Temperature Mineral-Fiber Board: 3 inches thick and 3-lb/cu. ft. nominal density.

#### 3.17 EQUIPMENT INSULATION SCHEDULE

- A. Insulation materials and thicknesses are identified below. If more than one material is listed for a type of equipment, selection from materials listed is Contractor's option.
- B. Insulate indoor and outdoor equipment in paragraphs below that is not factory insulated.
- 3.18 PIPING INSULATION SCHEDULE, GENERAL
  - A. Acceptable preformed pipe and tubular insulation materials and thicknesses are identified for each piping system and pipe size range. If more than one material is listed for a piping system, selection from materials listed is Contractor's option.
  - B. Items Not Insulated: Unless otherwise indicated, do not install insulation on the following:
    - 1. Drainage piping located in crawl spaces.
    - 2. Underground piping.
    - 3. Chrome-plated pipes and fittings unless there is a potential for personnel injury.
- 3.19 INDOOR PIPING INSULATION SCHEDULE
  - A. Domestic Cold Water:
    - 1. NPS 1 and Smaller: Insulation shall be one of the following:
      - a. Flexible Elastomeric: 1/2 inch thick.
      - b. Phenolic: 1 inch thick.
      - c. Polyisocyanurate: 1 inch thick.
      - d. Polyolefin: 1/2 inch thick.
    - 2. NPS 1-1/4 and Larger: Insulation shall be one of the following:
      - a. Flexible Elastomeric: 1 inch thick.
      - b. Phenolic: 1 inch thick.
      - c. Polyisocyanurate: 1 inch thick.
      - d. Polyolefin: 1 inch thick.
  - B. Domestic Hot and Recirculated Hot Water:
    - 2" and Smaller: Insulation shall be one of the following:
      - a. Flexible Elastomeric: 3/4 inch thick.
      - b. Phenolic: 1 inch thick.
      - c. Polyisocyanurate: 1 inch thick.
      - d. Polyolefin: 3/4 inch thick.

1

- C. Domestic Chilled Water (Potable):
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 1 inch thick.
    - b. Phenolic: 1 inch thick.
    - c. Polyisocyanurate: 1 inch thick.
    - d. Polyolefin: 1 inch thick.
- D. Stormwater and Overflow:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 1 inch thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1 inch thick.
    - c. Phenolic: 1 inch thick.
    - d. Polyisocyanurate: 1 inch thick.
    - e. Polyolefin: 1 inch thick.
- E. Roof Drain and Overflow Drain Bodies:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 1 inch thick.
    - b. Phenolic: 1 inch thick.
    - c. Polyisocyanurate: 1 inch thick.
    - d. Polyolefin: 1 inch thick.
- F. Exposed Sanitary Drains, Domestic Water, Domestic Hot Water, and Stops for Plumbing Fixtures for People with Disabilities:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 1/2 inch thick.
    - b. Polyolefin: 1/2 inch thick.
- G. Sanitary Waste Piping Where Heat Tracing Is Installed:
  - All Pipe Sizes: Insulation shall be one of the following:
    - a. Phenolic: 1-1/2 inches thick.
    - b. Polyisocyanurate: 1-1/2 inches thick.
- H. Condensate and Equipment Drain Water below 60 Deg F:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 3/4 inch thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1/2 inch thick.
    - c. Phenolic: 1 inch thick.
    - d. Polyisocyanurate: 1 inch thick.
    - e. Polyolefin: 3/4 inch thick.
- I. Floor Drains, Traps, and Sanitary Drain Piping within 10 Feet of Drain Receiving Condensate and Equipment Drain Water below 60 Deg F:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 3/4 inch thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 1/2 inch thick.
    - c. Phenolic: 1 inch thick.
    - d. Polyisocyanurate: 1 inch thick.
    - e. Polyolefin: 3/4 inch thick.
- J. Hot Service Drains:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Calcium Silicate: 1-1/2 inches thick.

1

- K. Hot Service Vents:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Calcium Silicate: 1-1/2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe, Type I or II: 1 inch thick.

### 3.20 OUTDOOR, ABOVEGROUND PIPING INSULATION SCHEDULE

- A. Domestic Water Piping:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 2 inches thick.
    - c. Phenolic: 2 inches thick.
    - d. Polyisocyanurate: 2 inches thick.
    - e. Polyolefin: 2 inches thick.
    - f. Polystyrene: 2 inches thick.
- B. Domestic Hot and Recirculated Hot Water:
  - 1. All Pipe Sizes: Insulation shall be one of the following:
    - a. Flexible Elastomeric: 2 inches thick.
    - b. Mineral-Fiber, Preformed Pipe Insulation, Type I: 2 inches thick.
    - c. Phenolic: 2 inches thick.
    - d. Polyisocyanurate: 2 inches thick.
    - e. Polyolefin: 2 inches thick.

#### 3.21 OUTDOOR, UNDERGROUND PIPING INSULATION SCHEDULE

- A. Loose-fill insulation, for belowground piping, is specified in Division 33 piping distribution Sections.
- B. Sanitary Waste Piping, All Sizes, Where Heat Tracing Is Installed: Cellular glass, 2 inches thick.
- C. Chilled Water, All Sizes: Cellular glass, 2 inches thick.

#### 3.22 INDOOR, FIELD-APPLIED JACKET SCHEDULE

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Equipment, Concealed:
  - 1. None.
  - 2. PVC: 20 mils thick.
  - 3. Aluminum, Smooth: 0.016 inch thick.
  - 4. Painted Aluminum, Smooth: 0.016 inch thick.
  - 5. Stainless Steel, Type 304,: 0.010 inch thick.

# 3.23 OUTDOOR, FIELD-APPLIED JACKET SCHEDULE

- A. Install jacket over insulation material. For insulation with factory-applied jacket, install the field-applied jacket over the factory-applied jacket.
- B. If more than one material is listed, selection from materials listed is Contractor's option.
- C. Piping, Exposed:
  - 1. PVC: 20 mils thick.
  - 2. Painted Aluminum,: 0.016 inch thick.
  - 3. Stainless Steel, Type 304, Smooth 2B Finish: 0.010 inch thick.

# 3.24 UNDERGROUND, FIELD-INSTALLED INSULATION JACKET

A. For underground direct-buried piping applications, install underground direct-buried jacket over insulation material.

### END OF SECTION

### SECTION 22 11 16

### DOMESTIC WATER PIPING

### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Under-building slab and aboveground domestic water pipes, tubes, fittings, and specialties inside the building.
  - 2. Encasement for piping.
  - 3. Specialty valves.
  - 4. Flexible connectors.
  - 5. Escutcheons.
  - 6. Sleeves and sleeve seals.
  - 7. Wall penetration systems.

# 1.03 PERFORMANCE REQUIREMENTS

A. Seismic Performance: Domestic water piping and support and installation shall withstand effects of earthquake motions determined according to ASCE/SEI 7.

# 1.04 SUBMITTALS

- A. Product Data: For the following products:
  - 1. Specialty valves.
  - 2. Transition fittings.
  - 3. Dielectric fittings.
  - 4. Flexible connectors.
  - 5. Backflow preventers and vacuum breakers.
  - 6. Escutcheons.
  - 7. Sleeves and sleeve seals.
  - 8. Water penetration systems.
- B. Water Samples: Specified in "Cleaning" Article.
- C. Coordination Drawings: For piping in equipment rooms and other congested areas, drawn to scale, on which the following items are shown and coordinated with each other, using input from Installers of the items involved:
  - 1. Fire-suppression-water piping.
  - 2. Domestic water piping.
  - 3. Compressed air piping.
  - 4. HVAC hydronic piping.

D. Field quality-control reports.

### 1.05 QUALITY ASSURANCE

- A. Piping materials shall bear label, stamp, or other markings of specified testing agency.
- B. Comply with NSF 14 for plastic, potable domestic water piping and components. Include marking "NSF-pw" on piping.
- C. Comply with NSF 61 for potable domestic water piping and components.

### 1.06 PROJECT CONDITIONS

- A. Interruption of Existing Water Service: Do not interrupt water service to facilities occupied by Owner or others unless permitted under the following conditions and then only after arranging to provide temporary water service according to requirements indicated:
  - 1. Notify Owner no fewer than 5 days in advance of proposed interruption of water service.
  - 2. Do not proceed with interruption of water service without Owner's written permission.

### 1.07 COORDINATION

A. Coordinate sizes and locations of concrete bases with actual equipment provided.

# PART 2 PRODUCTS

- 2.01 PIPING MATERIALS
  - A. Comply with requirements in "Piping Schedule" Article for applications of pipe, tube, fitting materials, and joining methods for specific services, service locations, and pipe sizes.

#### 2.02 COPPER TUBE AND FITTINGS

- A. Hard Copper Tube: ASTM B 88, Type L and ASTM B 88, Type M water tube, drawn temper.
   1. Cast-Copper Solder-Joint Fittings: ASME B16.18, pressure fittings.
  - 2. Wrought-Copper Solder-Joint Fittings: ASME B16.22, wrought-copper pressure fittings.
  - 3. Bronze Flanges: ASME B16.24, Class 150, with solder-joint ends.
  - 4. Copper Unions: MSS SP-123, cast-copper-alloy, hexagonal-stock body, with ball-andsocket, metal-to-metal seating surfaces, and solder-joint or threaded ends.
- B. Soft Copper Tube: ASTM B 88, Type K and ASTM B 88, Type L water tube, annealed temper.
  1. Copper Solder-Joint Fittings: ASME B16.22, wrought-copper pressure fittings.

#### 2.03 DUCTILE-IRON PIPE AND FITTINGS

- A. Mechanical-Joint, Ductile-Iron Pipe: AWWA C151, with mechanical-joint bell and plain spigot end unless grooved or flanged ends are indicated.
  - 1. Standard-Pattern, Mechanical-Joint Fittings: AWWA C110, ductile or gray iron.
  - 2. Compact-Pattern, Mechanical-Joint Fittings: AWWA C153, ductile iron.
    - a. Glands, Gaskets, and Bolts: AWWA C111, ductile- or gray-iron glands, rubber gaskets, and steel bolts.
- B. Plain-End, Ductile-Iron Pipe: AWWA C151.
  - 1. Grooved-Joint, Ductile-Iron-Pipe Appurtenances:

- a. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1) Anvil International.
  - 2) Shurjoint Piping Products.
  - 3) Star Pipe Products.
  - 4) Victaulic Company.
- b. Grooved-End, Ductile-Iron Fittings: ASTM A 47/A 47M, malleable-iron castings or ASTM A 536, ductile-iron castings with dimensions matching pipe.
- c. Grooved-End, Ductile-Iron-Pipe Couplings: AWWA C606 for ductile-iron-pipe dimensions. Include ferrous housing sections, EPDM-rubber gaskets suitable for hot and cold water, and bolts and nuts.

# 2.04 GALVANIZED-STEEL PIPE AND FITTINGS

- A. Galvanized-Steel Pipe: ASTM A 53/A 53M, Type E, Grade B, Standard Weight. Include ends matching joining method.
  - 1. Galvanized-Steel Pipe Nipples: ASTM A 733, made of ASTM A 53/A 53M or ASTM A 106/A 106M, Standard Weight, seamless steel pipe with threaded ends.
  - 2. Galvanized, Gray-Iron Threaded Fittings: ASME B16.4, Class 125, standard pattern.
  - 3. Malleable-Iron Unions: ASME B16.39, Class 150, hexagonal-stock body with ball-andsocket, metal-to-metal, bronze seating surface, and female threaded ends.
  - 4. Flanges: ASME B16.1, Class 125, cast iron.
  - 5. Grooved-Joint, Galvanized-Steel-Pipe Appurtenances:
    - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
      - 1) Anvil International.
      - 2) Shurjoint Piping Products.
      - 3) Star Pipe Products.
      - 4) Victaulic Company.
    - b. Galvanized, Grooved-End Fittings for Galvanized-Steel Piping: ASTM A 47/A 47M, malleable-iron casting; ASTM A 106/A 106M, steel pipe; or ASTM A 536, ductile-iron casting; with dimensions matching steel pipe.
    - c. Grooved-End-Pipe Couplings for Galvanized-Steel Piping: AWWA C606 for steelpipe dimensions. Include ferrous housing sections, EPDM-rubber gaskets suitable for hot and cold water, and bolts and nuts.

#### 2.05 PIPING JOINING MATERIALS

- A. Pipe-Flange Gasket Materials: AWWA C110, rubber, flat face, 1/8 inch thick or ASME B16.21, nonmetallic and asbestos free, unless otherwise indicated; full-face or ring type unless otherwise indicated.
- B. Metal, Pipe-Flange Bolts and Nuts: ASME B18.2.1, carbon steel unless otherwise indicated.
- C. Solder Filler Metals: ASTM B 32, lead-free alloys. Include water-flushable flux according to ASTM B 813.
- D. Brazing Filler Metals: AWS A5.8/A5.8M, BCuP Series, copper-phosphorus alloys for generalduty brazing unless otherwise indicated.
- E. and material recommended by piping system manufacturer unless otherwise indicated.

### 2.06 ENCASEMENT FOR PIPING

- A. Standard: ASTM A 674 or AWWA C105.
- B. Form: Sheet or Tube.
- C. Material: LLDPE film of 0.008-inch minimum thickness.
- D. Color: Black or Natural.

#### 2.07 SPECIALTY VALVES

A. Comply with requirements in Division 22 Section "General-Duty Valves for Plumbing Piping" for general-duty metal valves.

#### 2.08 DIELECTRIC FITTINGS

- A. General Requirements: Assembly of copper alloy and ferrous materials or ferrous material body with separating nonconductive insulating material suitable for system fluid, pressure, and temperature.
- B. Dielectric Unions:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Capitol Manufacturing Company.
    - b. EPCO Sales, Inc.
    - c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
    - d. Zurn Plumbing Products Group; Wilkins Water Control Products.
  - 2. Description:
    - a. Pressure Rating: 150 psig at 180 deg F.
    - b. End Connections: Solder-joint copper alloy and threaded ferrous.
- C. Dielectric Flanges:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Capitol Manufacturing Company.
    - b. EPCO Sales, Inc.

- c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
- 2. Description:
  - a. Factory-fabricated, bolted, companion-flange assembly.
  - b. Pressure Rating: 150 psig.
  - c. End Connections: Solder-joint copper alloy and threaded ferrous; threaded solderjoint copper alloy and threaded ferrous.
- D. Dielectric-Flange Kits:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Advance Products & Systems, Inc.
    - b. Calpico, Inc.
    - c. Pipeline Seal and Insulator, Inc.
  - 2. Description:
    - a. Nonconducting materials for field assembly of companion flanges.
    - b. Pressure Rating: 150 psig.
    - c. Gasket: Neoprene or phenolic.
    - d. Bolt Sleeves: Phenolic or polyethylene.
    - e. Washers: Phenolic with steel backing washers.
- E. Dielectric Couplings:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Calpico, Inc.
    - b. Lochinvar Corporation.
  - 2. Description:
    - a. Galvanized-steel coupling.
    - b. Pressure Rating: 300 psig at 225 deg F.
    - c. End Connections: Female threaded.
    - d. Lining: Inert and noncorrosive, thermoplastic.
- F. Dielectric Nipples:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Perfection Corporation; a subsidiary of American Meter Company.
    - b. Precision Plumbing Products, Inc.
    - c. Victaulic Company.
  - 2. Description:
    - a. Electroplated steel nipple complying with ASTM F 1545.
    - b. Pressure Rating: 300 psig at 225 deg F.
    - c. End Connections: Male threaded or grooved.
    - d. Lining: Inert and noncorrosive, propylene.

#### 2.09 FLEXIBLE CONNECTORS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Flex-Hose Co., Inc.
  - 2. Hyspan Precision Products, Inc.
  - 3. Mercer Rubber Co.
  - 4. Metraflex, Inc.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- B. Bronze-Hose Flexible Connectors: Corrugated-bronze tubing with bronze wire-braid covering and ends brazed to inner tubing.
  - 1. Working-Pressure Rating: Minimum 200 psig.
  - 2. End Connections NPS 2 and Smaller: Threaded copper pipe or plain-end copper tube.
  - 3. End Connections NPS 2-1/2 and Larger: Flanged copper alloy.
- C. Stainless-Steel-Hose Flexible Connectors: Corrugated-stainless-steel tubing with stainlesssteel wire-braid covering and ends welded to inner tubing.
  - 1. Working-Pressure Rating: Minimum 200 psig.
  - 2. End Connections NPS 2 and Smaller: Threaded steel-pipe nipple.
  - 3. End Connections NPS 2-1/2 and Larger: Flanged steel nipple.

# 2.10 ESCUTCHEONS

- A. General: Manufactured ceiling, floor, and wall escutcheons and floor plates.
- B. One Piece, Cast Brass: Polished, chrome-plated finish with setscrews.
- C. One Piece, Deep Pattern: Deep-drawn, box-shaped brass with chrome-plated finish.
- D. One Piece, Stamped Steel: Chrome-plated finish with setscrew.
- E. Split Casting, Cast Brass: Polished, chrome-plated finish with concealed hinge and setscrew.
- F. Split Plate, Stamped Steel: Chrome-plated finish with exposed-rivet hinge, setscrew.
- G. One-Piece Floor Plates: Cast-iron flange with holes for fasteners.
- H. Split-Casting Floor Plates: Cast brass with concealed hinge.

# 2.11 SLEEVES

- A. Cast-Iron Wall Pipes: Fabricated of cast iron, and equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop unless otherwise indicated.
- B. Galvanized-Steel-Sheet Sleeves: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.
- C. Molded-PE Sleeves: Reusable, PE, tapered-cup shaped, and smooth outer surface with nailing flange for attaching to wooden forms.
- D. Molded-PVC Sleeves: Permanent, with nailing flange for attaching to wooden forms.
- E. PVC-Pipe Sleeves: ASTM D 1785, Schedule 40.
- F. Galvanized-Steel-Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, zinccoated, with plain ends.
- G. Stack Sleeve Fittings: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring and bolts and nuts for membrane flashing.

# 2.12 SLEEVE SEALS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Advance Products & Systems, Inc.
  - 2. Calpico, Inc.
  - 3. Metraflex, Inc.
  - 4. Pipeline Seal and Insulator, Inc.
- B. Description: Modular sealing element unit, designed for field assembly, used to fill annular space between pipe and sleeve.
  - 1. Sealing Elements: EPDM-rubber interlocking links shaped to fit surface of pipe. Include type and number required for pipe material and size of pipe.
  - 2. Pressure Plates: Carbon steel.
  - 3. Connecting Bolts and Nuts: Carbon steel, with corrosion-resistant coating, of length required to secure pressure plates to sealing elements.

#### 2.13 WALL PENETRATION SYSTEMS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  1 SIGMA
  - 1. SIGMA.
- B. Description: Wall-sleeve assembly, consisting of housing and gland, gaskets, and pipe sleeve.
  - 1. Carrier-Pipe Deflection: Up to 5 percent without leakage.
  - 2. Housing: Ductile-iron casting with hub, waterstop, anchor ring, and locking devices. Include gland, bolts, and nuts.
  - 3. Housing-to-Sleeve Gasket: EPDM rubber.
  - 4. Housing-to-Carrier-Pipe Gasket: AWWA C111, EPDM rubber.
  - 5. Pipe Sleeve: AWWA C151, ductile-iron pipe or ASTM A 53/A 53M, Schedule 40, zinccoated steel pipe.

- 2.14 GROUT
  - A. Standard: ASTM C 1107, Grade B, post-hardening and volume-adjusting, dry, hydrauliccement grout.
  - B. Characteristics: Nonshrink; recommended for interior and exterior applications.
  - C. Design Mix: 5000-psi, 28-day compressive strength.
  - D. Packaging: Premixed and factory packaged.

# **PART 3 EXECUTION**

### 3.01 EARTHWORK

A. Comply with requirements in Division 31 Section "Earth Moving" for excavating, trenching, and backfilling.

#### 3.02 PIPING INSTALLATION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of domestic water piping. Indicated locations and arrangements are used to size pipe and calculate friction loss, expansion, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- B. Install copper tubing under building slab according to CDA's "Copper Tube Handbook."
- C. Install ductile-iron piping under building slab with restrained joints according to AWWA C600 and AWWA M41.
- D. Install underground copper tube in PE encasement according to ASTM A 674 or AWWA C105.
- E. Install shutoff valve, hose-end drain valve, strainer, pressure gage, and test tee with valve, inside the building at each domestic water service entrance. Comply with requirements in Division 22 Section "Meters and Gages for Plumbing Piping" for pressure gages and Division 22 Section "Domestic Water Piping Specialties" for drain valves and strainers.
- F. Install shutoff valve immediately upstream of each dielectric fitting.
- G. Install water-pressure-reducing valves downstream from shutoff valves. Comply with requirements in Division 22 Section "Domestic Water Piping Specialties" for pressure-reducing valves.
- H. Install domestic water piping level without pitch and plumb.
- I. Rough-in domestic water piping for water-meter installation according to utility company's requirements.
- J. Install seismic restraints on piping. Comply with requirements in Division 22 Section "Vibration and Seismic Controls for Plumbing Piping and Equipment" for seismic-restraint devices.
- K. Install piping concealed from view and protected from physical contact by building occupants unless otherwise indicated and except in equipment rooms and service areas.

- L. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- M. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal, and coordinate with other services occupying that space.
- N. Install piping adjacent to equipment and specialties to allow service and maintenance.
- O. Install piping to permit valve servicing.
- P. Install nipples, unions, special fittings, and valves with pressure ratings the same as or higher than system pressure rating used in applications below unless otherwise indicated.
- Q. Install piping free of sags and bends.
- R. Install fittings for changes in direction and branch connections.
- S. Install PEX piping with loop at each change of direction of more than 90 degrees.
- T. Install unions in copper tubing at final connection to each piece of equipment, machine, and specialty.
- U. Install pressure gages on suction and discharge piping from each plumbing pump and packaged booster pump. Comply with requirements in Division 22 Section "Meters and Gages for Plumbing Piping" for pressure gages.
- V. Install thermostats in hot-water circulation piping. Comply with requirements in Division 22 Section "Domestic Water Pumps" for thermostats.
- W. Install thermometers on inlet and outlet piping from each water heater. Comply with requirements in Division 22 Section "Meters and Gages for Plumbing Piping" for thermometers.

### 3.03 JOINT CONSTRUCTION

- A. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- B. Remove scale, slag, dirt, and debris from inside and outside of pipes, tubes, and fittings before assembly.
- C. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged.

- D. Brazed Joints: Join copper tube and fittings according to CDA's "Copper Tube Handbook," "Brazed Joints" Chapter.
- E. Soldered Joints: Apply ASTM B 813, water-flushable flux to end of tube. Join copper tube and fittings according to ASTM B 828 or CDA's "Copper Tube Handbook."
- F. Ductile-Iron-Piping Grooved Joints: Cut groove end of pipe. Assemble coupling with housing, gasket, lubricant, and bolts. Join ductile-iron pipe and grooved-end fittings according to AWWA C606 for ductile-iron-pipe, cut-grooved joints.
- G. Steel-Piping Grooved Joints: Cut or roll groove end of pipe. Assemble coupling with housing, gasket, lubricant, and bolts. Join steel pipe and grooved-end fittings according to AWWA C606 for steel-pipe grooved joints.
- H. Flanged Joints: Select appropriate asbestos-free, nonmetallic gasket material in size, type, and thickness suitable for domestic water service. Join flanges with gasket and bolts according to ASME B31.9.
- I. Plastic Piping Solvent-Cement Joints: Clean and dry joining surfaces. Join pipe and fittings according to the following:
  - 1. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements. Apply primer.
  - 2. CPVC Piping: Join according to ASTM D 2846/D 2846M Appendix.
  - 3. PVC Piping: Join according to ASTM D 2855.
- J. Dissimilar-Material Piping Joints: Make joints using adapters compatible with materials of both piping systems.

#### 3.04 VALVE INSTALLATION

- A. General-Duty Valves: Comply with requirements in Division 22 Section "General-Duty Valves for Plumbing Piping" for valve installations.
- B. Install shutoff valve close to water main on each branch and riser serving plumbing fixtures or equipment, on each water supply to equipment, and on each water supply to plumbing fixtures that do not have supply stops. Use ball or gate valves for piping NPS 2 and smaller. Use butterfly or gate valves for piping NPS 2-1/2 and larger.
- C. Install drain valves for equipment at base of each water riser, at low points in horizontal piping, and where required to drain water piping. Drain valves are specified in Division 22 Section "Domestic Water Piping Specialties."
  - 1. Hose-End Drain Valves: At low points in water mains, risers, and branches.
  - 2. Stop-and-Waste Drain Valves: Instead of hose-end drain valves where indicated.

- D. Install balancing valve in each hot-water circulation return branch and discharge side of each pump and circulator. Set balancing valves partly open to restrict but not stop flow. Use ball valves for piping NPS 2 and smaller and butterfly valves for piping NPS 2-1/2 and larger. Comply with requirements in Division 22 Section "Domestic Water Piping Specialties" for balancing valves.
- E. Install calibrated balancing valves in each hot-water circulation return branch and discharge side of each pump and circulator. Set calibrated balancing valves partly open to restrict but not stop flow. Comply with requirements in Division 22 Section "Domestic Water Piping Specialties" for calibrated balancing valves.

### 3.05 TRANSITION FITTING INSTALLATION

- A. Install transition couplings at joints of dissimilar piping.
- B. Transition Fittings in Underground Domestic Water Piping:
  - 1. NPS 1-1/2 and Smaller: Fitting-type coupling.
  - 2. NPS 2 and Larger: Sleeve-type coupling.
- C. Transition Fittings in Aboveground Domestic Water PipingNPS 2 and Smaller: Plastic-tometal transition fittings or unions.

#### 3.06 DIELECTRIC FITTING INSTALLATION

- A. Install dielectric fittings in piping at connections of dissimilar metal piping and tubing.
- B. Dielectric Fittings for NPS 2 and Smaller: Use dielectric.
- C. Dielectric Fittings for NPS 2-1/2 to NPS 4: Use dielectric.
- D. Dielectric Fittings for NPS 5 and Larger: Use dielectric flange kits.

#### 3.07 FLEXIBLE CONNECTOR INSTALLATION

- A. Install flexible connectors in suction and discharge piping connections to each domestic water pump and in suction and discharge manifold connections to each domestic water booster pump.
- B. Install bronze-hose flexible connectors in copper domestic water tubing.
- C. Install stainless-steel-hose flexible connectors in steel domestic water piping.

### 3.08 HANGER AND SUPPORT INSTALLATION

- A. Comply with requirements in Division 22 Section "Vibration and Seismic Controls for Plumbing Piping and Equipment" for seismic-restraint devices.
- B. Comply with requirements in Division 22 Section "Hangers and Supports for Plumbing Piping and Equipment" for pipe hanger and support products and installation.
  - 1. Vertical Piping: MSS Type 8 or 42, clamps.
  - 2. Individual, Straight, Horizontal Piping Runs:
    - a. 100 Feet and Less: MSS Type 1, adjustable, steel clevis hangers.
    - b. Longer Than 100 Feet: MSS Type 43, adjustable roller hangers.
    - c. Longer Than 100 Feet If Indicated: MSS Type 49, spring cushion rolls.

- 3. Multiple, Straight, Horizontal Piping Runs 100 Feet or Longer: MSS Type 44, pipe rolls. Support pipe rolls on trapeze.
- 4. Base of Vertical Piping: MSS Type 52, spring hangers.
- C. Support vertical piping and tubing at base and at each floor.
- D. Rod diameter may be reduced one size for double-rod hangers, to a minimum of 3/8 inch.
- E. Install hangers for copper tubing with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 3/4 and Smaller: 60 inches with 3/8-inch rod.
  - 2. NPS 1 and NPS 1-1/4: 72 inches with 3/8-inch rod.
  - 3. NPS 1-1/2 and NPS 2: 96 inches with 3/8-inch rod.
  - 4. NPS 2-1/2: 108 inches with 1/2-inch rod.
  - 5. NPS 3 to NPS 5: 10 feet with 1/2-inch rod.
  - 6. NPS 6: 10 feet with 5/8-inch rod.
  - 7. NPS 8: 10 feet with 3/4-inch rod.
- F. Install supports for vertical copper tubing every 10 feet.

# 3.09 CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Install piping adjacent to equipment and machines to allow service and maintenance.
- C. Connect domestic water piping to exterior water-service piping. Use transition fitting to join dissimilar piping materials.
- D. Connect domestic water piping to water-service piping with shutoff valve; extend and connect to the following:
  - 1. Domestic Water Booster Pumps: Cold-water suction and discharge piping.
  - 2. Water Heaters: Cold-water inlet and hot-water outlet piping in sizes indicated, but not smaller than sizes of water heater connections.
  - 3. Plumbing Fixtures: Cold- and hot-water supply piping in sizes indicated, but not smaller than required by plumbing code. Comply with requirements in Division 22 plumbing fixture Sections for connection sizes.
  - 4. Equipment: Cold- and hot-water supply piping as indicated, but not smaller than equipment connections. Provide shutoff valve and union for each connection. Use flanges instead of unions for NPS 2-1/2 and larger.

# 3.10 ESCUTCHEON INSTALLATION

- A. Install escutcheons for penetrations of walls, ceilings, and floors.
- B. Escutcheons for New Piping:
  - 1. Piping with Fitting or Sleeve Protruding from Wall: One piece, deep pattern.
  - 2. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One piece, cast brass with polished chrome-plated finish.
  - 3. Bare Piping at Ceiling Penetrations in Finished Spaces: One piece, cast brass with polished chrome-plated finish.
  - 4. Bare Piping in Unfinished Service Spaces: One piece, cast brass with polished chromeplated finish.
  - 5. Bare Piping in Equipment Rooms: One piece, stamped steel with spring clips.
  - 6. Bare Piping at Floor Penetrations in Equipment Rooms: One-piece floor plate.

### 3.11 SLEEVE INSTALLATION

- A. General Requirements: Install sleeves for pipes and tubes passing through penetrations in floors, partitions, roofs, and walls.
- B. Sleeves are not required for core-drilled holes.
- C. Permanent sleeves are not required for holes formed by removable PE sleeves.
- D. Cut sleeves to length for mounting flush with both surfaces unless otherwise indicated.
- E. Install sleeves in new partitions, slabs, and walls as they are built.
- F. For interior wall penetrations, seal annular space between sleeve and pipe or pipe insulation using joint sealants appropriate for size, depth, and location of joint. Comply with requirements in Division 07 Section "Joint Sealants" for joint sealants.
- G. For exterior wall penetrations above grade, seal annular space between sleeve and pipe using joint sealants appropriate for size, depth, and location of joint. Comply with requirements in Division 07 Section "Joint Sealants" for joint sealants.
- H. For exterior wall penetrations below grade, seal annular space between sleeve and pipe using sleeve seals specified in this Section.
- I. Seal space outside of sleeves in concrete slabs and walls with grout.
- J. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation unless otherwise indicated.
- K. Install sleeve materials according to the following applications:
  - 1. Sleeves for Piping Passing through Concrete Floor Slabs: Steel pipe.
  - 2. Sleeves for Piping Passing through Concrete Floor Slabs of Mechanical Equipment Areas or Other Wet Areas: Steel pipe.
    - a. Extend sleeves 2 inches above finished floor level.
    - b. For pipes penetrating floors with membrane waterproofing, extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified. Secure flashing between clamping flanges. Install section of cast-iron soil pipe to extend sleeve to 2 inches above finished floor level. Comply with requirements in Division 07 Section "Sheet Metal Flashing and Trim" for flashing.
  - 3. Sleeves for Piping Passing through Gypsum-Board Partitions:
    - a. Steel pipe sleeves for pipes smaller than NPS 6.
    - b. Galvanized-steel sheet sleeves for pipes NPS 6 and larger.
    - c. Exception: Sleeves are not required for water supply tubes and waste pipes for individual plumbing fixtures if escutcheons will cover openings.
  - 4. Sleeves for Piping Passing through Concrete Roof Slabs: Steel pipe.
  - 5. Sleeves for Piping Passing through Exterior Concrete Walls:
    - a. Steel pipe sleeves for pipes smaller than NPS 6.
    - b. Cast-iron wall pipe sleeves for pipes NPS 6 and larger.
    - c. Install sleeves that are large enough to provide 1-inch annular clear space between sleeve and pipe or pipe insulation when sleeve seals are used.
    - d. Do not use sleeves when wall penetration systems are used.
  - 6. Sleeves for Piping Passing through Interior Concrete Walls:
    - a. Steel pipe sleeves for pipes smaller than NPS 6.
    - b. Galvanized-steel sheet sleeves for pipes NPS 6 and larger.

L. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Comply with requirements in Division 07 Section "Penetration Firestopping" for firestop materials and installations.

### 3.12 SLEEVE SEAL INSTALLATION

- A. Install sleeve seals in sleeves in exterior concrete walls at water-service piping entries into building.
- B. Select type and number of sealing elements required for pipe material and size. Position pipe in center of sleeve. Assemble sleeve seal components and install in annular space between pipe and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.

# 3.13 WALL PENETRATION SYSTEM INSTALLATION

- A. Install wall penetration systems in new, exterior concrete walls.
- B. Assemble wall penetration system components with sleeve pipe. Install so that end of sleeve pipe and face of housing are flush with wall. Adjust locking devices to secure sleeve pipe in housing.

### 3.14 IDENTIFICATION

- A. Identify system components. Comply with requirements in Division 22 Section "Identification for Plumbing Piping and Equipment" for identification materials and installation.
- B. Label pressure piping with system operating pressure.

#### 3.15 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Piping Inspections:
  - 1. Do not enclose, cover, or put piping into operation until it has been inspected and approved by authorities having jurisdiction.
  - During installation, notify authorities having jurisdiction at least one day before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction:
    - a. Roughing-in Inspection: Arrange for inspection of piping before concealing or closing-in after roughing-in and before setting fixtures.
    - b. Final Inspection: Arrange final inspection for authorities having jurisdiction to observe tests specified below and to ensure compliance with requirements.
  - 3. Reinspection: If authorities having jurisdiction find that piping will not pass tests or inspections, make required corrections and arrange for reinspection.
  - 4. Reports: Prepare inspection reports and have them signed by authorities having jurisdiction.
- C. Piping Tests:
  - 1. Fill domestic water piping. Check components to determine that they are not air bound and that piping is full of water.
  - 2. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired. If testing is performed in segments, submit a separate report for each test, complete with diagram of portion of piping tested.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 3. Leave new, altered, extended, or replaced domestic water piping uncovered and unconcealed until it has been tested and approved. Expose work that was covered or concealed before it was tested.
- 4. Cap and subject piping to static water pressure of 50 psig above operating pressure, without exceeding pressure rating of piping system materials. Isolate test source and allow to stand for four hours. Leaks and loss in test pressure constitute defects that must be repaired.
- 5. Repair leaks and defects with new materials and retest piping or portion thereof until satisfactory results are obtained.
- 6. Prepare reports for tests and for corrective action required.
- D. Domestic water piping will be considered defective if it does not pass tests and inspections.
- E. Prepare test and inspection reports.

# 3.16 ADJUSTING

- A. Perform the following adjustments before operation:
  - 1. Close drain valves, hydrants, and hose bibbs.
  - 2. Open shutoff valves to fully open position.
  - 3. Open throttling valves to proper setting.
  - 4. Adjust balancing valves in hot-water-circulation return piping to provide adequate flow.
    - a. Manually adjust ball-type balancing valves in hot-water-circulation return piping to provide flow of hot water in each branch.
    - b. Adjust calibrated balancing valves to flows indicated.
  - 5. Remove plugs used during testing of piping and for temporary sealing of piping during installation.
  - 6. Remove and clean strainer screens. Close drain valves and replace drain plugs.
  - 7. Remove filter cartridges from housings and verify that cartridges are as specified for application where used and are clean and ready for use.
  - 8. Check plumbing specialties and verify proper settings, adjustments, and operation.

# 3.17 CLEANING

- A. Clean and disinfect potable and non-potable domestic water piping as follows:
  - 1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.
  - Use purging and disinfecting procedures prescribed by authorities having jurisdiction; if methods are not prescribed, use procedures described in either AWWA C651 or AWWA C652 or follow procedures described below:
    - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
    - b. Fill and isolate system according to either of the following:
      - 1) Fill system or part thereof with water/chlorine solution with at least 50 ppm of chlorine. Isolate with valves and allow to stand for 24 hours.
      - 2) Fill system or part thereof with water/chlorine solution with at least 200 ppm of chlorine. Isolate and allow to stand for three hours.
    - c. Flush system with clean, potable water until no chlorine is in water coming from system after the standing time.
    - d. Submit water samples in sterile bottles to authorities having jurisdiction. Repeat procedures if biological examination shows contamination.
- B. Clean non-potable domestic water piping as follows:
  - 1. Purge new piping and parts of existing piping that have been altered, extended, or repaired before using.

- 2. Use purging procedures prescribed by authorities having jurisdiction or; if methods are not prescribed, follow procedures described below:
  - a. Flush piping system with clean, potable water until dirty water does not appear at outlets.
  - b. Submit water samples in sterile bottles to authorities having jurisdiction. Repeat procedures if biological examination shows contamination.
- C. Prepare and submit reports of purging and disinfecting activities.
- D. Clean interior of domestic water piping system. Remove dirt and debris as work progresses.

# 3.18 PIPING SCHEDULE

- A. Transition and special fittings with pressure ratings at least equal to piping rating may be used in applications below unless otherwise indicated.
- B. Flanges and unions may be used for aboveground piping joints unless otherwise indicated.
- C. Fitting Option: Extruded-tee connections and brazed joints may be used on aboveground copper tubing.
- D. Under-building-slab, domestic water, building service piping, NPS 3 and smaller, shall be one of the following:
  - 1. Soft copper tube, ASTM B 88, Type K; wrought-copper solder-joint fittings; and brazed joints.
- E. Under-building-slab, domestic water, building-service piping, NPS 4 to NPS 8 and larger, shall be one of the following:
  - 1. Soft copper tube, ASTM B 88, Type K; wrought-copper solder-joint fittings; and brazed joints.
  - 2. Mechanical-joint, ductile-iron pipe; standard- or compact- pattern mechanical-joint fittings; and mechanical joints.
  - 3. Push-on-joint, ductile-iron pipe; standard- or compact- pattern push-on-joint fittings; and gasketed joints.
  - 4. Plain-end, ductile-iron pipe; grooved-joint, ductile-iron-pipe appurtenances; and grooved joints.
- F. Under-building-slab, domestic water piping, NPS 2 and smaller, shall be one of the following:
  - 1. Hard copper tube, ASTM B 88, Type L; wrought-copper solder-joint fittings; and brazed joints.
- G. Aboveground domestic water piping, NPS 2 and smaller, shall be one of the following:
  - 1. Galvanized-steel pipe and nipples; galvanized, gray-iron threaded fittings; and threaded joints.
  - 2. Hard copper tube, ASTM B 88, Type L; copper solder-joint fittings; and brazed joints.
  - 3. Hard copper tube, ASTM B 88, Type L; copper pressure-seal-joint fittings; and pressuresealed joints.
  - 4. Hard copper tube, ASTM B 88, Type L; copper push-on-joint fittings; and push-on joints.

# 3.19 VALVE SCHEDULE

- A. Drawings indicate valve types to be used. Where specific valve types are not indicated, the following requirements apply:
  - 1. Shutoff Duty: Use ball or gate valves for piping NPS 2 and smaller. Use butterfly, ball, or gate valves with flanged ends for piping NPS 2-1/2 and larger.

- 2. Throttling Duty: Use ball or globe valves for piping NPS 2 and smaller. Use butterfly or ball valves with flanged ends for piping NPS 2-1/2 and larger.
- Hot-Water Circulation Piping, Balancing Duty: Calibrated balancing valves.
- 4. Drain Duty: Hose-end drain valves.
- B. Use check valves to maintain correct direction of domestic water flow to and from equipment.
- C. Iron grooved-end valves may be used with grooved-end piping.

# END OF SECTION
# SECTION 22 11 19

# DOMESTIC WATER PIPING SPECIALTIES

### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following domestic water piping specialties:
  - 1. Vacuum breakers.
  - 2. Balancing valves.
  - 3. Temperature-activated water mixing valves.
  - 4. Strainers.
  - 5. Outlet boxes.
  - 6. Hose stations.
  - 7. Hose bibbs.
  - 8. Wall hydrants.
  - 9. Drain valves.
  - 10. Water hammer arresters.
  - 11. Air vents.
  - 12. Trap-seal primer valves.
  - 13. Trap-seal primer systems.
- B. Related Sections include the following:
  - 1. Division 22 Section "Domestic Water Piping" for water meters.
  - 2. Division 22 Section "Healthcare Plumbing Fixtures" for thermostatic mixing valves for sitz baths, thermostatic mixing-valve assemblies for hydrotherapy equipment, and outlet boxes for dialysis equipment.

### 1.03 PERFORMANCE REQUIREMENTS

A. Minimum Working Pressure for Domestic Water Piping Specialties: 125 psig, unless otherwise indicated.

#### 1.04 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: Diagram power, signal, and control wiring.
- C. Field quality-control test reports.
- D. Operation and Maintenance Data: For domestic water piping specialties to include in emergency, operation, and maintenance manuals.

### 1.05 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. NSF Compliance:
  - 1. Comply with NSF 14, "Plastics Piping Components and Related Materials," for plastic domestic water piping components.
  - 2. Comply with NSF 61, "Drinking Water System Components Health Effects; Sections 1 through 9."

# PART 2 PRODUCTS

- 2.01 VACUUM BREAKERS
  - A. Pipe-Applied, Atmospheric-Type Vacuum Breakers:
    - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - a. Conbraco Industries, Inc.
      - b. FEBCO; SPX Valves & Controls.
      - c. Watts Industries, Inc.; Water Products Div.
      - d. Zurn Plumbing Products Group; Wilkins Div.
    - 3. Standard: ASSE 1001.
    - 4. Size: NPS 1/4 to NPS 3, as required to match connected piping.
    - 5. Body: Bronze.
    - 6. Inlet and Outlet Connections: Threaded.
    - 7. Finish: Chrome plated.
  - B. Hose-Connection Vacuum Breakers:
    - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - a. Arrowhead Brass Products, Inc.
      - b. Cash Acme.
      - c. Conbraco Industries, Inc.
      - d. Legend Valve.
      - e. MIFAB, Inc.
      - f. Prier Products, Inc.
      - g. Watts Industries, Inc.; Water Products Div.
      - h. Woodford Manufacturing Company.
      - i. Zurn Plumbing Products Group; Light Commercial Operation.
      - j. Zurn Plumbing Products Group; Wilkins Div.
    - 3. Standard: ASSE 1011.
    - 4. Body: Bronze, nonremovable, with manual drain.
    - 5. Outlet Connection: Garden-hose threaded complying with ASME B1.20.7.
    - 6. Finish: Chrome or nickel plated.
  - C. Pressure Vacuum Breakers:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Flomatic Corporation.
  - b. Watts Industries, Inc.; Water Products Div.
  - c. Zurn Plumbing Products Group; Wilkins Div.
- 4. Standard: ASSE 1020.
- 5. Operation: Continuous-pressure applications.
- 6. Pressure Loss: 5 psig maximum, through middle 1/3 of flow range.
- 7. Size: Varies
- 8. Design Flow Rate: Varies
- 9. Selected Unit Flow Range Limits: Varies
- 10. Pressure Loss at Design Flow Rate:
- 11. Accessories:
  - a. Valves: Ball type, on inlet and outlet.
- D. Laboratory-Faucet Vacuum Breakers:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Conbraco Industries, Inc.
    - b. Watts Industries, Inc.; Water Products Div.
    - c. Woodford Manufacturing Company.
    - d. Zurn Plumbing Products Group; Wilkins Div.
  - 3. Standard: ASSE 1035.
  - 4. Size: NPS 1/4 or NPS 3/8 matching faucet size.
  - 5. Body: Bronze.
  - 6. End Connections: Threaded.
  - 7. Finish: Chrome plated.

# 2.02 BACKFLOW PREVENTERS

- A. Intermediate Atmospheric-Vent Backflow Preventers:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Conbraco Industries, Inc.
    - b. FEBCO; SPX Valves & Controls.
    - c. Legend Valve.
    - d. Watts Industries, Inc.; Water Products Div.
    - e. Zurn Plumbing Products Group; Wilkins Div.
  - 3. Standard: ASSE 1012.
  - 4. Operation: Continuous-pressure applications.
  - 5. Size: NPS 3/4.
  - 6. Body: Bronze.
  - 7. End Connections: Union, solder joint.
  - 8. Finish: Chrome plated.

### 2.03 BALANCING VALVES

- A. Copper-Alloy Calibrated Balancing Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Armstrong International, Inc.
    - b. ITT Industries; Bell & Gossett Div.
    - c. Taco, Inc.
    - d. Watts Industries, Inc.; Water Products Div.
  - 4. Type: Ball valve with two readout ports and memory setting indicator.
  - 5. Body: bronze,
  - 6. Size: Same as connected piping, but not larger than NPS 2.
  - 7. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.
- B. Cast-Iron Calibrated Balancing Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Armstrong International, Inc.
    - b. Flo Fab Inc.
    - c. ITT Industries; Bell & Gossett Div.
    - d. NIBCO INC.
    - e. TAC Americas.
    - f. Watts Industries, Inc.; Water Products Div.
  - 4. Type: Adjustable with Y-pattern globe valve, two readout ports, and memorysetting indicator.
  - 5. Size: Same as connected piping, but not smaller than NPS 2-1/2.
- C. Accessories: Meter hoses, fittings, valves, differential pressure meter, and carrying case.
- D. Memory-Stop Balancing Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Conbraco Industries, Inc.
    - b. Crane Co.; Crane Valve Group; Stockham Div.
    - c. Milwaukee Valve Company.
    - d. NIBCO INC.
    - e. Red-White Valve Corp.
  - 3. Standard: MSS SP-110 for two-piece, copper-alloy ball valves.
  - 4. Pressure Rating: 400-psig minimum CWP.
  - 5. Size: NPS 2 or smaller.
  - 6. Body: Copper alloy.

- 7. Port: Standard or full port.
- 8. Ball: Chrome-plated brass.
- 9. Seats and Seals: Replaceable.
- 10. End Connections: Solder joint or threaded.
- 11. Handle: Vinyl-covered steel with memory-setting device.

### 2.04 TEMPERATURE-ACTUATED WATER MIXING VALVES

- A. Water-Temperature Limiting Devices:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Armstrong International, Inc.
    - b. Leonard Valve Company.
    - c. Symmons Industries, Inc.
    - d. Taco, Inc.
    - e. Watts Industries, Inc.; Water Products Div.
    - f. Zurn Plumbing Products Group; Wilkins Div.
  - 4. Standard: ASSE 1017.
  - 5. Pressure Rating: 125 psig.
  - 6. Type: Thermostatically controlled water mixing valve.
  - 7. Material: Bronze body with corrosion-resistant interior components.
  - 8. Connections: Threaded union inlets and outlet.
  - 9. Accessories: Check stops on hot- and cold-water supplies, and adjustable, temperaturecontrol handle.
  - 10. Valve Finish: Chrome plated.

#### 2.05 STRAINERS FOR DOMESTIC WATER PIPING

- A. Y-Pattern Strainers:
  - 1. Pressure Rating: 125 psig minimum, unless otherwise indicated.
  - 2. Body: Bronze for NPS 2 and smaller; cast iron with interior lining complying with AWWA C550 or FDA-approved, epoxy coating and for NPS 2-1/2 and larger.
  - 3. End Connections: Threaded for NPS 2 and smaller;flanged for NPS 2-1/2 and larger.
  - 4. Screen: Stainless steel with round perforations, unless otherwise indicated.
  - 5. Perforation Size:
    - a. StrainersNPS 2 and Smaller: 0.020 inch.
    - b. Strainers NPS 2-1/2 to NPS 4: 0.045 inch.
    - c. Strainers NPS 5 and Larger:
  - 6. Drain: Factory-installed, hose-end drain valve.

# 2.06 OUTLET BOXES

- A. Clothes Washer Outlet Boxes:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Acorn Engineering Company.
  - b. Guy Gray Manufacturing Co., Inc.
  - c. IPS Corporation.
  - d. LSP Products Group, Inc.
  - e. Oatey.
  - f. Plastic Oddities; a division of Diverse Corporate Technologies.
  - g. Symmons Industries, Inc.
  - h. Watts Industries, Inc.; Water Products Div.
  - i. Whitehall Manufacturing; a div. of Acorn Engineering Company.
  - j. Zurn Plumbing Products Group; Light Commercial Operation.
- 3. Mounting: Recessed.
- 4. Material and Finish: Enameled-steel or epoxy-painted-steel box and faceplate.
- 5. Faucet: Combination, valved fitting or separate hot- and cold-water, valved fittings complying with ASME A112.18.1. Include garden-hose thread complying with ASME B1.20.7 on outlets.
- 6. Supply Shutoff Fittings: NPS 1/2 gate, globe, or ball valves and NPS 1/2 copper, water tubing.
- 7. Drain: NPS 1-1/2 standpipe and P-trap for direct waste connection to drainage piping.
- 8. Inlet Hoses: Two 60-inch-long, rubber household clothes washer inlet hoses with female, garden-hose-thread couplings. Include rubber washers.
- 9. Drain Hose: One 48-inch-long, rubber household clothes washer drain hose with hooked end.

### 2.07 HOSE STATIONS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. ARCHON Industries, Inc.
  - 2. Armstrong International, Inc.
  - 3. DynaFluid Ltd.
  - 4. Leonard Valve Company.
- C. Single-Temperature-Water Hose Stations:
  - 1. Standard: ASME A112.18.1.
  - 2. Cabinet: Stainless-steel enclosure with exposed valve handle, hose connection, and hose rack. Include thermometer in front.
  - 3. Hose-Rack Material: Stainless steel.
  - 4. Body Material: Bronze.
  - 5. Body Finish: Rough bronze.
  - 6. Mounting:
  - 7. Supply Fitting: NPS 1/2 gate, globe, or ball valve and check valve and NPS 1/2 copper, water tubing. Omit check valve if check stop is included with fitting.
  - 8. Hose: Manufacturer's standard, for service fluid, temperature, and pressure; 25 feet long.
  - 9. Nozzle: With hand squeeze on-off control.
  - 10. Vacuum Breaker: Integral or factory-installed, nonremovable, manual-drain-type, hose-connection vacuum breaker complying with ASSE 1011 or backflow

preventer complying with ASSE 1052; and garden-hose thread complying with ASME B1.20.7 on outlet.

# 2.08 HOSE BIBBS

- A. Hose Bibbs:
  - 1. Standard: ASME A112.18.1 for sediment faucets.
  - 2. Body Material: Bronze.
  - 3. Seat: Bronze, replaceable.
  - 4. Supply Connections: NPS 1/2 or NPS 3/4 threaded or solder-joint inlet.
  - 5. Outlet Connection: Garden-hose thread complying with ASMÉ B1.20.7.
  - 6. Pressure Rating: 125 psig.
  - 7. Vacuum Breaker: Integral or field-installation, nonremovable, drainable, hoseconnection vacuum breaker complying with ASSE 1011.
  - 8. Finish for Equipment Rooms: Rough bronze, or chrome or nickel plated.
  - 9. Finish for Service Areas: Chrome or nickel plated.
  - 10. Finish for Finished Rooms: Chrome or nickel plated.
  - 11. Operation for Equipment Rooms: Wheel handle or operating key.
  - 12. Operation for Service Areas: Operating key.
  - 13. Operation for Finished Rooms: Wheel handle.
  - 14. Include operating key with each operating-key hose bibb.
  - 15. Include integral wall flange with each chrome- or nickel-plated hose bibb.

#### 2.09 WALL HYDRANTS

3.

- A. Nonfreeze Wall Hydrants:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Josam Company.
    - b. MIFAB, Inc.
    - c. Prier Products, Inc.
    - d. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - e. Tyler Pipe; Wade Div.
    - f. Watts Drainage Products Inc.
    - g. Woodford Manufacturing Company.
    - h. Zurn Plumbing Products Group; Light Commercial Operation.
    - i. Zurn Plumbing Products Group; Specification Drainage Operation.
    - Standard: ASME A112.21.3M for concealed-outlet, self-draining wall hydrants.
  - 4. Pressure Rating: 125 psig.
  - 5. Operation: Loose key.
  - 6. Casing and Operating Rod: Of length required to match wall thickness. Include wall clamp.
  - 7. Inlet: NPS 3/4 or NPS 1.
  - 8. Outlet: Concealed, with integral vacuum breaker and garden-hose thread complying with ASME B1.20.7.
  - 9. Box: Deep, flush mounting with cover.
  - 10. Box and Cover Finish: Polished nickel bronze.
  - 11. Outlet: Exposed, with integral vacuum breaker and garden-hose thread complying with ASME B1.20.7.
  - 12. Nozzle and Wall-Plate Finish: Polished nickel bronze.
  - 13. Operating Keys(s): One with each wall hydrant.

- B. Vacuum Breaker Wall Hydrants:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Arrowhead Brass Products, Inc.
    - b. Mansfield Plumbing Products LLC.
    - c. McDonald, A. Y. Mfg. Co.
    - d. Prier Products, Inc.
    - e. Smith, Jay. R. Mfg. Co.; Division of Smith Industries, Inc.
    - f. Watts Industries, Inc.; Water Products Div.
    - g. Woodford Manufacturing Company.
    - h. Zurn Plumbing Products Group; Light Commercial Operation.
  - 3. Standard: ASSE 1019, Type A or Type B.
  - 4. Type: Freeze-resistant, automatic draining with integral air-inlet valve.
  - 5. Classification: Type A, for automatic draining with hose removed or Type B, for automatic draining with hose removed or with hose attached and nozzle closed.
  - 6. Pressure Rating: 125 psig.
  - 7. Operation: Loose key.
  - 8. Casing and Operating Rod: Of length required to match wall thickness. Include wall clamp.
  - 9. Inlet: NPS 1/2 or NPS 3/4.
  - 10. Outlet: Exposed with garden-hose thread complying with ASME B1.20.7.

# 2.10 DRAIN VALVES

- A. Ball-Valve-Type, Hose-End Drain Valves:
  - 1. Standard: MSS SP-110 for standard-port, two-piece ball valves.
  - 2. Pressure Rating: 400-psig minimum CWP.
  - 3. Size: NPS 3/4.
  - 4. Body: Copper alloy.
  - 5. Ball: Chrome-plated brass.
  - 6. Seats and Seals: Replaceable.
  - 7. Handle: Vinyl-covered steel.
  - 8. Inlet: Threaded or solder joint.
  - 9. Outlet: Threaded, short nipple with garden-hose thread complying with ASME B1.20.7 and cap with brass chain.
- B. Gate-Valve-Type, Hose-End Drain Valves:
  - 1. Standard: MSS SP-80 for gate valves.
  - 2. Pressure Rating: Class 125.
  - 3. Size: NPS 3/4.
  - 4. Body: ASTM B 62 bronze.
  - 5. Inlet: NPS 3/4 threaded or solder joint.
  - 6. Outlet: Garden-hose thread complying with ASME B1.20.7 and cap with brass chain.
- C. Stop-and-Waste Drain Valves:
  - 1. Standard: MSS SP-110 for ball valves or MSS SP-80 for gate valves.
  - 2. Pressure Rating: 200-psig minimum CWP or Class 125.
  - 3. Size: NPS 3/4.
  - 4. Body: Copper alloy or ASTM B 62 bronze.
  - 5. Drain: NPS 1/8 side outlet with cap.

# 2.11 WATER HAMMER ARRESTERS

- A. Water Hammer Arresters:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. AMTROL, Inc.
    - b. Josam Company.
    - c. MIFAB, Inc.
    - d. PPP Inc.
    - e. Sioux Chief Manufacturing Company, Inc.
    - f. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - g. Tyler Pipe; Wade Div.
    - h. Watts Drainage Products Inc.
    - i. Zurn Plumbing Products Group; Specification Drainage Operation.
  - 3. Standard: ASSE 1010 or PDI-WH 201.
  - 4. Type: Metal bellows.
  - 5. Size: ASSE 1010, Sizes AA and A through F or PDI-WH 201, Sizes A through F.

#### 2.12 AIR VENTS

- A. Bolted-Construction Automatic Air Vents:
  - 1. Body: Bronze.
  - 2. Pressure Rating: 125-psig minimum pressure rating at 140 deg F.
  - 3. Float: Replaceable, corrosion-resistant metal.
  - 4. Mechanism and Seat: Stainless steel.
  - 5. Size: NPS 1/2 minimum inlet.
  - 6. Inlet and Vent Outlet End Connections: Threaded.
- B. Welded-Construction Automatic Air Vents:
  - 1. Body: Stainless steel.
  - 2. Pressure Rating: 150-psig minimum pressure rating.
  - 3. Float: Replaceable, corrosion-resistant metal.
  - 4. Mechanism and Seat: Stainless steel.
  - 5. Size: NPS 3/8 minimum inlet.
  - 6. Inlet and Vent Outlet End Connections: Threaded.

# 2.13 TRAP-SEAL PRIMER VALVES

- A. Supply-Type, Trap-Seal Primer Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. MIFAB, Inc.
    - b. PPP Inc.
    - c. Sioux Chief Manufacturing Company, Inc.
    - d. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - e. Watts Industries, Inc.; Water Products Div.
  - 3. Standard: ASSE 1018.
  - 4. Pressure Rating: 125 psig minimum.
  - 5. Body: Bronze.

- 6. Inlet and Outlet Connections: NPS 1/2 threaded, union, or solder joint.
- 7. Gravity Drain Outlet Connection: NPS 1/2 threaded or solder joint.
- 8. Finish: Chrome plated, or rough bronze for units used with pipe or tube that is not chrome finished.
- B. Drainage-Type, Trap-Seal Primer Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - 3. Standard: ASSE 1044, lavatory P-trap with NPS 3/8 minimum, trap makeup connection.
  - 4. Size: NPS 1-1/4 minimum.
  - 5. Material: Chrome-plated, cast brass.

# 2.14 TRAP-SEAL PRIMER SYSTEMS

- A. Trap-Seal Primer Systems:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    a. PPP Inc.
  - 4. Standard: ASSE 1044,
  - 5. Piping: NPS 3/4, ASTM B 88, Type L; copper, water tubing.
  - 6. Cabinet: Recessed-mounting steel box with stainless-steel cover.
  - 7. Electric Controls: 24-hour timer, solenoid valve, and manual switch for 120-V ac power.
  - 8. Vacuum Breaker: ASSE 1001.
  - 9. Number Outlets: Four.
  - 10. Size Outlets: NPS 1/2.

# PART 3 EXECUTION

# 3.01 INSTALLATION

- A. Refer to Division 22 Section "Common Work Results for Plumbing" for piping joining materials, joint construction, and basic installation requirements.
- B. Install backflow preventers in each water supply to mechanical equipment and systems and to other equipment and water systems that may be sources of contamination. Comply with authorities having jurisdiction.
  - 1. Locate backflow preventers in same room as connected equipment or system.
  - 2. Install drain for backflow preventers with atmospheric-vent drain connection with air-gap fitting, fixed air-gap fitting, or equivalent positive pipe separation of at least two pipe diameters in drain piping and pipe to floor drain. Locate air-gap device attached to or under backflow preventer. Simple air breaks are not acceptable for this application.
  - 3. Do not install bypass piping around backflow preventers.

- C. Install water regulators with inlet and outlet shutoff valves and bypass with memory-stop balancing valve. Install pressure gages on inlet and outlet.
- D. Install water control valves with inlet and outlet shutoff valves and bypass with globe valve. Install pressure gages on inlet and outlet.
- E. Install balancing valves in locations where they can easily be adjusted.
- F. Install temperature-actuated water mixing valves with check stops or shutoff valves on inlets and with shutoff valve on outlet.
  - 1. Install thermometers and water regulators if specified.
  - 2. Install cabinet-type units recessed in or surface mounted on wall as specified.
- G. Install Y-pattern strainers for water on supply side of each water pressure-reducing valve,.
- H. Install outlet boxes recessed in wall. Install 2-by-4-inch fire-retardant-treated-wood blocking wall reinforcement between studs. Fire-retardant-treated-wood blocking is specified in Division 06 Section "Rough Carpentry."
- I. Install hose stations with check stops or shutoff valves on inlets and with thermometer on outlet.
  - 1. Install shutoff valve on outlet if specified.
  - Install cabinet-type units received in or surface mounted on wall as specified. Install 2-by-4-inch fire-retardant-treated-wood blocking wall reinforcement between studs. Fire-retardant-treated-wood blocking is specified in Division 06 Section "Rough Carpentry."
- J. Install ground hydrants with 1 cu. yd. of crushed gravel around drain hole. Set ground hydrants with box flush with grade.
- K. Install draining-type post hydrants with 1 cu. yd. of crushed gravel around drain hole. Set post hydrants in concrete paving or in 1 cu. ft. of concrete block at grade.
- L. Install nonfreeze, nondraining-type post hydrants set in concrete or pavement.
- M. Install freeze-resistant yard hydrants with riser pipe set in concrete or pavement. Do not encase canister in concrete.
- N. Install water hammer arresters in water piping according to PDI-WH 201.
- O. Install air vents at high points of water piping. Install drain piping and discharge onto floor drain.
- P. Install supply-type, trap-seal primer valves with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust valve for proper flow.
- Q. Install drainage-type, trap-seal primer valves as lavatory trap with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting.
- R. Install trap-seal primer systems with outlet piping pitched down toward drain trap a minimum of 1 percent, and connect to floor-drain body, trap, or inlet fitting. Adjust system for proper flow.

#### 3.02 CONNECTIONS

- A. Piping installation requirements are specified in other Division 22 Sections. Drawings indicate general arrangement of piping and specialties.
- B. Ground equipment according to Division 26 Section "Grounding and Bonding for Electrical Systems."
- C. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

### 3.03 LABELING AND IDENTIFYING

- A. Equipment Nameplates and Signs: Install engraved plastic-laminate equipment nameplate or sign on or near each of the following:
  - 1. Pressure vacuum breakers.
  - 2. Intermediate atmospheric-vent backflow preventers.
  - 3. Reduced-pressure-principle backflow preventers.
  - 4. Double-check backflow-prevention assemblies.
  - 5. Carbonated-beverage-machine backflow preventers.
  - 6. Dual-check-valve backflow preventers.
  - 7. Reduced-pressure-detector, fire-protection backflow-preventer assemblies.
  - 8. Double-check, detector-assembly backflow preventers.
  - 9. Water pressure-reducing valves.
  - 10. Calibrated balancing valves.
  - 11. Primary, thermostatic, water mixing valves.
  - 12. Manifold, thermostatic, water-mixing-valve assemblies.
  - 13. Photographic-process, thermostatic, water-mixing-valve assemblies.
  - 14. Primary water tempering valves.
  - 15. Outlet boxes.
  - 16. Hose stations.
  - 17. Supply-type, trap-seal primer valves.
  - 18. Trap-seal primer systems.
- B. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Division 22 Section "Identification for Plumbing Piping and Equipment."

# 3.04 FIELD QUALITY CONTROL

- A. Perform the following tests and prepare test reports:
  - 1. Test each pressure vacuum breaker reduced-pressure-principle backflow preventer double-check backflow-prevention assembly and double-check, detector-assembly backflow preventer according to authorities having jurisdiction and the device's reference standard.
- B. Remove and replace malfunctioning domestic water piping specialties and retest as specified above.

#### 3.05 ADJUSTING

- A. Set field-adjustable pressure set points of water pressure-reducing valves.
- B. Set field-adjustable flow set points of balancing valves.

C. Set field-adjustable temperature set points of temperature-actuated water mixing valves.

END OF SECTION

# SECTION 22 13 16

# SANITARY WASTE AND VENT PIPING

### PART 1 - GENERAL

- 1.01 RELATED DOCUMENTS
  - A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following for soil, waste, and vent piping inside the building:
  - 1. Pipe, tube, and fittings.
  - 2. Special pipe fittings.
  - 3. Encasement for underground metal piping.
- B. Related Sections include the following:
  - 1. Division 22 Section "Sanitary Sewerage Pumps."
  - 2. Division 22 Section "Chemical Waste-Systems for Laboratory and Healthcare Facilities" for chemical-waste and vent piping systems.

#### 1.03 DEFINITIONS

- A. ABS: Acrylonitrile-butadiene-styrene plastic.
- B. EPDM: Ethylene-propylene-diene terpolymer rubber.
- C. LLDPE: Linear, low-density polyethylene plastic.
- D. NBR: Acrylonitrile-butadiene rubber.
- E. PE: Polyethylene plastic.
- F. PVC: Polyvinyl chloride plastic.
- G. TPE: Thermoplastic elastomer.

#### 1.04 PERFORMANCE REQUIREMENTS

- A. Components and installation shall be capable of withstanding the following minimum working pressure, unless otherwise indicated:
  - 1. Soil, Waste, and Vent Piping: 10-foot head of water.
  - 2. Sanitary Sewer, Force-Main Piping: 50 psig 100 psig.
- B. Seismic Performance: Soil, waste, and vent piping and support and installation shall be capable of withstanding the effects of seismic events determined according to ASCE 7, "Minimum Design Loads for Buildings and Other Structures."

#### 1.05 SUBMITTALS

- A. Product Data: For pipe, tube, fittings, and couplings.
- B. Shop Drawings:
  - 1. Design Calculations: Signed and sealed by a qualified professional engineer for selecting seismic restraints.
  - 2. Sovent Drainage System: Include plans, elevations, sections, and details.
- C. Field quality-control inspection and test reports.
- 1.06 QUALITY ASSURANCE
  - A. Piping materials shall bear label, stamp, or other markings of specified testing agency.
  - B. Comply with NSF 14, "Plastics Piping Systems Components and Related Materials," for plastic piping components. Include marking with "NSF-dwv" for plastic drain, waste, and vent piping; "NSF-drain" for plastic drain piping; "NSF-tubular" for plastic continuous waste piping; and "NSF-sewer" for plastic sewer piping.

### PART 2 - PRODUCTS

### 2.01 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

# 2.02 PIPING MATERIALS

- A. Refer to Part 3 "Piping Applications" Article for applications of pipe, tube, fitting, and joining materials.
- 2.03 HUB-AND-SPIGOT, CAST-IRON SOIL PIPE AND FITTINGS
  - A. Pipe and Fittings: ASTM A 74, Service and Extra-Heavy class(es).
  - B. Gaskets: ASTM C 564, rubber.
  - C. Calking Materials: ASTM B 29, pure lead and oakum or hemp fiber.
- 2.04 HUBLESS CAST-IRON SOIL PIPE AND FITTINGS
  - A. Pipe and Fittings: ASTM A 888 or CISPI 301.
  - B. Sovent Stack Fittings: ASME B16.45 or ASSE 1043, hubless, cast-iron aerator and deaerator drainage fittings.

- C. Shielded Couplings: ASTM C 1277 assembly of metal shield or housing, corrosion-resistant fasteners, and rubber sleeve with integral, center pipe stop.
  - 1. Standard, Shielded, Stainless-Steel Couplings: CISPI 310, with stainless-steel corrugated shield; stainless-steel bands and tightening devices; and ASTM C 564, rubber sleeve.
    - a. Available Manufacturers:
      - 1) ANACO.
      - 2) Fernco, Inc.
      - 3) Ideal Div.; Stant Corp.
      - 4) Mission Rubber Co.
      - 5) Tyler Pipe; Soil Pipe Div.
  - 2. Heavy-Duty, Shielded, Stainless-Steel Couplings: With stainless-steel shield, minimum (4) stainless-steel bands and tightening devices, and ASTM C 564, rubber sleeve.
    - a. Available Manufacturers:
      - 1) ANACO.
      - 2) Clamp-All Corp.
      - 3) Ideal Div.; Stant Corp.
      - 4) Mission Rubber Co.
      - 5) Tyler Pipe; Soil Pipe Div.
  - 3. Heavy-Duty, Shielded, Cast-Iron Couplings: ASTM A 48/A 48M, two-piece, castiron housing; stainless-steel bolts and nuts; and ASTM C 564, rubber sleeve.
    - a. Available Manufacturers:
      - 1) MG Piping Products Co.
- D. Rigid, Unshielded Couplings: ASTM C 1461, sleeve-type, reducing- or transition-type mechanical coupling molded from ASTM C 1440, TPE material with corrosion-resistant-metal tension band and tightening mechanism on each end.
  - 1. Available Manufacturers:
    - a. ANACO.
- 2.05 STEEL PIPE AND FITTINGS
  - A. Steel Pipe: ASTM A 53/A 53M, Type E or S, Grade A or B, Standard Weight or Schedule 40, galvanized. Include ends matching joining method.
  - B. Drainage Fittings: ASME B16.12, galvanized, threaded, cast-iron drainage pattern.
  - C. Pressure Fittings:
    - 1. Steel Pipe Nipples: ASTM A 733, made of ASTM A 53/A 53M or ASTM A 106, Schedule 40, galvanized, seamless steel pipe. Include ends matching joining method.
    - 2. Malleable-Iron Unions: ASME B16.39; Class 150; hexagonal-stock body with balland-socket, metal-to-metal, bronze seating surface; and female threaded ends.
    - 3. Gray-Iron, Threaded Fittings: ASME B16.4, Class 125, galvanized, standard pattern.
    - 4. Cast-Iron Flanges: ASME B16.1, Class 125.
    - 5. Cast-Iron, Flanged Fittings: ASME B16.1, Class 125, galvanized.
  - D. Grooved-Joint Systems:
    - Available Manufacturers:
      - a. Anvil International.
      - b. Star Pipe Products; Star Fittings Div.
      - c. Victaulic Company.
      - d. Ward Manufacturing, Inc.

1.

- 2. Grooved-End, Steel-Piping Fittings: ASTM A 47/A 47M, galvanized, malleableiron casting; ASTM A 106, galvanized-steel pipe; or ASTM A 536, galvanized, ductile-iron casting; with dimensions matching steel pipe.
- 3. Grooved-End, Steel-Piping Couplings: AWWA C606, for steel-pipe dimensions. Include ferrous housing sections, gasket suitable for water, and bolts and nuts.

# 2.06 STAINLESS-STEEL PIPE AND FITTINGS

- A. Pipe and Fittings: ASME A112.3.1, drainage pattern with socket and spigot ends.
- B. Gaskets: Lip seals shaped to fit socket groove, with plastic backup ring.
  - 1. Material: EPDM, unless NBR is indicated.

# 2.07 DUCTILE-IRON PIPE AND FITTINGS

- A. Mechanical-Joint, Ductile-Iron Pipe: AWWA C151, with mechanical-joint bell and plain spigot end, unless grooved or flanged ends are indicated.
  - 1. Mechanical-Joint, Ductile-Iron Fittings: AWWA C110, ductile- or gray-iron standard pattern or AWWA C153, ductile-iron compact pattern.
  - 2. Glands, Gaskets, and Bolts: AWWA C111, ductile- or gray-iron glands, rubber gaskets, and steel bolts.
- B. Push-on-Joint, Ductile-Iron Pipe: AWWA C151, with push-on-joint bell and plain spigot end, unless grooved or flanged ends are indicated.
  - 1. Push-on-Joint, Ductile-Iron Fittings: AWWA C110, ductile- or gray-iron standard pattern or AWWA C153, ductile-iron compact pattern.
  - 2. Gaskets: AWWA C111, rubber.
- C. Grooved-Joint Systems:
  - 1. Available Manufacturers:
    - a. Victaulic Company.
  - 2. Grooved-End, Ductile-Iron Fittings: ASTM A 47/A 47M, malleable-iron castings or ASTM A 536, ductile-iron castings with dimensions matching pipe.
  - 3. Grooved-End, Ductile-Iron-Piping Couplings: AWWA C606, for ductile-iron-pipe dimensions. Include ferrous housing sections, gasket suitable for water, and bolts and nuts.
- D. Flanges: ASME 16.1, Class 125, cast iron.

# 2.08 COPPER TUBE AND FITTINGS

- A. Copper DWV Tube: ASTM B 306, drainage tube, drawn temper.
  - 1. Copper Drainage Fittings: ASME B16.23, cast copper or ASME B16.29, wrought copper, solder-joint fittings.
  - Hard Copper Tube: ASTM B 88, Types L and M, water tube, drawn temper.
    - 1. Copper Pressure Fittings: ASME B16.18, cast-copper-alloy or ASME B16.22, wrought-copper, solder-joint fittings. Furnish wrought-copper fittings if indicated.
    - 2. Copper Flanges: ASME B16.24, Class 150, cast copper with solder-joint end.
    - 3. Copper Unions: MSS SP-123, copper-alloy, hexagonal-stock body with ball-andsocket, metal-to-metal seating surfaces, and solder-joint or threaded ends.
- C. Soft Copper Tube: ASTM B 88, Type L, water tube, annealed temper.
  - 1. Copper Pressure Fittings: ASME B16.18, cast-copper-alloy or ASME B16.22, wrought-copper, solder-joint fittings. Furnish wrought-copper fittings if indicated.

Β.

- 2.09 ENCASEMENT FOR UNDERGROUND METAL PIPING
  - A. Description: ASTM A 674 or AWWA C105, high-density, crosslaminated PE film of 0.004-inch or LLDPE film of 0.008-inch minimum thickness.
  - B. Form: Sheet or tube.
  - C. Color: Black or natural.

### PART 3 - EXECUTION

#### 3.01 EXCAVATION

A. Refer to Division 31 Section "Earth Moving" for excavating, trenching, and backfilling.

### 3.02 PIPING APPLICATIONS

- A. Flanges and unions may be used on aboveground pressure piping, unless otherwise indicated.
- B. Aboveground, soil and waste piping NPS 4 and smaller shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  - 2. Hubless cast-iron soil pipe and fittings; heavy-duty shielded, stainless-steel couplings; and hubless-coupling joints.
  - 3. Steel pipe, drainage fittings, and threaded joints.
  - 4. Stainless-steel pipe and fittings, gaskets, and gasketed joints.
  - 5. Copper DWV tube, copper drainage fittings, and soldered joints.
- C. Aboveground, soil and waste piping NPS 5 and larger shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  - 2. Hubless cast-iron soil pipe and fittings; heavy-duty shielded, stainless-steel couplings; and hubless-coupling joints.
  - 3. Steel pipe, drainage fittings, and threaded joints.
- D. Aboveground, vent piping NPS 4 and smaller shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
  - 2. Hubless cast-iron soil pipe and fittings; standard, shielded, stainless-steel couplings; and hubless-coupling joints.
  - 3. Steel pipe, drainage fittings, and threaded joints.
  - 4. Stainless-steel pipe and fittings gaskets, and gasketed joints.
  - 5. Copper DWV tube, copper drainage fittings, and soldered joints.
    - a. Option for Vent Piping, NPS 2-1/2 and NPS 3-1/2: Hard copper tube, Type M; copper pressure fittings; and soldered joints.
- E. Aboveground, vent piping NPS 5 and larger shall be any of the following:
  - 1. Service class, cast-iron soil pipe and fittings; gaskets; and gasketed joints.
    - 2. Hubless cast-iron soil pipe and fittings; standard, and heavy-duty shielded, stainless-steel couplings; and hubless-coupling joints.
    - 3. Steel pipe, drainage fittings, and threaded joints.
- F. Underground, soil, waste, and vent piping NPS 4 and smaller shall be any of the following:
  - 1. Extra-Heavy Service class, cast-iron soil piping; gaskets; and gasketed joints.
  - 2. Hubless cast-iron soil pipe and fittings; heavy-duty shielded, stainless-steel heavyduty shielded, cast-iron and rigid, unshielded couplings; and hubless-coupling joints.
  - 3. Stainless-steel pipe and fittings, gaskets, and gasketed joints.
- G. Underground, soil and waste piping NPS 5 and larger shall be any of the following:
  - 1. Extra-Heavy Service class, cast-iron soil piping; gaskets; and gasketed joints.

- 2. Hubless cast-iron soil pipe and fittings; heavy-duty shielded, stainless-steel couplings; and hubless-coupling joints.
- H. Aboveground sanitary-sewage force mains NPS 1-1/2 and NPS 2 shall be any of the following:
  - 1. Hard copper tube, Type L Type M; copper pressure fittings; and soldered joints.
  - 2. Steel pipe, pressure fittings, and threaded joints.
- I. Aboveground sanitary-sewage force mains NPS 2-1/2 to NPS 6 shall be any of the following:
  - 1. Hard copper tube, Type L Type M; copper pressure fittings; and soldered joints.
  - 2. Steel pipe, pressure fittings, and threaded joints.
  - 3. Grooved-end steel pipe, grooved-joint system fittings and couplings, and grooved joints.
- J. Underground sanitary-sewage force mains NPS 4 and smaller shall be any of the following:
  - 1. Hard copper tube, Type L; wrought-copper pressure fittings; and soldered joints.
  - 2. Steel pipe, pressure fittings, and threaded joints.
    - a. Include grooved-joint system fittings and couplings and grooved joints where indicated.
  - 3. Mechanical-joint, ductile-iron pipe; mechanical-joint, ductile-iron fittings; glands, gaskets, and bolts; and mechanical joints.
    - a. Include grooved-joint system fittings and couplings and grooved joints where indicated.
  - 4. Push-on-joint, ductile-iron pipe; push-on-joint ductile-iron fittings; gaskets; and gasketed joints.
    - a. Include grooved-joint system fittings and couplings and grooved joints where indicated.
  - 5. Pressure pipe couplings, if dissimilar pipe materials or piping with small difference in OD must be joined.

# 3.03 PIPING INSTALLATION

- A. Sanitary sewer piping outside the building is specified in Division 22 Section "Facility Sanitary Sewers."
- B. Basic piping installation requirements are specified in Division 22 Section "Common Work Results for Plumbing."
- C. Install seismic restraints on piping. Seismic-restraint devices are specified in Division 22 Section "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- D. Install cleanouts at grade and extend to where building sanitary drains connect to building sanitary sewers.
- E. Install cleanout fitting with closure plug inside the building in sanitary force-main piping.
- F. Install underground, steel, force-main piping. Install encasement on piping according to ASTM A 674 or AWWA C105.
- G. Install underground, ductile-iron, force-main piping according to AWWA C600. Install buried piping inside the building between wall and floor penetrations and connection to sanitary sewer piping outside the building with restrained joints. Anchor pipe to wall or floor. Install thrust-block supports at vertical and horizontal offsets.
  - 1. Install encasement on piping according to ASTM A 674 or AWWA C105.

- H. Install underground, copper, force-main tubing according to CDA's "Copper Tube Handbook."
  - 1. Install encasement on piping according to ASTM A 674 or AWWA C105.
- I. Install underground, ductile-iron, special pipe fittings according to AWWA C600.
  - 1. Install encasement on piping according to ASTM A 674 or AWWA C105.
- J. Install cast-iron sleeve with water stop and mechanical sleeve seal at each service pipe penetration through foundation wall. Select number of interlocking rubber links required to make installation watertight. Sleeves and mechanical sleeve seals are specified in Division 22 Section "Common Work Results for Plumbing."
- K. Install wall-penetration fitting at each service pipe penetration through foundation wall. Make installation watertight.
- L. Install cast-iron soil piping according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook," Chapter IV, "Installation of Cast Iron Soil Pipe and Fittings."
  - 1. Install encasement on underground piping according to ASTM A 674 or AWWA C105.
- M. Make changes in direction for soil and waste drainage and vent piping using appropriate branches, bends, and long-sweep bends. Sanitary tees and short-sweep 1/4 bends may be used on vertical stacks if change in direction of flow is from horizontal to vertical. Use long-turn, double Y-branch and 1/8-bend fittings if 2 fixtures are installed back to back or side by side with common drain pipe. Straight tees, elbows, and crosses may be used on vent lines. Do not change direction of flow more than 90 degrees. Use proper size of standard increasers and reducers if pipes of different sizes are connected. Reducing size of drainage piping in direction of flow is prohibited.
- N. Lay buried building drainage piping beginning at low point of each system. Install true to grades and alignment indicated, with unbroken continuity of invert. Place hub ends of piping upstream. Install required gaskets according to manufacturer's written instructions for use of lubricants, cements, and other installation requirements. Maintain swab in piping and pull past each joint as completed.
- O. Install soil and waste drainage and vent piping at the following minimum slopes, unless otherwise indicated:
  - 1. Building Sanitary Drain: 2 percent downward in direction of flow for piping NPS 3 and smaller; 1 percent downward in direction of flow for piping NPS 4 and larger.
  - 2. Horizontal Sanitary Drainage Piping: 2 percent downward in direction of flow.
  - 3. Vent Piping: 1 percent down toward vertical fixture vent or toward vent stack.
- P. Install engineered soil and waste drainage and vent piping systems as follows:
  - 1. Combination Waste and Vent: Comply with standards of authorities having jurisdiction.
  - 2. Sovent Drainage System: Comply with ASSE 1043 and sovent fitting manufacturer's written installation instructions.
  - 3. Reduced-Size Venting: Comply with standards of authorities having jurisdiction.
- Q. Sleeves are not required for cast-iron soil piping passing through concrete slabs-ongrade if slab is without membrane waterproofing.
- R. Install ABS soil and waste drainage and vent piping according to ASTM D 2661.
- S. Install PVC soil and waste drainage and vent piping according to ASTM D 2665.

T. Do not enclose, cover, or put piping into operation until it is inspected and approved by authorities having jurisdiction.

### 3.04 JOINT CONSTRUCTION

- A. Basic piping joint construction requirements are specified in Division 22 Section "Common Work Results for Plumbing."
- B. Join hub-and-spigot, cast-iron soil piping with gasket joints according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for compression joints.
- C. Join hub-and-spigot, cast-iron soil piping with calked joints according to CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for lead and oakum calked joints.
- D. Join hubless cast-iron soil piping according to CISPI 310 and CISPI's "Cast Iron Soil Pipe and Fittings Handbook" for hubless-coupling joints.
- E. Soldered Joints: Use ASTM B 813, water-flushable, lead-free flux; ASTM B 32, lead-free-alloy solder; and ASTM B 828 procedure, unless otherwise indicated.
- F. Grooved Joints: Assemble joint with keyed coupling, gasket, lubricant, and bolts according to coupling and fitting manufacturer's written instructions.
- G. PVC Nonpressure Piping Joints: Join piping according to ASTM D 2665.

# 3.05 VALVE INSTALLATION

- A. General valve installation requirements are specified in Division 22 Section "General-Duty Valves for Plumbing Piping."
- B. Shutoff Valves: Install shutoff valve on each sewage pump discharge.
  - 1. Install gate or full-port ball valve for piping NPS 2 and smaller.
    - 2. Install gate valve for piping NPS 2-1/2 and larger.
- C. Check Valves: Install swing check valve, between pump and shutoff valve, on each sewage pump discharge.
- D. Backwater Valves: Install backwater valves in piping subject to sewage backflow.
  - 1. Horizontal Piping: Horizontal backwater valves. Use normally closed type, unless otherwise indicated.
  - 2. Floor Drains: Drain outlet backwater valves, unless drain has integral backwater valve.
  - 3. Install backwater valves in accessible locations.
  - 4. Backwater valve are specified in Division 22 Section "Sanitary Waste Piping Specialties."

#### 3.06 HANGER AND SUPPORT INSTALLATION

- A. Seismic-restraint devices are specified in Division 22 Section "Vibration and Seismic Controls for Plumbing Piping and Equipment."
- B. Pipe hangers and supports are specified in Division 22 Section "Hangers and Supports for Plumbing Piping and Equipment." Install the following:
  - 1. Vertical Piping: MSS Type 8 or Type 42, clamps.
  - 2. Install individual, straight, horizontal piping runs according to the following:

- a. 100 Feet and Less: MSS Type 1, adjustable, steel clevis hangers.
- b. Longer Than 100 Feet: MSS Type 43, adjustable roller hangers.
- c. Longer Than 100 Feet, if Indicated: MSS Type 49, spring cushion rolls.
- 3. Multiple, Straight, Horizontal Piping Runs 100 Feet or Longer: MSS Type 44, pipe rolls. Support pipe rolls on trapeze.
- 4. Base of Vertical Piping: MSS Type 52, spring hangers.
- C. Install supports according to Division 22 Section "Hangers and Supports for Plumbing Piping and Equipment."
- D. Support vertical piping and tubing at base and at each floor.
- E. Rod diameter may be reduced 1 size for double-rod hangers, with 3/8-inch minimum rods.
- F. Install hangers for cast-iron soil piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1-1/2 and NPS 2: 60 inches with 3/8-inch rod.
  - 2. NPS 3: 60 inches with 1/2-inch rod.
  - 3. NPS 4 and NPS 5: 60 inches with 5/8-inch rod.
  - 4. NPS 6: 60 inches with 3/4-inch rod.
  - 5. NPS 8 to NPS 12: 60 inches with 7/8-inch rod.
- G. Install supports for vertical cast-iron soil piping every 15 feet.
- H. Install hangers for steel piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1-1/4: 84 inches with 3/8-inch rod.
  - 2. NPS 1-1/2: 108 inches with 3/8-inch rod.
  - 3. NPS 2: 10 feet with 3/8-inch rod.
  - 4. NPS 2-1/2: 11 feet with 1/2-inch rod.
  - 5. NPS 3: 12 feet with 1/2-inch rod.
  - 6. NPS 4 and NPS 5: 12 feet with 5/8-inch rod.
  - 7. NPS 6: 12 feet with 3/4-inch rod.
  - 8. NPS 8 to NPS 12: 12 feet with 7/8-inch rod.
- I. Install supports for vertical steel piping every 15 feet.
- J. Install hangers for stainless-steel piping with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 2: 84 inches with 3/8-inch rod.
  - 2. NPS 3: 96 inches with 1/2-inch rod.
  - 3. NPS 4: 108 inches with 1/2-inch rod.
  - 4. NPS 6: 10 feet with 5/8-inch rod.
- K. Install supports for vertical stainless-steel piping every 10 feet.
- L. Install hangers for copper tubing with the following maximum horizontal spacing and minimum rod diameters:
  - 1. NPS 1-1/4: 72 inches with 3/8-inch rod.
  - 2. NPS 1-1/2 and NPS 2: 96 inches with 3/8-inch rod.
  - 3. NPS 2-1/2: 108 inches with 1/2-inch rod.
  - 4. NPS 3 to NPS 5: 10 feet with 1/2-inch rod.
  - 5. NPS 6: 10 feet with 5/8-inch rod.
  - 6. NPS 8: 10 feet with 3/4-inch rod.
- M. Install supports for vertical copper tubing every 10 feet.
- N. Support piping and tubing not listed above according to MSS SP-69 and manufacturer's written instructions.

# 3.07 CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Connect soil and waste piping to exterior sanitary sewerage piping. Use transition fitting to join dissimilar piping materials.
- C. Connect drainage and vent piping to the following:
  - 1. Plumbing Fixtures: Connect drainage piping in sizes indicated, but not smaller than required by plumbing code.
  - 2. Plumbing Fixtures and Equipment: Connect atmospheric vent piping in sizes indicated, but not smaller than required by authorities having jurisdiction.
  - 3. Plumbing Specialties: Connect drainage and vent piping in sizes indicated, but not smaller than required by plumbing code.
  - 4. Equipment: Connect drainage piping as indicated. Provide shutoff valve, if indicated, and union for each connection. Use flanges instead of unions for connections NPS 2-1/2 and larger.
- D. Connect force-main piping to the following:
  - 1. Sanitary Sewer: To exterior force main or sanitary manhole.
  - 2. Sewage Pumps: To sewage pump discharge.

# 3.08 FIELD QUALITY CONTROL

- A. During installation, notify authorities having jurisdiction at least 24 hours before inspection must be made. Perform tests specified below in presence of authorities having jurisdiction.
  - 1. Roughing-in Inspection: Arrange for inspection of piping before concealing or closing-in after roughing-in and before setting fixtures.
  - 2. Final Inspection: Arrange for final inspection by authorities having jurisdiction to observe tests specified below and to ensure compliance with requirements.
- B. Reinspection: If authorities having jurisdiction find that piping will not pass test or inspection, make required corrections and arrange for reinspection.
- C. Reports: Prepare inspection reports and have them signed by authorities having jurisdiction.
- D. Test sanitary drainage and vent piping according to procedures of authorities having jurisdiction or, in absence of published procedures, as follows:
  - 1. Test for leaks and defects in new piping and parts of existing piping that have been altered, extended, or repaired. If testing is performed in segments, submit separate report for each test, complete with diagram of portion of piping tested.
  - 2. Leave uncovered and unconcealed new, altered, extended, or replaced drainage and vent piping until it has been tested and approved. Expose work that was covered or concealed before it was tested.
  - 3. Roughing-in Plumbing Test Procedure: Test drainage and vent piping, except outside leaders, on completion of roughing-in. Close openings in piping system and fill with water to point of overflow, but not less than 10-foot head of water. From 15 minutes before inspection starts to completion of inspection, water level must not drop. Inspect joints for leaks.
  - 4. Finished Plumbing Test Procedure: After plumbing fixtures have been set and traps filled with water, test connections and prove they are gastight and watertight. Plug vent-stack openings on roof and building drains where they leave building. Introduce air into piping system equal to pressure of 1-inch wg. Use U-tube or

manometer inserted in trap of water closet to measure this pressure. Air pressure must remain constant without introducing additional air throughout period of inspection. Inspect plumbing fixture connections for gas and water leaks.

- 5. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.
- 6. Prepare reports for tests and required corrective action.
- E. Test force-main piping according to procedures of authorities having jurisdiction or, in absence of published procedures, as follows:
  - 1. Leave uncovered and unconcealed new, altered, extended, or replaced force-main piping until it has been tested and approved. Expose work that was covered or concealed before it was tested.
  - 2. Cap and subject piping to static-water pressure of 50 psig above operating pressure, without exceeding pressure rating of piping system materials. Isolate test source and allow to stand for four hours. Leaks and loss in test pressure constitute defects that must be repaired.
  - 3. Repair leaks and defects with new materials and retest piping, or portion thereof, until satisfactory results are obtained.
  - 4. Prepare reports for tests and required corrective action.

# 3.09 CLEANING

- A. Clean interior of piping. Remove dirt and debris as work progresses.
- B. Protect drains during remainder of construction period to avoid clogging with dirt and debris and to prevent damage from traffic and construction work.
- C. Place plugs in ends of uncompleted piping at end of day and when work stops.

# END OF SECTION

# SECTION 22 13 19

# SANITARY WASTE PIPING SPECIALTIES

# PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. This Section includes the following sanitary drainage piping specialties:
  - 1. Backwater valves.
  - 2. Cleanouts.
  - 3. Floor drains.
  - 4. Trench drains.
  - 5. Channel drainage systems.
  - 6. Air-admittance valves.
  - 7. Roof flashing assemblies.
  - 8. Through-penetration firestop assemblies.
  - 9. Miscellaneous sanitary drainage piping specialties.
  - 10. Flashing materials.
- B. Related Sections include the following:
  - 1. Division 22 Section "Storm Drainage Piping Specialties" for trench drains for storm water, channel drainage systems for storm water, roof drains, and catch basins.
  - 2. Division 22 Section "Plumbing Fixtures" for hair interceptors.
  - 3. Division 22 Section "Healthcare Plumbing Fixtures" for plaster sink interceptors.

#### 1.03 DEFINITIONS

- A. ABS: Acrylonitrile-butadiene-styrene plastic.
- B. FOG: Fats, oils, and greases.
- C. FRP: Fiberglass-reinforced plastic.
- D. HDPE: High-density polyethylene plastic.
- E. PE: Polyethylene plastic.
- F. PP: Polypropylene plastic.
- G. PVC: Polyvinyl chloride plastic.

# 1.04 SUBMITTALS

- A. Product Data: For each type of product indicated. Include rated capacities, operating characteristics, and accessories for the following:
  - 1. Plumbing Specialties.

- B. Shop Drawings: Show fabrication and installation details for frost-resistant vent terminals.
  - 1. Wiring Diagrams: Power, signal, and control wiring.
- C. Manufacturer Seismic Qualification Certification: Submit certification that Plumbing accessories, and components will withstand seismic forces defined in Division 22 Section "Vibration and Seismic Controls for Plumbing Piping and Equipment." Include the following:
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
    - a. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified."
    - b. The term "withstand" means "the unit will remain in place without separation of any parts from the device when subjected to the seismic forces specified and the unit will be fully operational after the seismic event."
  - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
  - 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- D. Field quality-control test reports.
- E. Operation and Maintenance Data: For drainage piping specialties to include in emergency, operation, and maintenance manuals.

#### 1.05 QUALITY ASSURANCE

- A. Drainage piping specialties shall bear label, stamp, or other markings of specified testing agency.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with NSF 14, "Plastics Piping Components and Related Materials," for plastic sanitary piping specialty components.

#### 1.06 COORDINATION

- A. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified in Division 03.
- B. Coordinate size and location of roof penetrations.

#### PART 2 PRODUCTS

- 2.01 BACKWATER VALVES
  - A. Horizontal, Cast-Iron Backwater Valves:
    - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Josam Company; Josam Div.
  - b. MIFAB, Inc.
  - c. Smith, Jay R. Mfr. Co.; Division of Smith Industries, Inc.
  - d. Tyler Pipe; Wade Div.
  - e. Watts Drainage Products Inc.
  - f. Zurn Plumbing Products Group; Specification Drainage Operation.
- 4. Standard: ASME A112.14.1.
- 5. Size: Same as connected piping.
- 6. Body: Cast iron.
- 7. Cover: Cast iron with bolted or threaded access check valve.
- 8. End Connections: Hubless.
- 9. Type Check Valve: Removable, bronze, swing check, factory assembled or field modified to hang open for airflow unless subject to backflow condition.
- 10. Extension: ASTM A 74, Service class; full-size, cast-iron, soil-pipe extension to field-installed cleanout at floor; replaces backwater valve cover.
- B. Drain-Outlet Backwater Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Josam Company; Josam Div.
    - b. Smith, Jay R. Mfr. Co.; Division of Smith Industries, Inc.
    - c. Watts Drainage Products Inc.
    - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - 3. Size: Same as floor drain outlet.
  - 4. Body: Cast iron or bronze made for vertical installation in bottom outlet of floor drain.
  - 5. Check Valve: Removable ball float.
  - 6. Inlet: Threaded.
  - 7. Outlet: Threaded or spigot.

# 2.02 CLEANOUTS

- A. Exposed Metal Cleanouts:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Josam Company; Josam Div.
    - b. MIFAB, Inc.
    - c. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - d. Tyler Pipe; Wade Div.
    - e. Watts Drainage Products Inc.
    - f. Zurn Plumbing Products Group; Specification Drainage Operation.
    - g. Josam Company; Blucher-Josam Div.
  - 4. Standard: ASME A112.36.2M for cast iron ASME A112.3.1 for stainless steel for cleanout test tee.
  - 5. Size: Same as connected drainage piping

- 6. Body Material: Hubless, cast-iron soil pipe test tee as required to match connected piping.
- 7. Closure: Countersunk, plug.
- 8. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
- 9. Closure: Stainless-steel plug with seal.
- B. Metal Floor Cleanouts:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Josam Company; Josam Div.
    - b. Oatey.
    - c. Sioux Chief Manufacturing Company, Inc.
    - d. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - e. Tyler Pipe; Wade Div.
    - f. Watts Drainage Products Inc.
    - g. Zurn Plumbing Products Group; Light Commercial Operation.
    - h. Zurn Plumbing Products Group; Specification Drainage Operation.
    - i. Josam Company; Josam Div.
    - j. Kusel Equipment Co.
    - k. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - I. Josam Company; Blucher-Josam Div.
  - 4. Standard: ASME A112.36.2M for threaded, adjustable housing cleanout.
  - 5. Size: Same as connected branch.
  - 6. Type: Heavy-duty, adjustable housing.
  - 7. Body or Ferrule: Cast iron.
  - 8. Clamping Device: Required.
  - 9. Outlet Connection: Threaded.
  - 10. Closure: Brass plug with straight threads and gasket.
  - 11. Adjustable Housing Material: Cast iron.
  - 12. Frame and Cover Material and Finish: Nickel-bronze, copper alloy.
  - 13. Frame and Cover Shape: Round.
  - 14. Top Loading Classification: Extra Heavy Duty.
  - 15. Riser: ASTM A 74, Service class, cast-iron drainage pipe fitting and riser to cleanout.
  - 16. Standard: ASME A112.3.1.
  - 17. Size: Same as connected branch.
  - 18. Housing: Stainless steel.
  - 19. Closure: Stainless steel with seal.
  - 20. Riser: Stainless-steel drainage pipe fitting to cleanout.
- C. Cast-Iron Wall Cleanouts:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Josam Company; Josam Div.
    - b. MIFAB, Inc.

- c. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
- d. Tyler Pipe; Wade Div.
- e. Watts Drainage Products Inc.
- f. Zurn Plumbing Products Group; Specification Drainage Operation.
- Standard: ASME A112.36.2M. Include wall access.
- 5. Size: Same as connected drainage piping.
- 6. Body: Hubless, cast-iron soil pipe test tee as required to match connected piping.
- 7. Closure: Countersunk, plug.
- 8. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
- 9. Wall Access: Round, deep, chrome-plated bronze cover plate with screw.
- 10. Wall Access: Round, wall-installation frame and cover.

#### 2.03 FLOOR DRAINS

4.

- A. Cast-Iron Floor Drains:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Commercial Enameling Co.
    - b. Josam Company; Josam Div.
    - c. MIFAB, Inc.
    - d. Prier Products, Inc.
    - e. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - f. Tyler Pipe; Wade Div.
    - g. Watts Drainage Products Inc.
    - h. Zurn Plumbing Products Group; Light Commercial Operation.
    - i. Zurn Plumbing Products Group; Specification Drainage Operation.
  - 4. Standard: ASME A112.6.3.
  - 5. Pattern: Floor drain.
  - 6. Body Material: Gray iron.
  - 7. Seepage Flange: Required.
  - 8. Anchor Flange: Required.
  - 9. Clamping Device: Required.
  - 10. Outlet: Bottom.
  - 11. Coating on Interior and Exposed Exterior Surfaces: Acid-resistant enamel.
  - 12. Sediment Bucket: Not required.
  - 13. Top or Strainer Material: Stainless steel.
  - 14. Top of Body and Strainer Finish: Stainless steel.
  - 15. Top Shape: See Architectual Plan.
  - 16. Dimensions of Top or Strainer:
  - 17. Top Loading Classification: Heavy Duty.
  - 18. Funnel: Not required.
  - 19. Inlet Fitting: Gray iron, with threaded inlet and threaded or spigot outlet, and trapseal primer valve connection.
  - 20. Trap Material: Cast iron.
  - 21. Trap Pattern: Standard P-trap.
  - 22. Trap Features: Trap-seal primer valve drain connection.
- B. Stainless-Steel Floor Drains:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Josam Company; Blucher-Josam Div.
  - b. Josam Company; Josam Div.
  - c. Kusel Equipment Co.
  - d. Scherping Systems, Inc.
  - e. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
  - f. Tyler Pipe; Wade Div.
  - g. Watts Drainage Products Inc.
  - h. Zurn Plumbing Products Group; Specification Drainage Operation.
- 4. Standard: ASME A112.3.1.
- 5. Outlet: Bottom.
- 6. Top or Strainer Material: Stainless steel.
- 7. Top Shape: See Plans.
- 8. Dimensions of Top or Strainer:
- 9. Seepage Flange: Required.
- 10. Anchor Flange: Required.
- 11. Clamping Device: Required.
- 12. Trap-Primer Connection: Required.
- 13. Trap Material: Cast iron.
- 14. Trap Pattern: Standard P-trap.

### 2.04 TRENCH DRAINS

- A. Trench Drains:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Josam Company; Josam Div.
    - b. MIFAB, Inc.
    - c. Smith, Jay R. Mfg. Co.; Division of Smith Industries, Inc.
    - d. Tyler Pipe; Wade Div.
    - e. Watts Drainage Products Inc.
    - f. Zurn Plumbing Products Group; Specification Drainage Operation.
  - 4. Standard: ASME A112.6.3 for trench drains.
  - 5. Material: Ductile or gray iron.
  - 6. Flange: Anchor.
  - 7. Clamping Device: Not required.
  - 8. Outlet: Bottom.
  - 9. Grate Material: Stainless steel.
  - 10. Grate Finish: Not required.
  - 11. Dimensions of Frame and Grate:
  - 12. Top Loading Classification: Heavy Duty.
  - 13. Trap Material: Cast iron.
  - 14. Trap Pattern: Standard P-trap.

### 2.05 AIR-ADMITTANCE VALVES

- A. Fixture Air-Admittance Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Ayrlett, LLC.
    - b. Durgo, Inc.
    - c. Oatey.
    - d. ProSet Systems Inc.
    - e. RectorSeal.
    - f. Studor, Inc.
  - 3. Standard: ASSE 1051, Type A for single fixture or Type B for branch piping.
  - 4. Housing: Plastic.
  - 5. Operation: Mechanical sealing diaphragm.
  - 6. Size: Same as connected fixture or branch vent piping.
- B. Stack Air-Admittance Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Durgo, Inc.
    - b. Oatey.
    - c. Studor, Inc.
  - 3. Standard: ASSE 1050 for vent stacks.
  - 4. Housing: Plastic.
  - 5. Operation: Mechanical sealing diaphragm.
  - 6. Size: Same as connected stack vent or vent stack.
- C. Wall Box:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Durgo, Inc.
    - b. Oatey.
    - c. RectorSeal.
    - d. Studor, Inc.
  - 3. Description: White plastic housing with white plastic grille, made for recessed installation. Include bottom pipe connection and space to contain one air-admittance valve.
  - 4. Size: About 9 inches wide by 8 inches high by 4 inches deep.

# 2.06 ROOF FLASHING ASSEMBLIES

- A. Roof Flashing Assemblies:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:

- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Acorn Engineering Company; Elmdor/Stoneman Div.
  - b. Thaler Metal Industries Ltd.
- B. Description: Manufactured assembly made of 4.0-lb/sq. ft., 0.0625-inch-thick, lead flashing collar and skirt extending at least 6 inches from pipe, with galvanized-steel boot reinforcement and counterflashing fitting.
  - 1. Open-Top Vent Cap: Without cap.
  - 2. Low-Silhouette Vent Cap: With vandal-proof vent cap.
  - 3. Extended Vent Cap: With field-installed, vandal-proof vent cap.

# 2.07 THROUGH-PENETRATION FIRESTOP ASSEMBLIES

- A. Through-Penetration Firestop Assemblies:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. ProSet Systems Inc.
  - 3. Standard: UL 1479 assembly of sleeve and stack fitting with firestopping plug.
  - 4. Size: Same as connected soil, waste, or vent stack.
  - 5. Sleeve: Molded PVC plastic, of length to match slab thickness and with integral nailing flange on one end for installation in cast-in-place concrete slabs.
  - 6. Stack Fitting: ASTM A 48/A 48M, gray-iron, hubless-pattern, wye branch with neoprene O-ring at base and gray-iron plug in thermal-release harness. Include PVC protective cap for plug.
  - 7. Special Coating: Corrosion resistant on interior of fittings.

# 2.08 MISCELLANEOUS SANITARY DRAINAGE PIPING SPECIALTIES

- A. Open Drains:
  - 1. Description: Shop or field fabricate from ASTM A 74, Service class, hub-andspigot, cast-iron, soil-pipe fittings. Include P-trap, hub-and-spigot riser section; and where required, increaser fitting joined with ASTM C 564, rubber gaskets.
  - 2. Size: Same as connected waste piping.
- B. Deep-Seal Traps:
  - 1. Description: Cast-iron or bronze casting, with inlet and outlet matching connected piping and cleanout trap-seal primer valve connection.
  - 2. Size: Same as connected waste piping.
    - a. NPS 2: 4-inch-minimum water seal.
      - b. NPS 2-1/2 and Larger: 5-inch-minimum water seal.
- C. Floor-Drain, Trap-Seal Primer Fittings:
  - 1. Description: Cast iron, with threaded inlet and threaded or spigot outlet, and trapseal primer valve connection.
  - 2. Size: Same as floor drain outlet with NPS 1/2 side inlet.
- D. Air-Gap Fittings:
  - 1. Standard: ASME A112.1.2, for fitting designed to ensure fixed, positive air gap between installed inlet and outlet piping.

- 2. Body: Bronze or cast iron.
- 3. Inlet: Opening in top of body.
- 4. Outlet: Larger than inlet.
- 5. Size: Same as connected waste piping and with inlet large enough for associated indirect waste piping.
- E. Sleeve Flashing Device:
  - 1. Description: Manufactured, cast-iron fitting, with clamping device, that forms sleeve for pipe floor penetrations of floor membrane. Include galvanized-steel pipe extension in top of fitting that will extend 2 inches above finished floor and galvanized-steel pipe extension in bottom of fitting that will extend through floor slab.
  - 2. Size: As required for close fit to riser or stack piping.
- F. Stack Flashing Fittings:
  - 1. Description: Counterflashing-type, cast-iron fitting, with bottom recess for terminating roof membrane, and with threaded or hub top for extending vent pipe.
  - 2. Size: Same as connected stack vent or vent stack.
- G. Vent Caps:
  - 1. Description: Cast-iron body with threaded or hub inlet and vandal-proof design. Include vented hood and setscrews to secure to vent pipe.
  - 2. Size: Same as connected stack vent or vent stack.
- H. Frost-Resistant Vent Terminals:
  - 1. Description: Manufactured or shop-fabricated assembly constructed of copper, lead-coated copper, or galvanized steel.
  - 2. Design: To provide 1-inch enclosed air space between outside of pipe and inside of flashing collar extension, with counterflashing.
- I. Expansion Joints:
  - 1. Standard: ASME A112.21.2M.
  - 2. Body: Cast iron with bronze sleeve, packing, and gland.
  - 3. End Connections: Matching connected piping.
  - 4. Size: Same as connected soil, waste, or vent piping.

#### 2.09 FLASHING MATERIALS

- A. Lead Sheet: ASTM B 749, Type L51121, copper bearing, with the following minimum weights and thicknesses, unless otherwise indicated:
  - 1. General Use: 4.0-lb/sq. ft., 0.0625-inch thickness.
  - 2. Vent Pipe Flashing: 3.0-lb/sq. ft., 0.0469-inch thickness.
  - 3. Burning: 6-lb/sq. ft., 0.0938-inch thickness.
- B. Copper Sheet: ASTM B 152/B 152M, of the following minimum weights and thicknesses, unless otherwise indicated:
  - 1. General Applications: 12 oz./sq. ft..
  - 2. Vent Pipe Flashing: 8 oz./sq. ft..
- C. Zinc-Coated Steel Sheet: ASTM A 653/A 653M, with 0.20 percent copper content and 0.04-inch minimum thickness, unless otherwise indicated. Include G90 hot-dip galvanized, mill-phosphatized finish for painting if indicated.
- D. Elastic Membrane Sheet: ASTM D 4068, flexible, chlorinated polyethylene, 40-mil minimum thickness.

- E. Fasteners: Metal compatible with material and substrate being fastened.
- F. Metal Accessories: Sheet metal strips, clamps, anchoring devices, and similar accessory units required for installation; matching or compatible with material being installed.
- G. Solder: ASTM B 32, lead-free alloy.
- H. Bituminous Coating: SSPC-Paint 12, solvent-type, bituminous mastic.

### PART 3 EXECUTION

#### 3.01 CONCRETE BASES

- A. Anchor plumbing equipments to concrete bases.
  - 1. Install dowel rods to connect concrete base to concrete floor. Unless otherwise indicated, install dowel rods on 19-inch centers around full perimeter of base.
  - 2. For installed equipment, install epoxy-coated anchor bolts that extend through concrete base and anchor into structural concrete floor.
  - 3. Place and secure anchorage devices. Use setting drawings, templates, diagrams, instructions, and directions furnished with items to be imbedded.
  - 4. Install anchor bolts to elevations required for proper attachment to supported equipment.
  - 5. Concrete base construction requirements are specified in Division 22 Section "Common Work Results for Plumbing."
  - 6. Cast-in-place concrete materials and placement requirements are specified in Division 03.

# 3.02 INSTALLATION

- A. Refer to Division 22 Section "Common Work Results for Plumbing" for piping joining materials, joint construction, and basic installation requirements.
- B. Install backwater valves in building drain piping. For interior installation, provide cleanout deck plate flush with floor and centered over backwater valve cover, and of adequate size to remove valve cover for servicing.
- C. Install cleanouts in aboveground piping and building drain piping according to the following, unless otherwise indicated:
  - 1. Size same as drainage piping up to NPS 4. Use NPS 4 for larger drainage piping unless larger cleanout is indicated.
  - 2. Locate at each change in direction of piping greater than 45 degrees.
  - 3. Locate at minimum intervals of 50 feet for piping NPS 4 and smaller and 100 feet for larger piping.
  - 4. Locate at base of each vertical soil and waste stack.
- D. For floor cleanouts for piping below floors, install cleanout deck plates with top flush with finished floor.
- E. For cleanouts located in concealed piping, install cleanout wall access covers, of types indicated, with frame and cover flush with finished wall.
- F. Install floor drains at low points of surface areas to be drained. Set grates of drains flush with finished floor, unless otherwise indicated.
  - 1. Position floor drains for easy access and maintenance.
- 2. Set floor drains below elevation of surrounding finished floor to allow floor drainage. Set with grates depressed according to the following drainage area radii:
  - a. Radius, 30 Inches or Less: Equivalent to 1 percent slope, but not less than 1/4-inch total depression.
  - b. Radius, 30 to 60 Inches: Equivalent to 1 percent slope.
  - c. Radius, 60 Inches or Larger: Equivalent to 1 percent slope, but not greater than 1-inch total depression.
- 3. Install floor-drain flashing collar or flange so no leakage occurs between drain and adjoining flooring. Maintain integrity of waterproof membranes where penetrated.
- 4. Install individual traps for floor drains connected to sanitary building drain, unless otherwise indicated.
- G. Install trench drains at low points of surface areas to be drained. Set grates of drains flush with finished surface, unless otherwise indicated.
- H. Assemble and install ASME A112.3.1, stainless-steel channel drainage systems according to ASME A112.3.1. Install on support devices so that top will be flush with surface.
- I. Assemble non-ASME A112.3.1, stainless-steel channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- J. Assemble FRP channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- K. Assemble plastic channel drainage system components according to manufacturer's written instructions. Install on support devices so that top will be flush with adjacent surface.
- L. Install fixture air-admittance valves on fixture drain piping.
- M. Install stack air-admittance valves at top of stack vent and vent stack piping.
- N. Install air-admittance-valve wall boxes recessed in wall.
- O. Install roof flashing assemblies on sanitary stack vents and vent stacks that extend through roof.
- P. Install flashing fittings on sanitary stack vents and vent stacks that extend through roof.
- Q. Install through-penetration firestop assemblies in plastic conductors and stacks at floor penetrations.
- R. Assemble open drain fittings and install with top of hub 2 inches above floor.
- S. Install deep-seal traps on floor drains and other waste outlets, if indicated.
- T. Install floor-drain, trap-seal primer fittings on inlet to floor drains that require trap-seal primer connection.
  - 1. Exception: Fitting may be omitted if trap has trap-seal primer connection.
  - 2. Size: Same as floor drain inlet.

- U. Install air-gap fittings on draining-type backflow preventers and on indirect-waste piping discharge into sanitary drainage system.
- V. Install sleeve flashing device with each riser and stack passing through floors with waterproof membrane.
- W. Install vent caps on each vent pipe passing through roof.
- X. Install frost-resistant vent terminals on each vent pipe passing through roof. Maintain 1inch clearance between vent pipe and roof substrate.
- Y. Install expansion joints on vertical stacks and conductors. Position expansion joints for easy access and maintenance.
- Z. Install frost-proof vent caps on each vent pipe passing through roof. Maintain 1-inch clearance between vent pipe and roof substrate.
- AA. Assemble components of FOG disposal systems and install on floor. Install trap, vent, fresh-air inlet, and flow-control fitting according to authorities having jurisdiction. Install shelf fastened to reinforcement in wall construction and adjacent to unit, unless otherwise indicated. Install culture bottle, culture metering pump, timer, and control on shelf. Install tubing between culture bottle, metering pump, and chamber.
- BB. Install grease interceptors, including trapping, venting, and flow-control fitting, according to authorities having jurisdiction and with clear space for servicing.
  - 1. Above-Floor Installation: Set unit with bottom resting on floor, unless otherwise indicated.
  - 2. Flush with Floor Installation: Set unit and extension, if required, with cover flush with finished floor.
  - 3. Recessed Floor Installation: Set unit in receiver housing having bottom or cradle supports, with receiver housing cover flush with finished floor.
  - 4. Install cleanout immediately downstream from interceptors not having integral cleanout on outlet.
- CC. Install grease removal devices on floor. Install trap, vent, and flow-control fitting according to authorities having jurisdiction. Install control panel adjacent to unit, unless otherwise indicated.
- DD. Install oil interceptors, including trapping, venting, and flow-control fitting, according to authorities having jurisdiction and with clear space for servicing. Coordinate oil-interceptor storage tank and gravity drain with Division 23 Section "Facility Fuel-Oil Piping."
- EE. Install solids interceptors with cleanout immediately downstream from interceptors that do not have integral cleanout on outlet. Install trap on interceptors that do not have integral trap and are connected to sanitary drainage and vent systems.
- FF. Install wood-blocking reinforcement for wall-mounting-type specialties.
- GG. Install traps on plumbing specialty drain outlets. Omit traps on indirect wastes unless trap is indicated.
- HH. Install escutcheons at wall, floor, and ceiling penetrations in exposed finished locations and within cabinets and millwork. Use deep-pattern escutcheons if required to conceal protruding pipe fittings.

## 3.03 FLASHING INSTALLATION

- A. Fabricate flashing from single piece unless large pans, sumps, or other drainage shapes are required. Join flashing according to the following if required:
  - 1. Lead Sheets: Burn joints of lead sheets 6.0-lb/sq. ft., 0.0938-inch thickness or thicker. Solder joints of lead sheets 4.0-lb/sq. ft., 0.0625-inch thickness or thinner.
  - 2. Copper Sheets: Solder joints of copper sheets.
- B. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
  - 1. Pipe Flashing: Sleeve type, matching pipe size, with minimum length of 10 inches, and skirt or flange extending at least 8 inches around pipe.
  - 2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches around sleeve.
  - 3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches around specialty.
- C. Set flashing on floors and roofs in solid coating of bituminous cement.
- D. Secure flashing into sleeve and specialty clamping ring or device.
- E. Install flashing for piping passing through roofs with counterflashing or commercially made flashing fittings, according to Division 07 Section "Sheet Metal Flashing and Trim."
- F. Extend flashing up vent pipe passing through roofs and turn down into pipe, or secure flashing into cast-iron sleeve having calking recess.
- G. Fabricate and install flashing and pans, sumps, and other drainage shapes.
- 3.04 LABELING AND IDENTIFYING
  - A. Distinguish among multiple units, inform operator of operational requirements, indicate safety and emergency precautions, and warn of hazards and improper operations, in addition to identifying unit. Nameplates and signs are specified in Division 22 Section "Identification for Plumbing Piping and Equipment."

#### 3.05 FIELD QUALITY CONTROL

- A. Tests and Inspections:
  - 1. Leak Test: After installation, charge system and test for leaks. Repair leaks and retest until no leaks exist.
  - 2. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.

## 3.06 PROTECTION

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

# 3.07 DEMONSTRATION

A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain plumbing equipments. Refer to Division 01 Section "Demonstration and Training."

END OF SECTION

## SECTION 22 43 00

## HEALTHCARE PLUMBING FIXTURES

## PART 1 GENERAL

#### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following medical plumbing fixtures and related components:
  - 1. Faucets for lavatories showers and sinks.
  - 2. Laminar-flow, faucet-spout outlets.
  - 3. Protective shielding guards.
  - 4. Fixture supports.
  - 5. Lavatories.
  - 6. Clinical sinks.
- B. Related Sections include the following:
  - 1. Division 22 Section "Domestic Water Piping Specialties" for backflow preventers.
  - 2. Division 22 Section "Sanitary Waste Piping Specialties" for floor drains.

#### 1.03 DEFINITIONS

- A. Accessible Medical Plumbing Fixture: Plumbing fixture that can be approached, entered, and used by people with disabilities.
- B. Fitting: Device that controls the flow of water into or out of the medical plumbing fixture. Fittings specified in this Section include supplies and stops, faucets and spouts, shower heads, drains and tailpieces, and traps and waste pipes.
- C. FRP: Fiberglass-reinforced plastic.
- D. PMMA: Polymethyl methacrylate (acrylic) plastic.

#### 1.04 SUBMITTALS

- A. Product Data: For each type of medical plumbing fixture indicated. Include selected fixture and trim, fittings, accessories, appliances, appurtenances, equipment, and supports. Indicate materials and finishes, dimensions, construction details, and flow-control rates.
- B. Shop Drawings: Diagram power, signal, and control wiring.
- C. Operation and Maintenance Data: For medical plumbing fixtures to include in emergency, operation, and maintenance manuals.

#### 1.05 QUALITY ASSURANCE

- A. Source Limitations: Obtain medical plumbing fixtures, faucets, and other components of each category through one source from a single manufacturer.
  - 1. Exception: If fixtures, faucets, or other components are not available from a single manufacturer, obtain similar products from other manufacturers specified for that category.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Regulatory Requirements: Comply with requirements in ICC A117.1, "Accessible and Usable Buildings and Facilities" for plumbing fixtures for people with disabilities.
- D. Regulatory Requirements: Comply with requirements in Public Law 102-486, "Energy Policy Act," about water flow and consumption rates for plumbing fixtures.
- E. NSF Standard: Comply with NSF 61, "Drinking Water System Components--Health Effects," for fixture materials that will be in contact with potable water.
- F. Select combinations fixtures and trim, faucets, fittings, and other components that are compatible.
- G. Comply with the following applicable standards and other requirements specified for medical plumbing fixtures:
  - 1. Enameled, Cast-Iron Fixtures: ASME A112.19.1M.
  - 2. Plastic Bathtubs: ANSI Z124.1.
  - 3. Plastic Shower Enclosures: ANSI Z124.2.
  - 4. Slip-Resistant Bathing Surfaces: ASTM F 462.
  - 5. Vitreous-China Fixtures: ASME A112.19.2M.
- H. Comply with the following applicable standards and other requirements specified for lavatory and sink faucets:
  - 1. Backflow Protection Devices for Faucets with Hose-Thread Outlet: ASME A112.18.3M.
  - 2. Diverter Valves for Faucets with Hose Spray: ASSE 1025.
  - 3. Faucets: ASME A112.18.1.
  - 4. Hose-Connection Vacuum Breakers: ASSE 1011.
  - 5. Hose-Coupling Threads: ASME B1.20.7.
  - 6. Integral, Atmospheric Vacuum Breakers: ASSE 1001.
  - 7. NSF Materials: NSF 61.
  - 8. Pipe Threads: ASME B1.20.1.
  - 9. Sensor-Actuated Faucets and Electrical Devices: UL 1951.
  - 10. Supply Fittings: ASME A112.18.1.
  - 11. Brass Waste Fittings: ASME A112.18.2.
- I. Comply with the following applicable standards and other requirements specified for bathtub and shower faucets:
  - 1. Backflow Protection Devices for Hand-Held Showers: ASME A112.18.3M.
  - 2. Combination, Pressure-Equalizing and Thermostatic-Control Antiscald Faucets: ASSE 1016.
  - 3. Faucets: ASME A112.18.1.
  - 4. Hand-Held Showers: ASSE 1014.

- 5. High-Temperature-Limit Controls for Thermal-Shock-Preventing Devices: ASTM F 445.
- 6. Hose-Coupling Threads: ASME B1.20.7.
- 7. Manual-Control Antiscald Faucets: ASTM F 444.
- 8. Pipe Threads: ASME B1.20.1.
- 9. Pressure-Equalizing-Control Antiscald Faucets: ASTM F 444 and ASSE 1016.
- 10. Sensor-Actuated Faucets and Electrical Devices: UL 1951.
- 11. Thermostatic-Control Antiscald Faucets: ASTM F 444 and ASSE 1016.
- J. Comply with the following applicable standards and other requirements specified for miscellaneous fittings:
  - 1. Atmospheric Vacuum Breakers: ASSE 1001.
  - 2. Brass and Copper Supplies: ASME A112.18.1.
  - 3. Flexible Water Connectors: ASME A112.18.6.
  - 4. Manual-Operation Flushometers: ASSE 1037.
  - 5. Sensor-Operation Flushometers: ASSE 1037 and UL 1951.
  - 6. Brass Waste Fittings: ASME A112.18.2.
- K. Comply with the following applicable standards and other requirements specified for miscellaneous components:
  - 1. Grab Bars: ASTM F 446.
  - 2. Hose-Coupling Threads: ASME B1.20.7.
  - 3. Off-Floor Fixture Supports: ASME A112.6.1M.
  - 4. Pipe Threads: ASME B1.20.1.
  - 5. Plastic Toilet Seats: ANSI Z124.5.
  - 6. Supply and Drain Protective Shielding Guards: ICC A117.1.

#### 1.06 EXTRA MATERIALS

A. Furnish extra materials described below that match products installed and that are packaged with protective covering for storage and identified with labels describing contents. See Material Matrix for Quantity.

# PART 2 PRODUCTS

# 2.01 LAVATORY FAUCETS

- A. Lavatory Faucets, See Plumbing Fixture Schedule:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. American Standard Companies, Inc.
    - b. Chicago Faucets.
    - c. Just Manufacturing Company.
    - d. Kohler Co.
    - e. Speakman Company.
  - 4. Description: Faucet for lavatory-type medical plumbing fixture. Coordinate faucet inlets with supplies, connectors, and fixture holes; coordinate outlet with spout and fixture receptor.
    - a. Maximum Flow Rate: 1.5 GM.

- b. Body Material: Solid brass.
- c. Finish: Polished chrome plate.
- d. Type: Single-control mixing.
- e. Tempering System: Not required.
- f. Supply Centers: Adjustable.
- g. Mounting: Deck, exposed.
- h. Handle(s): Not applicable.
- i. Temperature Indicators: Color-coded for hot and cold water.
- j. Inlet(s): NPS 3/8 tubing, with NPS 1/2 male adaptor.
- k. Spout: Rigid, brass.
- I. Spout Outlet: Laminar flow.
- m. Operation: Compression, manual Noncompression, manual.
- n. Drain: See fixture.

#### 2.02 SINK FAUCETS

- A. Sink Faucets, See Plumbing Fixture Schedule:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. American Standard Companies, Inc.
    - b. Chicago Faucets.
    - c. Just Manufacturing Company.
    - d. Kohler Co.
    - e. Speakman Company.
  - 4. Description: Faucet for sink-type medical plumbing fixtures. Coordinate faucet inlets with supplies and fixture holes; coordinate outlet with spout and fixture receptor.
    - a. Maximum Flow Rate: 2.2 gpm, unless otherwise indicated.
    - b. Body Material: Solid brass.
    - c. Finish: Polished chrome plate.
    - d. Type: Sink faucet.
    - e. Tempering Device: Not required.
    - f. Mixing Valve: Single control.
    - g. Backflow Protection Device for Hose Outlet: Not applicable.
    - h. Supply Centers: 8 inches.
    - i. Mounting: Deck, concealed.
    - j. Handle(s): Not applicable.
    - k. Temperature Indicators: Color-coded for hot water on left and cold water on right.
    - I. Inlet(s): NPS 3/8 plain-end tubing.
    - m. Spout: Rigid, gooseneck, solid Swivel, gooseneck, solid brass with wall brace.
    - n. Spout Outlet: Plain end.
    - o. Vacuum Breaker: Not required.
    - p. Operation: Automatic, hard-wired electronic sensor.

# 2.03 LAMINAR-FLOW FAUCET-SPOUT OUTLETS

A. Laminar-Flow Faucet-Spout Outlets, See Plumbing Fixture Schedule:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
   a. Chronomite Laboratories. Inc.
  - b. NEOPERL, Inc.
- 4. Description: Chrome-plated-brass faucet-spout outlet that produces non-aerating laminar stream. Include male or female thread that mates with faucet outlet for attachment to faucets where indicated and flow-rate range that includes flow of faucet.

# 2.04 PROTECTIVE SHIELDING GUARDS

- A. Protective Shielding Pipe Covers, See Plumbing Fixture Schedule:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Engineered Brass Co.
    - b. Insul-Tect Products Co.; a Subsidiary of MVG Molded Products.
    - c. McGuire Manufacturing Co., Inc.
    - d. Plumberex Specialty Products Inc.
    - e. TCI Plumbing Products, Inc.
    - f. TRUEBRO, Inc.
    - g. Zurn Plumbing Products Group; Tubular Brass Plumbing Products Operation.
  - 3. Description: Manufactured plastic wraps for covering medical plumbing fixture hotand cold-water supplies and trap and drain piping. Comply with Americans with Disabilities Act (ADA) requirements.
- B. Protective Shielding Piping Enclosures:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. TRUEBRO, Inc.
  - 3. Description: Manufactured plastic enclosure for covering medical plumbing fixture hot- and cold-water supplies and trap and drain piping. Comply with ADA requirements.

# 2.05 FIXTURE SUPPORTS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Josam Company.
  - 2. MIFAB Manufacturing Inc.
  - 3. Smith, Jay R. Mfg. Co.

- 4. Tyler Pipe; Wade Div.
- 5. Watts Drainage Products Inc.; a div. of Watts Industries, Inc.
- 6. Zurn Plumbing Products Group; Specification Drainage Operation.
- C. Lavatory Supports:
  - 1. Description: Type II, lavatory carrier with concealed arms and tie rod for wallmounting, lavatory-type medical plumbing fixture. Include steel uprights with feet.
  - 2. Accessible-Fixture Support: Include rectangular steel uprights.
- D. Sink Supports:
  - 1. Description: Type II, sink carrier with hanger plate, bearing studs, and tie rod for sink-type medical plumbing fixture. Include steel uprights with feet.

# 2.06 LAVATORIES

- A. Wall-Mounting Lavatories, See Plumbing Fixture Schedule:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. American Standard Companies, Inc.
    - b. Briggs Plumbing Products, Inc.
    - c. Crane Plumbing, L.L.C./Fiat Products.
    - d. Eljer.
    - e. Kohler Co.
  - 4. Description: Accessible, wall-mounting, vitreous-china medical plumbing fixture.
    - a. Type: With back.
    - b. Size: 19 by 16 inches rectangular.
    - c. Faucet Hole Punching: Three holes, 4-inch centers.
    - d. Faucet Hole Location: Top.
    - e. Color: White.
    - f. Faucet: Lavatory for separate drain.
    - g. Supplies: NPS 3/8 chrome-plated copper tubes or flexible connectors with stops.
    - h. Drain: See faucet.
      - 1) Location: Not applicable.
    - i. Drain Piping: NPS 1-1/4 by NPS 1-1/2 chrome-plated, cast-brass P-trap; NPS 1-1/2, 0.032-inch-0.045-inch-thick tubular brass waste to wall; and wall escutcheon.
    - j. Protective Shielding Guard(s):
    - k. Fixture Support: Lavatory.
- B. Counter-Mounting Lavatories:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
     a. American Standard Companies, Inc.
    - a. American Standard Companies, Incb. Briggs Plumbing Products, Inc.

- c. Crane Plumbing, L.L.C./Fiat Products.
- d. Eljer.
- e. Gerber Plumbing Fixtures LLC.
- f. Kohler Co.
- 4. Description: Accessible, vitreous-china, medical plumbing fixture.
  - a. Type: Self-rimming.
  - b. Rectangular Lavatory Size: 20 by 18 inches.
  - c. Oval Lavatory Size: 19 by 16 inches.
  - d. Round Lavatory Size: 19 inches in diameter.
  - e. Faucet Hole Punching: Three holes, 4-inch centers.
  - f. Faucet Hole Location: Top.
  - g. Color: White.
  - h. Faucet: Lavatory Grip.
  - i. Supplies: NPS 3/8 chrome-plated copper tubes or flexible connectors with stops.
  - j. Drain: Grid.
  - k. Location: Not applicable.
  - I. Drain Piping: NPS 1-1/4 by NPS 1-1/2 chrome-plated, cast-brass P-trap; NPS 1-1/2, 0.045-inch-thick tubular brass waste to wall; and wall escutcheon.
  - m. Protective Shielding Guard(s):

## 2.07 UTILITY SINKS

- A. Stainless Steel Counter Mounted, See Plumbing Fixture Schedule:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Just Sinks
    - b. Elkay

h.

- c. American Standard Companies, Inc.
- d. Kohler Co.
- 4. Description: Counter mounted, stainless steel, ledge back, self-rimming, medical plumbing fixture. ASME A112.19.3/CSA B45.4
  - a. Size: 20 by 18 inches.
  - b. Faucet: Mounted on ledge
  - c. Fixture Support: Counter mounted
  - d. Metal Thickness: 0050 inch
  - e. Drain: Grid with NPS 2 tailpiece
  - f. Drain Location: Centered in compartment
  - g. Supply Fittings: ASME A112.18.1/CSA B125.1
    - a) Chrome plated brass compression stop with inlet connection matching water-supply piping type and size
    - b) Loose key operation
    - c) Risers: NPS 1/2, ASME A112.18.6, braided or corrugated stainlesssteel flexible hose.
    - Waste Fittings: ASME A112.18..2/CSA B125.2
      - a) Trap: NPS 2
      - b) Chrome plated, two-piece, cast-brass trap and swivel elbow with 0.032-inch thick bass tube to wall; and chrome plated brass or steel wall flange.
  - i. Mounting: On counter with sealant.

## 2.08 CLINICAL SINKS

- A. Wall-Mounting Clinical Sinks, See Plumbing Fixture Schedule:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
     a. American Standard Companies, Inc.
    - b. Crane Plumbing, L.L.C./Fiat Products.
    - c. Elier.
    - d. Kohler Co.
  - 4. Description: Wall-mounting, back-outlet, vitreous-china, flushing-rim, service-sinktype medical plumbing fixture.
    - a. Size: Approximately 25 by 20 inches.
    - b. Color: White.
    - c. Rim Guard: Stainless steel on front and also on sides if flat rim.
    - d. Faucet: Sink.
    - e. Flushometer:
    - f. Bedpan Washer:
    - g. Fixture Support: Sink.
- B. Floor-Mounting Clinical Sinks:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. American Standard Companies, Inc.
    - b. Crane Plumbing, L.L.C./Fiat Products.
    - c. Eljer.
    - d. Kohler Co.
  - 4. Description: Floor-mounting, bottom-outlet, vitreous-china, flushing-rim, servicesink-type medical plumbing fixture. Include bolt caps.
    - a. Size: Approximately 27 by 20 inches.
    - b. Color: White.
    - c. Rim Guards: Stainless steel on front and sides.
    - d. Sink Base: 10-inch -high, cast terrazzo if required.
    - e. Faucet: Sink.
    - f. Flushometer:
    - g. Bedpan Washer:

#### 2.09 EYEWASH EQUIPMENT

- A. Sink, Fixed-Position, Plumbed Eyewash Unit
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - a. Haws Company
  - b. Guardian Equipment
  - c. Bradley Corporation
- 4. Description:
  - a. Capacity: Not less than 0.4 gpm for at least 15 minutes.
  - b. Supply Piping: NPS 1/2 chrome-plated brass or stainless steel with flow regulator and stay-open control valve.
  - c. Control-Valve Actuator: Paddle.
  - d. Spray-Head Assembly: Two spray heads positioned over sink.
  - e. Mounting: Attached to sink receptor
- B. Sink, Swivel-Type, Plumbed Eyewash Unit
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 3. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
    - a. Haws Company
    - b. Guardian Equipment
    - c. Bradley Corporation
  - 4. Description:
    - a. Capacity: Not less than 0.4 gpm for at least 15 minutes.
    - b. Supply Piping: NPS 1/2 chrome-plated brass or stainless steel with flow regulator and stay-open control valve.
    - c. Control-Valve Actuator: Movement of spray-head assembly to position over sink.
    - d. Spray-Head Assembly: Two spray heads with offset piping. Mounting: Deck next to sink

# PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Examine roughing-in for medical plumbing fixtures to verify actual locations of piping connections before fixture installation.
  - B. Examine cabinets, counters, floors, and walls for suitable conditions where fixtures will be installed.
  - C. Proceed with installation only after unsatisfactory conditions have been corrected.

## 3.02 INSTALLATION

- A. Assemble medical plumbing fixtures, trim, fittings, and other components according to manufacturers' written instructions.
- B. Install off-floor supports, affixed to building substrate, for wall-mounting fixtures.
  - 1. Use carrier supports with waste fitting and seal for back-outlet fixtures.
  - 2. Use carrier supports without waste fitting for fixtures with tubular waste piping.

- 3. Use chair-type carrier supports with rectangular steel uprights for accessible fixtures.
- C. Install back-outlet, wall-mounting fixtures onto waste fitting seals and attach to supports.
- D. Install floor-mounting fixtures on closet flanges or other attachments to piping or building substrate.
- E. Install wall-mounting fixtures with tubular waste piping attached to supports.
- F. Install counter-mounting fixtures in and attached to casework.
- G. Install fixtures level and plumb according to roughing-in drawings.
- H. Install water-supply piping with stop on each supply to each fixture to be connected to domestic water piping. Attach supplies to supports or substrate within pipe spaces behind fixtures. Install stops in locations where they can be easily reached for operation.
  - 1. Exception: Use ball, gate, or globe valve if stops are not specified with fixture. Valves are specified in Division 22 Section "General-Duty Valves for Plumbing Piping."
- I. Install trap and tubular waste piping on drain outlet of each fixture to be directly connected to sanitary drainage system.
- J. Install faucet-spout fittings with specified flow rates and patterns in faucet spouts if faucets are not available with required rates and patterns. Include adapters if required.
- K. Install traps on fixture outlets.
  - 1. Exception: Omit trap on fixtures with integral traps.
- L. Install escutcheons at piping wall penetrations in exposed, finished locations and within cabinets and millwork. Use deep-pattern escutcheons if required to conceal protruding fittings. Escutcheons are specified in Division 22 Section "Common Work Results for Plumbing."
- M. Seal joints between fixtures and walls, floors, and counters using sanitary-type, one-part, mildew-resistant silicone sealant. Match sealant color to fixture color. Sealants are specified in Division 07 Section "Joint Sealants."

#### 3.03 CONNECTIONS

- A. Piping installation requirements are specified in other Division 22 Sections. Drawings indicate general arrangement of piping, fittings, and specialties.
- B. Connect water supplies from domestic water piping to medical plumbing fixtures.
- C. Connect drain piping from medical plumbing fixtures to sanitary waste and vent piping.
- D. Ground equipment according to Division 26 Section "Grounding and Bonding for Electrical Systems."
- E. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

## 3.04 FIELD QUALITY CONTROL

- A. Verify that installed medical plumbing fixtures are categories and types specified for locations where installed.
- B. Check that medical plumbing fixtures are complete with trim, faucets, fittings, and other specified components.
- C. Inspect installed medical plumbing fixtures for damage. Replace damaged fixtures and components.
- D. Test installed fixtures after water systems are pressurized for proper operation. Replace malfunctioning fixtures and components, then retest. Repeat procedure until units operate properly.
- E. Install fresh batteries in sensor-operated mechanisms.

## 3.05 ADJUSTING

- A. Operate and adjust faucets and controls. Replace damaged and malfunctioning medical plumbing fixtures, fittings, and controls.
- B. Replace washers and seals of leaking and dripping faucets and stops.

## 3.06 CLEANING

- A. Clean medical plumbing fixtures, faucets, and other fittings with manufacturers' recommended cleaning methods and materials. Do the following:
  - 1. Remove faucet spouts and strainers, remove sediment and debris, and reinstall strainers and spouts.
  - 2. Remove sediment and debris from drains.
- B. After completing installation of exposed, factory-finished fixtures, faucets, and fittings, inspect exposed finishes and repair damaged finishes.

#### 3.07 PROTECTION

- A. Provide protective covering for installed fixtures and fittings.
- B. Do not allow use of medical plumbing fixtures for temporary facilities unless approved in writing by Owner.

## END OF SECTION

#### SECTION 23 00 10

## **MECHANICAL GENERAL REQUIREMENTS**

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. The General Conditions and Supplementary Conditions shall apply to and form part of this Division.

#### 1.02 SUMMARY

- A. Work includes, but is not limited to, the following:
  - 1. Labor, material, equipment and transportation to complete the Work as shown on the drawings, specified herein and/or implied thereby.
  - 2. A requirement of the plumbing sections shall be to provide make-up water and drain final connections to systems and equipment.
  - 3. Work specified in Section 23 00 50 and other Division 23 Sections.
- B. Work not included in this division:
  - 1. Painting, except as hereinafter specified. See Division 9 for painting.
  - 2. Electrical, except for controls hereinafter specified. See Division 26 for electrical.

#### 1.03 DEFINITIONS

- A. Unless otherwise specified, "all clarification form," "field direction by," "submittals to," "approved by," "processed by," "permission from," and like mentioned herein shall mean from/by/to Architect.
- B. "Provide" means furnish and install referenced item with all appurtenances.
- C. "Shall" indicates a mandatory requirement.
- D. "Air conditioning" is defined as the treatment and/or handling of any air to any degree by the systems shown on the drawings and herein specified and is not restricted to refrigerated cooling.

#### 1.04 DELIVERY AND STORAGE OF MATERIALS

A. Provide for the safety and good condition of all materials and equipment until final acceptance by the Owner. Protect all materials and equipment from damage from any cause whatever, and provide adequate and proper storage facilities during the progress of the work. Replace all damaged and defective work, material or equipment prior to filing application for final acceptance. Properly protect all openings to equipment, piping, ductwork, accessories, etc. from dirt, dust, and debris prior to and during installation of the work.

## 1.05 CODES AND STANDARDS

A. Work and materials shall be in full accordance with the latest rules and regulations of the Local Fire Marshal; the National Electric Code (NEC); the Uniform Plumbing Code; the California Plumbing Code; California Administrative Code, Title 24, (CAL/OSHA); Local Building Codes; the Uniform Mechanical Code; the California Mechanical Code; Vol. II of

the Uniform Building Code; Volume I and II of the California Building Code; SMACNA "Guidelines for Seismic Restraints of Mechanical Systems"; and other applicable codes, laws or regulations of bodies lawfully empowered and having jurisdiction over this project. Nothing in the plans or specifications shall be construed to permit work not conforming to these codes. When codes conflict with one another, provide larger, higher or more restrictive standards without additional costs.

#### 1.06 PERMITS

A. Obtain all permits, patent rights, and licenses that are required for the performing of this work by all laws, ordinances, rules and regulations, or orders of any officer and/or body. Provide all notices necessary in connection therewith, and pay all fees relating thereto and all costs and expenses incurred on account thereof. No work shall be covered before inspection by the jurisdictional authorities and observation by the Architect or his designated representative.

# 1.07 EXPLANATION AND PRECEDENCE OF DRAWINGS

- A. Drawings and specifications are intended to be read together so that any work mentioned in one and not the other shall be executed the same as if mentioned in both.
- B. For purposes of clearness and legibility, drawings are essentially diagrammatic. The size and location of equipment is drawn to scale wherever possible. Contractor shall make use of data in the contract documents and shall verify this information at the building site.
- C. Where the contract specifications and/or drawings are in conflict, obtain clarification of such during bidding. Where addenda for clarification of such is not timely, base the bid on the higher standards or more restrictive requirements; prior to fabrication, obtain written clarification.
- D. The drawings indicate required size and points of termination of pipes, and suggest proper routes to conform to structure, avoid obstructions and preserve clearances. It is not intended that drawings indicate necessary offsets. The Contractor shall make the installation in such a manner as to conform to the structure, avoid obstructions, preserve headroom and keep openings and passageways clear, without further instructions or costs to the Owner.
- E. It is intended that apparatus be located symmetrical with architectural elements. Refer to architectural details in completing the correlating work.
- F. The Contractor shall study drawings and specifications including, and not limited to, architectural, structural, mechanical, plumbing, fire protection, and electrical to determine conflict with ordinances and statutes. Errors or omissions shall be reported in writing, and changes shall be included in the as-built drawings and the additional work performed at no cost to the Owner.
- G. Submittal of bid shall indicate the Contractor has examined the site and drawings and has included required allowances in his bid. No allowance shall be made for any error resulting from Contractor's failure to visit job site and to review drawings and specifications. Bid shall include costs for required drawings and changes as outline above, all at no cost to owner.

#### 1.08 RECORD DRAWINGS

- A. Provide and maintain on the job one complete set of blue line prints of the record drawings for all the mechanical and plumbing work. Carefully record on this set of prints, work including piping, valves, etc., which is installed differently from that indicated in the specifications and on the drawings; locate dimensionally from fixed points. The depth shall be indicated for all plugged wyes, tees and capped lines.
- B. These record drawings shall be continuously kept up-to-date, and shall be available for inspection at all times. Existing lines discovered shall be indicated on these drawings.
- C. At completion of work, provide a neat and legible reproducible set of these up-to-date record drawings which shall be individually signed and dated by the Contractor and the job inspector as to their accuracy.
- D. Record drawings shall be submitted for acceptance and approval to the Architect and Mechanical Engineer before final certificate of acceptance will be issued.

## 1.09 CUTTING AND PATCHING

- A. Perform all cutting and fitting required for work of this section in rough construction of the building. Obtain permission of the Structural Engineer prior to cutting any structural building elements.
- B. All patching of finished construction of building shall be performed under the sections of specifications covering these materials by the trades at no additional cost to the Owner.
- C. All cutting of concrete work by Contractor shall be by core drilling or concrete saw. No cutting or coring shall be done without first obtaining the permission of the Architect and Owner.
- D. All patching of existing surfaces shall match existing material and finish.

# 1.10 DAMAGE BY LEAKS

A. Contractor shall be responsible for damage to the grounds, walks, roads, buildings, finishes, surfaces, materials, equipment, piping systems, electrical systems and their equipment and contents, caused by leaks in the piping systems being installed or having been installed herein. He shall repair at his expense all damage so caused. All repair work shall be done as directed by the Architect and Owner.

#### 1.11 EMERGENCY REPAIRS

A. The Owner reserves the right to make emergency repairs as required to keep equipment in operation without voiding the Contractor's guarantee bond nor relieving the Contractor of his responsibilities.

# 1.12 LOCATIONS

A. Coordinate in advance of the work, requirements for openings, equipment maintenance clearances, recesses and chases in the walls, partitions, equipment housekeeping pads, framing or openings. Should furnishing this information be neglected, delayed or incorrect and additional cutting is found to be required, the cost of same shall be borne by the Contractor. Nothing in this paragraph shall be construed to relieve the Contractor of the responsibility for providing and paying for the required core drilling and openings in existing work.

- B. Diagrammatic Indications on Drawings are:
  - 1. Approximate only.
  - 2. At various locations shown distorted for clarity.
- C. Exact Locations Shall:
  - 1. Be as required for proper installation in available space.
  - 2. Avoid interference with architectural, electrical and structural features.
  - 3. Be coordinated with the work of other trades toward the general purpose of having the work progress rapidly and smoothly with a minimum interference between one trade and another.
  - 4. Preserve headroom and keep openings and passageways clear.
  - 5. Have a neat arrangement symmetrical to the building lines, light and tile pattern.
  - 6. Be in locations reasonably accessible for hung ceiling areas for maintenance from the floor below. Specifically for equipment, valves, and other items requiring maintenance, adjustment and/or observation.

## 1.13 SUPPORTS, EQUIPMENT PADS, STAGING, ETC.

A. Construction supports required for the proper installation of equipment shall be in accordance with the drawings, manufacturer's requirements, seismic requirements, and applicable codes. Check architectural and structural drawings for equipment pads by others. Provide staging, scaffolds, platforms, ladders or similar facilities required to properly install the work.

## 1.14 INTERRUPTION OF UTILITIES

- A. This project includes elements of work which will require disconnection and modification of existing systems, with resultant outages. These episodes must be strictly limited and controlled. No outage affecting any portion of the existing facilities will be allowed without specified written authorization by the Owner, Architect and Engineer.
- B. The Contractor shall schedule and coordinate all interruptions of utilities with the Architect and Owner within 30 days after award of contract. The Contractor shall submit to the Owner a schedule of proposed interruptions. At least 72 hours prior to the interruption, the contractor shall submit a request indicating the proposed date and duration of interruption, the work to be accomplished, the areas which will be affected and a proposed contingency plan to be followed in the event that normal service or facilities cannot be restored on schedule. Do not commence work until the time, date, and contingency have been approved in writing by the Architect and Owner.
- C. Provide, at no additional cost, any labor and materials necessary to restore services on a contingency basis should normal service or facilities not be restored on schedule.
- D. Preparatory work associated with each interruption shall be performed during normal work hours. The actual interruption required for tie-in shall be performed between 8 P.M. and 5 A.M. Maximum shutdown during this period of any system shall be 4 hours.

#### 1.15 SUBSTITUTIONS

A. If substitutions of controls or equipment require any changes in the architectural, structural, mechanical, plumbing or electrical work from that shown on the drawings, the extra cost of the equipment or architectural, structural, mechanical, plumbing or electrical work shall be responsibility of the Contractor requesting the substitution. All substitutions shall be prior approved by the Architect before purchase by the contractor. B. If the Contractor proposes substitutions of any equipment specified herein or on the drawings, it shall be the Contractor's responsibility to obtain approval from the Architect for such equipment as well as approval for anchorage of such equipment from the Architect, Structural Engineer, and governing approval agencies. All costs required for such approval shall be the responsibility of the Contractor requesting the substitution.

# 1.16 PREPARATION OF SUBMITTALS

- A. Refer to Division 1. In addition to the requirements of Division 1, provide the requirements specified herein.
- B. Prior to commencement of work and in accordance with the General Requirements, submit for review six copies of proposed equipment and material submittals. The Contractor shall verify the delivery dates are compatible with the specified construction schedule; and verify the equipment is sized to accommodate the conditions specified. Submittals shall include manufacturer's names and model numbers and shall comply with specifications and drawings. The Contractor shall bear the cost of changes necessary to accommodate substitutions if substitution is approved.
- C. The project scope and work is defined in the contract documents. The contractor is responsible for determining the division of work between their subcontractors.
- D. Provide formal submittal to Architect. Review of the formal submittal is only for general conformance with design concept of project and general compliance with the information given in the contract documents. The Contractor is responsible for confirmation and correlation of the dimensions, quantities and sizes, for information that pertains to fabrication methods or construction techniques, and for coordination of work of all trades. Deviations from Drawings and Specifications shall be clearly and completely indicated (by a separate letter) in the formal submittals. Reviewed Submittals shall not relieve the Contractor of responsibility for errors or deviations.
  - 1. Where specific model numbers and/or manufacturers are specified or shown, it is the intent of the contract documents to procure the specified item(s). Alternate equipment may not be used unless data is submitted for consideration as a substitution in accordance with General Requirements and this section.
  - 2. Model numbers used may not indicate all features or options required for this specific installation. Modify the specified models to comply with the requirements, as specified or shown.
  - 3. Product Data for Proposed Substitutions:
    - a. Submit copies of complete data, with drawings and samples as appropriate, including:
      - 1) Comparison of the qualities of the proposed substitution with that specified.
      - 2) Changes required in other elements of the work because of the substitution.
      - 3) Affect on construction schedule.
      - 4) Cost data comparing the proposed substitution with the product specified.
      - 5) Availability of maintenance service and source of replacement materials.
      - 6) Reference to three (3) projects similar to this where such equipment is installed and operating to two (2) or more years.
    - b. Acceptance of substitutions is entirely at the discretion of the Architect.
- E. Formal submittals shall be complete with catalog data and information properly marked to indicate equality of material (where substitution is allowed and desired), adequacy in

capacity and performance to meet minimum capacities or performance as specified or indicated. Arrange the submittals in the same sequence as these Specifications and indicate the Section and Paragraph number (in the upper right-hand side with tabs) for which each submittal is intended. Incomplete submittals shall be rejected.

- F. Do not fabricate, order or deliver materials or equipment until formal submittals have been approved. Where material or equipment is used without such permission, it is deemed that the material or equipment shall be in complete compliance with drawings and specifications, without additional cost where such compliance is lacking and may be required to be altered in the field.
- G. Submittals shall be bound and shall include, at a minimum, the following:
  - 1. Complete bill of materials listing equipment furnished.
  - 2. Catalog cut sheets of every component being provided (highlighted).
  - 3. Provide completed blue-line shop drawings of the packaged equipment detailing all field connection points.
  - 4. Dimensions, clearance requirements, weights, and capacities.
  - 5. Wiring diagrams showing control interface as applicable.
  - 6. Warranty sheets.
  - 7. Pressure drops as applicable.
- H. Contractor shall incur all costs for time spent by Engineer for review of more than two submittals on each item. Costs shall be based on Engineer's hourly billing rate schedule at the time of review. Rate schedule available upon request. Engineer shall invoice the contractor upon completion of review and shall be paid by the contractor within 30 days of date of invoice. Failure to remit will withdraw approval (if any) of submittals in question.

#### 1.17 SHOP DRAWINGS:

- A. Proceed with preparation of shop drawings immediately upon receiving an authorization to proceed for the project. Shop drawings shall be originally prepared by the contractor. Provide shop drawings in electronic format. Submit prior to material fabrication, order and installation.
- B. Include:
  - 1. Duct and pipe elevations.
  - 2. Double line ductwork and piping (4" and larger).
  - 3. Actual size of purchased equipment.
  - 4. Access panels including ceiling panels.
  - 5. Access clearances for equipment.
  - 6. Actual locations of ceiling diffusers/ supply registers ad return registers.
  - 7. Locations of structural penetrations such as beams.
  - 8. Actual location of control panels and power connections to equipment.
  - 9. Color coded duct and piping based on material used.
  - 10. Minimum 1/4" scale drawings.
  - 11. Label and tag schedule for equipment.
  - 12. Duct transitions to clear beams or tight areas.
  - 13. Room temperature sensor locations.
  - 14. Point of connection to utilities outside the building.
  - 15. Sections or 3-dimensional drawings of congested areas.
  - 16. Gridlines.
  - 17. Utility tunnel plans and sections indicating double line piping, hangers, supports and utilities from other trades.

- C. Coordinate with other trades. Submit a copy to the General Contractor for distribution to other trades, including (but not limited to) controls, electrical, low voltage and fire sprinkler contractor.
- D. Submit a copy to General Contractor for distribution to other trades, including electrical and fire sprinkler contractor.
- E. Submit to commissioning agent for approval to assure design intent is met.
- F. Upon receiving approval from commissioning agent, submit a complete set of shop drawings at one time to the mechanical engineer.

# 1.18 ELECTRICAL REQUIREMENTS

- A. When electrical work is specified in subsequent sections to be furnished and installed by the Mechanical Contractor, it shall be installed in metallic conduit and in full accordance with the National Electric Code, the State of California Industrial Accident Commission's Safety Orders and the requirements of Division 26.
- B. The power wiring, safety switches, combination controllers, disconnect switches, motor starters, circuit breakers, motor-control equipment forming part of motor control centers or switchgear assemblies, and the electrical connections of the mechanical equipment to the electrical power source shall be coordinated with and provided under Division 26.
- C. Control Wiring: Low voltage and line voltage conduit and wiring required for controlling mechanical equipment shall be provided under Division 23 of this specification (unless otherwise shown on Electrical Drawings). Installation on these items shall comply with Division 16 requirements. Coordinate with Division 26 for power requirements to mechanical control panels, terminal controllers, etc.

# 1.19 MOTORS

A. Before order is placed for electrical devices, the Contractor shall check with the Electrical contractor and verify requirements as to type, mounting voltage and current characteristics as well as to any special delivery instructions.

# 1.20 TESTS

- A. Contractor shall make tests required by legally constituted authorities and as listed below.
  - 1. Tests shall be made in the presence of the Owner or his representative and a duly authorized inspector. The Owner or his representative shall be notified 5 days before tests are made.
  - 2. Concealed work and insulated work shall remain uncovered until required testing has been performed and approved by the Owner. If work to be tested is covered before the approval of the Owner or his authorized representative has been obtained, it shall be uncovered for testing at the Contractor's expense.
  - 3. Obtain required documents of certification indicating approval, acceptance and compliance with the requirements of all administrative authorities having jurisdiction over the work. No final payment shall be made until all such certificates are delivered to the Owner.
  - 4. Furnish labor, materials, instruments and bear other costs in connection with all tests.
  - 5. Piping systems, except as hereinafter noted, shall be given hydrostatic (with water) test of a least 150% of the maximum operating pressure but no less than 150 psig.

- 6. Before making test, remove or valve off from the system, gauges, traps, and other apparatus or equipment which may be damaged by test pressure.
- 7. Install a calibrated test pressure gauge in the system to observe any loss in pressure. Maintain the required test pressure for a sufficient length of time to enable an inspection to be made of all joints and connections. Perform tests after installation and prior to acceptance.
- 8. Final pressures at the end of the test period shall be no more or less than that caused by expansion or contraction of the test medium due to temperature changes.
- 9. After tests have been made and leaks repaired, clean and flush systems as hereinafter specified. Water piping shall be left under supply main pressure for the balance of the construction period.
- 10. Tests for mechanical, plumbing, and fire protection systems are specified within their own section. Equipment and ductwork system tests are specified in the test and balance section.
- 11. Provide necessary provisions and tests for maintaining the operational condition and cleanliness of existing systems.

# 1.21 LABOR AND MATERIALS

- A. A. Labor shall be carefully skilled for this kind of work, thorough and first class in all respects and under the direction of a competent foreman.
- B. Materials shall be new, in perfect condition and of domestic manufacturer. Materials for similar uses to be of same type and manufacturer.
- C. Equipment shall bear the manufacturer's label showing performance characteristics. Identifying size number shall be given only when it is not practicable or customary to show performance characteristics.
- D. Valves, pipe, fittings, etc., shall bear the manufacturer's name or trademark.
- E. Unless otherwise specified herein, equipment and fixtures shall be installed in accordance with the manufacturer's recommendations, including recommended service and removal clearances.

# 1.22 PROTECTION AND CLEAN-UP

- A. Protection: Provide for the safety and good condition of materials and equipment until final acceptance of the Architect. Protect materials and equipment from dirt, dust, debris, and damage from any cause whatever, and provide adequate and proper storage facilities during the progress of the work and replace all damaged and defective material, equipment or work precedent to filing application for final acceptance.
- B. Cleaning:
  - 1. Thoroughly clean all parts of the piping, ductwork, fixtures, apparatus and equipment. All parts shall be thoroughly cleaned of dirt, dust, debris, cement, plaster and other materials, and all grease and oil spots removed. Such surfaces shall be carefully wiped and all cracks and corners scraped out.
  - 2. Exposed rough metal work shall be carefully brushed down with steel brushes to remove rust and other spots and left in clean condition to receive painter's finish. Where factory prime coat has been damaged, this Contractor shall be responsible for restoration of same.

# 1.23 ACCESS PANELS

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- A. Access Doors and Panels:
  - 1. Wherever volume dampers, fire dampers, smoke fire dampers, controls, valves or other items or parts of the installation which require periodic inspection or adjustments are concealed by permanent non-removable construction, an access door shall be provided. Refer to Section 08310, "Access Doors and Frames." Verify all locations with Architect.

# 1.24 MAINTENANCE, OPERATION INSTRUCTION, ETC.

- A. General: Thoroughly instruct the Owner's operators in every detail of operation of the system. Provide the Owner with a list of all equipment, giving the manufacturer's name, model number, serial number, parts list and complete internal wiring diagrams. All directions for operation furnished by the manufacturer shall be carefully saved and turned over to the Owner, together with written sequence of operation, operating and maintenance instructions for each system and its equipment. Instruction shall consist of a minimum of four 8-hour periods over consecutive days and shall be 30% classroom and 70% at site location. Coordinate scheduling of instruction times with Owner's operators.
- B. Specific Data: Submit four complete sets of the following data to the Owner for approval prior to acceptance of the installation, complete and at one time; (partial or separate data will not be accepted) data shall consist of the following:
  - 1. Valve Directory: Indicating valve number, location, function and normal operating position for each.
  - 2. Color code schedule.
  - 3. Equipment: List of name plates, including name plate data.
  - 4. Manufacturer's Literature: Copies of manufacturer's instructions for operation and maintenance of all mechanical equipment, including replacement parts lists and drawings. Mark or highlight brochure literature indicating the models, sizes, capacities, curve operating points, etc., in a manner to clearly indicate the equipment installed. Remove all pages or sheets from the bulletin and catalogs that do not pertain to equipment installed on the project.
  - 5. Written Instructions: Typewritten instructions for operation and maintenance of the system composed of OPERATING INSTRUCTIONS, MAINTENANCE INSTRUCTIONS and a MAINTENANCE SCHEDULE.
    - a. OPERATING INSTRUCTIONS shall contain a brief description of the system. Adjustments requiring the technical knowledge of the service agency personnel shall not be included in the operating instructions. The fact such adjustments are required, however, shall be noted.
    - b. MAINTENANCE INSTRUCTIONS shall list each item of equipment requiring inspection, lubrication or service and describe the performance of such maintenance.
    - c. MAINTENANCE SCHEDULE shall list each item of equipment requiring maintenance, shall show the exact type of maintenance on every component of each item of equipment, and shall show when each item of equipment should be inspected or services.
    - d. Instructions: Operating personnel shall be instructed in the operation of the system in accordance with typewritten, approved instructions.
- C. Binders: Provide complete sets of the above data in loose-leaf ring-type binders with permanent covers, with identification on front and on spine.

# 1.25 SPECIAL REQUIREMENTS

- A. During the guarantee period and as directed by the Owner, make any additional tests, adjustment, etc., that may be required and correct any defects or deficiencies arising from operation of the systems. Operational tests shall be made during both heating and cooling seasons and on all systems.
- B. Completion:
  - 1. The entire mechanical system shall be commissioned in accordance with ASHRAE Guideline 1-1996 and the requirements of this specification. A final commissioning report shall be approved by the Owner, Architect, and Mechanical Engineer prior to final acceptance of the work.
  - 2. When the installation is complete and adjustments specified herein have been made, the system, shall be operated for a period of one week, during which time it shall be demonstrated to the Owner or his representative as being completed and operating in conformance with these specifications. The Contractor shall schedule all work so that this time period, which is to confirm a "bug-free" system, will occur before the total project is accepted for substantial completion by Owner.
  - 3. The work hereunder shall not be reviewed for final acceptance until operating and maintenance data, manufacturer's literature, valve directories, piping identification code directory, and nameplates specified herein have been approved and properly posted in the building.

# 1.26 WARRANTY/GUARANTEE

- A. The contractor shall warranty/guarantee that materials, apparatus, and equipment furnished and installed under the mechanical division of these specifications shall be new and free from all defects. Should any defects develop, within one year (unless a longer period is listed in other sections of the specifications) from the date of final acceptance by the owner or from the date of certificate of substantial completion, whichever is earlier, due to inferior or faulty materials and/or workmanship, the trouble shall be corrected by this Contractor without expense to the Owner. Any defective materials or inferior workmanship noticed at the time of installation or during the guarantee period shall be corrected immediately to the entire satisfaction of the Owner.
- B. The work shall be installed of such materials and in such a manner that:
  - 1. The operation of all parts of the system shall be noiseless to the extent that no objectionable sound of operation will be heard outside of the rooms enclosing the apparatus or equipment.
  - 2. Apparatus or equipment shall operate in accordance with detailed specifications covering each item.
  - 3. Contractor shall, at his own expense, make any adjustments or changes required to produce a condition of quietness satisfactory to the Engineer or his representative. Such adjustments or changes shall not reduce the performance or quantities called for on the drawings.
  - 4. Contractor shall guarantee that his installation of all materials and equipment will meet the performance requirements of these specifications and that all equipment will deliver the specified or required capacities.
  - 5. The Owner reserves the right to make temporary or emergency repairs as necessary to keep equipment in operating condition without voiding the guarantee contained herein nor relieving the Contractor of his responsibilities during the guarantee period.
  - 6. Contractor shall be responsible for all damage to any part of the premises caused by leaks or break in pipe lines, fixtures or equipment furnished and installed under his contract for a period of one year after date of acceptance of the project by Owner. He shall replace in kind, at his own expense, any and all items so damaged to the complete satisfaction of the Owner.

# PART 2 PRODUCTS - NOT APPLICABLE

# PART 3 EXECUTION – NOT APPLICABLE

END OF SECTION

#### SECTION 23 00 50

#### **BASIC MECHANICAL MATERIALS AND METHODS**

# PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following basic mechanical materials and methods to complement other Division 23 Sections.
  - 1. Piping materials and installation instructions common to most piping systems.
  - 2. Concrete base construction requirements.
  - 3. Escutcheons.
  - 4. Joining Materials.
  - 5. Dielectric fittings.
  - 6. Flexible connectors.
  - 7. Mechanical sleeve seals.
  - 8. Equipment nameplate data requirements.
  - 9. Labeling and identifying mechanical systems and equipment is specified in Division 23 Section "Identification for the HVAC Piping and Equipment."
  - 10. Non-shrink grout for equipment installations.
  - 11. Field-fabricated metal and wood equipment supports.
  - 12. Installation requirements common to equipment specification sections.
  - 13. Cutting and patching.
  - 14. Touchup painting and finishing.
- B. Pipe and pipe fitting materials are specified in Division 22 piping system Sections.

## 1.03 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe and duct shafts, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawl spaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors, or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and in duct shafts.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants, but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.

- F. The following are industry abbreviations for plastic materials:
  - 1. ABS: Acrylonitrile-butadiene-styrene plastic.
  - 2. CPVC: Chlorinated polyvinyl chloride plastic.
  - 3. NP: Nylon plastic.
  - 4. PE: Polyethylene plastic.
  - 5. PVC: Polyvinyl chloride plastic.
- G. The following are industry abbreviations for rubber materials:
  - 1. CR: Chlorosulfonated polyethylene synthetic rubber.
  - 2. EPDM: Ethylene propylene diene terpolymer rubber.

## 1.04 SUBMITTALS

- A. Product Data: For dielectric fittings, flexible connectors, mechanical sleeve seals, and identification materials and devices.
- B. Shop Drawings: Detail fabrication and installation for metal and wood supports and anchorage for mechanical materials and equipment.
- C. Coordination Drawings: For access panel and door locations.
- D. Coordination Drawings: Detail major elements, components, and systems of mechanical equipment and materials in relationship with other systems, installations, and building components. Show space requirements for installation and access. Indicate if sequence and coordination of installations are important to efficient flow of the Work. Include the following:
  - 1. Planned piping layout, including valve and specialty locations and valve-stem movement.
  - 2. Clearances for installing and maintaining insulation.
  - 3. Clearances for servicing and maintaining equipment, accessories, and specialties, including space for disassembly required for periodic maintenance.
  - 4. Equipment and accessory service connections and support details.
  - 5. Exterior wall and foundation penetrations.
  - 6. Fire-rated wall and floor penetrations.
  - 7. Sizes and location of required concrete pads and bases.
  - 8. Scheduling, sequencing, movement, and positioning of large equipment into building during construction.
  - 9. Floor plans, elevations, and details to indicate penetrations in floors, walls, and ceilings and their relationship to other penetrations and installations.
  - 10. Reflected ceiling plans to coordinate and integrate installation of air outlets and inlets, light fixtures, communication system components, sprinklers, and other ceiling-mounted items.
- E. Samples: Of color, lettering style, and other graphic representation required for each identification material and device.

#### 1.05 QUALITY ASSURANCE

A. Equipment Selection: Equipment of higher electrical characteristics, physical dimensions, capacities, and ratings may be furnished provided such proposed equipment is approved in writing and connecting mechanical and electrical services, circuit breakers, conduit, motors, bases, and equipment spaces are increased. Additional costs shall be approved in advance by appropriate Contract Modification for these increases. If

minimum energy ratings or efficiencies of equipment are specified, equipment must meet design and commissioning requirements.

#### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver pipes and tubes with factory-applied end caps. Maintain end caps through shipping, storage, and handling to prevent pipe end damage and prevent entrance of dirt, debris, and moisture.
- B. Protect stored pipes and tubes from moisture and dirt. Elevate above grade. Do not exceed structural capacity of floor, if stored inside.
- C. Protect flanges, fittings, and piping specialties from moisture and dirt.
- D. Store plastic pipes protected from direct sunlight. Support to prevent sagging and bending.

# 1.07 SEQUENCING AND SCHEDULING

- A. Coordinate mechanical equipment installation with other building components.
- B. Arrange for pipe spaces, chases, slots, and openings in building structure during progress of construction to allow for mechanical installations.
- C. Coordinate installation of required supporting devices and set sleeves in poured-in-place concrete and other structural components, as they are constructed.
- D. Sequence, coordinate, and integrate installations of mechanical materials and equipment for efficient flow of the Work. Coordinate installation of large equipment requiring positioning before closing in building.
- E. Coordinate connection of mechanical systems with exterior underground and overhead utilities and services. Comply with requirements of governing regulations, franchised service companies, and controlling agencies.
- F. Coordinate requirements for access panels and doors if mechanical items requiring access are concealed behind finished surfaces. Access panels and doors are specified in Division 8 Section "Access Doors and Frames."
- G. Coordinate installation of identifying devices after completing covering and painting, if devices are applied to surfaces. Install identifying devices before installing acoustical ceilings and similar concealment.

# PART 2 PRODUCTS

#### 2.01 MANUFACTURERS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Dielectric Unions:
    - a. Epco Sales Inc.
    - b. Watts Industries, Inc.; Water Products Div.

- c. Zurn Industries, Inc.; Wilkins Div.
- 2. Dielectric Flanges:
  - a. Epco Sales Inc.
  - b. Watts Industries, Inc.; Water Products Div.
  - Dielectric-Flange Kits:
  - a. Calpico, Inc.
  - b. Central Plastics Co.
- 4. Dielectric Couplings:
  - a. Calpico, Inc.
  - b. Lochinvar Corp.
- 5. Dielectric Nipples:
  - a. Grinnell Corp.; Grinnell Supply Sales Co.
  - b. Victaulic Co. of America.
- 6. Metal, Flexible Connectors:
  - a. Grinnell Corp.; Grinnell Supply Sales Co.
  - b. McWane, Inc.; Tyler Pipe; Gustin-Bacon Div.
  - c. Metraflex Co.
- 7. Mechanical Sleeve Seals:
  - a. Calpico, Inc.
  - b. Metraflex Co.
  - c. Thunderline/Link-Seal.
- 2.02 PIPE AND PIPE FITTINGS

3.

- A. Refer to individual Division 22 piping Sections for pipe and fitting materials and joining methods.
- B. Pipe Threads: ASME B1.20.1 for factory-threaded pipe and pipe fittings.
- 2.03 JOINING MATERIALS
  - A. Refer to individual Division 22 piping Sections for special joining materials not listed below.
  - B. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.
    - 1. ASME B16.21, nonmetallic, flat, asbestos-free, 1/8-inch maximum thickness, unless thickness or specific material is indicated.
      - a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.
      - b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.
    - 2. AWWA C110, rubber, flat face, 1/8 inch thick, unless otherwise indicated; and fullface or ring type, unless otherwise indicated.
  - C. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.
  - D. Plastic, Pipe-Flange Gasket, Bolts, and Nuts: Type and material recommended by piping system manufacturer, unless otherwise indicated.
  - E. Solder Filler Metals: ASTM B 32.
    1. Alloy E: Approximately 95 percent tin and 5 percent antimony, lead free.
  - F. Brazing Filler Metals: AWS A5.8.

- 1. BCuP Series: Copper-phosphorus alloys.
- 2. BAg1: Silver alloy.
- G. Welding Filler Metals: Comply with AWS D10.12 for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- H. Solvent Cements: Manufacturer's standard solvent cements for the following:
  - 1. ABS Piping: ASTM D 2235.
  - 2. CPVC Piping: ASTM F 493.
  - 3. PVC Piping: ASTM D 2564. Include primer according to ASTM F 656.
  - 4. PVC to ABS Piping Transition: ASTM D 3138.
- I. Plastic Pipe Seals: ASTM F 477, elastomeric gasket.
- J. Flanged, Ductile-Iron Pipe Gasket, Bolts, and Nuts: AWWA C110, rubber gasket, carbon-steel bolts and nuts.
- K. Couplings: Iron-body sleeve assembly, fabricated to match OD of plain-end, pressure pipes.
  - 1. Sleeve: ASTM A 126, Class B, gray iron.
  - 2. Followers: ASTM A 47 malleable iron or ASTM A 536 ductile iron.
  - 3. Gaskets: Rubber.
  - 4. Bolts and Nuts: AWWA C111.
  - 5. Finish: Enamel paint.

# 2.04 DIELECTRIC FITTINGS

- A. General: Assembly or fitting with insulating material isolating joined dissimilar metals, to prevent galvanic action and stop corrosion.
- B. Description: Combination of copper alloy and ferrous; threaded, solder, plain, and weldneck end types and matching piping system materials.
- C. Insulating Material: Suitable for system fluid, pressure, and temperature.
- D. Dielectric Unions: Factory-fabricated, union assembly, for 250-psig minimum working pressure at 180 deg F.
- E. Dielectric Flanges: Factory-fabricated, companion-flange assembly, for 150- or 300-psig minimum working pressure as required to suit system pressures.
- F. Dielectric-Flange Kits: Field-assembled, companion-flange assembly, full-face or ring type. Components include neoprene or phenolic gasket, phenolic or polyethylene bolt sleeves, phenolic washers, and steel backing washers.
  - 1. Provide separate companion flanges and steel bolts and nuts for 150- or 300-psig minimum working pressure as required to suit system pressures.
- G. Dielectric Couplings: Galvanized-steel coupling with inert and noncorrosive, thermoplastic lining; threaded ends; and 300-psig minimum working pressure at 225 deg F.

H. Dielectric Nipples: Electroplated steel nipple with inert and noncorrosive, thermoplastic lining; plain, threaded, or grooved ends; and 300-psig minimum working pressure at 225 deg F.

# 2.05 FLEXIBLE CONNECTORS

- A. General: Fabricated from materials suitable for system fluid and that will provide flexible pipe connections. Include 125-psig minimum working-pressure rating, unless higher working pressure is indicated, and ends according to the following:
  - 1. 2-Inch NPS and Smaller: Threaded.
  - 2. 2-1/2-Inch NPS and Larger: Flanged.
  - 3. Option for 2-1/2-Inch NPS and Larger: Grooved for use with keyed couplings.
- B. Bronze-Hose, Flexible Connectors: Corrugated, bronze, inner tubing covered with bronze wire braid. Include copper-tube ends or bronze flanged ends, braze welded to hose.
- C. Stainless-Steel-Hose/Steel Pipe, Flexible Connectors: Corrugated, stainless-steel, inner tubing covered with stainless-steel wire braid. Include steel nipples or flanges, welded to hose.

# 2.06 MECHANICAL SLEEVE SEALS

A. Description: Modular design, with interlocking rubber links shaped to continuously fill annular space between pipe and sleeve. Include connecting bolts and pressure plates.

# 2.07 PIPING SPECIALTIES

- A. Sleeves: The following materials are for wall, floor, slab, and roof penetrations:
  - 1. Steel Sheet Metal: 0.0239-inch minimum thickness, galvanized, round tube closed with welded longitudinal joint.
  - 2. Steel Pipe: ASTM A 53, Type E, Grade A, Schedule 40, galvanized, plain ends.
  - 3. Cast Iron: Cast or fabricated "wall pipe" equivalent to ductile-iron pressure pipe, with plain ends and integral water stop, unless otherwise indicated.
  - 4. Stack Sleeve Fittings: Manufactured, cast-iron sleeve with integral clamping flange. Include clamping ring and bolts and nuts for membrane flashing.
    a. Underdeck Clamp: Clamping ring with set screws.
  - 5. PVC: Manufactured, permanent, with nailing flange for attaching to wooden forms.
  - 6. PVC Pipe: ASTM D 1785, Schedule 40.
  - 7. PE: Manufactured, reusable, tapered, cup shaped, smooth outer surface, with nailing flange for attaching to wooden forms.
- B. Escutcheons: Manufactured wall, ceiling, and floor plates; deep-pattern type if required to conceal protruding fittings and sleeves.
  - 1. ID: Closely fit around pipe, tube, and insulation of insulated piping.
  - 2. OD: Completely cover opening.
  - Cast Brass: Split casting, with concealed hinge and set screw.
     a. Finish: Polished chrome-plate.
  - 4. Stamped Steel: One piece, with spring clips and chrome-plated finish.
  - 5. Stamped Steel: Split plate, with concealed hinge, spring clips, and chrome-plated finish.
  - 6. Cast-Iron Floor Plate: One-piece casting.
- 2.08 GROUT
  - A. Non-shrink, Nonmetallic Grout: ASTM C 1107, Grade B.
    - 1. Characteristics: Post-hardening, volume-adjusting, dry, hydraulic-cement grout, non-staining, noncorrosive, nongaseous, and recommended for interior and exterior applications.
    - 2. Design Mix: 5000-psig, 28-day compressive strength.
    - 3. Packaging: Premixed and factory packaged.

## **PART 3 EXECUTION**

- 3.01 PIPING SYSTEMS COMMON REQUIREMENTS
  - A. General: Install piping as described below, unless piping Sections specify otherwise. Individual Division 22 piping Sections specify unique piping installation requirements.
  - B. General Locations and Arrangements: Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated, unless deviations to layout are approved on Coordination Drawings.
  - C. Install piping to allow valve servicing.
  - D. Install piping at indicated slope.
  - E. Install components with pressure rating equal to or greater than system operating pressure.
  - F. Install piping in concealed interior and exterior locations, except in equipment rooms and service areas.
  - G. Install piping free of sags and bends.
  - H. Install exposed interior and exterior piping at right angles or parallel to building walls. Diagonal runs are prohibited, unless otherwise indicated.
  - I. Install piping tight to slabs, beams, joists, columns, walls, and other building elements. Allow sufficient space above removable ceiling panels to allow for ceiling panel removal.
  - J. Install piping to allow application of insulation plus 1-inch clearance around insulation.
  - K. Locate groups of pipes parallel to each other, spaced to permit valve servicing.
  - L. Install fittings for changes in direction and branch connections.
  - M. Install couplings according to manufacturer's written instructions.
  - N. Install pipe escutcheons for pipe penetrations of concrete and masonry walls, wall board partitions, and suspended ceilings according to the following:
    - 1. Chrome-Plated Piping: Cast brass, one piece, with set screw, and polished chrome-plated finish.

- 2. Uninsulated Piping Wall Escutcheons: Cast brass or stamped steel, with set screw.
- 3. Uninsulated Piping Floor Plates in Utility Areas: Cast-iron floor plates.
- 4. Insulated Piping: Cast brass or stamped steel; with concealed hinge, spring clips, and chrome-plated finish.
- 5. Piping in Utility Areas: Cast brass or stamped steel, with set-screw or spring clips.
- O. Sleeves are not required for core drilled holes.
- P. Permanent sleeves are not required for holes formed by PE removable sleeves.
- Q. Install sleeves for pipes passing through concrete and masonry walls, gypsum-board partitions, and concrete floor and roof slabs.
  - 1. Cut sleeves to length for mounting flush with both surfaces.
    - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level. Extend castiron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
  - 2. Build sleeves into walls and slabs as work progresses.
  - 3. Install sleeves large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation. Use the following sleeve materials:
    - a. Steel Pipe Sleeves: For pipes smaller than 6-inch NPS.
    - b. Steel, Sheet-Metal Sleeves: For pipes 6-inch NPS and larger, penetrating gypsum-board partitions.
    - c. Stack Sleeve Fittings: For pipes penetrating floors with membrane waterproofing. Secure flashing between clamping flanges. Install section of cast-iron soil pipe to extend sleeve to 2 inches above finished floor level. Refer to Division 7 Section "Sheet Metal Flashing and Trim" for flashing.
      - 1) Seal space outside of sleeve fittings with non-shrink, nonmetallic grout.
  - 4. Except for underground wall penetrations, seal annular space between sleeve and pipe or pipe insulation, using elastomeric joint sealants. Refer to Division 7 Section "Joint Sealants" for materials.
  - 5. Use Type S, Grade NS, Class 25, Use O, neutral-curing silicone sealant, unless otherwise indicated.
- R. Aboveground, Exterior-Wall, Pipe Penetrations: Seal penetrations using sleeves and mechanical sleeve seals. Size sleeve for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
  - 1. Install steel pipe for sleeves smaller than 6 inches in diameter.
  - 2. Install cast-iron "wall pipes" for sleeves 6 inches in diameter and larger.
  - 3. Assemble and install mechanical sleeve seals according to manufacturer's written instructions. Tighten bolts that cause rubber sealing elements to expand and make watertight seal.
- S. Underground, Exterior-Wall, Pipe Penetrations: Install cast-iron "wall pipes" for sleeves. Seal pipe penetrations using mechanical sleeve seals. Size sleeve for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
  - 1. Assemble and install mechanical sleeve seals according to manufacturer's written instructions. Tighten bolts that cause rubber sealing elements to expand and make watertight seal.

- T. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with fire stopping materials. Refer to Division 7 Section "Firestopping" for materials.
- U. Verify final equipment locations for roughing-in.
- V. Refer to equipment specifications in other Sections of these Specifications for roughing-in requirements.
- W. Piping Joint Construction: Join pipe and fittings as follows and as specifically required in individual piping specification Sections:
  - 1. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
  - 2. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
  - 3. Soldered Joints: Construct joints according to AWS's "Soldering Manual," Chapter "The Soldering of Pipe and Tube"; or CDA's "Copper Tube Handbook."
  - 4. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," Chapter "Pipe and Tube."
  - 5. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
    - a. Note internal length of threads in fittings or valve ends, and proximity of internal seat or wall, to determine how far pipe should be threaded into joint.
    - b. Apply appropriate tape or thread compound to external pipe threads, unless dry seal threading is specified.
    - c. Align threads at point of assembly.
    - d. Tighten joint with wrench. Apply wrench to valve end into which pipe is being threaded.
    - e. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
  - 6. Welded Joints: Construct joints according to AWS D10.12, "Recommended Practices and Procedures for Welding Low Carbon Steel Pipe," using qualified processes and welding operators according to "Quality Assurance" Article.
  - 7. Flanged Joints: Align flange surfaces parallel. Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Assemble joints by sequencing bolt tightening to make initial contact of flanges and gaskets as flat and parallel as possible. Use suitable lubricants on bolt threads. Tighten bolts gradually and uniformly using torque wrench.
  - 8. Plastic Piping Solvent-Cement Joints: Clean and dry joining surfaces by wiping with clean cloth or paper towels. Join pipe and fittings according to the following:
    - a. Comply with ASTM F 402 for safe-handling practice of cleaners, primers, and solvent cements.
    - b. ABS Piping: ASTM D 2235 and ASTM D 2661.
    - c. CPVC Piping: ASTM D 2846 and ASTM F 493.
    - d. PVC Pressure Piping: ASTM D 2672.
    - e. PVC Non-pressure Piping: ASTM D 2855.
    - f. PVC to ABS Non-pressure Transition Fittings: Procedure and solvent cement according to ASTM D 3138.
  - 9. Plastic Piping Heat-Fusion Joints: Clean and dry joining surfaces by wiping with clean cloth or paper towels. Join according to ASTM D 2657 procedures and manufacturer's written instructions.
    - a. Plain-End Pipe and Fittings: Use butt fusion.

- b. Plain-End Pipe and Socket Fittings: Use socket fusion.
- X. Piping Connections: Make connections according to the following, unless otherwise indicated:
  - 1. Install unions, in piping 2-inch NPS and smaller, adjacent to each valve and at final connection to each piece of equipment with 2-inch NPS or smaller threaded pipe connection.
  - 2. Install flanges, in piping 2-1/2-inch NPS and larger, adjacent to flanged valves and at final connection to each piece of equipment with flanged pipe connection.
  - 3. Dry Piping Systems: Install dielectric unions and flanges to connect piping materials of dissimilar metals.
  - 4. Wet Piping Systems: Install dielectric coupling and nipple fittings to connect piping materials of dissimilar metals.

## 3.02 EQUIPMENT INSTALLATION - COMMON REQUIREMENTS

- A. Install equipment to provide maximum possible headroom, if mounting heights are not indicated.
- B. Install equipment according to approved submittal data. Portions of the Work are shown only in diagrammatic form. Refer conflicts to Architect.
- C. Install equipment level and plumb, parallel and perpendicular to other building systems and components in exposed interior spaces, unless otherwise indicated.
- D. Install mechanical equipment to facilitate service, maintenance, and repair or replacement of components. Connect equipment for ease of disconnecting, with minimum interference to other installations. Extend grease fittings to accessible locations.
- E. Install equipment giving right of way to piping installed at required slope.
- F. Install flexible connectors on equipment side of shutoff valves, horizontally and parallel to equipment shafts if possible.

## 3.03 PAINTING AND FINISHING

- A. Refer to Division 9 Section "Painting" for paint materials, surface preparation, and application of paint.
- B. Apply paint to exposed piping according to the following, unless otherwise indicated:
  - 1. Interior, Ferrous Piping: Use semi-gloss, acrylic-enamel finish. Include finish coat over enamel undercoat and primer.
  - 2. Interior, Galvanized-Steel Piping: Use semi-gloss, acrylic-enamel finish. Include two finish coats over galvanized metal primer.
  - 3. Interior, Ferrous Supports: Use semi-gloss, acrylic-enamel finish. Include finish coat over enamel undercoat and primer.
  - 4. Exterior, Ferrous Piping: Use semi-gloss, acrylic-enamel finish. Include two finish coats over rust-inhibitive metal primer.
  - 5. Exterior, Galvanized-Steel Piping: Use semi-gloss, acrylic-enamel finish. Include two finish coats over galvanized metal primer.
  - 6. Exterior, Ferrous Supports: Use semi-gloss, acrylic-enamel finish. Include two finish coats over rust-inhibitive metal primer.

- C. Paint visible sheet metal behind ceiling inlets and outlets flat black.
- D. Do not paint piping specialties with factory-applied finish.
- E. Damage and Touchup: Repair marred and damaged factory-painted finishes with materials and procedures to match original factory finish.

## 3.04 CONCRETE BASES

A. Construct concrete bases of dimensions indicated, but not less than 4 inches larger in both directions than supported unit. Follow supported equipment manufacturer's setting templates for anchor bolt and tie locations. Use 3000-psig, 28-day compressive-strength concrete and reinforcement as specified in Division 3 Section "Cast-in-Place Concrete."

## 3.05 ERECTION OF METAL SUPPORTS AND ANCHORAGE

- A. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor mechanical materials and equipment.
- B. Field Welding: Comply with AWS D1.1, "Structural Welding Code--Steel."

## 3.06 ERECTION OF WOOD SUPPORTS AND ANCHORAGE

- A. Cut, fit, and place wood grounds, nailers, blocking, and anchorage to support and anchor mechanical materials and equipment.
- B. Select fastener sizes that will not penetrate members if opposite side will be exposed to view or will receive finish materials. Tighten connections between members. Install fasteners without splitting wood members.
- C. Attach to substrates as required to support applied loads.

## 3.07 CUTTING AND PATCHING

- A. Cut, channel, chase, and drill floors, walls, partitions, ceilings, and other surfaces necessary for mechanical installations. Perform cutting by skilled mechanics of trades involved.
- B. Repair cut surfaces to match adjacent surfaces.

## 3.08 GROUTING

- A. Install nonmetallic, non-shrink, grout for mechanical equipment base bearing surfaces, pump and other equipment base plates, and anchors. Mix grout according to manufacturer's written instructions.
- B. Clean surfaces that will come into contact with grout.
- C. Provide forms as required for placement of grout.
- D. Avoid air entrapment during placing of grout.
- E. Place grout, completely filling equipment bases.

- F. Place grout on concrete bases to provide smooth bearing surface for equipment.
- G. Place grout around anchors.
- H. Cure placed grout according to manufacturer's written instructions.

END OF SECTION

## SECTION 23 05 00

## COMMON WORK RESULTS FOR HVAC

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

## 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Piping materials and installation instructions common to most piping systems.
  - 2. Dielectric fittings.
  - 3. Mechanical sleeve seals.
  - 4. Sleeves.
  - 5. Escutcheons.
  - 6. Grout.
  - 7. HVAC demolition.
  - 8. Equipment installation requirements common to equipment sections.
  - 9. Painting and finishing.
  - 10. Supports and anchorages.

## 1.03 DEFINITIONS

- A. Finished Spaces: Spaces other than mechanical and electrical equipment rooms, furred spaces, pipe and duct chases, unheated spaces immediately below roof, spaces above ceilings, unexcavated spaces, crawlspaces, and tunnels.
- B. Exposed, Interior Installations: Exposed to view indoors. Examples include finished occupied spaces and mechanical equipment rooms.
- C. Exposed, Exterior Installations: Exposed to view outdoors or subject to outdoor ambient temperatures and weather conditions. Examples include rooftop locations.
- D. Concealed, Interior Installations: Concealed from view and protected from physical contact by building occupants. Examples include above ceilings and chases.
- E. Concealed, Exterior Installations: Concealed from view and protected from weather conditions and physical contact by building occupants but subject to outdoor ambient temperatures. Examples include installations within unheated shelters.
- F. The following are industry abbreviations for plastic materials:
  - 1. CPVC: Chlorinated polyvinyl chloride plastic.
  - 2. PE: Polyethylene plastic.
  - 3. PVC: Polyvinyl chloride plastic.
- G. The following are industry abbreviations for rubber materials:
  - 1. EPDM: Ethylene-propylene-diene terpolymer rubber.
  - 2. NBR: Acrylonitrile-butadiene rubber.

## 1.04 SUBMITTALS

- A. Product Data: For the following:
  - 1. Transition fittings.
  - 2. Dielectric fittings.
  - 3. Mechanical sleeve seals.
  - 4. Escutcheons.
- B. Welding certificates.

## 1.05 QUALITY ASSURANCE

- A. Steel Support Welding: Qualify processes and operators according to AWS D1.1, "Structural Welding Code--Steel."
- B. Steel Pipe Welding: Qualify processes and operators according to ASME Boiler and Pressure Vessel Code: Section IX, "Welding and Brazing Qualifications."
  - 1. Comply with provisions in ASME B31 Series, "Code for Pressure Piping."
  - 2. Certify that each welder has passed AWS qualification tests for welding processes involved and that certification is current.
- C. Electrical Characteristics for HVAC Equipment: Equipment of higher electrical characteristics may be furnished provided such proposed equipment is approved in writing and connecting electrical services, circuit breakers, and conduit sizes are appropriately modified. If minimum energy ratings or efficiencies are specified, equipment shall comply with requirements.

## 1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver pipes and tubes with factory-applied end caps. Maintain end caps through shipping, storage, and handling to prevent pipe end damage and to prevent entrance of dirt, debris, and moisture.
- B. Store plastic pipes protected from direct sunlight. Support to prevent sagging and bending.

## 1.07 COORDINATION

- A. Arrange for pipe spaces, chases, slots, and openings in building structure during progress of construction, to allow for HVAC installations.
- B. Coordinate installation of required supporting devices and set sleeves in poured-in-place concrete and other structural components as they are constructed.
- C. Coordinate requirements for access panels and doors for HVAC items requiring access that are concealed behind finished surfaces. Access panels and doors are specified in Division 08 Section "Access Doors and Frames."

## PART 2 PRODUCTS

- 2.01 MANUFACTURERS
  - A. In other Part 2 articles where subparagraph titles below introduce lists, the following requirements apply for product selection:
    - 1. Manufacturers: Subject to compliance with requirements, provide products by the manufacturers specified.

- 2.02 PIPE, TUBE, AND FITTINGS
  - A. Refer to individual Division 23 piping Sections for pipe, tube, and fitting materials and joining methods.
  - B. Pipe Threads: ASME B1.20.1 for factory-threaded pipe and pipe fittings.

## 2.03 JOINING MATERIALS

- A. Refer to individual Division 23 piping Sections for special joining materials not listed below.
- B. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.
  - 1. ASME B16.21, nonmetallic, flat, asbestos-free, 1/8-inch maximum thickness unless thickness or specific material is indicated.
    - a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.
    - b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.
  - 2. AWWA C110, rubber, flat face, 1/8 inch thick, unless otherwise indicated; and full-face or ring type, unless otherwise indicated.
- C. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.
- D. Solder Filler Metals: ASTM B 32, lead-free alloys. Include water-flushable flux according to ASTM B 813.
- E. Brazing Filler Metals: AWS A5.8, BCuP Series, copper-phosphorus alloys for general-duty brazing, unless otherwise indicated; and AWS A5.8, BAg1, silver alloy for refrigerant piping, unless otherwise indicated.
- F. Welding Filler Metals: Comply with AWS D10.12 for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.

## 2.04 DIELECTRIC FITTINGS

- A. Description: Combination fitting of copper alloy and ferrous materials with threaded, solderjoint, plain, or weld-neck end connections that match piping system materials.
- B. Insulating Material: Suitable for system fluid, pressure, and temperature.
- C. Dielectric Unions: Factory-fabricated, union assembly, for 250-psig minimum working pressure at 180 deg F.
  - 1. Manufacturers:
    - a. Capitol Manufacturing Co.
    - b. Central Plastics Company.
    - c. Eclipse, Inc.
    - d. Epco Sales, Inc.
    - e. Hart Industries, International, Inc.
    - f. Watts Industries, Inc.; Water Products Div.
    - g. Zurn Industries, Inc.; Wilkins Div.
- D. Dielectric Flanges: Factory-fabricated, companion-flange assembly, for 150- or 300-psig minimum working pressure as required to suit system pressures.
  - 1. Manufacturers:
    - a. Capitol Manufacturing Co.
    - b. Central Plastics Company.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- C. Epco Sales, Inc.
- d. Watts Industries. Inc.: Water Products Div.
- Dielectric-Flange Kits: Companion-flange assembly for field assembly. Include flanges, full-E. face- or ring-type neoprene or phenolic gasket, phenolic or polyethylene bolt sleeves, phenolic washers, and steel backing washers.
  - Manufacturers: 1.
    - Advance Products & Systems, Inc. a.
    - Calpico, Inc. b.
    - Central Plastics Company. C.
    - Pipeline Seal and Insulator, Inc. d.
  - Separate companion flanges and steel bolts and nuts shall have 150- or 300-psig 2. minimum working pressure where required to suit system pressures.
- Dielectric Couplings: Galvanized-steel coupling with inert and noncorrosive, thermoplastic F. lining; threaded ends; and 300-psig minimum working pressure at 225 deg F. 1.
  - Manufacturers:
    - Calpico, Inc. a.
    - b. Lochinvar Corp.
- Dielectric Nipples: Electroplated steel nipple with inert and noncorrosive, thermoplastic lining; G. plain, threaded, or grooved ends; and 300-psig minimum working pressure at 225 deg F.
  - Manufacturers: 1.
    - Perfection Corp. a.
    - Precision Plumbing Products, Inc. b.
    - C. Sioux Chief Manufacturing Co., Inc.
    - d. Victaulic Co. of America.

#### 2.05 MECHANICAL SLEEVE SEALS

- Description: Modular sealing element unit, designed for field assembly, to fill annular space Α. between pipe and sleeve.
  - Manufacturers: 1.
    - Advance Products & Systems, Inc. a.
    - Metraflex Co. b.
    - Pipeline Seal and Insulator, Inc. Linkseal С
  - Sealing Elements: EPDM interlocking links shaped to fit surface of pipe. Include type 2. and number required for pipe material and size of pipe.
  - 3. Pressure Plates: Plastic. Include two for each sealing element.
  - 4. Connecting Bolts and Nuts: Carbon steel with corrosion-resistant coating of length required to secure pressure plates to sealing elements. Include one for each sealing element.

#### 2.06 SLEEVES

- A. Galvanized-Steel Sheet: 0.0239-inch minimum thickness; round tube closed with welded longitudinal joint.
- B. Steel Pipe: ASTM A 53, Type E, Grade B, Schedule 40, galvanized, plain ends.
- C. Cast Iron: Cast or fabricated "wall pipe" equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.

## 2.07 ESCUTCHEONS

- A. Description: Manufactured wall and ceiling escutcheons and floor plates, with an ID to closely fit around pipe, tube, and insulation of insulated piping and an OD that completely covers opening.
- B. One-Piece, Deep-Pattern Type: Deep-drawn, box-shaped brass with polished chrome-plated finish.
- C. One-Piece, Cast-Brass Type: With set screw.1. Finish: Polished chrome-plated.
- D. Split-Casting, Cast-Brass Type: With concealed hinge and set screw.1. Finish: Polished chrome-plated.
- E. One-Piece, Stamped-Steel Type: With set screw or spring clips and chrome-plated finish.
- F. Split-Plate, Stamped-Steel Type: With concealed hinge, spring clips, and chrome-plated finish.
- G. One-Piece, Floor-Plate Type: Cast-iron floor plate.
- H. Split-Casting, Floor-Plate Type: Cast brass with concealed hinge and set screw.

## 2.08 GROUT

- A. Description: ASTM C 1107, Grade B, nonshrink and nonmetallic, dry hydraulic-cement grout.
   1. Characteristics: Post-hardening, volume-adjusting, nonstaining, noncorrosive,
  - nongaseous, and recommended for interior and exterior applications.
  - 2. Design Mix: 5000-psi, 28-day compressive strength.
  - 3. Packaging: Premixed and factory packaged.

## PART 3 EXECUTION

- 3.01 HVAC DEMOLITION
  - A. Refer to Division 01 Section "Cutting and Patching" and Division 02 Section "Selective Structure Demolition" for general demolition requirements and procedures.
  - B. Disconnect, demolish, and remove HVAC systems, equipment, and components indicated to be removed.
    - 1. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.

- 2. Piping to Be Abandoned in Place: Drain piping and cap or plug piping with same or compatible piping material.
- 3. Ducts to Be Removed: Remove portion of ducts indicated to be removed and plug remaining ducts with same or compatible ductwork material.
- 4. Ducts to Be Abandoned in Place: Cap or plug ducts with same or compatible ductwork material.
- 5. Equipment to Be Removed: Disconnect and cap services and remove equipment.
- 6. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
- 7. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
- C. If pipe, insulation, or equipment to remain is damaged in appearance or is unserviceable, remove damaged or unserviceable portions and replace with new products of equal capacity and quality.

# 3.02 PIPING SYSTEMS - COMMON REQUIREMENTS

- A. Install piping according to the following requirements and Division 23 Sections specifying piping systems.
- B. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicated locations and arrangements were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- C. Install piping in concealed locations, unless otherwise indicated and except in equipment rooms and service areas.
- D. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- E. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- F. Install piping to permit valve servicing.
- G. Install piping at indicated slopes.
- H. Install piping free of sags and bends.
- I. Install fittings for changes in direction and branch connections.
- J. Install piping to allow application of insulation.
- K. Select system components with pressure rating equal to or greater than system operating pressure.
- Install escutcheons for penetrations of walls, ceilings, and floors according to the following:
   New Piping:
  - a. Piping with Fitting or Sleeve Protruding from Wall: One-piece, deep-pattern type.
  - b. Chrome-Plated Piping: One-piece, cast-brass type with polished chrome-plated finish.
  - c. Insulated Piping: One-piece, stamped-steel type with spring clips.

- d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, castbrass type with polished chrome-plated finish.
- e. Bare Piping at Wall and Floor Penetrations in Finished Spaces: One-piece, stamped-steel type.
- f. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece or split-casting, cast-brass type with polished chrome-plated finish.
- g. Bare Piping at Ceiling Penetrations in Finished Spaces: One-piece, stamped-steel type or split-plate, stamped-steel type with concealed hinge and set screw.
- h. Bare Piping in Unfinished Service Spaces: One-piece, cast-brass type with polished chrome-plated finish.
- i. Bare Piping in Unfinished Service Spaces: One-piece, stamped-steel type with concealed hinge and set screw or spring clips.
- j. Bare Piping in Equipment Rooms: One-piece, cast-brass type.
- k. Bare Piping in Equipment Rooms: One-piece, stamped-steel type with set screw or spring clips.
- I. Bare Piping at Floor Penetrations in Equipment Rooms: One-piece, floor-plate type.
- 2. Existing Piping: Use the following:
  - a. Chrome-Plated Piping: Split-casting, cast-brass type with chrome-plated finish.
  - b. Insulated Piping: Split-plate, stamped-steel type with concealed hinge and spring clips.
  - c. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split-casting, castbrass type with chrome-plated finish.
  - d. Bare Piping at Wall and Floor Penetrations in Finished Spaces: Split-plate, stamped-steel type with concealed hinge and spring clips.
  - e. Bare Piping at Ceiling Penetrations in Finished Spaces: Split-casting, cast-brass type with chrome-plated finish.
  - f. Bare Piping at Ceiling Penetrations in Finished Spaces: Split-plate, stamped-steel type with concealed hinge and set screw.
  - g. Bare Piping in Unfinished Service Spaces: Split-casting, cast-brass type with polished chrome-plated finish.
  - h. Bare Piping in Unfinished Service Spaces: Split-plate, stamped-steel type with concealed hinge and set screw or spring clips.
  - i. Bare Piping in Equipment Rooms: Split-casting, cast-brass type.
  - j. Bare Piping in Equipment Rooms: Split-plate, stamped-steel type with set screw or spring clips.
  - k. Bare Piping at Floor Penetrations in Equipment Rooms: Split-casting, floor-plate type.
- M. Sleeves are not required for core-drilled holes.
- N. Permanent sleeves are not required for holes formed by removable PE sleeves.
- O. Install sleeves for pipes passing through concrete and masonry walls and concrete floor and roof slabs.
- P. Install sleeves for pipes passing through concrete and masonry walls, gypsum-board partitions, and concrete floor and roof slabs.
  - 1. Cut sleeves to length for mounting flush with both surfaces.
    - a. Exception: Extend sleeves installed in floors of mechanical equipment areas or other wet areas 2 inches above finished floor level. Extend cast-iron sleeve fittings below floor slab as required to secure clamping ring if ring is specified.
  - 2. Install sleeves in new walls and slabs as new walls and slabs are constructed.
  - 3. Install sleeves that are large enough to provide 1/4-inch annular clear space between sleeve and pipe or pipe insulation. Use the following sleeve materials:

- a. Steel Pipe Sleeves: For pipes smaller than NPS 6.
- b. Steel Sheet Sleeves: For pipes NPS 6 and larger, penetrating gypsum-board partitions.
- c. Stack Sleeve Fittings: For pipes penetrating floors with membrane waterproofing. Secure flashing between clamping flanges. Install section of cast-iron soil pipe to extend sleeve to 2 inches above finished floor level. Refer to Division 07 Section "Sheet Metal Flashing and Trim" for flashing.
  - 1) Seal space outside of sleeve fittings with grout.
- 4. Except for underground wall penetrations, seal annular space between sleeve and pipe or pipe insulation, using joint sealants appropriate for size, depth, and location of joint. Refer to Division 07 Section "Joint Sealants" for materials and installation.
- Q. Aboveground, Exterior-Wall Pipe Penetrations: Seal penetrations using sleeves and mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
  - 1. Install steel pipe for sleeves smaller than 6 inches in diameter.
  - 2. Install cast-iron "wall pipes" for sleeves 6 inches and larger in diameter.
  - 3. Mechanical Sleeve Seal Installation: Select type and number of sealing elements required for pipe material and size. Position pipe in center of sleeve. Assemble mechanical sleeve seals and install in annular space between pipe and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.
- R. Fire-Barrier Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at pipe penetrations. Seal pipe penetrations with firestop materials. Refer to Division 07 Section "Penetration Firestopping" for materials.
- S. Verify final equipment locations for roughing-in.
- T. Refer to equipment specifications in other Sections of these Specifications for roughing-in requirements.
- 3.03 PIPING JOINT CONSTRUCTION
  - A. Join pipe and fittings according to the following requirements and Division 23 Sections specifying piping systems.
  - B. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
  - C. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
  - D. Soldered Joints: Apply ASTM B 813, water-flushable flux, unless otherwise indicated, to tube end. Construct joints according to ASTM B 828 or CDA's "Copper Tube Handbook," using lead-free solder alloy complying with ASTM B 32.
  - E. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," "Pipe and Tube" Chapter, using copper-phosphorus brazing filler metal complying with AWS A5.8.
  - F. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
    - 1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.

- 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- G. Welded Joints: Construct joints according to AWS D10.12, using qualified processes and welding operators according to Part 1 "Quality Assurance" Article.
- H. Flanged Joints: Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.

## 3.04 PIPING CONNECTIONS

- A. Make connections according to the following, unless otherwise indicated:
  - 1. Install unions, in piping NPS 2 and smaller, adjacent to each valve and at final connection to each piece of equipment.
  - 2. Install flanges, in piping NPS 2-1/2 and larger, adjacent to flanged valves and at final connection to each piece of equipment.
  - 3. Dry Piping Systems: Install dielectric unions and flanges to connect piping materials of dissimilar metals.
  - 4. Wet Piping Systems: Install dielectric coupling and nipple fittings to connect piping materials of dissimilar metals.

## 3.05 EQUIPMENT INSTALLATION - COMMON REQUIREMENTS

- A. Install equipment to allow maximum possible headroom unless specific mounting heights are not indicated.
- B. Install equipment level and plumb, parallel and perpendicular to other building systems and components in exposed interior spaces, unless otherwise indicated.
- C. Install HVAC equipment to facilitate service, maintenance, and repair or replacement of components. Connect equipment for ease of disconnecting, with minimum interference to other installations. Extend grease fittings to accessible locations.
- D. Install equipment to allow right of way for piping installed at required slope.

#### 3.06 PAINTING

- A. Painting of HVAC systems, equipment, and components is specified in Division 09 Sections "Interior Painting" and "Exterior Painting."
- B. Damage and Touchup: Repair marred and damaged factory-painted finishes with materials and procedures to match original factory finish.

#### 3.07 ERECTION OF METAL SUPPORTS AND ANCHORAGES

- A. Refer to Division 05 Section "Metal Fabrications" for structural steel.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor HVAC materials and equipment.
- C. Field Welding: Comply with AWS D1.1.

## 3.08 GROUTING

- A. Mix and install grout for HVAC equipment base bearing surfaces, pump and other equipment base plates, and anchors.
- B. Clean surfaces that will come into contact with grout.
- C. Provide forms as required for placement of grout.
- D. Avoid air entrapment during placement of grout.
- E. Place grout, completely filling equipment bases.
- F. Place grout on concrete bases and provide smooth bearing surface for equipment.
- G. Place grout around anchors.
- H. Cure placed grout.

END OF SECTION

## SECTION 23 05 13

#### COMMON MOTOR REQUIREMENTS FOR HVAC EQUIPMENT

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

A. Section includes general requirements for single-phase and polyphase, general-purpose, horizontal, small and medium, squirrel-cage induction motors for use on ac power systems up to 600 V and installed at equipment manufacturer's factory or shipped separately by equipment manufacturer for field installation.

## 1.03 COORDINATION

- A. Coordinate features of motors, installed units, and accessory devices to be compatible with the following:
  - 1. Motor controllers.
  - 2. Torque, speed, and horsepower requirements of the load.
  - 3. Ratings and characteristics of supply circuit and required control sequence.
  - 4. Ambient and environmental conditions of installation location.

## PART 2 PRODUCTS

## 2.01 GENERAL MOTOR REQUIREMENTS

- A. Comply with requirements in this Section except when stricter requirements are specified in HVAC equipment schedules or Sections.
- B. Comply with NEMA MG 1 unless otherwise indicated.
- C. Comply with IEEE 841 for severe-duty motors.

## 2.02 MOTOR CHARACTERISTICS

- A. Duty: Continuous duty at ambient temperature of 40 deg C and at altitude of 3300 feet above sea level.
- B. Capacity and Torque Characteristics: Sufficient to start, accelerate, and operate connected loads at designated speeds, at installed altitude and environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.

## 2.03 POLYPHASE MOTORS

- A. Description: NEMA MG 1, Design B, medium induction motor.
- B. Efficiency: Energy efficient, as defined in NEMA MG 1.

- C. Service Factor: 1.15.
- D. Multispeed Motors: Variable torque.
  - 1. For motors with 2:1 speed ratio, consequent pole, single winding.
  - 2. For motors with other than 2:1 speed ratio, separate winding for each speed.
- E. Multispeed Motors: Separate winding for each speed.
- F. Rotor: Random-wound, squirrel cage.
- G. Bearings: Regreasable, shielded, antifriction ball bearings suitable for radial and thrust loading.
- H. Temperature Rise: Match insulation rating.
- I. Insulation: Class F.
- J. Code Letter Designation:
  - 1. Motors 15 HP and Larger: NEMA starting Code F or Code G.
  - 2. Motors Smaller than 15 HP: Manufacturer's standard starting characteristic.
- K. Enclosure Material: Cast iron for motor frame sizes 324T and larger; rolled steel for motor frame sizes smaller than 324T.

## 2.04 POLYPHASE MOTORS WITH ADDITIONAL REQUIREMENTS

- A. Motors Used with Reduced-Voltage and Multispeed Controllers: Match wiring connection requirements for controller with required motor leads. Provide terminals in motor terminal box, suited to control method.
- B. Motors Used with Variable Frequency Controllers: Ratings, characteristics, and features coordinated with and approved by controller manufacturer.
  - 1. Windings: Copper magnet wire with moisture-resistant insulation varnish, designed and tested to resist transient spikes, high frequencies, and short time rise pulses produced by pulse-width modulated inverters.
  - 2. Energy- and Premium-Efficient Motors: Class B temperature rise; Class F insulation.
  - 3. Inverter-Duty Motors: Class F temperature rise; Class H insulation.
  - 4. Thermal Protection: Comply with NEMA MG 1 requirements for thermally protected motors.
- C. Severe-Duty Motors: Comply with IEEE 841, with 1.15 minimum service factor.

# 2.05 SINGLE-PHASE MOTORS

- A. Motors larger than 1/20 hp shall be one of the following, to suit starting torque and requirements of specific motor application:
  - 1. Permanent-split capacitor.
  - 2. Split phase.
  - 3. Capacitor start, inductor run.
  - 4. Capacitor start, capacitor run.
- B. Multispeed Motors: Variable-torque, permanent-split-capacitor type.
- C. Bearings: Prelubricated, antifriction ball bearings or sleeve bearings suitable for radial and thrust loading.

- D. Motors 1/20 HP and Smaller: Shaded-pole type.
- E. Thermal Protection: Internal protection to automatically open power supply circuit to motor when winding temperature exceeds a safe value calibrated to temperature rating of motor insulation. Thermal-protection device shall automatically reset when motor temperature returns to normal range.

PART 3 EXECUTION (Not Applicable)

END OF SECTION

## **SECTION 23 05 19**

## METERS AND GAGES FOR HVAC PIPING

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

## 1.02 SUMMARY

- A. Section Includes:
  - 1. Liquid-in-glass thermometers.
  - 2. Light-activated thermometers.
  - 3. Thermowells.
  - 4. Dial-type pressure gages.
  - 5. Gage attachments.
  - 6. Test plugs.
  - 7. Test-plug kits.

## 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Wiring Diagrams: For power, signal, and control wiring.
- C. Product Certificates: For each type of meter and gage, from manufacturer.
- D. Operation and Maintenance Data: For meters and gages to include in operation and maintenance manuals.

## PART 2 PRODUCTS

- 2.01 LIQUID-IN-GLASS THERMOMETERS
  - A. Metal-Case, Industrial-Style, Liquid-in-Glass Thermometers:
    - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 2. Basis-of-Design Product: Subject to compliance with requirements, provide or comparable product by one of the following:
      - a. Trerice, H. O. Co.
      - b. Weiss Instruments, Inc.
      - c. Weksler.
    - 3. Standard: ASME B40.200.
    - 4. Case: Cast aluminum; 7-inch nominal size unless otherwise indicated.
    - 5. Case Form: Adjustable angle unless otherwise indicated.
    - 6. Tube: Glass with magnifying lens and blue organic liquid.
    - 7. Tube Background: Nonreflective aluminum with permanently etched scale markings graduated in deg F.
    - 8. Window: Glass or plastic.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 9. Stem: Aluminum and of length to suit installation.
  - a. Design for Air-Duct Installation: With ventilated shroud.
  - b. Design for Thermowell Installation: Bare stem.
- 10. Connector: 1-1/4 inches, with ASME B1.1 screw threads.
- 11. Accuracy: Plus or minus 1 percent of scale range or one scale division, to a maximum of 1.5 percent of scale range.
- B. Plastic-Case, Industrial-Style, Liquid-in-Glass Thermometers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Ernst Flow Industries.
    - b. Marsh Bellofram.
    - c. Watts Regulator Co.; a div. of Watts Water Technologies, Inc.
    - d. Weiss Instruments, Inc.
    - e. WIKA Instrument Corporation USA.
    - f. Weksler.
  - 2. Standard: ASME B40.200.
  - 3. Case: Plastic; 7-inch nominal size unless otherwise indicated.
  - 4. Case Form: Adjustable angle unless otherwise indicated.
  - 5. Tube: Glass with magnifying lens and blue or red organic liquid.
  - 6. Tube Background: Nonreflective aluminum with permanently etched scale markings graduated in deg F.
  - 7. Window: Glass or plastic.
  - 8. Stem: Aluminum and of length to suit installation.
    - a. Design for Thermowell Installation: Bare stem.
  - 9. Connector: 1-1/4 inches, with ASME B1.1 screw threads.
  - 10. Accuracy: Plus or minus 1 percent of scale range or one scale division, to a maximum of 1.5 percent of scale range.

# 2.02 LIGHT-ACTIVATED THERMOMETERS

- A. Direct-Mounted, Light-Activated Thermometers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Trerice, H. O. Co.
    - b. Weiss Instruments, Inc.
    - c. WIKA Instrument Corporation USA.
    - d. Winters Instruments U.S.
  - 2. Case: Plastic; 7-inch nominal size unless otherwise indicated.
  - 3. Scale(s): Deg F.
  - 4. Case Form: Adjustable angle.
  - 5. Connector: 1-1/4 inches, with ASME B1.1 screw threads.
  - 6. Stem: Aluminum and of length to suit installation. a. Design for Thermowell Installation: Bare stem.
  - 7. Display: Digital.
  - 8. Accuracy: Plus or minus 2 deg F.
- 2.03 THERMOWELLS
  - A. Thermowells:
    - 1. Standard: ASME B40.200.
    - 2. Description: Pressure-tight, socket-type fitting made for insertion into piping tee fitting.
    - 3. Material for Use with Copper Tubing: CNR or CUNI.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 4. Material for Use with Steel Piping: CRES.
- 5. Type: Stepped shank unless straight or tapered shank is indicated.
- 6. External Threads: NPS 1/2, NPS 3/4, or NPS 1, ASME B1.20.1 pipe threads.
- 7. Internal Threads: 1/2, 3/4, and 1 inch, with ASME B1.1 screw threads.
- 8. Bore: Diameter required to match thermometer bulb or stem.
- 9. Insertion Length: Length required to match thermometer bulb or stem.
- 10. Lagging Extension: Include on thermowells for insulated piping and tubing.
- 11. Bushings: For converting size of thermowell's internal screw thread to size of thermometer connection.
- B. Heat-Transfer Medium: Mixture of graphite and glycerin.

## 2.04 PRESSURE GAGES

- A. Direct-Mounted, Metal-Case, Dial-Type Pressure Gages:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Ernst Flow Industries.
    - b. Marsh Bellofram.
    - c. Trerice, H. O. Co.
    - d. Watts Regulator Co.; a div. of Watts Water Technologies, Inc.
    - e. Weiss Instruments, Inc.
    - f. WIKA Instrument Corporation USA.
  - 2. Standard: ASME B40.100.
  - 3. Case: Liquid-filled type(s); cast aluminum or drawn steel; 4-1/2-inch nominal diameter.
  - 4. Pressure-Element Assembly: Bourdon tube unless otherwise indicated.
  - 5. Pressure Connection: Brass, with NPS 1/4 or NPS 1/2 NPS 1/2, ASME B1.20.1 pipe threads and bottom-outlet type unless back-outlet type is indicated.
  - 6. Movement: Mechanical, with link to pressure element and connection to pointer.
  - 7. Dial: Nonreflective aluminum with permanently etched scale markings graduated in psi.
  - 8. Pointer: Dark-colored metal.
  - 9. Window: Glass or plastic.
  - 10. Ring: Stainless steel.
  - 11. Accuracy: Grade B, plus or minus 2 percent of middle half of scale range.

## 2.05 GAGE ATTACHMENTS

- A. Snubbers: ASME B40.100, brass; with NPS 1/4 or NPS 1/2, ASME B1.20.1 pipe threads and piston or porous-metal-type surge-dampening device. Include extension for use on insulated piping.
- B. Valves: Brass or stainless-steel needle, with NPS 1/4 or NPS 1/2, ASME B1.20.1 pipe threads.

## 2.06 TEST PLUGS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Flow Design, Inc.
  - 2. Peterson Equipment Co., Inc.
  - 3. Sisco Manufacturing Company, Inc.
  - 4. Trerice, H. O. Co.

- B. Description: Test-station fitting made for insertion into piping tee fitting.
- C. Body: Brass or stainless steel with core inserts and gasketed and threaded cap. Include extended stem on units to be installed in insulated piping.
- D. Thread Size: NPS 1/4 or NPS 1/2, ASME B1.20.1 pipe thread.
- E. Minimum Pressure and Temperature Rating: 500 psig at 200 deg F.
- F. Core Inserts: EPDM self-sealing rubber.

## 2.07 TEST-PLUG KITS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Flow Design, Inc.
  - 2. Peterson Equipment Co., Inc.
  - 3. Sisco Manufacturing Company, Inc.
  - 4. Trerice, H. O. Co.
- B. Furnish one test-plug kit(s) containing two thermometer(s), one pressure gage and adapter, and carrying case. Thermometer sensing elements, pressure gage, and adapter probes shall be of diameter to fit test plugs and of length to project into piping.
- C. Low-Range Thermometer: Small, bimetallic insertion type with 1- to 2-inch-diameter dial and tapered-end sensing element. Dial range shall be at least 25 to 125 deg F.
- D. High-Range Thermometer: Small, bimetallic insertion type with 1- to 2-inch-diameter dial and tapered-end sensing element. Dial range shall be at least 0 to 220 deg F.
- E. Pressure Gage: Small, Bourdon-tube insertion type with 2- to 3-inch-diameter dial and probe. Dial range shall be at least 0 to 100 psig.
- F. Carrying Case: Metal or plastic, with formed instrument padding.

## 2.08 FLOWMETERS

- A. In-line Body Electromagnetic Flow Meter:
  - 1. <u>Manufacturers:</u> Subject to compliance with requirements, provide products by one of the following:
    - a. ONICON Incorporated.
    - b. Spirax Sarco, Inc.
  - 2. Description:
    - a. No moving parts.
    - b. Suitable for flow measurement of fluids with electrical conductivity more than 5 micro-Siemens per cm.
    - c. Inherent bi-directional flow measurement.
    - d. Flow measurement with three pipe diameters upstream and two pipe diameters downstream.
    - e. Wet calibrate and tag meters to standards traceable to NIST, and provide each meter with a certificate of calibration.
    - f. Transmitter remote from meter.
  - 3. Performance:
    - a. Accuracy for Velocities between 3.3 and 33 fps: Within 0.2 percent of reading.
    - b. Accuracy for Velocities between 1.0 and 3.3 fps: Within 0.75 percent of reading.

- c. Accuracy for Velocities Less than 1.0 fps: Within 0.0075 fps.
- d. Ambient Temperature: Minus 4 to plus 140 deg F.
- e. Process Temperature: Minus 4 to 212 deg F.
- f. Pressure: 225 psig.
- 4. Analog Output Current Signal:
  - a. Two-wire, 4- to 20-mA dc current source.
  - b. Signal capable of operating into 1000-ohm load.
  - c. Isolated.
- 5. Digital Output Signal: Two, programmable, digital/pulse outputs configurable for frequency, pulse, or directional flow.
- 6. Operator Interface:
  - a. Keypad.
  - b. Digital Display: Multiple-line digital display of alphanumerical characters.
  - c. LED for normal and alarm operation.
- 7. Construction:
  - a. Body: Type 316 stainless steel.
  - b. Body Liner Material: PTFE.
  - c. Flow Tube: Type 304 stainless steel.
  - d. Connection: 150 Class flange.
  - e. Electrodes: Type 316 stainless steel. Quantity determined by manufacturer based on application.
  - f. Electronics Enclosure:
    - 1) Painted aluminum.
    - 2) Removable cover.
    - 3) NEMA 250, Type 6.

## **PART 3 EXECUTION**

## 3.01 INSTALLATION

- A. Install thermowells with socket extending to center of pipe and in vertical position in piping tees.
- B. Install thermowells of sizes required to match thermometer connectors. Include bushings if required to match sizes.
- C. Install thermowells with extension on insulated piping.
- D. Fill thermowells with heat-transfer medium.
- E. Install direct-mounted thermometers in thermowells and adjust vertical and tilted positions.
- F. Install direct-mounted pressure gages in piping tees with pressure gage located on pipe at the most readable position.
- G. Install valve and snubber in piping for each pressure gage for fluids (except steam).
- H. Install test plugs in piping tees.
- I. Assemble and install connections, tubing, and accessories between flow-measuring elements and flowmeters according to manufacturer's written instructions.
- J. Install flowmeter elements in accessible positions in piping systems.
- K. Install permanent indicators on walls or brackets in accessible and readable positions.
- L. Install connection fittings in accessible locations for attachment to portable indicators.
- M. Install thermometers in the following locations:
  - 1. Inlet and outlet of each hydronic zone.
  - 2. Inlet and outlet of each hydronic boiler.
  - 3. Two inlets and two outlets of each chiller.
  - 4. Inlet and outlet of each hydronic coil in air-handling units.
  - 5. Two inlets and two outlets of each hydronic heat exchanger.
  - 6. Outside-, return-, supply
- N. Install pressure gages in the following locations:
  - 1. Inlet and outlet of each boiler water connection.
  - 2. Suction and discharge of each pump.

## 3.02 CONNECTIONS

- A. Install meters and gages adjacent to machines and equipment to allow service and maintenance of meters, gages, machines, and equipment.
- B. Connect flowmeter-system elements to meters.
- C. Connect flowmeter transmitters to meters.

## 3.03 ADJUSTING

- A. After installation, calibrate meters according to manufacturer's written instructions.
- B. Adjust faces of meters and gages to proper angle for best visibility.

# 3.04 THERMOMETER SCHEDULE

- A. Thermometers at boiler and water heater inlets and outlets shall be one of the following:
  - 1. Industrial-style, liquid-in-glass type.
  - 2. Direct-mounted, light-activated type.
- B. Thermometer stems shall be of length to match thermowell insertion length.

## 3.05 THERMOMETER SCALE-RANGE SCHEDULE

A. Scale Range for Heating, Hot-Water Piping: 30 to 240 deg F.

## 3.06 PRESSURE-GAGE SCHEDULE

- A. Pressure gages at hot water inlet and outlet of each boiler and water heater shall be the following:
  - 1. Liquid-filled, direct-mounted, metal case.
- B. Pressure gages at suction and discharge of each pump shall be one of the following:
  1. Liquid-filled, direct-mounted, metal case.

## 3.07 PRESSURE-GAGE SCALE-RANGE SCHEDULE

A. Scale Range for Heating, Hot-Water Piping: 0 to 100 psi.

## 3.08 FLOWMETER SCHEDULE

A. Flowmeters for Heating, Hot-Water Piping: Vortex-shedding type.

# END OF SECTION

## SECTION 23 05 23

#### **GENERAL-DUTY VALVES FOR HVAC PIPING**

#### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Bronze ball valves.
  - 2. Iron, single-flange butterfly valves.
  - 3. Bronze Swing check valves.
- B. Related Sections:
  - 1. Division 23 HVAC piping Sections for specialty valves applicable to those Sections only.
  - 2. Division 23 Section "Identification for HVAC Piping and Equipment" for valve tags and schedules.

## 1.03 DEFINITIONS

- A. CWP: Cold working pressure.
- B. EPDM: Ethylene propylene copolymer rubber.
- C. NBR: Acrylonitrile-butadiene, Buna-N, or nitrile rubber.
- D. NRS: Nonrising stem.
- E. OS&Y: Outside screw and yoke.
- F. RS: Rising stem.

## 1.04 SUBMITTALS

A. Product Data: For each type of valve indicated.

#### 1.05 QUALITY ASSURANCE

- A. Source Limitations for Valves: Obtain each type of valve from single source from single manufacturer.
- B. ASME Compliance:
  - 1. ASME B31.9 for building services piping valves..

#### 1.06 DELIVERY, STORAGE, AND HANDLING

- A. Prepare valves for shipping as follows:
  - 1. Protect internal parts against rust and corrosion.

- 2. Protect threads, flange faces, grooves, and weld ends.
- 3. Set angle, gate, and globe valves closed to prevent rattling.
- 4. Set ball and plug valves open to minimize exposure of functional surfaces.
- 5. Set butterfly valves closed or slightly open.
- 6. Block check valves in either closed or open position.
- B. Use the following precautions during storage:
  - 1. Maintain valve end protection.
  - 2. Store valves indoors and maintain at higher than ambient dew point temperature. If outdoor storage is necessary, store valves off the ground in watertight enclosures.
- C. Use sling to handle large valves; rig sling to avoid damage to exposed parts. Do not use handwheels or stems as lifting or rigging points.

## PART 2 PRODUCTS

- 2.01 GENERAL REQUIREMENTS FOR VALVES
  - A. Refer to HVAC valve schedule articles for applications of valves.
  - B. Valve Pressure and Temperature Ratings: Not less than indicated and as required for system pressures and temperatures.
  - C. Valve Sizes: Same as upstream piping unless otherwise indicated.
  - D. Valve Actuator Types:
    - 1. Gear Actuator: For quarter-turn valves NPS 8 and larger.
    - 2. Handwheel: For valves other than quarter-turn types.
    - 3. Handlever: For quarter-turn valves NPS 6 and smaller.
    - 4. Wrench: For plug valves with square heads. Furnish Owner with 1 wrench for every 5 plug valves, for each size square plug-valve head.
    - 5. Chainwheel: Device for attachment to valve handwheel, stem, or other actuator; of size and with chain for mounting height, as indicated in the "Valve Installation" Article.
  - E. Valves in Insulated Piping: With 2-inch stem extensions and the following features:
    - 1. Gate Valves: With rising stem.
    - 2. Ball Valves: With extended operating handle of non-thermal-conductive material, and protective sleeve that allows operation of valve without breaking the vapor seal or disturbing insulation.
    - 3. Butterfly Valves: With extended neck.
  - F. Valve-End Connections:
    - 1. Flanged: With flanges according to ASME B16.1 for iron valves.
    - 2. Grooved: With grooves according to AWWA C606.
    - 3. Threaded: With threads according to ASME B1.20.1.
    - 4. Soldered Joint: With according to ASME B16.18.
  - G. Valve Bypass and Drain Connections: MSS SP-45.
- 2.02 BRONZE BALL VALVES
  - A. Two-Piece, Full-Port, Bronze Ball Valves with Stainless-Steel Trim:
    - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- a. Conbraco Industries, Inc.; Apollo Valves.
- b. Milwaukee Valve Company.
- c. NIBCO INC.
- 2. Description:
  - a. Standard: MSS SP-110.
  - b. SWP Rating: 150 psig.
  - c. CWP Rating: 600 psig.
  - d. Body Design: Two piece.
  - e. Body Material: Bronze.
  - f. Ends: Threaded.
  - g. Seats: PTFE or TFE.
  - h. Stem: Stainless steel.
  - i. Ball: Stainless steel, vented.
  - j. Port: Full.

# 2.03 IRON, SINGLE-FLANGE BUTTERFLY VALVES

- A. 150 CWP, Iron, Single-Flange Butterfly Valves with EPDM Seat and Aluminum-Bronze Disc:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Bray Controls; a division of Bray International.
    - b. Conbraco Industries, Inc.; Apollo Valves.
    - c. Crane Co.; Crane Valve Group; Center Line.
    - d. Crane Co.; Crane Valve Group; Stockham Division.
    - e. Hammond Valve.
  - 2. Description:
    - a. Standard: MSS SP-67, Type I.
    - b. CWP Rating: 150 psig.
    - c. Body Design: Lug type; suitable for bidirectional dead-end service at rated pressure without use of downstream flange.
    - d. Body Material: ASTM A 126, cast iron or ASTM A 536, ductile iron.
    - e. Seat: EPDM.
    - f. Stem: One- or two-piece stainless steel.
    - g. Disc: Aluminum-Bronze
- B. Class 125, Lift Check Valves with Nonmetallic TFE Disc:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. NIBCO INC.
    - b. Crance Co.
    - c. Powell Valves.
  - 2. Description:
    - a. Standard: MSS SP-80, Type 2.
    - b. CWP Rating: 200 psig.
    - c. Body Design: Vertical flow.
    - d. Body Material: ASTM B 584 alloy C844, bronze.
    - e. Ends: Threaded.
    - f. Disc: PTFE, or TFE.

- 2.04 BRONZE SWING CHECK VALVES
  - A. Class 150, Bronze Swing Check Valves with Nonmetallic Disc:
    - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
      - a. Crane Co.; Crane Valve Group; Crane Valves.
      - b. Milwaukee Valve Company.
      - c. NIBCO INC.
    - 2. Description:
      - a. Standard: MSS SP-80, Type 4.
      - b. CWP Rating: 300 psig.
      - c. Body Design: Horizontal flow.
      - d. Body Material: ASTM B 62, bronze.
      - e. Ends: Threaded.
      - f. Disc: PTFE or TFE.
      - g.

## PART 3 EXECUTION

# 3.01 EXAMINATION

- A. Examine valve interior for cleanliness, freedom from foreign matter, and corrosion. Remove special packing materials, such as blocks, used to prevent disc movement during shipping and handling.
- B. Operate valves in positions from fully open to fully closed. Examine guides and seats made accessible by such operations.
- C. Examine threads on valve and mating pipe for form and cleanliness.
- D. Examine mating flange faces for conditions that might cause leakage. Check bolting for proper size, length, and material. Verify that gasket is of proper size, that its material composition is suitable for service, and that it is free from defects and damage.
- E. Do not attempt to repair defective valves; replace with new valves.

## 3.02 VALVE INSTALLATION

- A. Install valves with unions or flanges at each piece of equipment arranged to allow service, maintenance, and equipment removal without system shutdown.
- B. Locate valves for easy access and provide separate support where necessary.
- C. Install valves in horizontal piping with stem at or above center of pipe.
- D. Install valves in position to allow full stem movement.
- E. Install chainwheels on operators for ball butterfly globe and plug valves NPS 4 and larger and more than 96 inches above floor. Extend chains to 60 inches above finished floor.
- F. Install check valves for proper direction of flow and as follows:
  - 1. Center-Guided Check Valves: In horizontal or vertical position, between flanges.
  - 2. Lift Check Valves: With stem upright and plumb.

## 3.03 ADJUSTING

A. Adjust or replace valve packing after piping systems have been tested and put into service but before final adjusting and balancing. Replace valves if persistent leaking occurs.

## 3.04 GENERAL REQUIREMENTS FOR VALVE APPLICATIONS

- A. If valve applications are not indicated, use the following:
  - 1. Shutoff Service: Ball, butterfly valves.
  - 2. Butterfly Valve Dead-End Service: Single-flange (lug) type.
  - 3. Throttling Service except Steam: Globe or angle or butterfly valves.
  - 4. Pump-Discharge Check Valves:
    - a. NPS 2 and Smaller: Bronze swing check valves with nonmetallic disc.
    - b. NPS 2-1/2 and Larger: iron, center-guided, resilient-seat check valves.
- B. If valves with specified SWP classes or CWP ratings are not available, the same types of valves with higher SWP classes or CWP ratings may be substituted.
- C. Select valves, except wafer types, with the following end connections:
  - 1. For Copper Tubing, NPS 2 and Smaller: Threaded ends except where solder-joint valveend option is indicated in valve schedules below.
  - 2. For Copper Tubing, NPS 2-1/2 to NPS 4: Flanged ends except where threaded valveend option is indicated in valve schedules below.
  - 3. For Copper Tubing, NPS 5 and Larger: Flanged ends.
  - 4. For Steel Piping, NPS 2 and Smaller: Threaded ends.
  - 5. For Steel Piping, NPS 2-1/2 to NPS 4: Flanged ends except where threaded valve-end option is indicated in valve schedules below.
  - 6. For Steel Piping, NPS 5 and Larger: Flanged ends.

## 3.05 HEATING, HOT WATER VALVE SCHEDULE

- A. Pipe NPS 2 and Smaller:
  - 1. Ball Valves
  - 2. Bronze Swing Check Valves
- B. Pipe NPS 2-1/2 and Larger:
  - 1. Iron, Single-Flange Butterfly Valves, NPS 2-1/2 to NPS 12

END OF SECTION

## SECTION 23 05 29

## HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

## 1.02 SUMMARY

- A. Section Includes:
  - 1. Metal pipe hangers and supports.
  - 2. Trapeze pipe hangers.
  - 3. Metal framing systems.
  - 4. Thermal-hanger shield inserts.
  - 5. Fastener systems.
  - 6. Equipment supports.
- B. Related Sections:
  - 1. Division 05 Section "Metal Fabrications" for structural-steel shapes and plates for trapeze hangers for pipe and equipment supports.
  - 2. Division 23 Section "Vibration and Seismic Controls for HVAC Piping and Equipment" for vibration isolation devices.
  - 3. Division 23 Section(s) "Metal Ducts" for duct hangers and supports.

## 1.03 DEFINITIONS

A. MSS: Manufacturers Standardization Society of The Valve and Fittings Industry Inc.

## 1.04 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Design trapeze pipe hangers and equipment supports, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- B. Structural Performance: Hangers and supports for HVAC piping and equipment shall withstand the effects of gravity loads and stresses within limits and under conditions indicated according to ASCE/SEI 7.
  - 1. Design supports for multiple pipes, including pipe stands, capable of supporting combined weight of supported systems, system contents, and test water.
  - 2. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
  - 3. Design seismic-restraint hangers and supports for piping and equipment and obtain approval from authorities having jurisdiction.

## 1.05 SUBMITTALS

A. Product Data: For each type of product indicated.

- B. Shop Drawings: Signed and sealed by a qualified professional engineer. Show fabrication and installation details and include calculations for the following; include Product Data for components:
  - 1. Trapeze pipe hangers.
  - 2. Metal framing systems.
  - 3. Equipment supports.
- C. Delegated-Design Submittal: For trapeze hangers indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Detail fabrication and assembly of trapeze hangers.
  - 2. Design Calculations: Calculate requirements for designing trapeze hangers.
- D. Welding certificates.

## 1.06 QUALITY ASSURANCE

- A. Structural Steel Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code Steel."
- B. Pipe Welding Qualifications: Qualify procedures and operators according to ASME Boiler and Pressure Vessel Code.

## PART 2 PRODUCTS

- 2.01 METAL PIPE HANGERS AND SUPPORTS
  - A. Carbon-Steel Pipe Hangers and Supports:
    - 1. Description: MSS SP-58, Types 1 through 58, factory-fabricated components.
    - 2. Galvanized Metallic Coatings: Pregalvanized or hot dipped.
    - 3. Nonmetallic Coatings: Plastic coating, jacket, or liner.
    - 4. Padded Hangers: Hanger with fiberglass or other pipe insulation pad or cushion to support bearing surface of piping.
    - 5. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
  - B. Copper Pipe Hangers:
    - 1. Description: MSS SP-58, Types 1 through 58, copper-coated-steel, factory-fabricated components.
    - 2. Hanger Rods: Continuous-thread rod, nuts, and washer made of copper-coated steel.

## 2.02 TRAPEZE PIPE HANGERS

A. Description: MSS SP-69, Type 59, shop- or field-fabricated pipe-support assembly made from structural carbon-steel shapes with MSS SP-58 carbon-steel hanger rods, nuts, saddles, and U-bolts.

## 2.03 METAL FRAMING SYSTEMS

- A. MFMA Manufacturer Metal Framing Systems:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Allied Tube & Conduit.
    - b. Cooper B-Line, Inc.
- c. Flex-Strut Inc.
- d. Unistrut Corporation; Tyco International, Ltd.
- 2. Description: Shop- or field-fabricated pipe-support assembly for supporting multiple parallel pipes.
- 3. Standard: MFMA-4.
- 4. Channels: Continuous slotted steel channel with inturned lips.
- 5. Channel Nuts: Formed or stamped steel nuts or other devices designed to fit into channel slot and, when tightened, prevent slipping along channel.
- 6. Hanger Rods: Continuous-thread rod, nuts, and washer made of carbon steel.
- 7. Metallic Coating: Electroplated zinc.
- 2.04 THERMAL-HANGER SHIELD INSERTS
  - A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 1. Carpenter & Paterson, Inc.
    - 2. Clement Support Services.
    - 3. ERICO International Corporation.
    - 4. National Pipe Hanger Corporation.
    - 5. PHS Industries, Inc.
    - 6. Pipe Shields, Inc.; a subsidiary of Piping Technology & Products, Inc.
    - 7. Piping Technology & Products, Inc.
    - 8. Rilco Manufacturing Co., Inc.
    - 9. Value Engineered Products, Inc.
  - B. Insulation-Insert Material for Cold Piping: ASTM C 552, Type II cellular glass with 100-psig or ASTM C 591, Type VI, Grade 1 polyisocyanurate with 125-psig minimum compressive strength and vapor barrier.
  - C. Insulation-Insert Material for Hot Piping: ASTM C 552, Type II cellular glass with 100-psig or ASTM C 591, Type VI, Grade 1 polyisocyanurate with 125-psig minimum compressive strength.
  - D. For Trapeze or Clamped Systems: Insert and shield shall cover entire circumference of pipe.
  - E. For Clevis or Band Hangers: Insert and shield shall cover lower 180 degrees of pipe.
  - F. Insert Length: Extend 2 inches beyond sheet metal shield for piping operating below ambient air temperature.

### 2.05 FASTENER SYSTEMS

- A. Mechanical-Expansion Anchors: Insert-wedge-type, zinc-coated steel anchors, for use in hardened portland cement concrete; with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.
- 2.06 EQUIPMENT SUPPORTS
  - A. Description: Welded, shop- or field-fabricated equipment support made from structural carbon-steel shapes.
- 2.07 MISCELLANEOUS MATERIALS
  - A. Structural Steel: ASTM A 36/A 36M, carbon-steel plates, shapes, and bars; black and galvanized.

- B. Grout: ASTM C 1107, factory-mixed and -packaged, dry, hydraulic-cement, nonshrink and nonmetallic grout; suitable for interior and exterior applications.
  - 1. Properties: Nonstaining, noncorrosive, and nongaseous.
  - 2. Design Mix: 5000-psi, 28-day compressive strength.

## PART 3 EXECUTION

### 3.01 HANGER AND SUPPORT INSTALLATION

- A. Metal Pipe-Hanger Installation: Comply with MSS SP-69 and MSS SP-89. Install hangers, supports, clamps, and attachments as required to properly support piping from the building structure.
- B. Metal Trapeze Pipe-Hanger Installation: Comply with MSS SP-69 and MSS SP-89. Arrange for grouping of parallel runs of horizontal piping, and support together on field-fabricated trapeze pipe hangers.
  - 1. Pipes of Various Sizes: Support together and space trapezes for smallest pipe size or install intermediate supports for smaller diameter pipes as specified for individual pipe hangers.
  - 2. Field fabricate from ASTM A 36/A 36M, carbon-steel shapes selected for loads being supported. Weld steel according to AWS D1.1/D1.1M.
- C. Metal Framing System Installation: Arrange for grouping of parallel runs of piping, and support together on field-assembled metal framing systems.
- D. Thermal-Hanger Shield Installation: Install in pipe hanger or shield for insulated piping.
- E. Fastener System Installation:
  - 1. Install powder-actuated fasteners for use in lightweight concrete or concrete slabs less than 4 inches thick in concrete after concrete is placed and completely cured. Use operators that are licensed by powder-actuated tool manufacturer. Install fasteners according to powder-actuated tool manufacturer's operating manual.
  - 2. Install mechanical-expansion anchors in concrete after concrete is placed and completely cured. Install fasteners according to manufacturer's written instructions.
- F. Pipe Stand Installation:
  - 1. Pipe Stand Types except Curb-Mounted Type: Assemble components and mount on smooth roof surface. Do not penetrate roof membrane.
  - Curb-Mounted-Type Pipe Stands: Assemble components or fabricate pipe stand and mount on permanent, stationary roof curb. See Division 07 Section "Roof Accessories" for curbs.
- G. Install hangers and supports complete with necessary attachments, inserts, bolts, rods, nuts, washers, and other accessories.
- H. Equipment Support Installation: Fabricate from welded-structural-steel shapes.
- I. Install hangers and supports to allow controlled thermal and seismic movement of piping systems, to permit freedom of movement between pipe anchors, and to facilitate action of expansion joints, expansion loops, expansion bends, and similar units.
- J. Install lateral bracing with pipe hangers and supports to prevent swaying.

- K. Install building attachments within concrete slabs or attach to structural steel. Install additional attachments at concentrated loads, including valves, flanges, and strainers, NPS 2-1/2 and larger and at changes in direction of piping. Install concrete inserts before concrete is placed; fasten inserts to forms and install reinforcing bars through openings at top of inserts.
- L. Load Distribution: Install hangers and supports so that piping live and dead loads and stresses from movement will not be transmitted to connected equipment.
- M. Pipe Slopes: Install hangers and supports to provide indicated pipe slopes and to not exceed maximum pipe deflections allowed by ASME B31.9 for building services piping.
- N. Insulated Piping:
  - 1. Attach clamps and spacers to piping.
    - a. Piping Operating above Ambient Air Temperature: Clamp may project through insulation.
    - b. Piping Operating below Ambient Air Temperature: Use thermal-hanger shield insert with clamp sized to match OD of insert.
    - c. Do not exceed pipe stress limits allowed by ASME B31.9 for building services piping.
  - 2. Install MSS SP-58, Type 39, protection saddles if insulation without vapor barrier is indicated. Fill interior voids with insulation that matches adjoining insulation.
    - a. Option: Thermal-hanger shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 and larger if pipe is installed on rollers.
  - 3. Install MSS SP-58, Type 40, protective shields on cold piping with vapor barrier. Shields shall span an arc of 180 degrees.
    - a. Option: Thermal-hanger shield inserts may be used. Include steel weight-distribution plate for pipe NPS 4 and larger if pipe is installed on rollers.
  - 4. Shield Dimensions for Pipe: Not less than the following:
    - a. NPS 1/4 to NPS 3-1/2: 12 inches long and 0.048 inch thick.
      - b. NPS 4: 12 inches long and 0.06 inch thick.
      - c. NPS 5 and NPS 6: 18 inches long and 0.06 inch thick.
      - d. NPS 8 to NPS 14: 24 inches long and 0.075 inch thick.
      - e. NPS 16 to NPS 24: 24 inches long and 0.105 inch thick.
  - 5. Pipes NPS 8 and Larger: Include wood or reinforced calcium-silicate-insulation inserts of length at least as long as protective shield.
  - 6. Thermal-Hanger Shields: Install with insulation same thickness as piping insulation.

# 3.02 EQUIPMENT SUPPORTS

- A. Fabricate structural-steel stands to suspend equipment from structure overhead or to support equipment above floor.
- B. Grouting: Place grout under supports for equipment and make bearing surface smooth.
- C. Provide lateral bracing, to prevent swaying, for equipment supports.

# 3.03 METAL FABRICATIONS

- A. Cut, drill, and fit miscellaneous metal fabrications for trapeze pipe hangers and equipment supports.
- B. Fit exposed connections together to form hairline joints. Field weld connections that cannot be shop welded because of shipping size limitations.

- C. Field Welding: Comply with AWS D1.1/D1.1M procedures for shielded, metal arc welding; appearance and quality of welds; and methods used in correcting welding work; and with the following:
  - 1. Use materials and methods that minimize distortion and develop strength and corrosion resistance of base metals.
  - 2. Obtain fusion without undercut or overlap.
  - 3. Remove welding flux immediately.
  - 4. Finish welds at exposed connections so no roughness shows after finishing and so contours of welded surfaces match adjacent contours.

### 3.04 ADJUSTING

- A. Hanger Adjustments: Adjust hangers to distribute loads equally on attachments and to achieve indicated slope of pipe.
- B. Trim excess length of continuous-thread hanger and support rods to 1-1/2 inches.

### 3.05 PAINTING

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
  1. Apply paint by brush or spray to provide a minimum dry film thickness of 2.0 mils.
- B. Touchup: Cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint on miscellaneous metal are specified in Division 09 painting Sections.
- C. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A 780.

### 3.06 HANGER AND SUPPORT SCHEDULE

- A. Specific hanger and support requirements are in Sections specifying piping systems and equipment.
- B. Comply with MSS SP-69 for pipe-hanger selections and applications that are not specified in piping system Sections.
- C. Use hangers and supports with galvanized metallic coatings for piping and equipment that will not have field-applied finish.
- D. Use nonmetallic coatings on attachments for electrolytic protection where attachments are in direct contact with copper tubing.
- E. Use carbon-steel pipe hangers and supports metal trapeze pipe hangers and metal framing systems and attachments for general service applications.
- F. Use copper-plated pipe hangers and copper attachments for copper piping and tubing.
- G. Use padded hangers for piping that is subject to scratching.
- H. Use thermal-hanger shield inserts for insulated piping and tubing.
- I. Horizontal-Piping Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:

- 1. Adjustable, Steel Clevis Hangers (MSS Type 1): For suspension of noninsulated or insulated, stationary pipes NPS 1/2 to NPS 30.
- 2. Yoke-Type Pipe Clamps (MSS Type 2): For suspension of up to 1050 deg F,pipes NPS 4 to NPS 24, requiring up to 4 inches of insulation.
- 3. Carbon- or Alloy-Steel, Double-Bolt Pipe Clamps (MSS Type 3): For suspension of pipes NPS 3/4 to NPS 36, requiring clamp flexibility and up to 4 inches of insulation.
- 4. Steel Pipe Clamps (MSS Type 4): For suspension of cold and hot pipes NPS 1/2 to NPS 24 if little or no insulation is required.
- 5. Pipe Hangers (MSS Type 5): For suspension of pipes NPS 1/2 to NPS 4, to allow offcenter closure for hanger installation before pipe erection.
- 6. Adjustable, Swivel Split- or Solid-Ring Hangers (MSS Type 6): For suspension of noninsulated, stationary pipes NPS 3/4 to NPS 8.
- 7. Adjustable, Steel Band Hangers (MSS Type 7): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
- 8. Adjustable Band Hangers (MSS Type 9): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
- 9. Adjustable, Swivel-Ring Band Hangers (MSS Type 10): For suspension of noninsulated, stationary pipes NPS 1/2 to NPS 8.
- 10. Split Pipe Ring with or without Turnbuckle Hangers (MSS Type 11): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 8.
- 11. Extension Hinged or Two-Bolt Split Pipe Clamps (MSS Type 12): For suspension of noninsulated, stationary pipes NPS 3/8 to NPS 3.
- 12. U-Bolts (MSS Type 24): For support of heavy pipes NPS 1/2 to NPS 30.
- 13. Clips (MSS Type 26): For support of insulated pipes not subject to expansion or contraction.
- 14. Pipe Saddle Supports (MSS Type 36): For support of pipes NPS 4 to NPS 36, with steelpipe base stanchion support and cast-iron floor flange or carbon-steel plate.
- 15. Pipe Stanchion Saddles (MSS Type 37): For support of pipes NPS 4 to NPS 36, with steel-pipe base stanchion support and cast-iron floor flange or carbon-steel plate, and with U-bolt to retain pipe.
- 16. Adjustable Pipe Saddle Supports (MSS Type 38): For stanchion-type support for pipes NPS 2-1/2 to NPS 36 if vertical adjustment is required, with steel-pipe base stanchion support and cast-iron floor flange.
- 17. Single-Pipe Rolls (MSS Type 41): For suspension of pipes NPS 1 to NPS 30, from two rods if longitudinal movement caused by expansion and contraction might occur.
- Adjustable Roller Hangers (MSS Type 43): For suspension of pipes NPS 2-1/2 to NPS 24, from single rod if horizontal movement caused by expansion and contraction might occur.
- 19. Complete Pipe Rolls (MSS Type 44): For support of pipes NPS 2 to NPS 42 if longitudinal movement caused by expansion and contraction might occur but vertical adjustment is not necessary.
- 20. Pipe Roll and Plate Units (MSS Type 45): For support of pipes NPS 2 to NPS 24 if small horizontal movement caused by expansion and contraction might occur and vertical adjustment is not necessary.
- 21. Adjustable Pipe Roll and Base Units (MSS Type 46): For support of pipes NPS 2 to NPS 30 if vertical and lateral adjustment during installation might be required in addition to expansion and contraction.
- J. Vertical-Piping Clamps: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Extension Pipe or Riser Clamps (MSS Type 8): For support of pipe risers NPS 3/4 to NPS 24.
  - 2. Carbon- or Alloy-Steel Riser Clamps (MSS Type 42): For support of pipe risers NPS 3/4 to NPS 24 if longer ends are required for riser clamps.

- K. Hanger-Rod Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Steel Turnbuckles (MSS Type 13): For adjustment up to 6 inches for heavy loads.
  - 2. Steel Clevises (MSS Type 14): For 120 to 450 deg F piping installations.
  - 3. Swivel Turnbuckles (MSS Type 15): For use with MSS Type 11, split pipe rings.
  - 4. Malleable-Iron Sockets (MSS Type 16): For attaching hanger rods to various types of building attachments.
  - 5. Steel Weldless Eye Nuts (MSS Type 17): For 120 to 450 deg F piping installations.
- L. Building Attachments: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Steel or Malleable Concrete Inserts (MSS Type 18): For upper attachment to suspend pipe hangers from concrete ceiling.
  - 2. Top-Beam C-Clamps (MSS Type 19): For use under roof installations with bar-joist construction, to attach to top flange of structural shape.
  - 3. Side-Beam or Channel Clamps (MSS Type 20): For attaching to bottom flange of beams, channels, or angles.
  - 4. Center-Beam Clamps (MSS Type 21): For attaching to center of bottom flange of beams.
  - 5. Welded Beam Attachments (MSS Type 22): For attaching to bottom of beams if loads are considerable and rod sizes are large.
  - 6. C-Clamps (MSS Type 23): For structural shapes.
  - 7. Top-Beam Clamps (MSS Type 25): For top of beams if hanger rod is required tangent to flange edge.
  - 8. Side-Beam Clamps (MSS Type 27): For bottom of steel I-beams.
  - 9. Steel-Beam Clamps with Eye Nuts (MSS Type 28): For attaching to bottom of steel Ibeams for heavy loads.
  - 10. Linked-Steel Clamps with Eye Nuts (MSS Type 29): For attaching to bottom of steel Ibeams for heavy loads, with link extensions.
  - 11. Malleable-Beam Clamps with Extension Pieces (MSS Type 30): For attaching to structural steel.
  - 12. Welded-Steel Brackets: For support of pipes from below or for suspending from above by using clip and rod. Use one of the following for indicated loads:
    - a. Light (MSS Type 31): 750 lb.
    - b. Medium (MSS Type 32): 1500 lb.
    - c. Heavy (MSS Type 33): 3000 lb.
  - 13. Side-Beam Brackets (MSS Type 34): For sides of steel or wooden beams.
  - 14. Plate Lugs (MSS Type 57): For attaching to steel beams if flexibility at beam is required.
  - 15. Horizontal Travelers (MSS Type 58): For supporting piping systems subject to linear horizontal movement where headroom is limited.
- M. Saddles and Shields: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Steel-Pipe-Covering Protection Saddles (MSS Type 39): To fill interior voids with insulation that matches adjoining insulation.
  - 2. Protection Shields (MSS Type 40): Of length recommended in writing by manufacturer to prevent crushing insulation.
  - 3. Thermal-Hanger Shield Inserts: For supporting insulated pipe.
- N. Spring Hangers and Supports: Unless otherwise indicated and except as specified in piping system Sections, install the following types:
  - 1. Restraint-Control Devices (MSS Type 47): Where indicated to control piping movement.
  - 2. Spring Cushions (MSS Type 48): For light loads if vertical movement does not exceed 1-1/4 inches.
  - 3. Spring-Cushion Roll Hangers (MSS Type 49): For equipping Type 41, roll hanger with springs.

- 4. Spring Sway Braces (MSS Type 50): To retard sway, shock, vibration, or thermal expansion in piping systems.
- 5. Variable-Spring Hangers (MSS Type 51): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from hanger.
- 6. Variable-Spring Base Supports (MSS Type 52): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from base support.
- 7. Variable-Spring Trapeze Hangers (MSS Type 53): Preset to indicated load and limit variability factor to 25 percent to allow expansion and contraction of piping system from trapeze support.
- 8. Constant Supports: For critical piping stress and if necessary to avoid transfer of stress from one support to another support, critical terminal, or connected equipment. Include auxiliary stops for erection, hydrostatic test, and load-adjustment capability. These supports include the following types:
  - a. Horizontal (MSS Type 54): Mounted horizontally.
  - b. Vertical (MSS Type 55): Mounted vertically.
  - c. Trapeze (MSS Type 56): Two vertical-type supports and one trapeze member.
- O. Comply with MSS SP-69 for trapeze pipe-hanger selections and applications that are not specified in piping system Sections.
- P. Comply with MFMA-103 for metal framing system selections and applications that are not specified in piping system Sections.
- Q. Use powder-actuated fasteners or mechanical-expansion anchors instead of building attachments where required in concrete construction.

END OF SECTION

### SECTION 23 05 48

### VIBRATION AND SEISMIC CONTROLS FOR HVAC PIPING AND EQUIPMENT

## PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Isolation pads.
  - 2. Restraining braces and cables.

### 1.03 DEFINITIONS

- A. IBC: International Building Code.
- B. ICC-ES: ICC-Evaluation Service.
- C. OSHPD: Office of Statewide Health Planning and Development for the State of California.

### 1.04 PERFORMANCE REQUIREMENTS

- A. Seismic-Restraint Loading:
  - 1. Site Class as Defined in the IBC: D.
  - 2. Assigned Seismic Use Group or Building Category as Defined in the IBC: IV.

### 1.05 SUBMITTALS

- A. Product Data: For the following:
  - 1. Include rated load, rated deflection, and overload capacity for each vibration isolation device.
  - 2. Illustrate and indicate style, material, strength, fastening provision, and finish for each type and size of seismic-restraint component used.
    - a. Tabulate types and sizes of seismic restraints, complete with report numbers and rated strength in tension and shear as evaluated by OSHPD.
    - b. Annotate to indicate application of each product submitted and compliance with requirements.
  - 3. Interlocking Snubbers: Include ratings for horizontal, vertical, and combined loads.
- B. Delegated-Design Submittal: For vibration isolation and seismic-restraint details indicated to comply with performance requirements and design criteria, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation.
  - 1. Design Calculations: Calculate static and dynamic loading due to equipment weight and operation, seismic and wind forces required to select vibration isolators, seismic and wind restraints, and for designing vibration isolation bases.
    - a. Coordinate design calculations with wind load calculations required for equipment mounted outdoors. Comply with requirements in other Division 22 Sections for equipment mounted outdoors.

- 2. Riser Supports: Include riser diagrams and calculations showing anticipated expansion and contraction at each support point, initial and final loads on building structure, spring deflection changes, and seismic loads. Include certification that riser system has been examined for excessive stress and that none will exist.
- 3. Vibration Isolation Base Details: Detail overall dimensions, including anchorages and attachments to structure and to supported equipment. Include auxiliary motor slides and rails, base weights, equipment static loads, power transmission, component misalignment, and cantilever loads.
  - a. Coordinate seismic-restraint and vibration isolation details with wind-restraint details required for equipment mounted outdoors. Comply with requirements in other Division 22 Sections for equipment mounted outdoors.
  - b. Preapproval and Evaluation Documentation: By OSHPD, showing maximum ratings of restraint items and the basis for approval (tests or calculations).
- C. Coordination Drawings: Show coordination of seismic bracing for HVAC piping and equipment with other systems and equipment in the vicinity, including other supports and seismic restraints.
- D. Welding certificates.
- E. Qualification Data: For professional engineer and testing agency.
- F. Field quality-control test reports.

### 1.06 QUALITY ASSURANCE

- A. Testing Agency Qualifications: An independent agency, with the experience and capability to conduct the testing indicated, that is a nationally recognized testing laboratory (NRTL) as defined by OSHA in 29 CFR 1910.7, and that is acceptable to authorities having jurisdiction.
- B. Comply with seismic-restraint requirements in the IBC unless requirements in this Section are more stringent.
- C. Welding: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code Steel."
- D. Seismic-restraint devices shall have horizontal and vertical load testing and analysis and shall bear anchorage preapproval OPA number from OSHPD, preapproval by ICC-ES, or preapproval by another agency acceptable to authorities having jurisdiction, showing maximum seismic-restraint ratings. Ratings based on independent testing are preferred to ratings based on calculations. If preapproved ratings are not available, submittals based on independent testing are preferred. Calculations (including combining shear and tensile loads) to support seismic-restraint designs must be signed and sealed by a qualified professional engineer.

### PART 2 PRODUCTS

- 2.01 VIBRATION ISOLATOR PADS
  - A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:

- C. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - 1. Amber/Booth Company, Inc.
  - 2. California Dynamics Corporation.
  - 3. Mason Industries.
  - 4. Sausse.
- D. Pads: Arranged in single or multiple layers of sufficient stiffness for uniform loading over pad area, molded with a nonslip pattern and galvanized-steel baseplates, and factory cut to sizes that match requirements of supported equipment.
  - 1. Resilient Material: Oil- and water-resistant neoprene.

### 2.02 SEISMIC-RESTRAINT DEVICES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
- C. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on Drawings or a comparable product by one of the following:
  - 1. Amber/Booth Company, Inc.
  - 2. California Dynamics Corporation.
  - 3. Cooper B-Line, Inc.; a division of Cooper Industries.
  - 4. Hilti, Inc.
  - 5. Kinetics Noise Control.
  - 6. Mason Industries.
  - 7. TOLCO Incorporated; a brand of NIBCO INC.
  - 8. Unistrut; Tyco International, Ltd.
  - 9. Sausse.
- D. General Requirements for Restraint Components: Rated strengths, features, and applications shall be as defined in reports by OSHPD.
  - 1. Structural Safety Factor: Allowable strength in tension, shear, and pullout force of components shall be at least four times the maximum seismic forces to which they will be subjected.
- E. Snubbers: Factory fabricated using welded structural-steel shapes and plates, anchor bolts, and replaceable resilient isolation washers and bushings.
  - 1. Anchor bolts for attaching to concrete shall be seismic-rated, drill-in, and stud-wedge or female-wedge type.
  - 2. Resilient Isolation Washers and Bushings: Oil- and water-resistant neoprene.
  - 3. Maximum 1/4-inch air gap, and minimum 1/4-inch-thick resilient cushion.
- F. Channel Support System: MFMA-3, shop- or field-fabricated support assembly made of slotted steel channels with accessories for attachment to braced component at one end and to building structure at the other end and other matching components and with corrosion-resistant coating; and rated in tension, compression, and torsion forces.
- G. Restraint Cables: ASTM A 603 galvanized-steel cables with end connections made of steel assemblies with thimbles, brackets, swivel, and bolts designed for restraining cable service; and with a minimum of two clamping bolts for cable engagement.

- H. Hanger Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections to hanger rod.
- I. Bushings for Floor-Mounted Equipment Anchor Bolts: Neoprene bushings designed for rigid equipment mountings, and matched to type and size of anchor bolts and studs.
- J. Bushing Assemblies for Wall-Mounted Equipment Anchorage: Assemblies of neoprene elements and steel sleeves designed for rigid equipment mountings, and matched to type and size of attachment devices used.
- K. Resilient Isolation Washers and Bushings: One-piece, molded, oil- and water-resistant neoprene, with a flat washer face.
- L. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type in zinc-coated steel for interior applications and stainless steel for exterior applications. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488. Minimum length of eight times diameter.
- M. Adhesive Anchor Bolts: Drilled-in and capsule anchor system containing polyvinyl or urethane methacrylate-based resin and accelerator, or injected polymer or hybrid mortar adhesive. Provide anchor bolts and hardware with zinc-coated steel for interior applications and stainless steel for exterior applications. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

### 2.03 FACTORY FINISHES

- A. Finish: Manufacturer's standard prime-coat finish ready for field painting.
- B. Finish: Manufacturer's standard paint applied to factory-assembled and -tested equipment before shipping.
  - 1. Powder coating on springs and housings.
  - 2. All hardware shall be galvanized. Hot-dip galvanize metal components for exterior use.
  - 3. Baked enamel or powder coat for metal components on isolators for interior use.
  - 4. Color-code or otherwise mark vibration isolation and seismic- and wind-control devices to indicate capacity range.

# PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Examine areas and equipment to receive vibration isolation and seismic- and wind-control devices for compliance with requirements for installation tolerances and other conditions affecting performance.
- B. Examine roughing-in of reinforcement and cast-in-place anchors to verify actual locations before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 APPLICATIONS

A. Multiple Pipe Supports: Secure pipes to trapeze member with clamps approved for application by OSHPD.

- B. Hanger Rod Stiffeners: Install hanger rod stiffeners where indicated or scheduled on Drawings to receive them and where required to prevent buckling of hanger rods due to seismic forces.
- C. Strength of Support and Seismic-Restraint Assemblies: Where not indicated, select sizes of components so strength will be adequate to carry present and future static and seismic loads within specified loading limits.

## 3.03 VIBRATION-CONTROL AND SEISMIC-RESTRAINT DEVICE INSTALLATION

- A. Comply with requirements in Division 07 Section "Roof Accessories" for installation of roof curbs, equipment supports, and roof penetrations.
- B. Equipment Restraints:
  - 1. Install seismic snubbers on HVAC equipment mounted on vibration isolators. Locate snubbers as close as possible to vibration isolators and bolt to equipment base and supporting structure.
  - 2. Install resilient bolt isolation washers on equipment anchor bolts where clearance between anchor and adjacent surface exceeds 0.125 inch.
  - 3. Install seismic-restraint devices using methods approved by OSHPD providing required submittals for component.
- C. Piping Restraints:
  - 1. Comply with requirements in MSS SP-127.
  - 2. Space lateral supports a maximum of 40 feet o.c., and longitudinal supports a maximum of 80 feet o.c.
  - 3. Brace a change of direction longer than 12 feet.
- D. Install cables so they do not bend across edges of adjacent equipment or building structure.
- E. Install seismic-restraint devices using methods approved by OSHPD providing required submittals for component.
- F. Install bushing assemblies for anchor bolts for floor-mounted equipment, arranged to provide resilient media between anchor bolt and mounting hole in concrete base.
- G. Install bushing assemblies for mounting bolts for wall-mounted equipment, arranged to provide resilient media where equipment or equipment-mounting channels are attached to wall.
- H. Attachment to Structure: If specific attachment is not indicated, anchor bracing to structure at flanges of beams, at upper truss chords of bar joists, or at concrete members.
- I. Drilled-in Anchors:
  - Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Do not damage existing reinforcing or embedded items during coring or drilling. Notify the structural engineer if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.
  - 2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
  - 3. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in the structural element to which anchor is to be fastened.
  - 4. Adhesive Anchors: Clean holes to remove loose material and drilling dust prior to installation of adhesive. Place adhesive in holes proceeding from the bottom of the hole

and progressing toward the surface in such a manner as to avoid introduction of air pockets in the adhesive.

- 5. Set anchors to manufacturer's recommended torque, using a torque wrench.
- 6. Install zinc-coated steel anchors for interior and stainless-steel anchors for exterior applications.

### 3.04 ACCOMMODATION OF DIFFERENTIAL SEISMIC MOTION

A. Install flexible connections in piping where they cross seismic joints, where adjacent sections or branches are supported by different structural elements, and where the connections terminate with connection to equipment that is anchored to a different structural element from the one supporting the connections as they approach equipment.

### 3.05 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Perform tests and inspections.
- C. Tests and Inspections:
  - 1. Provide evidence of recent calibration of test equipment by a testing agency acceptable to authorities having jurisdiction.
  - 2. Schedule test with Owner, through Architect, before connecting anchorage device to restrained component (unless postconnection testing has been approved), and with at least seven days' advance notice.
  - 3. Obtain Architect's approval before transmitting test loads to structure. Provide temporary load-spreading members.
  - 4. Test at least four of each type and size of installed anchors and fasteners selected by Architect.
  - 5. Test to 90 percent of rated proof load of device.
  - 6. Measure isolator restraint clearance.
  - 7. Measure isolator deflection.
  - 8. Verify snubber minimum clearances.
  - 9. If a device fails test, modify all installations of same type and retest until satisfactory results are achieved.
- D. Remove and replace malfunctioning units and retest as specified above.
- E. Prepare test and inspection reports.

# 3.06 ADJUSTING

- A. Adjust isolators after piping system is at operating weight.
- B. Adjust limit stops on restrained spring isolators to mount equipment at normal operating height. After equipment installation is complete, adjust limit stops so they are out of contact during normal operation.
- C. Adjust active height of spring isolators.
- D. Adjust restraints to permit free movement of equipment within normal mode of operation.

END OF SECTION

#### SECTION 23 05 53

#### **IDENTIFICATION FOR HVAC PIPING AND EQUIPMENT**

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Equipment labels.
  - 2. Warning signs and labels.
  - 3. Pipe labels.
  - 4. Duct labels.
  - 5. Stencils.
  - 6. Valve tags.
  - 7. Warning tags.

#### 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Samples: For color, letter style, and graphic representation required for each identification material and device.
- C. Equipment Label Schedule: Include a listing of all equipment to be labeled with the proposed content for each label.
- D. Valve numbering scheme.
- E. Valve Schedules: For each piping system to include in maintenance manuals.

#### 1.04 COORDINATION

- A. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- B. Coordinate installation of identifying devices with locations of access panels and doors.
- C. Install identifying devices before installing acoustical ceilings and similar concealment.

### PART 2 PRODUCTS

- 2.01 EQUIPMENT LABELS
  - A. Metal Labels for Equipment:
    - 1. Material and Thickness: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.

- 2. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- 3. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- 4. Fasteners: Stainless-steel rivets or self-tapping screws.
- 5. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- B. Plastic Labels for Equipment:
  - 1. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
  - 2. Letter Color: White.
  - 3. Background Color: White.
  - 4. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
  - 5. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
  - 6. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
  - 7. Fasteners: Stainless-steel rivets or self-tapping screws.
  - 8. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- C. Label Content: Include equipment's Drawing designation or unique equipment number, Drawing numbers where equipment is indicated (plans, details, and schedules), plus the Specification Section number and title where equipment is specified.
- D. Equipment Label Schedule: For each item of equipment to be labeled, on 8-1/2-by-11-inch bond paper. Tabulate equipment identification number and identify Drawing numbers where equipment is indicated (plans, details, and schedules), plus the Specification Section number and title where equipment is specified. Equipment schedule shall be included in operation and maintenance data.

### 2.02 WARNING SIGNS AND LABELS

- A. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/8 inch thick, and having predrilled holes for attachment hardware.
- B. Letter Color: Black.
- C. Background Color: White.
- D. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- E. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- F. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- G. Fasteners: Stainless-steel rivets or self-tapping screws.

- H. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- I. Label Content: Include caution and warning information, plus emergency notification instructions.

### 2.03 PIPE LABELS

- A. General Requirements for Manufactured Pipe Labels: Preprinted, color-coded, with lettering indicating service, and showing flow direction.
- B. Pretensioned Pipe Labels: Precoiled, semirigid plastic formed to partially cover circumference of pipe and to attach to pipe without fasteners or adhesive.
- C. Self-Adhesive Pipe Labels: Printed plastic with contact-type, permanent-adhesive backing.
- D. Pipe Label Contents: Include identification of piping service using same designations or abbreviations as used on Drawings, pipe size, and an arrow indicating flow direction.
  - 1. Flow-Direction Arrows: Integral with piping system service lettering to accommodate both directions, or as separate unit on each pipe label to indicate flow direction.
  - 2. Lettering Size: At least 1-1/2 inches high.

### 2.04 DUCT LABELS

- A. Material and Thickness: Multilayer, multicolor, plastic labels for mechanical engraving, 1/16 inch thick, and having predrilled holes for attachment hardware.
- B. Letter Color: White.
- C. Background Color: Black.
- D. Maximum Temperature: Able to withstand temperatures up to 160 deg F.
- E. Minimum Label Size: Length and width vary for required label content, but not less than 2-1/2 by 3/4 inch.
- F. Minimum Letter Size: 1/4 inch for name of units if viewing distance is less than 24 inches, 1/2 inch for viewing distances up to 72 inches, and proportionately larger lettering for greater viewing distances. Include secondary lettering two-thirds to three-fourths the size of principal lettering.
- G. Fasteners: Stainless-steel rivets or self-tapping screws.
- H. Adhesive: Contact-type permanent adhesive, compatible with label and with substrate.
- I. Duct Label Contents: Include identification of duct service using same designations or abbreviations as used on Drawings, duct size, and an arrow indicating flow direction.
  - 1. Flow-Direction Arrows: Integral with duct system service lettering to accommodate both directions, or as separate unit on each duct label to indicate flow direction.
  - 2. Lettering Size: At least 1-1/2 inches high.

### 2.05 STENCILS

- A. Stencils: Prepared with letter sizes according to ASME A13.1 for piping; minimum letter height of 1-1/4 inches for ducts; and minimum letter height of 3/4 inch for access panel and door labels, equipment labels, and similar operational instructions.
  - 1. Stencil Material: Brass.
  - 2. Stencil Paint: Exterior, gloss, acrylic enamel black unless otherwise indicated. Paint may be in pressurized spray-can form.
  - 3. Identification Paint: Exterior, acrylic enamel in colors according to ASME A13.1 unless otherwise indicated.

### 2.06 VALVE TAGS

- A. Valve Tags: Stamped or engraved with 1/4-inch letters for piping system abbreviation and 1/2-inch numbers.
  - 1. Tag Material: Brass, 0.032-inch minimum thickness, and having predrilled or stamped holes for attachment hardware.
  - 2. Fasteners: Brass wire-link or beaded chain; or S-hook.
- B. Valve Schedules: For each piping system, on 8-1/2-by-11-inch bond paper. Tabulate valve number, piping system, system abbreviation (as shown on valve tag), location of valve (room or space), normal-operating position (open, closed, or modulating), and variations for identification. Mark valves for emergency shutoff and similar special uses.
  - 1. Valve-tag schedule shall be included in operation and maintenance data.

### 2.07 WARNING TAGS

- A. Warning Tags: Preprinted or partially preprinted, accident-prevention tags, of plasticized card stock with matte finish suitable for writing.
  - 1. Size: 3 by 5-1/4 inches minimum Approximately 4 by 7 inches.
  - 2. Fasteners: Brass grommet and wire.
  - 3. Nomenclature: Large-size primary caption such as "DANGER," "CAUTION," or "DO NOT OPERATE."
  - 4. Color: Yellow background with black lettering.

# PART 3 EXECUTION

## 3.01 PREPARATION

A. Clean piping and equipment surfaces of substances that could impair bond of identification devices, including dirt, oil, grease, release agents, and incompatible primers, paints, and encapsulants.

### 3.02 EQUIPMENT LABEL INSTALLATION

- A. Install or permanently fasten labels on each major item of mechanical equipment.
- B. Locate equipment labels where accessible and visible.

### 3.03 PIPE LABEL INSTALLATION

A. Piping Color-Coding: Painting of piping is specified in Division 09 Section "Interior Painting."

- B. Stenciled Pipe Label Option: Stenciled labels may be provided instead of manufactured pipe labels, at Installer's option. Install stenciled pipe labels, complying with ASME A13.1, on each piping system.
  - 1. Identification Paint: Use for contrasting background.
  - 2. Stencil Paint: Use for pipe marking.
- C. Locate pipe labels where piping is exposed or above accessible ceilings in finished spaces; machine rooms; accessible maintenance spaces such as shafts, tunnels, and plenums; and exterior exposed locations as follows:
  - 1. Near each valve and control device.
  - 2. Near each branch connection, excluding short takeoffs for fixtures and terminal units. Where flow pattern is not obvious, mark each pipe at branch.
  - 3. Near penetrations through walls, floors, ceilings, and inaccessible enclosures.
  - 4. At access doors, manholes, and similar access points that permit view of concealed piping.
  - 5. Near major equipment items and other points of origination and termination.
  - 6. Spaced at maximum intervals of 50 feet along each run. Reduce intervals to 25 feet in areas of congested piping and equipment.
  - 7. On piping above removable acoustical ceilings. Omit intermediately spaced labels.
- D. Pipe Label Color Schedule:
  - 1. Heating, Hot-Water Piping:
    - a. Background Color: Yellow.
    - b. Letter Color: Black.

### 3.04 DUCT LABEL INSTALLATION

- A. Install self-adhesive duct labels with permanent adhesive on air ducts in the following color codes:
  - 1. Green: For exhaust ducts.
- B. Stenciled Duct Label Option: Stenciled labels, showing service and flow direction, may be provided instead of plastic-laminated duct labels, at Installer's option, if lettering larger than 1 inch high is needed for proper identification because of distance from normal location of required identification.
- C. Locate labels near points where ducts enter into concealed spaces and at maximum intervals of 50 feet in each space where ducts are exposed or concealed by removable ceiling system.

## 3.05 VALVE-TAG INSTALLATION

- A. Install tags on valves and control devices in piping systems, except check valves; valves within factory-fabricated equipment units; shutoff valves; faucets; convenience and lawn-watering hose connections; and HVAC terminal devices and similar roughing-in connections of end-use fixtures and units. List tagged valves in a valve schedule.
- B. Valve-Tag Application Schedule: Tag valves according to size, shape, and color scheme and with captions similar to those indicated in the following subparagraphs:
  - 1. Valve-Tag Size and Shape:
    - a. Heating, Hot-Water: 2 inches, square.
  - 2. Valve-Tag Color:
    - a. Heating, Hot-Water: Green.
  - 3. Letter Color:
    - a. Heating, Hot- Water: Black.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

# 3.06 WARNING-TAG INSTALLATION

A. Write required message on, and attach warning tags to, equipment and other items where required.

END OF SECTION

#### SECTION 23 05 93

#### TESTING, ADJUSTING, AND BALANCING FOR HVAC

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Balancing Air Systems:
    - a. Variable-air-volume-systems.
    - b. Constant-volume air systems.
  - 2. Balancing Hydronic Piping Systems:
    - a. Constant-flow hydronic systems.

#### 1.03 DEFINITIONS

- A. AABC: Associated Air Balance Council.
- B. TAB: Testing, adjusting, and balancing.
- C. TABB: Testing, Adjusting, and Balancing Bureau.
- D. TAB Specialist: An entity engaged to perform TAB Work.

#### 1.04 SUBMITTALS

- A. Qualification Data: Within 30 days of Contractor's Notice to Proceed, submit documentation that the TAB contractor and this Project's TAB team members meet the qualifications specified in "Quality Assurance" Article.
- B. Contract Documents Examination Report: Within 45 days of Contractor's Notice to Proceed, submit the Contract Documents review report as specified in Part 3.
- C. Strategies and Procedures Plan: Within 60 days of Contractor's Notice to Proceed, submit TAB strategies and step-by-step procedures as specified in "Preparation" Article.
- D. Certified TAB reports.
- E. Sample report forms.
- F. Instrument calibration reports, to include the following:
  - 1. Instrument type and make.
  - 2. Serial number.
  - 3. Application.
  - 4. Dates of use.
  - 5. Dates of calibration.

#### 1.05 QUALITY ASSURANCE

- A. TAB Contractor Qualifications: Engage a TAB entity certified by AABC.
  - 1. TAB Field Supervisor: Employee of the TAB contractor and certified by AABC.
  - 2. TAB Technician: Employee of the TAB contractor and who is certified by AABC as a TAB technician.
- B. TAB Conference: Meet with Architect Commissioning Authority on approval of the TAB strategies and procedures plan to develop a mutual understanding of the details. Require the participation of the TAB field supervisor and technicians. Provide seven days' advance notice of scheduled meeting time and location.
  - 1. Agenda Items:
    - a. The Contract Documents examination report.
    - b. The TAB plan.
    - c. Coordination and cooperation of trades and subcontractors.
    - d. Coordination of documentation and communication flow.
- C. Certify TAB field data reports and perform the following:
  - 1. Review field data reports to validate accuracy of data and to prepare certified TAB reports.
  - 2. Certify that the TAB team complied with the approved TAB plan and the procedures specified and referenced in this Specification.
- D. TAB Report Forms: Use standard TAB contractor's forms approved by Architect Commissioning Authority.
- E. Instrumentation Type, Quantity, Accuracy, and Calibration: As described in ASHRAE 111, Section 5, "Instrumentation."

# 1.06 PROJECT CONDITIONS

- A. Partial Owner Occupancy: Owner may occupy completed areas of building before Substantial Completion. Cooperate with Owner during TAB operations to minimize conflicts with Owner's operations.
- 1.07 COORDINATION
  - A. Notice: Provide seven days' advance notice for each test. Include scheduled test dates and times.
  - B. Perform TAB after leakage and pressure tests on air and water distribution systems have been satisfactorily completed.

### PART 2 PRODUCTS (NOT USED)

### PART 3 EXECUTION

# 3.01 EXAMINATION

A. Examine the Contract Documents to become familiar with Project requirements and to discover conditions in systems' designs that may preclude proper TAB of systems and equipment.

- B. Examine systems for installed balancing devices, such as test ports, gage cocks, thermometer wells, flow-control devices, balancing valves and fittings, and manual volume dampers. Verify that locations of these balancing devices are accessible.
- C. Examine the approved submittals for HVAC systems and equipment.
- D. Examine design data including HVAC system descriptions, statements of design assumptions for environmental conditions and systems' output, and statements of philosophies and assumptions about HVAC system and equipment controls.
- E. Examine equipment performance data including fan and pump curves.
  - 1. Relate performance data to Project conditions and requirements, including system effects that can create undesired or unpredicted conditions that cause reduced capacities in all or part of a system.
  - 2. Calculate system-effect factors to reduce performance ratings of HVAC equipment when installed under conditions different from the conditions used to rate equipment performance. To calculate system effects for air systems, use tables and charts found in AMCA 201, "Fans and Systems," or in SMACNA's "HVAC Systems Duct Design." Compare results with the design data and installed conditions.
- F. Examine system and equipment installations and verify that field quality-control testing, cleaning, and adjusting specified in individual Sections have been performed.
- G. Examine test reports specified in individual system and equipment Sections.
- H. Examine HVAC equipment and verify that bearings are greased, belts are aligned and tight, and equipment with functioning controls is ready for operation.
- I. Examine strainers. Verify that startup screens are replaced by permanent screens with indicated perforations.
- J. Examine three-way valves for proper installation for their intended function of diverting or mixing fluid flows.
- K. Examine system pumps to ensure absence of entrained air in the suction piping.
- L. Examine operating safety interlocks and controls on HVAC equipment.
- M. Report deficiencies discovered before and during performance of TAB procedures. Observe and record system reactions to changes in conditions. Record default set points if different from indicated values.

# 3.02 PREPARATION

- A. Prepare a TAB plan that includes strategies and step-by-step procedures.
- B. Complete system-readiness checks and prepare reports. Verify the following:
  - 1. Permanent electrical-power wiring is complete.
  - 2. Hydronic systems are filled, clean, and free of air.
  - 3. Automatic temperature-control systems are operational.
  - 4. Equipment and duct access doors are securely closed.
  - 5. Balance, combination smoke and fire dampers are open.
  - 6. Isolating and balancing valves are open and control valves are operational.
  - 7. Ceilings are installed in critical areas where air-pattern adjustments are required and access to balancing devices is provided.

8. Windows and doors can be closed so indicated conditions for system operations can be met.

## 3.03 GENERAL PROCEDURES FOR TESTING AND BALANCING

- A. Perform testing and balancing procedures on each system according to the procedures contained in AABC's "National Standards for Total System Balance" and ASHRAE 111 and in this Section.
  - 1. Comply with requirements in ASHRAE 62.1-2004, Section 7.2.2, "Air Balancing."
- B. Cut insulation, ducts, pipes, and equipment cabinets for installation of test probes to the minimum extent necessary for TAB procedures.
  - 1. After testing and balancing, install test ports and duct access doors that comply with requirements in Division 23 Section "Air Duct Accessories."
  - 2. Install and join new insulation that matches removed materials. Restore insulation, coverings, vapor barrier, and finish according to Division 23 Section "HVAC Equipment Insulation" And "HVAC Piping Insulation".
- C. Mark equipment and balancing devices, including damper-control positions, valve position indicators, fan-speed-control levers, and similar controls and devices, with paint or other suitable, permanent identification material to show final settings.
- D. Take and report testing and balancing measurements in inch-pound (IP) units.

### 3.04 GENERAL PROCEDURES FOR BALANCING AIR SYSTEMS

- A. Prepare test reports for both fans and outlets. Obtain manufacturer's outlet factors and recommended testing procedures. Crosscheck the summation of required outlet volumes with required fan volumes.
- B. Prepare schematic diagrams of systems' "as-built" duct layouts.
- C. Determine the best locations in main and branch ducts for accurate duct-airflow measurements.
- D. Check airflow patterns from the outdoor-air louvers and dampers and the return- and exhaustair dampers through the supply-fan discharge and mixing dampers.
- E. Locate start-stop and disconnect switches, electrical interlocks, and motor starters.
- F. Verify that motor starters are equipped with properly sized thermal protection.
- G. Check dampers for proper position to achieve desired airflow path.
- H. Check for airflow blockages.
- I. Check condensate drains for proper connections and functioning.
- J. Check for proper sealing of air-handling-unit components.
- K. Verify that air duct system is sealed as specified in Division 23 Section "Metal Ducts."

### 3.05 PROCEDURES FOR VARIABLE-VOLUME AIR SYSTEMS

- A. Compensating for Diversity: When the total airflow of all terminal units is more than the indicated airflow of the fan, place a selected number of terminal units at a minimum set-point airflow with the remainder at maximum-airflow condition until the total airflow of the terminal units equals the indicated airflow of the fan. Select the reduced-airflow terminal units so they are distributed evenly among the branch ducts.
- B. Pressure-Independent, Variable-Air-Volume Systems: After the fan systems have been adjusted, adjust the variable-air-volume systems as follows:
  - 1. Set outdoor-air dampers at minimum, and set return- and exhaust-air dampers at a position that simulates full-cooling load.
  - 2. Select the terminal unit that is most critical to the supply-fan airflow and static pressure. Measure static pressure. Adjust system static pressure so the entering static pressure for the critical terminal unit is not less than the sum of the terminal-unit manufacturer's recommended minimum inlet static pressure plus the static pressure needed to overcome terminal-unit discharge system losses.
  - 3. Measure total system airflow. Adjust to within indicated airflow.
  - 4. Set terminal units at maximum airflow and adjust controller or regulator to deliver the designed maximum airflow. Use terminal-unit manufacturer's written instructions to make this adjustment. When total airflow is correct, balance the air outlets downstream from terminal units the same as described for constant-volume air systems.
  - 5. Set terminal units at minimum airflow and adjust controller or regulator to deliver the designed minimum airflow. Check air outlets for a proportional reduction in airflow the same as described for constant-volume air systems.
    - a. If air outlets are out of balance at minimum airflow, report the condition but leave outlets balanced for maximum airflow.
  - 6. Remeasure the return airflow to the fan while operating at maximum return airflow and minimum outdoor airflow.
    - a. Adjust the fan and balance the return-air ducts and inlets the same as described for constant-volume air systems.
  - 7. Measure static pressure at the most critical terminal unit and adjust the static-pressure controller at the main supply-air sensing station to ensure that adequate static pressure is maintained at the most critical unit.
  - 8. Record final fan-performance data.

# 3.06 PROCEDURES FOR CONSTANT-VOLUME AIR SYSTEMS

- A. Adjust fans to deliver total indicated airflows within the maximum allowable fan speed listed by fan manufacturer.
  - 1. Measure total airflow.
    - a. Where sufficient space in ducts is unavailable for Pitot-tube traverse measurements, measure airflow at terminal outlets and inlets and calculate the total airflow.
  - 2. Measure fan static pressures as follows to determine actual static pressure:
    - a. Measure outlet static pressure as far downstream from the fan as practical and upstream from restrictions in ducts such as elbows and transitions.
    - b. Measure static pressure directly at the fan outlet or through the flexible connection.
    - c. Measure inlet static pressure of single-inlet fans in the inlet duct as near the fan as possible, upstream from the flexible connection, and downstream from duct restrictions.
  - 3. Measure static pressure across each component that makes up an air-handling unit, rooftop unit, and other air-handling and -treating equipment.
    - a. Report the cleanliness status of filters and the time static pressures are measured.
  - 4. Measure static pressures entering and leaving other devices, such as sound traps, heatrecovery equipment, under final balanced conditions.

- 5. Review Record Documents to determine variations in design static pressures versus actual static pressures. Calculate actual system-effect factors. Recommend adjustments to accommodate actual conditions.
- 6. Comply with requirements in Division 23 Sections for air-handling units for adjustment of fans, belts, and pulley sizes to achieve indicated air-handling-unit performance.
- 7. Do not make fan-speed adjustments that result in motor overload. Consult equipment manufacturers about fan-speed safety factors. Modulate dampers and measure fanmotor amperage to ensure that no overload will occur. Measure amperage in full-cooling, full-heating, economizer, and any other operating mode to determine the maximum required brake horsepower.
- B. Adjust volume dampers for main duct, submain ducts, and major branch ducts to indicated airflows within specified tolerances.
  - 1. Measure airflow of submain and branch ducts.
    - a. Where sufficient space in submain and branch ducts is unavailable for Pitot-tube traverse measurements, measure airflow at terminal outlets and inlets and calculate the total airflow for that zone.
  - 2. Measure static pressure at a point downstream from the balancing damper, and adjust volume dampers until the proper static pressure is achieved.
  - 3. Remeasure each submain and branch duct after all have been adjusted. Continue to adjust submain and branch ducts to indicated airflows within specified tolerances.
- C. Measure air outlets and inlets without making adjustments.
  - 1. Measure terminal outlets using a direct-reading hood or outlet manufacturer's written instructions and calculating factors.
- D. Adjust air outlets and inlets for each space to indicated airflows within specified tolerances of indicated values. Make adjustments using branch volume dampers rather than extractors and the dampers at air terminals.
  - 1. Adjust each outlet in same room or space to within specified tolerances of indicated quantities without generating noise levels above the limitations prescribed by the Contract Documents.
  - 2. Adjust patterns of adjustable outlets for proper distribution without drafts.

# 3.07 PROCEDURES FOR CONSTANT-FLOW HYDRONIC SYSTEMS

- A. Measure water flow at pumps. Use the following procedures except for positive-displacement pumps:
  - 1. Verify impeller size by operating the pump with the discharge valve closed. Read pressure differential across the pump. Convert pressure to head and correct for differences in gage heights. Note the point on manufacturer's pump curve at zero flow and verify that the pump has the intended impeller size.
    - a. If impeller sizes must be adjusted to achieve pump performance, obtain approval from Architect and comply with requirements in Division 23 Section "Hydronic Pumps."
  - 2. Check system resistance. With all valves open, read pressure differential across the pump and mark pump manufacturer's head-capacity curve. Adjust pump discharge valve until indicated water flow is achieved.
    - a. Monitor motor performance during procedures and do not operate motors in overload conditions.
  - 3. Verify pump-motor brake horsepower. Calculate the intended brake horsepower for the system based on pump manufacturer's performance data. Compare calculated brake horsepower with nameplate data on the pump motor. Report conditions where actual amperage exceeds motor nameplate amperage.
  - 4. Report flow rates that are not within plus or minus 10 percent of design.

- B. Measure flow at all automatic flow control valves to verify that valves are functioning as designed.
- C. Measure flow at all pressure-independent characterized control valves, with valves in fully open position, to verify that valves are functioning as designed.
- D. Set calibrated balancing valves, if installed, at calculated presettings.
- E. Measure flow at all stations and adjust, where necessary, to obtain first balance.
  - 1. System components that have Cv rating or an accurately cataloged flow-pressure-drop relationship may be used as a flow-indicating device.
- F. Measure flow at main balancing station and set main balancing device to achieve flow that is 5 percent greater than indicated flow.
- G. Adjust balancing stations to within specified tolerances of indicated flow rate as follows:
  - 1. Determine the balancing station with the highest percentage over indicated flow.
  - 2. Adjust each station in turn, beginning with the station with the highest percentage over indicated flow and proceeding to the station with the lowest percentage over indicated flow.
  - 3. Record settings and mark balancing devices.
- H. Measure pump flow rate and make final measurements of pump amperage, voltage, rpm, pump heads, and systems' pressures and temperatures including outdoor-air temperature.
- I. Measure the differential-pressure-control-valve settings existing at the conclusion of balancing.
- J. Check settings and operation of each safety valve. Record settings.

### 3.08 PROCEDURES FOR MOTORS

- A. Motors, 1/2 HP and Larger: Test at final balanced conditions and record the following data:
  - 1. Manufacturer's name, model number, and serial number.
  - 2. Motor horsepower rating.
  - 3. Motor rpm.
  - 4. Efficiency rating.
  - 5. Nameplate and measured voltage, each phase.
  - 6. Nameplate and measured amperage, each phase.
  - 7. Starter thermal-protection-element rating.
- B. Motors Driven by Variable-Frequency Controllers: Test for proper operation at speeds varying from minimum to maximum. Test the manual bypass of the controller to prove proper operation. Record observations including name of controller manufacturer, model number, serial number, and nameplate data.

### 3.09 TOLERANCES

- A. Set HVAC system's air flow rates and water flow rates within the following tolerances:
  - 1. Exhaust Fans and Equipment with Fans: Plus or minus 10 percent.
  - 2. Air Outlets and Inlets: Plus or minus 10 percent.
  - 3. Cooling-Water Flow Rate: Plus or minus 10 percent.

### 3.10 REPORTING

- A. Initial Construction-Phase Report: Based on examination of the Contract Documents as specified in "Examination" Article, prepare a report on the adequacy of design for systems' balancing devices. Recommend changes and additions to systems' balancing devices to facilitate proper performance measuring and balancing. Recommend changes and additions to HVAC systems and general construction to allow access for performance measuring and balancing devices.
- B. Status Reports: Prepare weekly progress reports to describe completed procedures, procedures in progress, and scheduled procedures. Include a list of deficiencies and problems found in systems being tested and balanced. Prepare a separate report for each system and each building floor for systems serving multiple floors.

### 3.11 FINAL REPORT

- A. General: Prepare a certified written report; tabulate and divide the report into separate sections for tested systems and balanced systems.
  - 1. Include a certification sheet at the front of the report's binder, signed and sealed by the certified testing and balancing engineer.
  - 2. Include a list of instruments used for procedures, along with proof of calibration.
- B. Final Report Contents: In addition to certified field-report data, include the following:
  - 1. Pump curves.
  - 2. Fan curves.
  - 3. Manufacturers' test data.
  - 4. Field test reports prepared by system and equipment installers.
  - 5. Other information relative to equipment performance; do not include Shop Drawings and product data.
- C. General Report Data: In addition to form titles and entries, include the following data:
  - 1. Title page.
  - 2. Name and address of the TAB contractor.
  - 3. Project name.
  - 4. Project location.
  - 5. Architect's name and address.
  - 6. Engineer's name and address.
  - 7. Contractor's name and address.
  - 8. Report date.
  - 9. Signature of TAB supervisor who certifies the report.
  - 10. Table of Contents with the total number of pages defined for each section of the report. Number each page in the report.
  - 11. Summary of contents including the following:
    - a. Indicated versus final performance.
    - b. Notable characteristics of systems.
    - c. Description of system operation sequence if it varies from the Contract Documents.
  - 12. Nomenclature sheets for each item of equipment.
  - 13. Data for terminal units, including manufacturer's name, type, size, and fittings.
  - 14. Notes to explain why certain final data in the body of reports vary from indicated values.
  - 15. Test conditions for fans and pump performance forms including the following:
    - a. Settings for exhaust-air dampers.
    - b. Fan drive settings including settings and percentage of maximum pitch diameter.
    - c. Other system operating conditions that affect performance.

- D. System Diagrams: Include schematic layouts of air and hydronic distribution systems. Present each system with single-line diagram and include the following:
  - 1. Quantities of outdoor, supply, return, and exhaust airflows.
  - 2. Water and steam flow rates.
  - 3. Duct, outlet, and inlet sizes.
  - 4. Pipe and valve sizes and locations.
  - 5. Balancing stations.
  - 6. Position of balancing devices.
- E. Fan Test Reports: For supply, return, and exhaust fans, include the following:
  - 1. Fan Data:
    - a. System identification.
    - b. Location.
    - c. Make and type.
    - d. Model number and size.
    - e. Manufacturer's serial number.
    - f. Arrangement and class.
    - g. Sheave make, size in inches, and bore.
    - h. Center-to-center dimensions of sheave, and amount of adjustments in inches.
  - 2. Motor Data:
    - a. Motor make, and frame type and size.
    - b. Horsepower and rpm.
    - c. Volts, phase, and hertz.
    - d. Full-load amperage and service factor.
    - e. Sheave make, size in inches, and bore.
    - f. Center-to-center dimensions of sheave, and amount of adjustments in inches.
    - g. Number, make, and size of belts.
  - 3. Test Data (Indicated and Actual Values):
    - a. Total airflow rate in cfm.
    - b. Total system static pressure in inches wg.
    - c. Fan rpm.
    - d. Discharge static pressure in inches wg.
    - e. Suction static pressure in inches wg.
- F. Round, Flat-Oval, and Rectangular Duct Traverse Reports: Include a diagram with a grid representing the duct cross-section and record the following:
  - 1. Report Data:
    - a. System and air-handling-unit number.
    - b. Location and zone.
    - c. Traverse air temperature in deg F.
    - d. Duct static pressure in inches wg.
    - e. Duct size in inches.
    - f. Duct area in sq. ft..
    - g. Indicated air flow rate in cfm.
    - h. Indicated velocity in fpm.
    - i. Actual air flow rate in cfm.
    - j. Actual average velocity in fpm.
    - k. Barometric pressure in psig.
- 3.12 INSPECTIONS
  - A. Initial Inspection:
    - 1. After testing and balancing are complete, operate each system and randomly check measurements to verify that the system is operating according to the final test and balance readings documented in the final report.

- 2. Check the following for each system:
  - a. Measure airflow of at least 10 percent of air outlets.
  - b. Measure water flow of at least 5 percent of terminals.
  - c. Measure room temperature at each thermostat/temperature sensor. Compare the reading to the set point.
  - d. Verify that balancing devices are marked with final balance position.
  - e. Note deviations from the Contract Documents in the final report.
- B. Final Inspection:
  - 1. After initial inspection is complete and documentation by random checks verifies that testing and balancing are complete and accurately documented in the final report, request that a final inspection be made by Architect and Commissioning Authority.
  - 2. The TAB contractor's test and balance engineer shall conduct the inspection in the presence of Architect Commissioning Authority.
  - 3. Architect Commissioning Authority shall randomly select measurements, documented in the final report, to be rechecked. Rechecking shall be limited to either 10 percent of the total measurements recorded or the extent of measurements that can be accomplished in a normal 8-hour business day.
  - 4. If rechecks yield measurements that differ from the measurements documented in the final report by more than the tolerances allowed, the measurements shall be noted as "FAILED."
  - 5. If the number of "FAILED" measurements is greater than 10 percent of the total measurements checked during the final inspection, the testing and balancing shall be considered incomplete and shall be rejected.
- C. TAB Work will be considered defective if it does not pass final inspections. If TAB Work fails, proceed as follows:
  - 1. Recheck all measurements and make adjustments. Revise the final report and balancing device settings to include all changes; resubmit the final report and request a second final inspection.
  - 2. If the second final inspection also fails, Owner may contract the services of another TAB contractor to complete TAB Work according to the Contract Documents and deduct the cost of the services from the original TAB contractor's final payment.
- D. Prepare test and inspection reports.

# 3.13 ADDITIONAL TESTS

- A. Within 90 days of completing TAB, perform additional TAB to verify that balanced conditions are being maintained throughout and to correct unusual conditions.
- B. Seasonal Periods: If initial TAB procedures were not performed during near-peak summer and winter conditions, perform additional TAB during near-peak summer and winter conditions.

# END OF SECTION

### SECTION 23 07 13

### **DUCT INSULATION**

### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section includes insulating the following duct services:
  - 1. Indoor, concealed supply.
  - 2. Indoor, exposed supply.
  - 3. Indoor, concealed return located in unconditioned space.
  - 4. Indoor, exposed return located in unconditioned space.
- B. Related Sections:
  - 1. Division 23 Section "HVAC Piping Insulation."

### 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated. Include thermal conductivity, water-vapor permeance thickness, and jackets (both factory- and field-applied if any).
- B. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail insulation application at elbows, fittings, dampers, specialties and flanges for each type of insulation.
  - 3. Detail application of field-applied jackets.
  - 4. Detail application at linkages of control devices.
- C. Qualification Data: For qualified Installer.
- D. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.
- E. Field quality-control reports.

### 1.04 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84, by a testing agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.
  - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.

2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.

# 1.05 DELIVERY, STORAGE, AND HANDLING

A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

# 1.06 COORDINATION

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Division 23 Section "Hangers and Supports for HVAC Piping and Equipment."
- B. Coordinate clearance requirements with duct Installer for duct insulation application. Before preparing ductwork Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

# 1.07 SCHEDULING

- A. Schedule insulation application after pressure testing systems and, where required, after installing and testing heat tracing. Insulation application may begin on segments that have satisfactory test results.
- B. Complete installation and concealment of plastic materials as rapidly as possible in each area of construction.

# PART 2 PRODUCTS

# 2.01 INSULATION MATERIALS

- A. Comply with requirements in "Duct Insulation Schedule, General," "Indoor Duct and Plenum Insulation Schedule," and "Aboveground, Outdoor Duct and Plenum Insulation Schedule" articles for where insulating materials shall be applied.
- B. Products shall not contain asbestos, lead, mercury, or mercury compounds.
- C. Products that come in contact with stainless steel shall have a leachable chloride content of less than 50 ppm when tested according to ASTM C 871.
- D. Insulation materials for use on austenitic stainless steel shall be qualified as acceptable according to ASTM C 795.
- E. Foam insulation materials shall not use CFC or HCFC blowing agents in the manufacturing process.
- F. Mineral-Fiber Blanket Insulation: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type II and ASTM C 1290, Type III with factory-applied FSK jacket. Factory-applied jacket requirements are specified in "Factory-Applied Jackets" Article.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. CertainTeed Corp.; SoftTouch Duct Wrap.
      - b. Johns Manville; Microlite.
      - c. Knauf Insulation; Friendly Feel Duct Wrap.
      - d. Manson Insulation Inc.; Alley Wrap.
      - e. Owens Corning; SOFTR All-Service Duct Wrap.

### 2.02 ADHESIVES

- A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated unless otherwise indicated.
- B. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; CP-127.
    - b. Eagle Bridges Marathon Industries; 225.
    - c. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 85-60/85-70.
    - d. Mon-Eco Industries, Inc.; 22-25.
  - 2. For indoor applications, use adhesive that has a VOC content of 80 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Use adhesive that complies with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers," including 2004 Addenda.
- C. ASJ Adhesive, and FSK Jacket Adhesive: Comply with MIL-A-3316C, Class 2, Grade A for bonding insulation jacket lap seams and joints.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; CP-82.
    - b. Eagle Bridges Marathon Industries; 225.
    - c. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 85-50.
    - d. Mon-Eco Industries, Inc.; 22-25.
  - 2. For indoor applications, use adhesive that has a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 3. Use adhesive that complies with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers," including 2004 Addenda.

### 2.03 MASTICS

- A. Materials shall be compatible with insulation materials, jackets, and substrates; comply with MIL-PRF-19565C, Type II.
  - 1. For indoor applications, use mastics that have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. Vapor-Barrier Mastic: Water based; suitable for indoor use on below ambient services.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 30-80/30-90.
    - b. Vimasco Corporation; 749.
  - 2. Water-Vapor Permeance: ASTM E 96/E 96M, Procedure B, 0.013 perm at 43-mil dry film thickness.
  - 3. Service Temperature Range: Minus 20 to plus 180 deg F.
  - 4. Solids Content: ASTM D 1644, 58 percent by volume and 70 percent by weight.
  - 5. Color: White.
- C. Vapor-Barrier Mastic: Solvent based; suitable for indoor use on below ambient services.
  - 1. Products: Subject to compliance with requirements, provide one of the following:

- a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; CP-30.
- b. Eagle Bridges Marathon Industries; 501.
- c. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 30-35.
- d. Mon-Eco Industries, Inc.; 55-10.
- 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 35-mil dry film thickness.
- 3. Service Temperature Range: 0 to 180 deg F.
- 4. Solids Content: ASTM D 1644, 44 percent by volume and 62 percent by weight.
- 5. Color: White.
- D. Vapor-Barrier Mastic: Solvent based; suitable for outdoor use on below ambient services.
  - Products: Subject to compliance with requirements, provide one of the following:
    - a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; Encacel.
    - b. Eagle Bridges Marathon Industries; 570.
    - c. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 60-95/60-96.
  - 2. Water-Vapor Permeance: ASTM F 1249, 0.05 perm at 30-mil dry film thickness.
  - 3. Service Temperature Range: Minus 50 to plus 220 deg F.
  - 4. Solids Content: ASTM D 1644, 33 percent by volume and 46 percent by weight.
  - 5. Color: White.

### 2.04 LAGGING ADHESIVES

- A. Description: Comply with MIL-A-3316C, Class I, Grade A and shall be compatible with insulation materials, jackets, and substrates.
  - 1. For indoor applications, use lagging adhesives that have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 2. Products: Subject to compliance with requirements, provide one of the following:
    - a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; CP-50 AHV2.
    - b. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 30-36.
    - c. Vimasco Corporation; 713 and 714.
  - 3. Fire-resistant, water-based lagging adhesive and coating for use indoors to adhere fireresistant lagging cloths over duct insulation.
  - 4. Service Temperature Range: 0 to plus 180 deg F.
  - 5. Color: White.

### 2.05 SEALANTS

- A. FSK and Metal Jacket Flashing Sealants:
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; CP-76.
    - b. Eagle Bridges Marathon Industries; 405.
    - c. Foster Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; 95-44.
    - d. Mon-Eco Industries, Inc.; 44-05.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 3. Fire- and water-resistant, flexible, elastomeric sealant.
  - 4. Service Temperature Range: Minus 40 to plus 250 deg F.
  - 5. Color: Aluminum.

- 6. For indoor applications, use sealants that have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- 7. Use sealants that comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers," including 2004 Addenda.

# 2.06 FACTORY-APPLIED JACKETS

- A. Insulation system schedules indicate factory-applied jackets on various applications. When factory-applied jackets are indicated, comply with the following:
  - 1. ASJ: White, kraft-paper, fiberglass-reinforced scrim with aluminum-foil backing; complying with ASTM C 1136, Type I.
  - 2. ASJ-SSL: ASJ with self-sealing, pressure-sensitive, acrylic-based adhesive covered by a removable protective strip; complying with ASTM C 1136, Type I.
  - 3. FSK Jacket: Aluminum-foil, fiberglass-reinforced scrim with kraft-paper backing; complying with ASTM C 1136, Type II.
  - 4. FSP Jacket: Aluminum-foil, fiberglass-reinforced scrim with polyethylene backing; complying with ASTM C 1136, Type II.

### 2.07 FIELD-APPLIED JACKETS

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
  - 1. Adhesive: As recommended by jacket material manufacturer.
  - 2. Color: White Color-code jackets based on system. Color as selected by Architect.
- B. Metal Jacket:
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; Metal Jacketing Systems.
    - b. ITW Insulation Systems; Aluminum and Stainless Steel Jacketing.
    - c. RPR Products, Inc.; Insul-Mate.
  - 2. Aluminum Jacket: Comply with ASTM B 209, Alloy 3003, 3005, 3105, or 5005, Temper H-14.
    - a. Sheet and roll stock ready for shop or field sizing.
    - b. Finish and thickness are indicated in field-applied jacket schedules.
    - c. Moisture Barrier for Indoor Applications: 3-mil-thick, heat-bonded polyethylene and kraft paper.
    - d. Moisture Barrier for Outdoor Applications: 3-mil-thick, heat-bonded polyethylene and kraft paper.

# 2.08 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. ABI, Ideal Tape Division; 428 AWF ASJ.
    - b. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0836.
    - c. Compac Corporation; 104 and 105.
    - d. Venture Tape; 1540 CW Plus, 1542 CW Plus, and 1542 CW Plus/SQ.
  - 2. Width: 3 inches.
  - 3. Thickness: 11.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.

- 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. FSK Tape: Foil-face, vapor-retarder tape matching factory-applied jacket with acrylic adhesive; complying with ASTM C 1136.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. ABI, Ideal Tape Division; 491 AWF FSK.
    - b. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0827.
    - c. Compac Corporation; 110 and 111.
  - 2. Width: 3 inches.
  - 3. Thickness: 6.5 mils.
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. FSK Tape Disks and Squares: Precut disks or squares of FSK tape.
- C. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. ABI, Ideal Tape Division; 488 AWF.
    - b. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0800.
    - c. Compac Corporation; 120.
    - d. Venture Tape; 3520 CW.
  - 2. Width: 2 inches.
  - 3. Thickness: 3.7 mils.
  - 4. Adhesion: 100 ounces force/inch in width.
  - 5. Elongation: 5 percent.
  - 6. Tensile Strength: 34 lbf/inch in width.

### 2.09 SECUREMENTS

- A. Bands:
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. ITW Insulation Systems; Gerrard Strapping and Seals.
    - b. RPR Products, Inc.; Insul-Mate Strapping, Seals, and Springs.
  - 2. Aluminum: ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch thick, 3/4 inch wide with wing seal or closed seal.
  - 3. Springs: Twin spring set constructed of stainless steel with ends flat and slotted to accept metal bands. Spring size determined by manufacturer for application.
- B. Insulation Pins and Hangers:
  - 1. Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.135-inch-diameter shank, length to suit depth of insulation indicated.
    - a. Products: Subject to compliance with requirements, provide one of the following:
      - 1) AGM Industries, Inc.; CWP-1.
      - 2) GEMCO; CD.
      - 3) Midwest Fasteners, Inc.; CD.
      - 4) Nelson Stud Welding; TPA, TPC, and TPS.
  - 2. Cupped-Head, Capacitor-Discharge-Weld Pins: Copper- or zinc-coated steel pin, fully annealed for capacitor-discharge welding, 0.135-inch-diameter shank, length to suit depth of insulation indicated with integral 1-1/2-inch galvanized carbon-steel washer.
    - a. Products: Subject to compliance with requirements, provide one of the following:
      - 1) AGM Industries, Inc.; CHP-1.
      - 2) GEMCO; Cupped Head Weld Pin.
      - 3) Midwest Fasteners, Inc.; Cupped Head.
      - 4) Nelson Stud Welding; CHP.
- 3. Metal, Adhesively Attached, Perforated-Base Insulation Hangers: Baseplate welded to projecting spindle that is capable of holding insulation, of thickness indicated, securely in position indicated when self-locking washer is in place. Comply with the following requirements:
  - a. Products: Subject to compliance with requirements, provide one of the following:
    - 1) AGM Industries, Inc.; Tactoo Perforated Base Insul-Hangers.
    - 2) GEMCO; Perforated Base.
    - 3) Midwest Fasteners, Inc.; Spindle.
  - b. Baseplate: Perforated, galvanized carbon-steel sheet, 0.030 inch thick by 2 inches square.
  - c. Spindle: Copper- or zinc-coated, low-carbon steel, fully annealed, 0.106-inchdiameter shank, length to suit depth of insulation indicated.
  - d. Adhesive: Recommended by hanger manufacturer. Product with demonstrated capability to bond insulation hanger securely to substrates indicated without damaging insulation, hangers, and substrates.
- 4. Insulation-Retaining Washers: Self-locking washers formed from 0.016-inch-thick, galvanized-steel sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
  - a. Products: Subject to compliance with requirements, provide one of the following:
    - 1) AGM Industries, Inc.; RC-150.
    - 2) GEMCO; R-150.
    - 3) Midwest Fasteners, Inc.; WA-150.
    - 4) Nelson Stud Welding; Speed Clips.
  - b. Protect ends with capped self-locking washers incorporating a spring steel insert to ensure permanent retention of cap in exposed locations.
- 5. Nonmetal Insulation-Retaining Washers: Self-locking washers formed from 0.016-inchthick nylon sheet, with beveled edge sized as required to hold insulation securely in place but not less than 1-1/2 inches in diameter.
  - a. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - 1) GEMCO.
    - 2) Midwest Fasteners, Inc.
- C. Staples: Outward-clinching insulation staples, nominal 3/4-inch-wide, stainless steel or Monel.
- D. Wire: 0.080-inch nickel-copper alloy.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by the following:
    - a. C & F Wire.

# PART 3 EXECUTION

## 3.01 EXAMINATION

- A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
  - 1. Verify that systems to be insulated have been tested and are free of defects.
  - 2. Verify that surfaces to be insulated are clean and dry.

B. Proceed with installation only after unsatisfactory conditions have been corrected.

# 3.02 PREPARATION

A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.

# 3.03 GENERAL INSTALLATION REQUIREMENTS

- A. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of ducts and fittings.
- B. Install insulation materials, vapor barriers or retarders, jackets, and thicknesses required for each item of duct system as specified in insulation system schedules.
- C. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- D. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- E. Install multiple layers of insulation with longitudinal and end seams staggered.
- F. Keep insulation materials dry during application and finishing.
- G. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- H. Install insulation with least number of joints practical.
- I. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  - 1. Install insulation continuously through hangers and around anchor attachments.
  - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
  - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
- J. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- K. Install insulation with factory-applied jackets as follows:
  - 1. Draw jacket tight and smooth.
  - 2. Cover circumferential joints with 3-inch-wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
  - Overlap jacket longitudinal seams at least 1-1/2 inches. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches o.c.
     a. For below ambient services, apply vapor-barrier mastic over staples.
  - Cover joints and seams with tape, according to insulation material manufacturer's written instructions, to maintain vapor seal.
  - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to duct flanges and fittings.

- L. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- M. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- N. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.

# 3.04 PENETRATIONS

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
  - 1. Seal penetrations with flashing sealant.
  - 2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
  - 3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches below top of roof flashing.
  - 4. Seal jacket to roof flashing with flashing sealant.
- B. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.
- C. Insulation Installation at Fire-Rated Wall and Partition Penetrations: Terminate insulation at fire damper sleeves for fire-rated wall and partition penetrations. Externally insulate damper sleeves to match adjacent insulation and overlap duct insulation at least 2 inches.
  - 1. Comply with requirements in Division 07 Section "Penetration Firestopping" firestopping and fire-resistive joint sealers.

## 3.05 INSTALLATION OF MINERAL-FIBER INSULATION

- A. Blanket Insulation Installation on Ducts and Plenums: Secure with adhesive and insulation pins.
  - 1. Apply adhesives according to manufacturer's recommended coverage rates per unit area, for 50 percent coverage of duct and plenum surfaces.
  - 2. Apply adhesive to entire circumference of ducts and to all surfaces of fittings and transitions.
  - 3. Install either capacitor-discharge-weld pins and speed washers or cupped-head, capacitor-discharge-weld pins on sides and bottom of horizontal ducts and sides of vertical ducts as follows:
    - a. On duct sides with dimensions 18 inches and smaller, place pins along longitudinal centerline of duct. Space 3 inches maximum from insulation end joints, and 16 inches o.c.
    - b. On duct sides with dimensions larger than 18 inches, place pins 16 inches o.c. each way, and 3 inches maximum from insulation joints. Install additional pins to hold insulation tightly against surface at cross bracing.
    - c. Pins may be omitted from top surface of horizontal, rectangular ducts and plenums.
    - d. Do not overcompress insulation during installation.
    - e. Impale insulation over pins and attach speed washers.
    - f. Cut excess portion of pins extending beyond speed washers or bend parallel with insulation surface. Cover exposed pins and washers with tape matching insulation facing.
  - 4. For ducts and plenums with surface temperatures below ambient, install a continuous unbroken vapor barrier. Create a facing lap for longitudinal seams and end joints with insulation by removing 2 inches from one edge and one end of insulation segment.

Secure laps to adjacent insulation section with 1/2-inch outward-clinching staples, 1 inch o.c. Install vapor barrier consisting of factory- or field-applied jacket, adhesive, vapor-barrier mastic, and sealant at joints, seams, and protrusions.

- a. Repair punctures, tears, and penetrations with tape or mastic to maintain vaporbarrier seal.
- b. Install vapor stops for ductwork and plenums operating below 50 deg F at 18-foot intervals. Vapor stops shall consist of vapor-barrier mastic applied in a Z-shaped pattern over insulation face, along butt end of insulation, and over the surface. Cover insulation face and surface to be insulated a width equal to two times the insulation thickness, but not less than 3 inches.
- 5. Overlap unfaced blankets a minimum of 2 inches on longitudinal seams and end joints. At end joints, secure with steel bands spaced a maximum of 18 inches o.c.
- 6. Install insulation on rectangular duct elbows and transitions with a full insulation section for each surface. Install insulation on round and flat-oval duct elbows with individually mitered gores cut to fit the elbow.
- 7. Insulate duct stiffeners, hangers, and flanges that protrude beyond insulation surface with 6-inch-wide strips of same material used to insulate duct. Secure on alternating sides of stiffener, hanger, and flange with pins spaced 6 inches o.c.

# 3.06 FIELD-APPLIED JACKET INSTALLATION

- A. Where FSK jackets are indicated, install as follows:
  - 1. Draw jacket material smooth and tight.
  - 2. Install lap or joint strips with same material as jacket.
  - 3. Secure jacket to insulation with manufacturer's recommended adhesive.
  - 4. Install jacket with 1-1/2-inch laps at longitudinal seams and 3-inch-wide joint strips at end joints.
  - 5. Seal openings, punctures, and breaks in vapor-retarder jackets and exposed insulation with vapor-barrier mastic.
- B. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with stainless-steel bands 12 inches o.c. and at end joints.

## 3.07 FINISHES

- A. Insulation with ASJ, Glass-Cloth, or Other Paintable Jacket Material: Paint jacket with paint system identified below and as specified in Division 09 painting Sections.
  - 1. Flat Acrylic Finish: Two finish coats over a primer that is compatible with jacket material and finish coat paint. Add fungicidal agent to render fabric mildew proof.
    - a. Finish Coat Material: Interior, flat, latex-emulsion size.

- B. Flexible Elastomeric Thermal Insulation: After adhesive has fully cured, apply two coats of insulation manufacturer's recommended protective coating.
- C. Color: Final color as selected by Architect. Vary first and second coats to allow visual inspection of the completed Work.
- D. Do not field paint aluminum or stainless-steel jackets.
- 3.08 FIELD QUALITY CONTROL
  - A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
  - B. Perform tests and inspections.
  - C. Tests and Inspections:
    - 1. Inspect ductwork, randomly selected by Architect, by removing field-applied jacket and insulation in layers in reverse order of their installation. Extent of inspection shall be limited to one location(s) for each duct system defined in the "Duct Insulation Schedule, General" Article.
  - D. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.
- 3.09 DUCT INSULATION SCHEDULE, GENERAL
  - A. Plenums and Ducts Requiring Insulation:
    - 1. Indoor, concealed supply.
    - 2. Indoor, exposed supply.
    - 3. Indoor, concealed return located in unconditioned space.
    - 4. Indoor, exposed return located in unconditioned space.
    - 5. Outdoor, concealed supply and return.
    - 6. Outdoor, exposed supply and return.
  - B. Items Not Insulated:
    - 1. Factory-insulated flexible ducts.
    - 2. Factory-insulated plenums and casings.
    - 3. Flexible connectors.
    - 4. Vibration-control devices.
    - 5. Factory-insulated access panels and doors.
- 3.10 INDOOR DUCT AND PLENUM INSULATION SCHEDULE
  - A. Concealed, round and flat-oval, supply-air duct insulation shall be the following:
    - 1. Mineral-Fiber Blanket: 2 inches thick and 1.5-lb/cu. ft. nominal density.
  - B. Concealed, round and flat-oval, return-air duct insulation shall be one of the following:
    1. Mineral-Fiber Blanket: 2 inches thick and 1.5-lb/cu. ft. nominal density.
  - C. Concealed, rectangular, supply-air duct insulation shall be the following:
    - 1. Mineral-Fiber Blanket: 2 inches thick and 0.75-lb/cu. ft. 1.5-lb/cu. ft. 3-lb/cu. ft. nominal density.
  - D. Concealed, rectangular, return-air duct insulation shall be the following:
    - 1. Mineral-Fiber Blanket: 1-1/2 inches thick and 1.5-lb/cu. ft. nominal density.
  - E. Exposed, round and flat-oval, supply-air duct insulation shall be the following:
    - 1. Mineral-Fiber Blanket: 2 inches thick and 1.5-lb/cu. ft. nominal density.

- F. Exposed, round and flat-oval, return-air duct insulation shall be one of the following:
  1. Mineral-Fiber Blanket: 1-1/2 inches thick and 1.5-lb/cu. ft. nominal density.
- G. Exposed, rectangular, return-air duct insulation shall be the following:
  - 1. Mineral-Fiber Blanket: 1-1/2 inches thick and 1.5-lb/cu. ft. nominal density.

END OF SECTION

### SECTION 23 07 19

### **HVAC PIPING INSULATION**

## PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section includes insulating the following HVAC piping systems:
  - 1. Heating, hot-water piping, indoors and outdoors.

### 1.03 ACTION SUBMITTALS

- A. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail application of protective shields, saddles, and inserts at hangers for each type of insulation and hanger.
  - 2. Detail insulation application at pipe expansion joints for each type of insulation.
  - 3. Detail insulation application at elbows, fittings, flanges, valves, and specialties for each type of insulation.
  - 4. Detail removable insulation at piping specialties.
- 1.04 INFORMATIONAL SUBMITTALS
  - A. Qualification Data: For qualified Installer.
  - B. Material Test Reports: From a qualified testing agency acceptable to authorities having jurisdiction indicating, interpreting, and certifying test results for compliance of insulation materials, sealers, attachments, cements, and jackets, with requirements indicated. Include dates of tests and test methods employed.
  - C. Field quality-control reports.

### 1.05 QUALITY ASSURANCE

- A. Installer Qualifications: Skilled mechanics who have successfully completed an apprenticeship program or another craft training program certified by the Department of Labor, Bureau of Apprenticeship and Training.
- B. Surface-Burning Characteristics: For insulation and related materials, as determined by testing identical products according to ASTM E 84, by a testing and inspecting agency acceptable to authorities having jurisdiction. Factory label insulation and jacket materials and adhesive, mastic, tapes, and cement material containers, with appropriate markings of applicable testing agency.
  - 1. Insulation Installed Indoors: Flame-spread index of 25 or less, and smoke-developed index of 50 or less.
  - 2. Insulation Installed Outdoors: Flame-spread index of 75 or less, and smoke-developed index of 150 or less.

### 1.06 DELIVERY, STORAGE, AND HANDLING

A. Packaging: Insulation material containers shall be marked by manufacturer with appropriate ASTM standard designation, type and grade, and maximum use temperature.

#### 1.07 COORDINATION

- A. Coordinate sizes and locations of supports, hangers, and insulation shields specified in Section 23 05 29 "Hangers and Supports for HVAC Piping and Equipment."
- B. Coordinate clearance requirements with piping Installer for piping insulation application. Before preparing piping Shop Drawings, establish and maintain clearance requirements for installation of insulation and field-applied jackets and finishes and for space required for maintenance.

## 1.08 SCHEDULING

A. Schedule insulation application after pressure testing systems and, where required. Insulation application may begin on segments that have satisfactory test results.

### PART 2 PRODUCTS

- 2.01 INSULATION MATERIALS
  - A. Products shall not contain CFC, asbestos, lead, mercury, or mercury compounds.
  - B. Insulation shall meet fire and smoke hazard ratings as tested under procedure ASTM E-84, NFPA 255, and UL 723 and shall not exceed flame spread rating of 25 and maximum smoke developed rating of 50.
  - C. Mineral-Fiber, Preformed Pipe Insulation
    - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
      - a. Fibrex Insulations Inc.; Coreplus 1200.
      - b. Johns Manville; Micro-Lok.
      - c. Knauf Insulation; 1000 Pipe Insulation.
      - d. Owens Corning; Fiberglas Pipe Insulation.
    - 2. Type I, 850 deg F Materials: Mineral or glass fibers bonded with a thermosetting resin. Comply with ASTM C 547, Type I, Grade A, with factory-applied ASJ-SSL. Factoryapplied jacket requirements are specified in "Factory-Applied Jackets" Article.
  - D. Flexible Closed Cell Elastomeric Insulation:
    - 1. Products: Subject to compliance with requirements, provide one of the following: a. Armaflex
      - b. Acceptable Equal
    - 2. Preformed pipe insulation of flexible, expanded, closed-cell structure. Comply with ASTM C 1126, Type III, Grade 1.
    - 3. Insulation materials shall have a maximum thermal conductivity of 0.27 Btu-in./h-ft2-°F
- 2.02 ADHESIVES
  - A. Materials shall be compatible with insulation materials, jackets, and substrates and for bonding insulation to itself and to surfaces to be insulated unless otherwise indicated.

- B. Mineral-Fiber Adhesive: Comply with MIL-A-3316C, Class 2, Grade A.
  - 1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Childers Products, Division of ITW; CP-82.
    - b. Foster Products Corporation, H. B. Fuller Company; 85-20.
    - c. ITW TACC, Division of Illinois Tool Works; S-90/80.
    - d. Marathon Industries, Inc.; 225.
    - e. Mon-Eco Industries, Inc.; 22-25.
- C. PVC Jacket Adhesive: Compatible with PVC jacket.
  - Products: Subject to compliance with requirements, provide one of the following: Dow Corning Corporation; 739, Dow Silicone. Johns Manville; Zeston Perma-Weld, CEEL-TITE Solvent Welding Adhesive. P.I.C. Plastics, Inc.; Welding Adhesive. Speedline Corporation; Polyco VP Adhesive.
  - 2. For indoor applications, adhesive shall have a VOC content of 50 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

## 2.03 SEALANTS

- A. FSK and Metal Jacket Flashing Sealants:
  - Products: Subject to compliance with requirements, provide one of the following: Childers Brand CP-76.
     Eagle Bridges - Marathon Industries; 405.
     Foster Brand 95-44.
     Mon-Eco Industries, Inc.; 44-05.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 3. Fire- and water-resistant, flexible, elastomeric sealant.
  - 4. Service Temperature Range: Minus 40 to plus 250 deg F.
  - 5. Color: Aluminum.
  - 6. For indoor applications, sealants shall have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
- B. PVC Jacket Flashing Sealants:
  - 1. Products: Subject to compliance with requirements, provide one of the following: Childers Brand CP-76.
  - 2. Materials shall be compatible with insulation materials, jackets, and substrates.
  - 3. Fire- and water-resistant, flexible, elastomeric sealant.
  - 4. Service Temperature Range: Minus 40 to plus 250 deg F.
  - 5. Color: White.
  - 6. For indoor applications, sealants shall have a VOC content of 420 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).

## 2.04 FIELD-APPLIED JACKETS

- A. Field-applied jackets shall comply with ASTM C 921, Type I, unless otherwise indicated.
- B. PVC Jacket: High-impact-resistant, UV-resistant PVC complying with ASTM D 1784, Class 16354-C; thickness as scheduled; roll stock ready for shop or field cutting and forming. Thickness is indicated in field-applied jacket schedules.

 Products: Subject to compliance with requirements, provide one of the following: Johns Manville; Zeston.
 P.I.C. Plastics, Inc.; FG Series.
 Proto Corporation; LoSmoke.
 Speedline Corporation; SmokeSafe.

- 2. Adhesive: As recommended by jacket material manufacturer.
- PVC Jacket Color: Heating, hot-water Piping: Green Heating, hot-water Supply: Green Heating, hot-water Return: Green
- 4. Factory-fabricated fitting covers to match jacket if available; otherwise, field fabricate. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, unions, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories.
- C. Aluminum Jacket: Comply with ASTM B 209, Alloy 3003, 3005, 3105, or 5005, Temper H-14.
  - Products: Subject to compliance with requirements, provide one of the following: Childers Brand, Specialty Construction Brands, Inc., a business of H. B. Fuller Company; Metal Jacketing Systems. ITW Insulation Systems; Aluminum and Stainless Steel Jacketing. RPR Products, Inc.; Insul-Mate.
  - 2. Factory cut and rolled to size.
  - 3. Finish and thickness are indicated in field-applied jacket schedules.
  - 4. Moisture Barrier for Outdoor Applications: 3-mil- thick, heat-bonded polyethylene and kraft paper 2.5-mil- thick polysurlyn.
  - 5. Factory-Fabricated Fitting Covers: Same material, finish, and thickness as jacket. Preformed 2-piece or gore, 45- and 90-degree, short- and long-radius elbows. Tee covers. Flange and union covers. End caps. Beveled collars. Valve covers. Field fabricate fitting covers only if factory-fabricated fitting covers are not available.

## 2.05 TAPES

- A. ASJ Tape: White vapor-retarder tape matching factory-applied jacket with acrylic adhesive, complying with ASTM C 1136.
  - Products: Subject to compliance with requirements, provide one of the following: ABI, Ideal Tape Division; 428 AWF ASJ. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0836. Compac Corporation; 104 and 105. Venture Tape; 1540 CW Plus, 1542 CW Plus, and 1542 CW Plus/SQ.
  - 2. Width: 3 inches.
  - 3. Thickness: 11.5 mils
  - 4. Adhesion: 90 ounces force/inch in width.
  - 5. Elongation: 2 percent.
  - 6. Tensile Strength: 40 lbf/inch in width.
  - 7. ASJ Tape Disks and Squares: Precut disks or squares of ASJ tape.
- B. FSK Tape: Foil-face, vapor-retarder tape matching factory-applied jacket with acrylic adhesive; complying with ASTM C 1136.
  - Products: Subject to compliance with requirements, provide one of the following: ABI, Ideal Tape Division; 491 AWF FSK. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0827. Compac Corporation; 110 and 111. Venture Tape; 1525 CW NT, 1528 CW, and 1528 CW/SQ.
  - 2. Width: 3 inches.
  - 3. Thickness: 6.5 mils.

- 4. Adhesion: 90 ounces force/inch in width.
- 5. Elongation: 2 percent.
- 6. Tensile Strength: 40 lbf/inch in width.
- 7. FSK Tape Disks and Squares: Precut disks or squares of FSK tape.
- C. PVC Tape: White vapor-retarder tape matching field-applied PVC jacket with acrylic adhesive; suitable for indoor and outdoor applications.
  - Products: Subject to compliance with requirements, provide one of the following: ABI, Ideal Tape Division; 370 White PVC tape. Compac Corporation; 130. Venture Tape; 1506 CW NS.
  - 2. Width: 2 inches.
  - 3. Thickness: 6 mils.
  - 4. Adhesion: 64 ounces force/inch in width.
  - 5. Elongation: 500 percent.
  - 6. Tensile Strength: 18 lbf/inch in width.
- D. Aluminum-Foil Tape: Vapor-retarder tape with acrylic adhesive.
  - Products: Subject to compliance with requirements, provide one of the following: ABI, Ideal Tape Division; 488 AWF. Avery Dennison Corporation, Specialty Tapes Division; Fasson 0800. Compac Corporation; 120. Venture Tape; 3520 CW.
  - 2. Width: 2 inches.
  - 3. Thickness: 3.7 mils.
  - 4. Adhesion: 100 ounces force/inch in width.
  - 5. Elongation: 5 percent.
  - 6. Tensile Strength: 34 lbf/inch in width.

### 2.06 SECUREMENTS

- A. Aluminum Bands: ASTM B 209, Alloy 3003, 3005, 3105, or 5005; Temper H-14, 0.020 inch thick, 1/2 inch 3/4 inch wide with closed seal.
  - Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, the following]: ITW Insulation Systems; Gerrard Strapping and Seals. RPR Products, Inc.; Insul-Mate Strapping, Seals, and Springs.
- B. Staples: Outward-clinching insulation staples, nominal 3/4-inch wide, stainless steel or Monel.
- C. Wire: 0.062-inch soft-annealed, stainless steel.
  - 1. Manufacturers: Subject to compliance with requirements, provide product by: C & F Wire.

## PART 3 EXECUTION

- 3.01 EXAMINATION
  - A. Examine substrates and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of insulation application.
    - 1. Verify that systems to be insulated have been tested and are free of defects.
    - 2. Verify that surfaces to be insulated are clean and dry.
    - 3. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 PREPARATION

A. Surface Preparation: Clean and dry surfaces to receive insulation. Remove materials that will adversely affect insulation application.

#### 3.03 GENERAL INSTALLATION REQUIREMENTS

- A. Insulation shall not be installed until the following have been completed and documentation has been submitted to University Representative and USC Facility Management Services (FMS) for approval and record:
  - 1. Cleaning and flushing
  - 2. Pressure testing
- B. Install insulation materials, accessories, and finishes with smooth, straight, and even surfaces; free of voids throughout the length of piping including fittings, valves, and specialties.
- C. Install insulation materials, forms, vapor barriers or retarders, jackets, and thicknesses required for each item of pipe system as specified in insulation system schedules.
- D. Install accessories compatible with insulation materials and suitable for the service. Install accessories that do not corrode, soften, or otherwise attack insulation or jacket in either wet or dry state.
- E. Install insulation with longitudinal seams at top and bottom of horizontal runs.
- F. Install multiple layers of insulation with longitudinal and end seams staggered.
- G. Do not weld brackets, clips, or other attachment devices to piping, fittings, and specialties.
- H. Keep insulation materials dry during application and finishing.
- I. Install insulation with tight longitudinal seams and end joints. Bond seams and joints with adhesive recommended by insulation material manufacturer.
- J. Install insulation with least number of joints practical.
- K. Install rigid pre-insulated pipe supports to protect from compression of insulation material due to point loads.
- L.Provide aluminum sleeves at all pipe support joints, between hanger support and exterior layer of insulating systems, to protect from compression of insulation material due to point loads.
- M. Install insulation on piping accessories requiring future reoccuring access and service with factory fabricated insulation covers that are easily removed and reapplied.
- N. Where vapor barrier is indicated, seal joints, seams, and penetrations in insulation at hangers, supports, anchors, and other projections with vapor-barrier mastic.
  - 1. Install insulation continuously through hangers and around anchor attachments.
  - 2. For insulation application where vapor barriers are indicated, extend insulation on anchor legs from point of attachment to supported item to point of attachment to structure. Taper and seal ends at attachment to structure with vapor-barrier mastic.
  - 3. Install insert materials and install insulation to tightly join the insert. Seal insulation to insulation inserts with adhesive or sealing compound recommended by insulation material manufacturer.
  - 4. Cover inserts with jacket material matching adjacent pipe insulation. Install shields over

jacket, arranged to protect jacket from tear or puncture by hanger, support, and shield.

- O. Apply adhesives, mastics, and sealants at manufacturer's recommended coverage rate and wet and dry film thicknesses.
- P. Install insulation with factory-applied jackets as follows:
  - 1. Draw jacket tight and smooth.
  - 2. Cover circumferential joints with 3-inch- wide strips, of same material as insulation jacket. Secure strips with adhesive and outward clinching staples along both edges of strip, spaced 4 inches o.c.
  - 3. Overlap jacket longitudinal seams at least 1-1/2 inches. Install insulation with longitudinal seams at bottom of pipe. Clean and dry surface to receive self-sealing lap. Staple laps with outward clinching staples along edge at 2 inches 4 inches o.c. For below-ambient services, apply vapor-barrier mastic over staples.
  - Cover joints and seams with tape, according to insulation material manufacturer's written instructions, to maintain vapor seal.
  - 5. Where vapor barriers are indicated, apply vapor-barrier mastic on seams and joints and at ends adjacent to pipe flanges and fittings.
- Q. Cut insulation in a manner to avoid compressing insulation more than 75 percent of its nominal thickness.
- R. Finish installation with systems at operating conditions. Repair joint separations and cracking due to thermal movement.
- S. Repair damaged insulation facings by applying same facing material over damaged areas. Extend patches at least 4 inches beyond damaged areas. Adhere, staple, and seal patches similar to butt joints.
- T. For above-ambient services, do not install insulation to the following:
  - 1. Vibration-control devices.
  - 2. Testing agency labels and stamps.
  - 3. Nameplates and data plates.
  - 4. Manholes.
  - 5. Handholes.
  - 6. Cleanouts.

## 3.04 PENETRATIONS

- A. Insulation Installation at Roof Penetrations: Install insulation continuously through roof penetrations.
  - 1. Seal penetrations with flashing sealant.
  - 2. For applications requiring only indoor insulation, terminate insulation above roof surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
  - 3. Extend jacket of outdoor insulation outside roof flashing at least 2 inches below top of roof flashing.
  - 4. Seal jacket to roof flashing with flashing sealant.
- B. Insulation Installation at Underground Exterior Wall Penetrations: Terminate insulation flush with sleeve seal. Seal terminations with flashing sealant.
- C. Insulation Installation at Aboveground Exterior Wall Penetrations: Install insulation continuously through wall penetrations.

- 1. Seal penetrations with flashing sealant.
- 2. For applications requiring only indoor insulation, terminate insulation inside wall surface and seal with joint sealant. For applications requiring indoor and outdoor insulation, install insulation for outdoor applications tightly joined to indoor insulation ends. Seal joint with joint sealant.
- 3. Extend jacket of outdoor insulation outside wall flashing and overlap wall flashing at least 2 inches.
- 4. Seal jacket to wall flashing with flashing sealant.
- D. Insulation Installation at Interior Wall and Partition Penetrations (That Are Not Fire Rated): Install insulation continuously through walls and partitions.

## 3.05 GENERAL PIPE INSULATION INSTALLATION

- A. Insulation Installation on Fittings, Valves, Strainers, Flanges, and Unions:
  - 1. Install insulation over fittings, valves, strainers, flanges, unions, and other specialties with continuous thermal and vapor-retarder integrity unless otherwise indicated.
  - 2. Insulate pipe elbows using preformed fitting insulation or mitered fittings made from same material and density as adjacent pipe insulation. Each piece shall be butted tightly against adjoining piece and bonded with adhesive. Fill joints, seams, voids, and irregular surfaces with insulating cement finished to a smooth, hard, and uniform contour that is uniform with adjoining pipe insulation.
  - 3. Insulate tee fittings with preformed fitting insulation or sectional pipe insulation of same material and thickness as used for adjacent pipe. Cut sectional pipe insulation to fit. Butt each section closely to the next and hold in place with tie wire. Bond pieces with adhesive.
  - 4. Insulate valves using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. For valves, insulate up to and including the bonnets, valve stuffing-box studs, bolts, and nuts. Fill joints, seams, and irregular surfaces with insulating cement.
  - 5. Insulate strainers using preformed fitting insulation or sectional pipe insulation of same material, density, and thickness as used for adjacent pipe. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker. Fill joints, seams, and irregular surfaces with insulating cement. Insulate strainers so strainer basket flange or plug can be easily removed and replaced without damaging the insulation and jacket. Provide a removable reusable insulation cover. For below-ambient services, provide a design that maintains vapor barrier.
  - 6. Insulate flanges and unions using a section of oversized preformed pipe insulation. Overlap adjoining pipe insulation by not less than two times the thickness of pipe insulation, or one pipe diameter, whichever is thicker.
  - 7. Cover segmented insulated surfaces with a layer of finishing cement and coat with a mastic. Install vapor-barrier mastic for below-ambient services and a breather mastic for above-ambient services. Reinforce the mastic with fabric-reinforcing mesh. Trowel the mastic to a smooth and well-shaped contour.
  - 8. For services not specified to receive a field-applied jacket, install fitted PVC cover over elbows, tees, strainers, valves, flanges, and unions. Terminate ends with PVC end caps. Tape PVC covers to adjoining insulation facing using PVC tape.
  - 9. Stencil or label the outside insulation jacket of each union with the word "union." Match size and color of pipe labels.
- B. Insulate instrument connections for thermometers, pressure gages, pressure temperature taps, test connections, flow meters, sensors, switches, and transmitters on insulated pipes.

Shape insulation at these connections by tapering it to and around the connection with insulating cement and finish with finishing cement, mastic, and flashing sealant.

- C. Install removable insulation covers at locations indicated. Installation shall conform to the following:
  - 1. Make removable flange and union insulation from sectional pipe insulation of same thickness as that on adjoining pipe. Install same insulation jacket as adjoining pipe insulation.
  - 2. When flange and union covers are made from sectional pipe insulation, extend insulation from flanges or union long at least two times the insulation thickness over adjacent pipe insulation on each side of flange or union. Secure flange cover in place with stainless-steel or aluminum bands. Select band material compatible with insulation and jacket.
  - 3. Construct removable valve insulation covers in same manner as for flanges, except divide the two-part section on the vertical center line of valve body.
  - 4. When covers are made from block insulation, make two halves, each consisting of mitered blocks wired to stainless-steel fabric. Secure this wire frame, with its attached insulation, to flanges with tie wire. Extend insulation at least 2 inches over adjacent pipe insulation on each side of valve. Fill space between flange or union cover and pipe insulation with insulating cement. Finish cover assembly with insulating cement applied in two coats. After first coat is dry, apply and trowel second coat to a smooth finish.
  - 5. Unless a PVC jacket is indicated in field-applied jacket schedules, finish exposed surfaces with a metal jacket.

## 3.06 FIELD-APPLIED JACKET INSTALLATION

- A. Where FSK jackets are indicated, install as follows:
  - 1. Draw jacket material smooth and tight.
  - 2. Install lap or joint strips with same material as jacket.
  - 3. Secure jacket to insulation with manufacturer's recommended adhesive.
  - 4. Install jacket with 1-1/2-inch laps at longitudinal seams and 3-inch wide joint strips at end joints.
  - 5. Seal openings, punctures, and breaks in vapor-retarder jackets and exposed insulation with vapor-barrier mastic.
- B. Where PVC jackets are indicated, install with 1-inch overlap at longitudinal seams and end joints; for horizontal applications. Seal with manufacturer's recommended adhesive.
  - 1. Apply two continuous beads of adhesive to seams and joints, one bead under lap and the finish bead along seam and joint edge.
- C. Where metal jackets are indicated, install with 2-inch overlap at longitudinal seams and end joints. Overlap longitudinal seams arranged to shed water. Seal end joints with weatherproof sealant recommended by insulation manufacturer. Secure jacket with bands 12 inches o.c. and at end joints.

### 3.07 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. All insulation applications will be considered defective Work if sample inspection reveals noncompliance with requirements.

## 3.08 PIPING INSULATION SCHEDULE, GENERAL

A. Acceptable preformed pipe and tubular insulation materials and thicknesses are identified for each piping system and pipe size range.

## 3.09 ABOVEGROUND PIPING INSULATION SCHEDULE

- A. Heating-Hot-Water Supply and Return, 200 Deg F and below
  - 1. NPS 12 and Smaller: Insulation shall be the following:
    - a. Mineral-Fiber, Preformed Pipe, Type I: 1-1/2 inches thick.

# 3.10 INDOOR, FIELD-APPLIED JACKET SCHEDULE

- A. Install jacket over insulation material.
- B. Piping, Exposed:
  - 1. PVC, Color-Coded by System: 30 mils thick for all indoor applications.

END OF SECTION

### SECTION 23 09 00

### INSTRUMENTATION AND CONTROL FOR HVAC

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. This Section includes control equipment for HVAC systems and components, including control components for terminal heating and cooling units not supplied with factory-wired controls.
- B. Related Sections include the following:
  - 1. List below only products, construction, and equipment that the reader might expect to find in this Section but are specified elsewhere.
  - 2. Division 23 Section "Meters and Gages for HVAC Piping" for measuring equipment that relates to this Section.
  - 3. Division 23 Section "Sequence of Operations for HVAC Controls" for requirements that relate to this Section.

## 1.03 DEFINITIONS

- A. Retain abbreviations and terms that remain after this Section has been edited.
- B. DDC: Direct digital control.
- C. I/O: Input/output.
- D. MS/TP: Master slave/token passing.
- E. PC: Personal computer.
- F. PID: Proportional plus integral plus derivative.
- G. RTD: Resistance temperature detector.

### 1.04 SYSTEM PERFORMANCE

- A. Comply with the following performance requirements:
  - 1. Graphic Display: Display graphic with minimum 20 dynamic points with current data within 10 seconds.
  - 2. Graphic Refresh: Update graphic with minimum 20 dynamic points with current data within 8 seconds.
  - 3. Object Command: Reaction time of less than two seconds between operator command of a binary object and device reaction.
  - 4. Object Scan: Transmit change of state and change of analog values to control units or workstation within six seconds.
  - 5. Alarm Response Time: Annunciate alarm at workstation within 45 seconds. Multiple workstations must receive alarms within five seconds of each other.

- 6. Program Execution Frequency: Run capability of applications as often as five seconds, but selected consistent with mechanical process under control.
- 7. Performance: Programmable controllers shall execute DDC PID control loops, and scan and update process values and outputs at least once per second.
- 8. Reporting Accuracy and Stability of Control: Report values and maintain measured variables within tolerances as follows:
  - a. Water Temperature: Plus or minus 1 deg F.
  - b. Water Flow: Plus or minus 5 percent of full scale.
  - c. Water Pressure: Plus or minus 2 percent of full scale.
  - d. Space Temperature: Plus or minus 1 deg F.
  - e. Temperature Differential: Plus or minus 0.25 deg F.
  - f. Carbon Dioxide: Plus or minus 50 ppm.
  - g. Electrical: Plus or minus 5 percent of reading.

## 1.05 SUBMITTALS

- A. Product Data: Include manufacturer's technical literature for each control device. Indicate dimensions, capacities, performance characteristics, electrical characteristics, finishes for materials, and installation and startup instructions for each type of product indicated.
  - 1. Retain three subparagraphs below for DDC systems.
  - 2. DDC System Hardware: Bill of materials of equipment indicating quantity, manufacturer, and model number. Include technical data for operator workstation equipment, interface equipment, control units, transducers/transmitters, sensors, actuators, valves, relays/switches, control panels, and operator interface equipment.
  - 3. Control System Software: Include technical data for operating system software, operator interface, color graphics, and other third-party applications.
  - 4. Controlled Systems: Instrumentation list with element name, type of device, manufacturer, model number, and product data. Include written description of sequence of operation including schematic diagram.
- B. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 1. Bill of materials of equipment indicating quantity, manufacturer, and model number.
  - 2. Schematic flow diagrams showing fans, pumps, coils, dampers, valves, and control devices.
  - 3. Wiring Diagrams: Power, signal, and control wiring.
  - 4. Details of control panel faces, including controls, instruments, and labeling.
  - 5. Written description of sequence of operation.
  - 6. Schedule of dampers including size, leakage, and flow characteristics.
  - 7. Schedule of valves including flow characteristics.
  - 8. DDC System Hardware:
    - a. Schematic diagrams and floor plans for field sensors and control hardware.
    - b. Schematic diagrams for control, communication, and power wiring, showing trunk data conductors and wiring between operator workstation and control unit locations.
  - 9. Control System Software: List of color graphics indicating monitored systems, data (connected and calculated) point addresses, output schedule, and operator notations.
  - 10. Controlled Systems:
    - a. Schematic diagrams of each controlled system with control points labeled and control elements graphically shown, with wiring.
    - b. Scaled drawings showing mounting, routing, and wiring of elements including bases and special construction.
    - c. Written description of sequence of operation including schematic diagram.
    - d. Points list.

- C. Data Communications Protocol Certificates: Certify that each proposed DDC system component complies with ASHRAE 135.
- D. Data Communications Protocol Certificates: Certify that each proposed DDC system component complies with BACNet.
- E. Samples for Initial Selection: For each color required, of each type of thermostat or sensor cover with factory-applied color finishes.
- F. Samples for Verification: For each color required, of each type of thermostat or sensor cover.
- G. Software and Firmware Operational Documentation: Include the following:
  - 1. Software operating and upgrade manuals.
  - 2. Program Software Backup: On a magnetic media or compact disc, complete with data files.
  - 3. Device address list.
  - 4. Printout of software application and graphic screens.
  - 5. Software license required by and installed for DDC workstations and control systems.
- H. Software Upgrade Kit: For Owner to use in modifying software to suit future systems revisions or monitoring and control revisions.
- I. Field quality-control test reports.
- J. Operation and Maintenance Data: For HVAC instrumentation and control system to include in emergency, operation, and maintenance manuals. In addition to items specified in Division 01 Section "Operation and Maintenance Data," include the following:
  - 1. Maintenance instructions and lists of spare parts for each type of control device.
  - 2. Interconnection wiring diagrams with identified and numbered system components and devices.
  - 3. Keyboard illustrations and step-by-step procedures indexed for each operator function.
  - 4. Inspection period, cleaning methods, cleaning materials recommended, and calibration tolerances.
  - 5. Calibration records and list of set points.

### 1.06 QUALITY ASSURANCE

- A. Installer Qualifications: Automatic control system manufacturer's authorized representative who is trained and approved for installation of system components required for this Project.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with ASHRAE 135 for DDC system components.

## 1.07 DELIVERY, STORAGE, AND HANDLING

- A. Factory-Mounted Components: Where control devices specified in this Section are indicated to be factory mounted on equipment, arrange for shipping of control devices to equipment manufacturer.
- B. System Software: Update to latest version of software at Project completion.

## 1.08 COORDINATION

- A. Coordinate location of thermostats, humidistats, and other exposed control sensors with plans and room details before installation.
- B. Coordinate equipment with Division 28 Section "Intrusion Detection" to achieve compatibility with equipment that interfaces with that system and with building master clock.
- C. Coordinate equipment with Division 28 Section "Access Control" to achieve compatibility with equipment that interfaces with that system.
- D. Coordinate equipment with Division 27 Section "Clock Systems" to achieve compatibility with equipment that interfaces with that system.
- E. Coordinate equipment with Division 28 Section "PLC Electronic Detention Monitoring and Control Systems" to achieve compatibility with equipment that interfaces with that system.
- F. Coordinate equipment with Division 26 Section "Network Lighting Controls" to achieve compatibility with equipment that interfaces with that system.
- G. Coordinate equipment with Division 28 Section "Fire Detection and Alarm" to achieve compatibility with equipment that interfaces with that system.
- H. Coordinate supply of conditioned electrical branch circuits for control units and operator workstation.
- I. Coordinate equipment with Division 26 Section "Electrical Power Monitoring and Control" to achieve compatibility of communication interfaces.
- J. Coordinate equipment with Division 26 Section "Panelboards" to achieve compatibility with starter coils and annunciation devices.
- K. Coordinate equipment with Division 26 Section "Motor-Control Centers" to achieve compatibility with motor starters and annunciation devices.

L. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified in Division 03 Section "Cast-in-Place Concrete."

# PART 2 PRODUCTS

## 2.01 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

## 2.02 CONTROL SYSTEM

- A. Manufacturers:
  - 1. Siemens
  - 2. Alertron through Climatec
- B. Control system shall consist of sensors, indicators, actuators, final control elements, interface equipment, other apparatus, accessories, and software connected to distributed controllers operating in multiuser, multitasking environment on token-passing network and programmed to control mechanical systems. An operator workstation permits interface with the network via dynamic color graphics with each mechanical system, building floor plan, and control device depicted by point-and-click graphics.
- C. Control system shall include the following:

### 2.03 DDC EQUIPMENT

- A. Operator Workstation: One PC-based microcomputer(s) with minimum configuration as follows:
  - 1. Motherboard: With 8 integrated USB 2.0 ports, integrated Intel Pro 10/100 (Ethernet), integrated audio, bios, and hardware monitoring.
  - 2. Processor: Intel Pentium 4, 3.8 GHz.
  - 3. Random-Access Memory: 2 GB.
  - 4. Graphics: Video adapter, minimum 1280 x 1024 pixels, 64-MB video memory, with TV out.
  - 5. Monitor: 17 inches, LCD color.
  - 6. Keyboard: QWERTY, 105 keys in ergonomic shape.
  - 7. Floppy-Disk Drive: 1.44 MB.
  - 8. Hard-Disk Drive: 80 GB.
  - 9. CD-ROM Read/Write Drive: 48x24x48.
  - 10. Mouse: Three button, optical.
  - 11. Uninterruptible Power Supply: 2 kVa.
  - 12. Operating System: Microsoft Windows XP Professional with high-speed Internet access.
    - a. ASHRAE 135 Compliance: Workstation shall use ASHRAE 135 protocol and communicate using ISO 8802-3 (Ethernet) datalink/physical layer protocol.
    - b. BACNet Compliance: System shall be capable of BACNet communication according to ANSI/ASHRAE 135-2004.
    - c. Print Head: 4800 x 1200 dpi optimized color resolution.
    - d. Paper Handling: Minimum of 100 sheets.
    - e. Print Speed: Minimum of 17 ppm in black and 12 ppm in color.
  - 13. Application Software:

- a. I/O capability from operator station.
- b. System security for each operator via software password and access levels.
- c. Automatic system diagnostics; monitor system and report failures.
- d. Database creation and support.
- e. Automatic and manual database save and restore.
- f. Dynamic color graphic displays with up to 10 screen displays at once.
- g. Custom graphics generation and graphics library of HVAC equipment and symbols.
- h. Alarm processing, messages, and reactions.
- i. Trend logs retrievable in spreadsheets and database programs.
- j. Alarm and event processing.
- k. Object and property status and control.
- I. Automatic restart of field equipment on restoration of power.
- m. Data collection, reports, and logs. Include standard reports for the following:
  - 1) Current values of all objects.
  - 2) Current alarm summary.
  - 3) Disabled objects.
  - 4) Alarm lockout objects.
  - 5) Logs.
- n. Custom report development.
- o. Utility and weather reports.
- p. Workstation application editors for controllers and schedules.
- q. Maintenance management.
- 14. Custom Application Software:
  - a. English language oriented.
  - b. Full-screen character editor/programming environment.
  - c. Allow development of independently executing program modules with debugging/simulation capability.
  - d. Support conditional statements.
  - e. Support floating-point arithmetic with mathematic functions.
  - f. Contains predefined time variables.
- B. Diagnostic Terminal Unit: Portable notebook-style, PC-based microcomputer terminal capable of accessing system data by connecting to system network with minimum configuration as follows:
  - 1. System: With one integrated USB 2.0 port, integrated Intel Pro 10/100 (Ethernet), integrated audio, bios, and hardware monitoring.
  - 2. Processor: Intel Pentium 4, 2 GHz.
  - 3. Random-Access Memory: 1 GHz.
  - 4. Graphics: Video adapter, minimum 1024 x 768 pixels, 64-MB video memory.
  - 5. Monitor: 17 inches, LCD color.
  - 6. Keyboard: QWERTY 105 keys in ergonomic shape.
  - 7. Floppy-Disk Drive: 1.44 MB.
  - 8. Hard-Disk Drive: 20 GB.
  - 9. CD-ROM Read/Write Drive: 48x24x48.
  - 10. Pointing Device: Touch pad or other internal device.
- C. Control Units: Modular, comprising processor board with programmable, nonvolatile, randomaccess memory; local operator access and display panel; integral interface equipment; and backup power source.
  - 1. Units monitor or control each I/O point; process information; execute commands from other control units, devices, and operator stations; and download from or upload to operator workstation or diagnostic terminal unit.
  - 2. Stand-alone mode control functions operate regardless of network status. Functions include the following:
    - a. Global communications.

- b. Discrete/digital, analog, and pulse I/O.
- c. Monitoring, controlling, or addressing data points.
- d. Software applications, scheduling, and alarm processing.
- e. Testing and developing control algorithms without disrupting field hardware and controlled environment.
- 3. Standard Application Programs:
  - a. Electric Control Programs: Demand limiting, duty cycling, automatic time scheduling, start/stop time optimization, night setback/setup, on-off control with differential sequencing, staggered start, antishort cycling, PID control, DDC with fine tuning, and trend logging.
  - b. Chiller Control Programs: Control function of condenser-water reset, chilled-water reset, and equipment sequencing.
  - c. Programming Application Features: Include trend point; alarm processing and messaging; weekly, monthly, and annual scheduling; energy calculations; run-time totalization; and security access.
  - d. Remote communications.
  - e. Maintenance management.
  - f. Units of Measure: Inch-pound and SI (metric).
- 4. Local operator interface provides for download from or upload to operator workstation or diagnostic terminal unit.
- 5. ASHRAE 135 Compliance: Control units shall use ASHRAE 135 protocol and communicate using ISO 8802-3 (Ethernet) datalink/physical layer protocol.
- D. Local Control Units: Modular, comprising processor board with electronically programmable, nonvolatile, read-only memory; and backup power source.
  - 1. Units monitor or control each I/O point, process information, and download from or upload to operator workstation or diagnostic terminal unit.
  - 2. Stand-alone mode control functions operate regardless of network status. Functions include the following:
    - a. Global communications.
    - b. Discrete/digital, analog, and pulse I/O.
    - c. Monitoring, controlling, or addressing data points.
  - 3. Local operator interface provides for download from or upload to operator workstation or diagnostic terminal unit.
  - 4. ASHRAE 135 Compliance: Control units shall use ASHRAE 135 protocol and communicate using ISO 8802-3 (Ethernet) datalink/physical layer protocol.
- E. I/O Interface: Hardwired inputs and outputs may tie into system through controllers. Protect points so that shorting will cause no damage to controllers.
  - 1. Binary Inputs: Allow monitoring of on-off signals without external power.
  - 2. Pulse Accumulation Inputs: Accept up to 10 pulses per second.
  - 3. Analog Inputs: Allow monitoring of low-voltage (0- to 10-V dc), current (4 to 20 mA), or resistance signals.
  - 4. Binary Outputs: Provide on-off or pulsed low-voltage signal, selectable for normally open or normally closed operation with three-position (on-off-auto) override switches and status lights.
  - Analog Outputs: Provide modulating signal, either low voltage (0- to 10-V dc) or current (4 to 20 mA) with status lights, two-position (auto-manual) switch, and manually adjustable potentiometer.
  - 6. Tri-State Outputs: Provide two coordinated binary outputs for control of three-point, floating-type electronic actuators.
  - 7. Universal I/Os: Provide software selectable binary or analog outputs.
  - 8. F. Power Supplies: Transformers with Class 2 current-limiting type or overcurrent protection; limit connected loads to 80 percent of rated capacity. DC power supply shall

match output current and voltage requirements and be full-wave rectifier type with the following:

- 9. Output ripple of 5.0 mV maximum peak to peak.
- 10. Combined 1 percent line and load regulation with 100-mic.sec. response time for 50 percent load changes.
- 11. Built-in overvoltage and overcurrent protection and be able to withstand 150 percent overload for at least 3 seconds without failure.
- F. Power Line Filtering: Internal or external transient voltage and surge suppression for workstations or controllers with the following:
  - 1. Minimum dielectric strength of 1000 V.
  - 2. Maximum response time of 10 nanoseconds.
  - 3. Minimum transverse-mode noise attenuation of 65 dB.
  - 4. Minimum common-mode noise attenuation of 150 dB at 40 to 100 Hz.

## 2.04 UNITARY CONTROLLERS

- A. Unitized, capable of stand-alone operation with sufficient memory to support its operating system, database, and programming requirements, and with sufficient I/O capacity for the application.
  - 1. Configuration: Local keypad and display; diagnostic LEDs for power, communication, and processor; wiring termination to terminal strip or card connected with ribbon cable; memory with bios; and 72-hour battery backup.
  - 2. Operating System: Manage I/O communication to allow distributed controllers to share real and virtual object information and allow central monitoring and alarms. Perform scheduling with real-time clock. Perform automatic system diagnostics; monitor system and report failures.
  - 3. ASHRAE 135 Compliance: Communicate using read (execute and initiate) and write (execute and initiate) property services defined in ASHRAE 135. Reside on network using MS/TP datalink/physical layer protocol and have service communication port for connection to diagnostic terminal unit.
  - 4. Enclosure: Dustproof rated for operation at 32 to 120 deg F.
  - 5. Enclosure: Waterproof rated for operation at 40 to 150 deg F.

### 2.05 ALARM PANELS

- A. Unitized cabinet with suitable brackets for wall or floor mounting. Fabricate of 0.06-inch-thick, furniture-quality steel or extruded-aluminum alloy, totally enclosed, with hinged doors and keyed lock and with manufacturer's standard shop-painted finish. Provide common keying for all panels.
- B. Indicating light for each alarm point, single horn, acknowledge switch, and test switch, mounted on hinged cover.
  - 1. Alarm Condition: Indicating light flashes and horn sounds.
  - 2. Acknowledge Switch: Horn is silent and indicating light is steady.
  - 3. Second Alarm: Horn sounds and indicating light is steady.
  - 4. Alarm Condition Cleared: System is reset and indicating light is extinguished.
  - 5. Contacts in alarm panel allow remote monitoring by independent alarm company.

## 2.06 ELECTRONIC SENSORS

- A. Description: Vibration and corrosion resistant; for wall, immersion, or duct mounting as required.
- B. Thermistor Temperature Sensors and Transmitters:
  - 1. Manufacturers:
    - a. Siemens.
    - b. ACI Automation Components
    - c. Building Automation Products (BAPI)
  - 2. Accuracy: Plus or minus 0.5 deg F at calibration point.
  - 3. Wire: Twisted, shielded-pair cable.
  - 4. Insertion Elements for Liquids: Brass or stainless-steel socket with minimum insertion length of 2-1/2 inches.
  - 5. Room Sensor Cover Construction: Manufacturer's standard locking covers.
    - a. Set-Point Adjustment: Exposed.
    - b. Set-Point Indication: Exposed.
    - c. Thermometer: Concealed.
    - d. Color:
      - 1) Orientation: Vertical or Horizontal.
- C. RTDs and Transmitters:
  - 1. Manufacturers:
    - a. Siemens.
    - b. ACI Automation Components
    - c. Building Automation Products (BAPI)
  - 2. Accuracy: Plus or minus 0.2 percent at calibration point.
  - 3. Wire: Twisted, shielded-pair cable.
  - 4. Insertion Elements for Liquids: Brass socket with minimum insertion length of 2-1/2 inches.
  - 5. Room Sensor Cover Construction: Manufacturer's standard locking covers.
    - a. Set-Point Adjustment: Exposed.
    - b. Set-Point Indication: Keyed Exposed.
    - c. Thermometer: Concealed.
    - d. Color:
    - e. Orientation: Vertical or Horizontal.
- D. Pressure Transmitters/Transducers:
  - 1. Manufacturers:
    - a. Setra.
    - b. General Eastern Instruments.
    - c. MAMAC Systems, Inc.
    - d. ROTRONIC Instrument Corp.
    - e. TCS/Basys Controls.
    - f. Vaisala.
  - 2. Water Pressure Transducers: Stainless-steel diaphragm construction, suitable for service; minimum 150-psig operating pressure; linear output 4 to 20 mA.
  - 3. Water Differential-Pressure Transducers: Stainless-steel diaphragm construction, suitable for service; minimum 150-psig operating pressure and tested to 300-psig; linear output 4 to 20 mA.
  - 4. Differential-Pressure Switch (Water): Snap acting, with pilot-duty rating and with suitable scale range and differential.
  - 5. Pressure Transmitters: Direct acting for gas, liquid, or steam service; range suitable for system; linear output 4 to 20 mA.

- E. Room Sensor Cover Construction: Manufacturer's standard locking covers.
- F. Room sensor accessories include the following:1. Insulating Bases: For sensors located on exterior walls.

### 2.07 STATUS SENSORS

- A. Status Inputs for Fans: Differential-pressure switch with pilot-duty rating and with adjustable range of 0- to 5-inch wg.
- B. Status Inputs for Pumps: Differential-pressure switch with pilot-duty rating and with adjustable pressure-differential range of 8 to 60 psig, piped across pump.
- C. Status Inputs for Electric Motors: Comply with ISA 50.00.01, current-sensing fixed- or splitcore transformers with self-powered transmitter, adjustable and suitable for 175 percent of rated motor current.
- D. Voltage Transmitter (100- to 600-V ac): Comply with ISA 50.00.01, single-loop, self-powered transmitter, adjustable, with suitable range and 1 percent full-scale accuracy.
- E. Power Monitor: 3-phase type with disconnect/shorting switch assembly, listed voltage and current transformers, with pulse kilowatt hour output and 4- to 20-mA kW output, with maximum 2 percent error at 1.0 power factor and 2.5 percent error at 0.5 power factor.
- F. Current Switches: Self-powered, solid-state with adjustable trip current, selected to match current and system output requirements.
- G. Electronic Valve/Damper Position Indicator: Visual scale indicating percent of travel and 2- to 10-V dc, feedback signal.
- H. Water-Flow Switches: Bellows-actuated mercury or snap-acting type with pilot-duty rating, stainless-steel or bronze paddle, with appropriate range and differential adjustment, in NEMA 250, Type 1 enclosure.
  - 1. Manufacturers:
    - a. BEC Controls Corporation.
    - b. I.T.M. Instruments Inc.

### 2.08 THERMOSTATS

- A. Manufacturers:
- B. Combination Thermostat and Fan Switches: Line-voltage thermostat with push-button or lever-operated fan switch.
  - 1. Label switches "FAN ON-OFF".
  - 2. Mount on single electric switch box.
- C. Electric, solid-state, microcomputer-based room thermostat with remote sensor.
  - 1. Automatic switching from heating to cooling.
  - 2. Preferential rate control to minimize overshoot and deviation from set point.
  - 3. Set up for four separate temperatures per day.
  - 4. Instant override of set point for continuous or timed period from 1 hour to 31 days.
  - 5. Short-cycle protection.
  - 6. Programming based on every day of week.
  - 7. Selection features include degree F or degree C display, 12- or 24-hour clock, keyboard disable, remote sensor, and fan on-auto.

- 8. Battery replacement without program loss.
- 9. Thermostat display features include the following:
  - a. Time of day.
  - b. Actual room temperature.
  - c. Programmed temperature.
  - d. Programmed time.
  - e. Duration of timed override.
  - f. Day of week.
  - g. System mode indications include "heating," "off," "fan auto," and "fan on."
- D. Low-Voltage, On-Off Thermostats: NEMA DC 3, 24-V, bimetal-operated, mercury-switch type, with adjustable or fixed anticipation heater, concealed set-point adjustment, 55 to 85 deg F set-point range, and 2 deg F maximum differential.
- E. Line-Voltage, On-Off Thermostats: Bimetal-actuated, open contact or bellows-actuated, enclosed, snap-switch or equivalent solid-state type, with heat anticipator; listed for electrical rating; with concealed set-point adjustment, 55 to 85 deg F set-point range, and 2 deg F maximum differential.
  - 1. Selector Switch: Integral, manual on-off-auto.
- F. Remote-Bulb Thermostats: On-off or modulating type, liquid filled to compensate for changes in ambient temperature; with copper capillary and bulb, unless otherwise indicated.
  - 1. Bulbs in water lines with separate wells of same material as bulb.
  - 2. Scale settings and differential settings are clearly visible and adjustable from front of instrument.
  - 3. On-Off Thermostat: With precision snap switches and with electrical ratings required by application.
  - 4. Modulating Thermostats: Construct so complete potentiometer coil and wiper assembly is removable for inspection or replacement without disturbing calibration of instrument.
- G. Immersion Thermostat: Remote-bulb or bimetal rod-and-tube type, proportioning action with adjustable throttling range and adjustable set point.
- H. Duct-Mounting Humidistats: Electric insertion, 2-position type with adjustable, 2 percent throttling range, 20 to 80 percent operating range, and single- or double-pole contacts.

### 2.09 ACTUATORS

- A. Electric Motors: Size to operate with sufficient reserve power to provide smooth modulating action or two-position action.
  - 1. Comply with requirements in Division 23 Section "Common Motor Requirements for HVAC Equipment."
  - 2. Permanent Split-Capacitor or Shaded-Pole Type: Gear trains completely oil immersed and sealed. Equip spring-return motors with integral spiral-spring mechanism in housings designed for easy removal for service or adjustment of limit switches, auxiliary switches, or feedback potentiometer.
  - 3. Spring-Return Motors for Valves Larger Than NPS 2-1/2: Size for running and breakaway torque of 150 in. x lbf.
  - 4. Spring-Return Motors for Dampers Larger Than 25 Sq. Ft.: Size for running and breakaway torque of 150 in. x lbf.
- B. Electronic Actuators: Direct-coupled type designed for minimum 60,000 full-stroke cycles at rated torque.
  - 1. Manufacturers:
    - a. Belimo Aircontrols (USA), Inc.

- b. Siemens
- 2. Valves: Size for torque required for valve close off at maximum pump differential pressure.
- 3. Dampers: Size for running torque calculated as follows:
- a. Parallel-Blade Damper with Edge Seals: 7 inch-lb/sq. ft. of damper.
- 4. Coupling: V-bolt and V-shaped, toothed cradle.
- 5. Overload Protection: Electronic overload or digital rotation-sensing circuitry.
- 6. Fail-Safe Operation: Mechanical, spring-return mechanism. Provide external, manual gear release on nonspring-return actuators.
- 7. Power Requirements (Two-Position Spring Return): 24-V ac.
- 8. Power Requirements (Modulating): Maximum 10 VA at 24-V ac or 8 W at 24-V dc.
- 9. Proportional Signal: 2- to 10-V dc or 4 to 20 mA, and 2- to 10-V dc position feedback signal.
- 10. Temperature Rating: Minus 22 to plus 122 deg F.
- 11. Temperature Rating (Smoke Dampers): Minus 22 to plus 250 deg F.
- 12. Run Time: 12 seconds open, 5 seconds closed.

### 2.10 CONTROL VALVES

- A. Manufacturers:
  - 1. Danfoss Inc.; Air Conditioning & Refrigeration Div.
  - 2. Siemens.
  - 3. Hayward Industrial Products, Inc.
  - 4. Magnatrol Valve Corporation.0
  - 5. Neles-Jamesbury.
  - 6. Bray.
- B. Control Valves: Factory fabricated, of type, body material, and pressure class based on maximum pressure and temperature rating of piping system, unless otherwise indicated.
- C. Hydronic system globe valves for modulating flow control applications shall have the following characteristics:
  - 1. NPS 2 and Smaller: Class 125 bronze body, bronze trim, rising stem, renewable composition disc, and screwed ends with backseating capacity repackable under pressure.
  - 2. NPS 2-1/2 and Larger: Class 125 iron body, bronze trim, rising stem, plug-type disc, flanged ends, and renewable seat and disc.
  - 3. Internal Construction: Replaceable plugs and stainless-steel or brass seats.
    - a. Single-Seated Valves: Cage trim provides seating and guiding surfaces for plug on top and bottom.
    - b. Double-Seated Valves: Balanced plug; cage trim provides seating and guiding surfaces for plugs on top and bottom.
  - 4. Flow Characteristics: Two-way valves shall have equal percentage characteristics; threeway valves shall have linear characteristics.
  - 5. Close-Off (Differential) Pressure Rating: Combination of actuator and trim shall provide minimum close-off pressure rating of 150 percent of total system (pump) head for two-way valves and 100 percent of pressure differential across valve or 100 percent of total system (pump) head.
- D. Butterfly Valves for two position, non-modulating applications shall be 200-psig, 150-psig maximum pressure differential, ASTM A 126 cast-iron or ASTM A 536 ductile-iron body and bonnet, extended neck, stainless-steel stem, field-replaceable EPDM or Buna N sleeve and stem seals.
  - 1. Body Style: Lug.
  - 2. Disc Type: Nickel-plated ductile iron.

3. Sizing: 1-psig maximum pressure drop at design flow rate.

# 2.11 COMMUNICATION AND CONTROL WIRING

- A. Provide copper wiring, plenum cable, and raceways as specified in the applicable sections of Division 16 unless otherwise noted herein.
- B. All insulated wire to be copper conductors, UL labeled for 90°C minimum service.
- C. Wire Sizing and Insulation
- D. Wiring shall comply with minimum wire size and insulation based on services listed below:
  - 1. Service Minimum Gage/Type Insulation Class
  - 2. Class 1 12 14 AWG Stranded 600 Volt
  - 3. Class 2 18 22 AWG Stranded 300 Volt
  - 4. Class 3 18 AWG Stranded 300 Volt
  - 5. Provide plenum-rated cable when open cable is permitted in supply or return air plenum and where allowed per execution specifications
- E. Control Wiring:
  - 1. Digital output shall use Class 1 or Class 2, twisted pair not required, per local codes.
  - 2. Low voltage digital input shall use Class 2 twisted pair, insulated.
  - 3. Low voltage analog input shall use Class 2 twisted pair, insulated and shielded where required.
  - 4. Low voltage analog output shall use Class 2 twisted pair, insulated and shielded where required.
  - 5. Actuators with tri-state control shall use 3 conductor with same characteristics.
- F. Communication Wiring
  - 1. MLN Ethernet Cable shall be minimum CAT 5e or better.
  - 2. ALN, FLN, and TX-I/O IBE shall be 24 AWG, TSP, 12.5 pf/ft or less low capacitance cable, 4 twists per foot minimum.

## **PART 3 EXECUTION**

- 3.01 EXAMINATION
  - A. Verify that conditioned power supply is available to control units and operator workstation.
  - B. Verify that duct-, pipe-, and equipment-mounted devices are installed before proceeding with installation.

### 3.02 INSTALLATION

- A. Install software in control units and operator workstation(s). Implement all features of programs to specified requirements and as appropriate to sequence of operation.
- B. Connect and configure equipment and software to achieve sequence of operation specified.
- C. Verify location of thermostats and other exposed control sensors with drawings and room details before installation.
- D. Install guards on thermostats in the following locations:
   1. Where indicated.

- E. Install automatic dampers according to Division 23 Section "Air Duct Accessories."
- F. Install damper motors on outside of duct in warm areas, not in locations exposed to outdoor temperatures.
- G. Install labels and nameplates to identify control components according to Division 23 Section "Identification for HVAC Piping and Equipment."
- H. Install hydronic instrument wells, valves, and other accessories according to Division 23 Section "Hydronic Piping."
- I. Install duct volume-control dampers according to Division 23 Sections specifying air ducts.

## 3.03 ELECTRICAL WIRING AND CONNECTION INSTALLATION

- A. Install raceways, boxes, and cabinets according to Division 26 Section "Raceway and Boxes for Electrical Systems."
- B. Install building wire and cable according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."
- C. Connect manual-reset limit controls independent of manual-control switch positions. Automatic duct heater resets may be connected in interlock circuit of power controllers.
- D. Connect hand-off-auto selector switches to override automatic interlock controls when switch is in hand position.

### 3.04 CONTROL WIRING

- A. All control and interlock wiring shall comply with national and local electrical codes and Division 26 of this specification. Where the requirements of this section differ from those in Division 26, the requirements of this section shall take precedence.
- B. All NEC Class 1 (line voltage) wiring shall be UL Listed in approved conduit according to NEC and Division 26 requirements.
- C. All low-voltage wiring shall meet NEC Class 2 requirements. (Low-voltage power circuits shall be sub fused when required to meet Class 2 current limit.)
- D. Where NEC Class 2 (current-limited) wires are in concealed and accessible locations, including ceiling return air plenums, approved cables not in conduit may be used provided that cables are UL Listed for the intended application. For example, cables used in ceiling plenums shall be UL Listed specifically for that purpose.
- E. All wiring in mechanical, electrical, or service rooms—or where subject to damage— shall be installed in conduit.
- F. Do not install Class 2 wiring in conduit containing Class 1 wiring. Boxes and panels containing high voltage wiring and equipment may not be used for low-voltage wiring except for the purpose of interfacing the two (e.g., relays and transformers).
- G. Do not install wiring in conduit containing tubing.

- H. Where plenum rated cable is run exposed, wiring is to be run parallel along a surface or perpendicular to it and neatly tied at 3 m (10 ft) intervals.
- I. Where plenum rated cable is used without conduit, it shall be supported from or anchored to structural members. Cables shall not be supported by or anchored to electrical conduits, piping, or ceiling suspension systems.
- J. All wire-to-device connections shall be made at a terminal block or wire nut. All wire-to-wire connections shall be at a terminal strip or wire nut.
- K. All wiring within enclosures shall be neatly bundled and anchored to permit access and prevent restriction to devices and terminals.
- L. Maximum allowable voltage for control wiring shall be 120 V. If only higher voltages are available, the contractor shall provide step-down transformers or interposing relays.
- M. All plenum rated wiring shall be installed as continuous lengths, with no splices permitted between termination points.
- N. All wiring in conduit shall be installed as continuous lengths, with no splices permitted between termination points or junction boxes.
- O. Maintain fire rating at all penetrations. Install plenum wiring in sleeves where it passes through walls and floors.
- P. Size and type of conduit and size and type of wire shall be the responsibility of the contractor, in keeping with the manufacturer's recommendations and NEC requirements, except as noted elsewhere.
- Q. Control and status relays are to be located in designated enclosures only. These enclosures can include packaged equipment control panel enclosures.
- R. Conceal all conduit, except within mechanical, electrical, or service rooms. Install conduit to maintain a minimum clearance of 15 cm (6 in.) from high-temperature equipment (e.g., steam pipes or flues).
- S. Secure conduit with conduit clamps fastened to the structure and spaced according to code requirements. Conduit and pull boxes may not be hung on flexible duct strap or tie rods. Conduits may not be run on or attached to ductwork.
- T. Adhere to this specification's Division 26 requirements where conduit crosses building expansion joints.
- U. The Contractor shall terminate all control and/or interlock wiring and shall maintain updated (as-built) wiring diagrams with terminations identified at the job site.
- V. Flexible metal conduits and liquid-tight, flexible metal conduits shall not exceed 1 m (3 ft) in length and shall be supported at each end. Flexible metal conduit less than ½ in. electrical trade size shall not be used. In areas exposed to moisture, including chiller and boiler rooms, liquid-tight, flexible metal conduits shall be used.
- W. Conduit must be adequately supported, properly reamed at both ends, and left clean and free of obstructions. Conduit sections shall be joined with couplings (according to code). Terminations must be made with fittings at boxes, and ends not terminating in boxes shall have bushings installed.

### 3.05 COMMUNICATION WIRING

- A. The contractor shall adhere to the items listed in the "Wiring" article in Part 2 of the specification.
- B. All cabling shall be installed in a neat and workmanlike manner. Follow manufacturer's installation recommendations for all communication cabling.
- C. Do not install communication wiring in raceway and enclosures containing Class 1.
- D. Maximum pulling, tension, and bend radius for cable installation, as specified by the cable manufacturer, shall not be exceeded during installation.
- E. Contractor shall verify the integrity of the entire network following the cable installation. Use appropriate test measures for each particular cable.
- F. When a cable enters or exits a building, a lightning arrestor must be installed between the lines and ground. The lighting arrestor shall be installed according to the manufacturer's instructions.
- G. All runs of communication wiring shall be unspliced length when that length is commercially available.
- H. All communication wiring shall be labeled in accordance with the HVAC Control System control drawing submittal package instructions or to indicate origination and destination data at a minimum.

### 3.06 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust field-assembled components and equipment installation, including connections, and to assist in field testing. Report results in writing.
- B. Perform the following field tests and inspections and prepare test reports:
  - 1. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation. Remove and replace malfunctioning units and retest.
  - 2. Test and adjust controls and safeties.
  - 3. Test calibration of electronic controllers by disconnecting input sensors and stimulating operation with compatible signal generator.
  - 4. Test each point through its full operating range to verify that safety and operating control set points are as required.
  - 5. Test each control loop to verify stable mode of operation and compliance with sequence of operation. Adjust PID actions.
  - 6. Test each system for compliance with sequence of operation.
  - 7. Test software and hardware interlocks.
- C. DDC Verification:
  - 1. Verify that instruments are installed before calibration, testing, and loop or leak checks.
  - 2. Check instruments for proper location and accessibility.
  - 3. Check instrument installation for direction of flow, elevation, orientation, insertion depth, and other applicable considerations.
  - 4. Check instrument tubing for proper fittings, slope, material, and support.
  - 5. Check installation of air supply for each instrument.
  - 6. Check flow instruments. Inspect tag number and line and bore size, and verify that inlet side is identified and that meters are installed correctly.

- 7. Check pressure instruments, piping slope, installation of valve manifold, and selfcontained pressure regulators.
- 8. Check temperature instruments and material and length of sensing elements.
- 9. Check control valves. Verify that they are in correct direction.
- 10. Check DDC system as follows:
  - a. Verify that DDC controller power supply is from emergency power supply, if applicable.
  - b. Verify that wires at control panels are tagged with their service designation and approved tagging system.
  - c. Verify that spare I/O capacity has been provided.
  - d. Verify that DDC controllers are protected from power supply surges.
- D. Replace damaged or malfunctioning controls and equipment and repeat testing procedures.

# 3.07 ADJUSTING

- A. Calibrating and Adjusting:
  - 1. Calibrate instruments.
  - 2. Make three-point calibration test for both linearity and accuracy for each analog instrument.
  - 3. Calibrate equipment and procedures using manufacturer's written recommendations and instruction manuals. Use test equipment with accuracy at least double that of instrument being calibrated.
  - 4. Control System Inputs and Outputs:
    - a. Check analog inputs at 0, 50, and 100 percent of span.
    - b. Check analog outputs using milliampere meter at 0, 50, and 100 percent output.
    - c. Check digital inputs using jumper wire.
    - d. Check digital outputs using ohmmeter to test for contact making or breaking.
    - e. Check resistance temperature inputs at 0, 50, and 100 percent of span using a precision-resistant source.
  - 5. Flow:
    - a. Set differential pressure flow transmitters for 0 and 100 percent values with 3-point calibration accomplished at 50, 90, and 100 percent of span.
    - b. Manually operate flow switches to verify that they make or break contact.
  - 6. Pressure:
    - a. Calibrate pressure transmitters at 0, 50, and 100 percent of span.
  - 7. Calibrate pressure switches to make or break contacts, with adjustable differential set at minimum.
  - 8. Temperature:
    - a. Calibrate resistance temperature transmitters at 0, 50, and 100 percent of span using a precision-resistance source.
    - b. Calibrate temperature switches to make or break contacts.
  - 9. Stroke and adjust control valves and dampers without positioners, following the manufacturer's recommended procedure, so that valve or damper is 100 percent open and closed.
  - 10. Stroke and adjust control valves and dampers with positioners, following manufacturer's recommended procedure, so that valve and damper is 0, 50, and 100 percent closed.
  - 11. Provide diagnostic and test instruments for calibration and adjustment of system.
  - 12. Provide written description of procedures and equipment for calibrating each type of instrument. Submit procedures review and approval before initiating startup procedures.

B. Adjust initial temperature set points.

# 3.08 DEMONSTRATION

A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain HVAC instrumentation and controls. Refer to Division 01 Section "Demonstration and Training."

# END OF SECTION

## SECTION 23 09 70

## DIRECT DIGITAL CONTROL (DDC) SYSTEM COMMISSIONING

## PART 1 GENERAL

## 1.01 WORK INCLUDED

- A. Provide the following:
  - 1. DDCS and equipment testing and start-up
  - 2. Validation of proper and thorough installation of DDCS and equipment
  - 3. Functional testing of control systems
  - 4. Demonstration testing of control systems
  - 5. Documentation of tests, procedures, and installations
  - 6. Coordination of DDCS training
  - 7. Documentation of DDCS Operation and Maintenance materials
- B. For general DDC System requirements, refer to Section 23 09 00 Instrumentation and Control for HVAC.

### 1.02 COORDINATION

- A. Assist Owner's Commissioning Authority/Coordinator in Commissioning, including attending commissioning meetings.
- B. Testing Adjusting & Balancing
  - Coordinate with TAB contractors in test and balance work as specified in Section 23 05 93 Testing Adjusting & Balancing. A significant number of balancing procedures require the DDCS to be operational and require Contractor time to assist the TAB contractor in their work.
  - 2. Assist the TAB contractor in determining pump differential pressure setpoints.
- C. Coordinate with Division 23 contractors in the performance of pre-functional and functional tests as specified in Section 23 09 95 Mechanical Commissioning.

### 1.03 SEQUENCING

- A. The following list outlines the general sequence of events for submittals and commissioning:
  - 1. Submit Hardware and Shop Drawings and receive approval.
  - 2. Initiate installation of DDCS hardware, devices and wiring.
  - 3. Develop point database and application software.
  - 4. Simulate sequencing and debug programming off-line to the extent practical.
  - 5. Submit Programming and Graphics no less than 30 days before software is to be installed in field devices and receive approval.
  - 6. Complete installation of DDCS hardware, devices and wiring.
  - 7. Install point database and application software in field panels.
  - 8. Submit Functional Tests no less than 30 days prior to conducting tests and receive approval.
  - 9. Perform DDCS Pre-functional Tests (start up, calibration and tuning) and submit Prefunctional Tests for approval.
  - 10. Field test application programs prior to functional testing.
  - 11. Receive DDCS Pre-functional Test Report approval and approval to schedule Functional Tests.
  - 12. Perform and record functional tests and submit Functional Test Report for approval.

- a. Some tests may not be possible due to weather conditions. These tests may be deferred to post-occupancy period on approval from the Commissioning Authority.
- 13. Assist TAB contractor in TAB tests and determining setpoints as specified in Sections 230593 Testing Adjusting & Balancing and 230995 Mechanical Systems Commissioning.
- 14. Submit Training Materials and receive approval.
- 15. Receive DDCS Functional Test Report approval and approval to schedule Demonstration Tests.
- 16. Perform Demonstration Tests to Commissioning Authority and submit Demonstration Test Report.
- 17. Receive acceptance of Demonstration Tests.
- 18. Train Owner personnel on DDCS operation and maintenance.
- 19. Substantial Completion.
- 20. Prepare and initiate commissioning Trend Logs.
- 21. Submit Trend Logs in format specified for review and approval.
- 22. Receive approval of successful Trend Log tests, or retest as required.
- 23. Complete all items in Completion Requirements per Paragraph 1.6.
- 24. Provide administration level password access to the Owner.
- 25. Final Acceptance.
- 26. Begin Warranty Period.

## 1.04 SUBMITTALS

A. For shop drawing and other submittals, refer to Section 23 09 00 Direct Digital Control Systems and Section 23 09 01 DDC Server and User Interface.

## 1.05 FUNCTIONAL TEST DOCUMENTATION

- A. Pre-functional Tests
  - 1. Prepare forms to document the proper startup of the DDCS.
  - 2. All equipment shall be included on the test forms including but not limited to:
    - a. Digital outputs: proper installation, normal position, response to command at control unit (CU)
    - b. Digital inputs: proper installation, device test, response at CU
    - c. Analog outputs: proper installation of devices, verification of maximum and minimum stroke
    - d. Analog inputs: proper installation of sensors, calibration
    - e. Wiring connections and other electrical issues
    - f. Panels: confirmation of location, power source (electrical circuit used), confirmation of emergency power where specified
    - g. Alarms and safeties: verification of alarm routing to all specified devices and correct hierarchy. Example: confirm alarm routing to cell phones, email, servers, remote workstations. Confirm that appropriate alarm levels are routed to appropriate devices.
    - h. Loop tuning: document setting of P/I parameters for all loops, chosen setpoints, time delays, loop execution speed.
    - i. Network traffic: document speed of screen generation, alarm and signal propagation in system with all required commissioning trends active.
  - 3. Each form shall have a header or footer where the technician performing the test can indicate his/her name and the date of the test.
  - 4. Submit forms for approval.
  - 5. Complete work, document results on forms, and submit for approval as Pre-Functional Test Report.
- B. Functional Tests
- 1. Commissioning Authority will prepare functional testing forms after Programming and Graphics Submittal has been reviewed and approved. Tests will be designed to test all sequences in a formal manner with simulations and expected outcomes.
- 2. DDCS Contractor will review tests and recommend changes that will improve ease of testing or avoid possible system damage, etc.
- 3. DDCS Contractor will complete tests and document on forms in electronic format. Each form shall have a header or footer where the technician performing the test can indicate his/her name and the date of the test.
- 4. Submit forms for approval as Functional Test Report.
- 1.06 COMPLETION REQUIREMENTS
  - A. Procedure
    - 1. Until the documents required in this section are submitted and approved, the system will not be considered "accepted" and final payment to DDCS Contractor will not be made.
    - 2. Before requesting acceptance of work, submit one set of completion documents for review and approval of Owner.
    - 3. After review, furnish quantity of sets indicated below to Owner.
  - B. Completion Documents
    - 1. Owner's Manuals. See Section 23 09 00 Instrumentation and Control for HVAC.
    - 2. English language control sequences updated to reflect final programming installed in the DDCS at the time of system acceptance.
    - 3. Complete original issue diskettes/CDs for all software provided, including operating systems, programming language, operator workstation software, and graphics software.
    - Complete CD copy of DDCS database, user screens, setpoints and all configuration settings necessary to allow re-installation of system after crash or replacement of server, and resume operations with the DDCS in the same configuration as during Owner signoff.
    - 5. Project Record Drawings. "As-built" versions of the submittal drawings in reproducible format.
    - 6. Commissioning Reports. Completed versions of all Pre-functional and Functional Test reports, calibration logs, etc., per paragraph 1.5.
    - 7. Copy of inspection certificates provided by the local code authorities.
    - 8. Written guarantee and warranty documents for all equipment and systems, including the start and end date for each.
    - 9. Training materials as required by 3.6E.
    - 10. Contact information. Names, addresses, and 24-hour telephone numbers of contractors installing equipment, and the control systems and service representatives of each.

# PART 2 PRODUCTS

- 2.01 INSTRUMENTATION
  - A. Instrumentation required to verify readings, calibrate sensors, and test the system and equipment performance shall be provided by Contractor.

# PART 3 EXECUTION

#### 3.01 PRE-FUNCTIONAL TESTS

- A. General
  - 1. Check installed products before continuity tests, leak tests and calibration.

- 2. Inspect the installation of all devices. Review the manufacturer's installation instructions and validate that the device is installed in accordance with them and that the devices are accessible.
- 3. Verify proper electrical voltages and amperages, and verify that all circuits are free from faults.
- 4. Verify integrity/safety of all electrical connections.
- 5. Verify that shielded cables are grounded only at one end.
- 6. Verify that all sensor locations are as indicated on drawings and are away from causes of erratic operation.
- 7. Check instruments for proper installation on direction of flow, elevation, orientation, insertion depth, or other applicable considerations that will impact performance.
- B. Digital Outputs
  - 1. Verify that all digital output devices (relays, solenoid valves, two-position actuators and control valves, magnetic starters, etc.) operate properly and that the normal positions are correct.
- C. Digital Inputs
  - 1. Adjust setpoints, where applicable.
    - a. For current switches used as status on fans, adjust current setpoint so that fan status is "off" when fan discharge damper (if present) is fully closed and when belt is broken (temporarily remove belt).
    - b. For current switches used as status on pumps, adjust current setpoint so that pump status is "off" when pump is dead-headed (temporarily close discharge valve).
    - c. For differential pressure sensors on pumps and fans, set so that status is on when pump operating with all valves open (out on its curve).
- D. Analog Outputs
  - 1. Verify start and span are correct and control action is correct.
  - 2. Check all control valves and automatic dampers to ensure proper action and closure.
  - 3. Make any necessary adjustments to valve stem and damper blade travel.
  - 4. Check all normal positions of actuators with spring return.
  - 5. For outputs to reset other manufacturer's devices (for example, chiller setpoint) and for feedback from them, calibrate ranges to establish proper parameters.
- E. Control Valve Checkout:
  - 1. Verify that control valves are installed correctly for flow direction.
  - 2. Verify that valve body attachment is properly secured and sealed.
  - 3. Verify that valve actuator and linkage attachment is secure.
  - 4. Verify that actuator wiring is complete, enclosed and connected to correct power source.
  - 5. Verify that valve ball, disc or plug travel is unobstructed.
  - 6. After piping systems have been tested and put into service, but before insulating and balancing, inspect each valve for leaks. Adjust or replace packing to stop leaks. Replace the valve if leaks persist.
- F. Instrument Checkout:
  - 1. Verify that instrument is correctly installed for location, orientation, direction and operating clearances.
  - 2. Verify that attachment is properly secured and sealed.
  - 3. Verify that conduit connections are properly secured and sealed.
  - 4. Verify that wiring is properly labeled with unique identification, correct type and size and is securely attached to proper terminals.
  - 5. Inspect instrument tag against approved submittal.
  - 6. For instruments with tubing connections, verify that tubing attachment is secure and isolation valves have been provided.

- 7. For flow instruments, verify that recommended upstream and downstream distances have been maintained.
- 8. For temperature instruments:
  - a. Verify sensing element type and proper material.
  - b. Verify length and insertion.
- G. Alarms and Interlocks
  - 1. A log shall be kept and initialed by the technician showing date and time, alarm/interlock description, action taken to initiate the alarm/interlock, and resulting action, and included in the Pre-functional Test Report.
  - 2. Check each alarm separately by including an appropriate signal at a value that will trip the alarm.
  - 3. Coordinate with Division 26 to test fire and life safety systems alarm contacts.
  - 4. Interlocks shall be tripped using field contacts to check the logic, as well as to ensure that the fail-safe condition for all actuators is in the proper direction.
  - 5. Interlock actions shall be tested by simulating alarm conditions to check the initiating value of the variable and interlock action.
- H. Analog Input Calibration
- I. Variable Frequency Drive Minimum Speed
  - 1. Minimum speed for VFD-driven equipment shall be determined in accordance with manufacturer recommended low speed limit settings.
- J. Tuning
  - Tune all control loops to obtain the fastest stable response without hunting, offset or overshoot. Record tuning parameters and response test results for each control loop in the Pre-functional Test Report. Except from a startup, maximum allowable variance from set point for controlled variables under normal load fluctuations shall be as follows. Within 3 minutes of any upset (for which the system has the capability to respond) in the control loop, tolerances shall be maintained (exceptions noted):

Controlled Variable	Control Accuracy	
Airflow and waterflow	±10%	
Heating, hot Water Temperature	±1°F	
Duct Temperature	±2°F	
Water Differential Pressure	±1.5 psi	
Others	±2 times reported	
	accuracy	

- K. Interface and Control Panels
  - 1. Ensure devices are properly installed with adequate clearance for maintenance and with clear labels in accordance with the record drawings.
  - 2. Ensure that terminations are safe, secure and labeled in accordance with the record drawings.
  - 3. Check power supplies for proper voltage ranges and loading.
  - 4. Ensure that wiring and tubing are run in a neat and workman-like manner, either bound or enclosed in trough.
  - 5. Check for adequate signal strength on communication networks.
  - 6. Check for standalone performance of controllers by disconnecting the controller from the LAN. Verify the event is annunciated at Operator Interfaces. Verify that the controlling LAN reconfigures as specified in the event of a LAN disconnection.
  - 7. Ensure that buffered and/or volatile information is held through power outage.

- 8. With all system and communications operating normally, sample and record update/annunciation times for critical alarms fed from the panel to the Operator Interface.
- 9. Check for adequate grounding of all DDC panels and devices.
- L. Operator Interfaces
  - 1. Verify that all elements on the graphics are functional and are properly bound to physical devices and/or virtual points, and that hot links or page jumps are functional and logical.
  - 2. Verify that the alarm printing, logging, paging, emailing etc. is functional and per requirements.
- 3.02 DDC SYSTEM I/O ADJUSTMENT, CALIBRATION
  - A. Calibrate each instrument installed that is not factory calibrated and provided with calibration documentation.
  - B. Provide a written description of proposed field procedures and equipment for calibrating each type of instrument. Submit procedures before calibration and adjustment.
  - C. For each analog instrument, make a three-point test of calibration for both linearity and accuracy.
  - D. Equipment and procedures used for calibration shall comply with instrument manufacturer's written instructions.
  - E. Provide diagnostic and test equipment for calibration and adjustment.
  - F. Field instruments and equipment used to test and calibrate installed instruments shall have accuracy at least twice the instrument accuracy being calibrated. An installed instrument with an accuracy of 1 percent shall be checked by an instrument with an accuracy of 0.5 percent.
  - G. Calibrate each instrument according to instrument instruction manual supplied by manufacturer.
  - H. If after calibration indicated performance cannot be achieved, replace out-of-tolerance instruments.
  - I. Comply with field testing requirements and procedures indicated by ASHRAE's Guideline 11, "Field Testing of HVAC Control Components," in the absence of specific requirements, and to supplement requirements indicated.
  - J. Analog Signals:
    - 1. Check analog voltage signals using a precision voltage meter at zero, 50, and 100 percent.
    - 2. Check analog current signals using a precision current meter at zero, 50, and 100 percent.
    - 3. Check resistance signals for temperature sensors at zero, 50, and 100 percent of operating span using a precision-resistant source.
    - 4. The calibrating parameters in software (e.g. slope and intercept) shall be adjusted as required. A calibration log shall be kept and initialed by the technician showing date and time, sensor and hand-held readings, and calibration constant adjustments and included in the Pre-functional Test Report.
    - 5. Inaccurate sensors must be replaced if calibration is not possible.
  - K. Digital Signals:
    - 1. Check digital signals using a jumper wire.

- 2. Check digital signals using an ohmmeter to test for contact making or breaking.
- L. Control Valves:
  - 1. Stroke and adjust control valves following manufacturer's recommended procedure, from 100 percent open to 100 percent closed and back to 100 percent open.
  - 2. Stroke control valves with pilot positioners. Adjust valve and positioner following manufacturer's recommended procedure, so valve is 100 percent closed, 50 percent closed and 100 percent open at proper air pressures.
  - 3. Check and document open and close cycle times for applications with a cycle time less than 30 seconds.
  - 4. For control valves equipped with positive position indication, check feedback signal at multiple positions to confirm proper position indication.
- M. Meters: Check sensors at zero, 50, and 100 percent of Project design values.
- N. Sensors: Check sensors at zero, 50, and 100 percent of Project design values.
- O. Switches: Calibrate switches to make or break contact at set points indicated.
- P. Transmitters:
  - 1. Check and calibrate transmitters at zero, 50, and 100 percent of Project design values.
  - 2. Calibrate resistance temperature transmitters at zero, 50, and 100 percent of span using a precision-resistant source.
- Q. Pressure:
  - 1. Calibrate pressure transmitters at 0, 50, and 100 percent of span.
  - 2. Calibrate pressure switches to make or break contacts, with adjustable differential set at minimum.
- R. Temperature:
  - 1. Calibrate resistance temperature transmitters at 0, 50, and 100 percent of span using a precision-resistance source.
  - 2. Calibrate temperature switches to make or break contacts.
  - 3. Stroke and adjust control valves and dampers without positioners, following the manufacturer's recommended procedure, so that valve or damper is 100 percent open and closed.
  - 4. Stroke and adjust control valves and dampers with positioners, following manufacturer's recommended procedure, so that valve and damper is 0, 50, and 100 percent closed.
  - 5. Provide diagnostic and test instruments for calibration and adjustment of system.
  - 6. Provide written description of procedures and equipment for calibrating each type of instrument. Submit procedures review and approval before initiating startup procedures.
- S. Adjust initial temperature and humidity set points.
- T. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting system to suit actual occupied conditions. Provide up to three visits to Project during other than normal occupancy hours for this purpose

# 3.03 DDC SYSTEM CONTROLLER CHECKOUT

- A. Verify power supply.
  - 1. Verify voltage, phase and hertz.
  - 2. Verify that protection from power surges is installed and functioning.
  - 3. Verify that ground fault protection is installed.
  - 4. If applicable, verify if connected to UPS unit.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 5. If applicable, verify if connected to a backup power source.
- 6. If applicable, verify that power conditioning units, transient voltage suppression and high-frequency noise filter units are installed.
- B. Verify that wire and cabling is properly secured to terminals and labeled with unique identification.
- C. Verify that spare I/O capacity is provided.

## 3.04 DDC CONTROLLER I/O CONTROL LOOP TESTS

## A. Testing:

- 1. Test every I/O point connected to DDC controller to verify that safety and operating control set points are as indicated and as required to operate controlled system safely and at optimum performance.
- 2. Test every I/O point throughout its full operating range.
- 3. Test every control loop to verify operation is stable and accurate.
- 4. Adjust control loop proportional, integral and derivative settings to achieve optimum performance while complying with performance requirements indicated. Document testing of each control loop's precision and stability via trend logs.
- 5. Test and adjust every control loop for proper operation according to sequence of operation.
- 6. Test software and hardware interlocks for proper operation. Correct deficiencies.
- 7. Operate each analog point at the following:
  - a. Upper quarter of range.
  - b. Lower quarter of range.
  - c. At midpoint of range.
- 8. Exercise each binary point.
- 9. For every I/O point in DDC system, read and record each value at operator workstation, at DDC controller and at field instrument simultaneously. Value displayed at operator workstation, at DDC controller and at field instrument shall match.
- 10. Prepare and submit a report documenting results for each I/O point in DDC system and include in each I/O point a description of corrective measures and adjustments made to achieve desire results.

#### 3.05 DDC SYSTEM VALIDATION TESTS

- A. Perform validation tests before requesting final review of system. Before beginning testing, first submit Pretest Checklist and Test Plan.
- B. After approval of Test Plan, execute all tests and procedures indicated in plan.
- C. After testing is complete, submit completed test checklist.
- D. Pretest Checklist: Submit the following list with items checked off once verified:
  - 1. Detailed explanation for any items that are not completed or verified.
  - 2. Required mechanical installation work is successfully completed and HVAC equipment is working correctly.
  - 3. HVAC equipment motors operate below full-load amperage ratings.
  - 4. Required DDC system components, wiring, and accessories are installed.
  - 5. Installed DDC system architecture matches approved Drawings.
  - 6. Control electric power circuits operate at proper voltage and are free from faults.
  - 7. Required surge protection is installed.
  - 8. DDC system network communications function properly, including uploading and downloading programming changes.

- 9. Using BACnet protocol analyzer, verify that communications are error free.
- 10. Each controller's programming is backed up.
- 11. Equipment, products, tubing, wiring cable and conduits are properly labeled.
- 12. All I/O points are programmed into controllers.
- 13. Testing, adjusting and balancing work affecting controls is complete.
- 14. Dampers and actuators zero and span adjustments are set properly.
- 15. Each control damper and actuator goes to failed position on loss of power.
- 16. Valves and actuators zero and span adjustments are set properly.
- 17. Each control valve and actuator goes to failed position on loss of power.
- 18. Meter, sensor and transmitter readings are accurate and calibrated.
- 19. Control loops are tuned for smooth and stable operation.
- 20. View trend data where applicable.
- 21. Each controller works properly in standalone mode.
- 22. Safety controls and devices function properly.
- 23. Interfaces with fire-alarm system function properly.
- 24. Electrical interlocks function properly.
- 25. Operator workstations and other interfaces are delivered, all system and database software is installed, and graphic are created.
- 26. Record Drawings are completed.
- 27. Test Plan:
- 28. Prepare and submit a validation test plan including test procedures for performance validation tests.
- 29. Test plan shall address all specified functions of DDC system and sequences of operation.
- 30. Explain detailed actions and expected results to demonstrate compliance with requirements indicated.
- 31. Explain method for simulating necessary conditions of operation used to demonstrate performance.
- 32. Include a test checklist to be used to check and initial that each test has been successfully completed.
- 33. Submit test plan documentation 30 business days before start of tests.
- 34. Validation Test:
- 35. Verify operating performance of each I/O point in DDC system.
- 36. Verify analog I/O points at operating value.
- 37. Make adjustments to out-of-tolerance I/O points.
- 38. Identify I/O points for future reference.
- 39. Simulate abnormal conditions to demonstrate proper function of safety devices.
- 40. Replace instruments and controllers that cannot maintain performance indicated after adjustments.
- 41. Simulate conditions to demonstrate proper sequence of control.
- 42. Readjust settings to design values and observe ability of DDC system to establish desired conditions.
- 43. After 24 Hours following Initial Validation Test:
- 44. Re-check I/O points that required corrections during initial test.
- 45. Identify I/O points that still require additional correction and make corrections necessary to achieve desired results.
- 46. After 24 Hours of Second Validation Test:
- 47. Re-check I/O points that required corrections during second test.
- 48. Continue validation testing until I/O point is normal on two consecutive tests.
- 49. Completely check out, calibrate, and test all connected hardware and software to ensure that DDC system performs according to requirements indicated.
- 50. After validation testing is complete, prepare and submit a report indicating all I/O points that required correction and how many validation re-tests it took to pass. Identify adjustments made for each test and indicate instruments that were replaced.
- 51. DDC System Response Time Test:

- 52. Simulate Heavy Load Condition (HLC).
- 53. Heavy load shall be an occurrence of 50 percent of total connected binary COV, one-half of which represent an "alarm" condition, and 50 percent of total connected analog COV, one-half of which represent an "alarm" condition, that are initiated simultaneously on a one-time basis.
- 54. Initiate 10 successive occurrences of HLC and measure response time to typical alarms and status changes.
- 55. Measure with a timer having at least 0.1-second resolution and 0.01 percent accuracy.
- 56. Purpose of test is to demonstrate DDC system, as follows:
- 57. Reaction to COV and alarm conditions during HLC.
- 58. Ability to update DDC system database during HLC.
- 59. Passing test is contingent on the following:
- 60. Alarm reporting at printer beginning no more than 10 seconds after the initiation (time zero) of HLC.
- 61. All alarms, both binary and analog, are reported and printed; none are lost.
- 62. Compliance with response times specified.
- 63. Prepare and submit a report documenting HLC tested and results of test including time stamp and print out of all alarms.

# 3.06 DDC SYSTEM NETWORK BANDWIDTH TEST:

- A. Test network bandwidth usage on all DDC system networks to demonstrate bandwidth usage under DDC system normal operating conditions and under simulated HLC.
  - 1. To pass, none of DDC system networks shall use more than 70 percent of available bandwidth under normal and HLC operation.

## 3.07 EXTENDED OPERATION TEST

- A. Extended operation test is intended to simulate normal operation of DDC system by Owner.
- B. Operate DDC system for an operating period of 28 consecutive calendar days following Substantial Completion. Coordinate exact start date of testing with Owner.
- C. Provide an operator familiar with DDC system installed to man an operator workstation during eight hours of each normal business day occurring during operating period.
- D. During operating period, DDC system shall demonstrate correct operation and accuracy of monitored and controlled points as well as operation capabilities of sequences, logs, trends, reports, specialized control algorithms, diagnostics, and other software indicated.
  1. Correct defects of hardware and software when it occurs.
- E. Definition of Failures and Downtime during Operating Period:
  - Failed I/O point constituting downtime is an I/O point failing to perform its intended function consistently and a point physically failed due to hardware and software.
  - 2. Downtime is when any I/O point in DDC system is unable to fulfill its' required function.
  - 3. Downtime shall be calculated as elapsed time between a detected point failure as confirmed by an operator and time point is restored to service.
  - 4. Maximum time interval allowed between DDC system detection of failure occurrence and operator confirmation shall be 0.5 hours.
  - 5. Downtime shall be logged in hours to nearest 0.1 hour.
  - 6. Power outages shall not count as downtime, but shall suspend test hours unless systems are provided with UPS and served through a backup power source.
  - 7. Hardware or software failures caused by power outages shall count as downtime.
- F. During operating period, log downtime and operational problems are encountered.

- 1. Identify source of problem.
- 2. Provide written description of corrective action taken.
- 3. Record duration of downtime.
- 4. Maintain log showing the following:
- 5. Time of occurrence.
- 6. Description of each occurrence and pertinent written comments for reviewer to understand scope and extent of occurrence.
- 7. Downtime for each failed I/O point.
- 8. Running total of downtime and total time of I/O point after each problem has been restored.
- 9. Log shall be available to Owner for review at any time.
- G. For DDC system to pass extended operation test, total downtime shall not exceed 1 percent of total point-hours during operating period.
  - 1. Failure to comply with minimum requirements of passing at end of operating period indicated shall require that operating period be extended one consecutive day at a time until DDC system passes requirement.
- H. Evaluation of DDC system passing test shall be based on the following calculation:
  - 1. Downtime shall be counted on a point-hour basis where total number of DDC system point-hours is equal to total number of I/O points in DDC system multiplied by total number of hours during operating period.
  - 2. One point-hour of downtime is one I/O point down for one hour. Three points down for five hours is a total of 15 point-hours of downtime. Four points down for one-half hour is 2 point-hours of downtime.
  - 3. Example Calculation: Maximum allowable downtime for 30-day test when DDC system has 1000 total I/O points (combined analog and binary) and has passing score of 1 percent downtime is computed by 30 days x 24 h/day x 1000 points x 1 percent equals 7200 point-hours of maximum allowable downtime.
- I. Prepare test and inspection reports.

# 3.08 FUNCTIONAL TESTS

- A. Functional Test schedule shall be coordinated with the Commissioning Authority.
- B. Submit forms for approval. Test schedule shall be coordinated with the Commissioning Authority.
- C. Tests may be witnessed by an Owner's Representative at the Owner's option.
- D. All approved Functional Tests shall be conducted by the DDCS Contractor with results confirmed and signed by the Contractor's start-up technician.
  - 1. Seasonal Impacts: It shall be assumed that not all tests will be possible due to weather conditions. Those that are not possible shall be deferred until the next season, performed during the warranty period.
- E. Test documentation shall be submitted to the Owner for review and approval.

# 3.09 DEMONSTRATION TEST

A. Demonstration tests consist of a representative sample of functional tests and systems randomly selected by the Commissioning Authority. Tests will be designed to occur over no longer than 2 working days.

- B. Schedule the demonstration with the Commissioning Authority at least 1 week in advance.
- C. Demonstration shall not be scheduled until the Functional Test Report has been approved.
- D. The Contractor shall supply all personnel and equipment for the demonstration, including, but not limited to, instruments, ladders, etc. Contractor-supplied personnel shall be those who conducted the Functional tests or who are otherwise competent with and knowledgeable of all project-specific hardware, software, and the HVAC systems.
- E. The system will be demonstrated following procedures that are the same or similar to those used in the Pre-Functional and Functional Tests. The Commissioning Authority will supply the test forms at the site at the start of the tests.
- F. Contractor shall conduct tests as directed by and in the presence of the Commissioning Authority and complete test forms. Completed forms shall be submitted as the Demonstration Test Report to the Commissioning Authority after tests are complete.
- G. Demonstration Tests shall be successfully completed and approved prior to Substantial Completion.

## 3.10 COMMISSIONING TREND TEST

- A. Trend logging shall not commence until Demonstration Tests are successfully completed.
- B. Hardware Points: Contractor shall configure all hardware points to trend with the following qualifications.
  - 1. Unless approved otherwise by the Commissioning Authority, all points shall be trended on a 5 minute interval during the Commissioning tests and system evaluation.
  - 2. Commissioning Authority may request certain Trends based on a Change of Value, with COV sensitivity at +/- 1% of the Maximum expected value of the analog point.
- C. Software Points: Include the following in trends of systems and zones whose hardware points are being trended as called for above. Time interval shall be the same as associated hardware point.
  - 1. All setpoints and limits that are automatically reset, plus the points that are driving the reset (For example, % Chilled water Valve Open driving the chilled water distribution system Differential pressure setpoint)
  - 2. All setpoints that are adjustable by Operator
  - 3. Outputs of all control loops, other than those driving a single AO point that is already being trended
  - 4. System mode points (e.g. Charge Mode of TES, Discharge Mode, etc..)
  - 5. Global overrides such as demand shed signals
- D. Submit for review and approval by the by Commissioning Authority a table of points to be trended along with trend intervals or change-of-value a minimum of 14 days prior to trend collection period.
- E. Upload trend data from control panels to the control system server on a user-defined interval, manual command, or automatically when the trend buffer becomes full.
- F. Trend logs of all points indicated above shall be collected for a 3 week Trend Period.
- G. At the completion of the Trend Period, data shall be reviewed by the Contractor to ensure that the system is operating properly. If so, data shall be submitted to the Commissioning Authority in an electronic format agreed to by the Commissioning Authority and Contractor and as

summarized below (e.g. CD-ROM or via direct access to the control system server via the internet).

- H. Data shall be exported to one of the following formats for analysis by external software.
  - 1. Text (Comma or tab delimited with "" text delimiters)
  - 2. MS Excel Worksheet
  - 3. MS Access Database Tables
  - 4. SQL Database Tables
  - 5. Exported data shall have the following characteristics:
    - a. There shall be no duplicate records. Each time/date stamp for a specific point shall be unique.
    - b. The data shall be fully contained in a single file or table for each point. Data shall not span multiple files or database tables.
    - c. Each field of data shall have one and only one unique identifier. The label shall be in the first row of the file. Labels shall not be repeated in the stream of data.
    - d. Each table or file shall have a single date/time stamp. Multiple fields that are
    - e. sampled on the same time stamp can be combined in a single file or table provided that they have the same number of records and are stored in the following format:

Date/Time	Field 1	Field2	Field n	f.	Date/Time
DateTimeValue1	Value 11	Value 21	Value n1		
DateTimeValuej	Value 1j	Value 2j	Value nj		

fields shall be in a single column in a format automatically recognized by MS Access or MS Excel.

- g. Data will be analyzed over approximately a two- to three-week period by the Commissioning Authority.
- h. The system shall be accepted only if the trend review indicates proper system operation without malfunction, without alarm caused by control action or device failure, and with smooth and stable control of systems and equipment in conformance with these specifications. If any glitches are indicated in the trends, including minor glitches, steps F to G above shall be repeated for the same Trend Period until there is a complete Trend Period of error free operation.
- i. At the end of the successful Commissioning Trend Tests all points shall be reconfigured to trend on either a 15 minute interval or a COV of +/- 5% of scale for analog values and COV for digital values.

#### 3.11 REMEDIAL WORK

- A. Remedial work identified by site reviews, review of submittals, demonstration test, trend reviews, etc. shall be performed to the satisfaction of the Commissioning Authority, at no additional cost to the Owner.
- B. Contractor shall compensate Engineer and Commissioning Authority on a time and material basis at standard billing rates for any additional time required to witness additional demonstration tests or to review additional DDCS trends beyond the initial tests, at no additional cost to the Owner. Refer to owners commissioning requirements for additional requirements.

# 3.12 TRAINING

- A. Coordinate schedule and materials with Commissioning Authority.
- B. Interim Training

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 1. Provide minimal training so the operating staff can respond to occupant needs and other operating requirements during start-up and commissioning phase.
- C. Formal Training
  - 1. Provide training sessions for personnel indicated in § 3.12G.
  - 2. Training shall be conducted after all commissioning is complete and systems are fully operational.
  - 3. The length of each training period will depend on the complexity of the system and the audience, described below. Minimum training shall be 40 hours, but period shall be longer if required to complete the training tasks described below.
  - 4. Training may be in non-contiguous days at the request of the Owner.
  - 5. Owner shall be permitted to videotape training sessions.
  - 6. During the warranty period, provide unlimited telephone support for all trained operators.
- D. Operators are divided into three categories and shall receive training including but not limited to the tasks listed.
  - 1. Day-to-day Operators shall be trained to:
    - a. Proficiently operate the system
    - b. Understand control system architecture and configuration
    - c. Understand DDC system components
    - d. Understand system operation and control sequences
    - e. Operate the workstation and peripherals
    - f. Log on and off the system
    - g. Access graphics, point reports, and logs
    - h. Adjust and change system set points, time schedules, and holiday schedules
    - i. Recognize malfunctions of the system by observation of the printed copy and graphical visual signals
    - j. Understand and acknowledge alarms
    - k. Understand system drawings, and Operation and Maintenance manual
    - I. Understand the job layout and location of control components
    - m. Create, delete, and modify point trend logs, and graph or print these both on an adhoc basis and at user-definable time intervals
    - n. Print point and predefined reports
  - 2. Advanced Operators shall be trained to do all items for Day-to-day operators plus:
    - a. Make and change graphics on the workstation
    - b. Create, delete, and modify alarms, including annunciation and routing
    - c. Create, delete, and modify reports
    - d. Add, remove, and modify system's physical points
    - e. Create, modify, and delete programming
    - f. Add control panels
    - g. Add Operator Workstations
    - h. Create, delete, and modify system displays both graphical and otherwise
    - i. Perform DDC system field checkout procedures
    - j. Perform DDC controller unit operation and maintenance procedures
    - k. Perform workstation and peripheral operation and maintenance procedures
    - I. Perform DDC system diagnostic procedures
    - m. Configure hardware including PC boards, switches, communication, and I/O points
    - n. Maintain, calibrate, troubleshoot, diagnose, and repair hardware
    - o. Adjust, calibrate, and replace system components
    - p. Maintain software and prepare backups
  - 3. System Managers/Administrators shall be trained to do all items for Day-to-day operators plus:
    - a. Maintain software and prepare backups
    - b. Create and print custom reports, including tenant billing summaries
    - c. Interface with job-specific, third-party operator software

- d. Add new users and understand password security procedures
- E. Provide an outline and any and all course materials required for training. As a minimum, training materials shall include step-by-step instructions (including illustrations, screen captures, etc.) for performing all tasks identified in Paragraph 3.6D such that a new trainee, one who has not previously attended a training session and who has minimal familiarity with this DDCS system, can easily follow the instructions and successfully perform the tasks. One copy of training material shall be provided per student in the format specified this Section.
- F. The instructor(s) shall be factory-trained instructors experienced in presenting this material.
- G. The type and number of personnel and location for training shall include.
  - 1. Day-to-day Operator: 1
  - 2. Advanced Operator: 1
  - 3. System Managers/Administrators: 1

END OF SECTION

## SECTION 23 09 95

## **MECHANICAL SYSTEMS COMMISSIONING**

## PART 1 GENERAL

# 1.01 SUMMARY

- A. Section Includes:
  - 1. System specific commissioning
  - 2. Mechanical systems to be commissioned are as follows:
    - a. All Direct Digital Controls and control sequences related to HVAC systems incorporated into the contract documents.
    - b. Process measurement instruments and gauges
    - c. Alarms and notification
    - d. Trending and data export
    - e. Graphical user interface
    - f. Control system and sequences
- B. Related Sections:
  - 1. Division 1 Submittals Procedures
  - 2. Division 1 Contract Closeout Procedures
  - 3. Division 1 Operation and Maintenance Data
  - 4. 23 09 70 Division 23 DDC System Commissioning
- 1.02 DESCRIPTION OF WORK Refer to owners commissioning requirements
- 1.03 SUBMITTALS Refer to owners commissioning requirements

#### PART 2 PRODUCTS – Refer to owners commissioning requirements

## PART 3 EXECUTION

- 3.01 COMMISSIONING PROCESS AND PROCEDURES Refer to owners commissioning requirements
- 3.02 PRE-FUNCTIONAL CHECKLIST
  - A. These checklists do not take the place of the manufacturer's recommended checkout and start-up procedures or report.
  - B. Regardless of whether the CA includes them or not, checks, inspections, safety measures, quality control measures and start-up procedures recommended by the manufacturer shall be implemented by the Contractor prior to initiation of the commissioning activity.
  - C. The Commissioning Coordinator (CC) employed by the Contractor shall be responsible for directing all Pre-Functional Check lists provided by the CA. The CC shall engage subcontractors and vendors service representatives with expertise in the specific equipment or system to determine whether the equipment or system passes the checks detailed in the Pre-Functional Checklist.

- D. CC shall communicate the actual schedule for the execution of the Pre-Functional Checks to the CA as provided by the owner.
- E. The Commissioning Authority (CA) may choose to participate in the inspection of items along with the Contractor and his specialty subcontractors and vendors. In addition, CA reserves the right to inspect any or all of the items on his own in order to satisfy that the installation conforms to the design objectives and the system is ready for Functional Testing.
- F. For additional information on how the Pre-Functional Checklists fits within the overall framework of Commissioning as well as the Contractor's obligations under the same, please Refer to owners commissioning requirements.

# 3.03 FUNCTIONAL PERFORMANCE TESTING

- A. Contractor shall assist the Commissioning Authority (CA) in developing the Working Functional Performance Test (FPT) Procedures (also named Functional Test Plans FTPs) as specified in owners commissioning requirements. For any given equipment or system subcontractors and equipment suppliers associated with and specializing in the specific equipment are required to participate in developing the working procedures for the indicated FPTs. It is conceivable that for certain equipment and systems, multiple subcontractors and specialities may be required to participate to contribute to the development of the Functional Test. Contractor shall extend his full cooperation to the CA in securing the subcontractor or supplier resources necessary to develop and implement the Functional Tests.
- B. The Contractor's Commissioning Coordinator is required to manage the subcontractors in developing the Working FPT Procedures and Data Forms, and in performing all FPT's.
- C. Though not developed specifically for this project, the sample Functional Test procedures shown in Section 23 09 95 Exhibit B are provided as an indication of the format and rigor of the required functional testing procedures and documentation.
- D. CA may approve certain equipment performance tests to be conducted at the factory. If so, Contractor shall make arrangements and pay for travel costs for Owner and the CA to visit the factory and witness such tests at the factory.
- E. Contractor shall be responsible for demonstrating the successful testing of 100% of the systems to be commissioned per the Functional Test plans and procedures provided by the CA.
- F. CA shall develop the Functional Test following review of all contractor submittals. The Functional Test documents shall be made available immediately upon the successful completion of the Pre-Functional Check Lists and correction of all issues identified in the Pre-Functional Checklist.
- G. Contractor shall allow a reasonable time frame after the completion of TAB activities to schedule and conduct the Functional Tests. Functional tests shall commence only upon completion of the TAB activities and all flows and measurement data established through the TAB process are available for the Commissioning Agent's review. In no event shall the commissioning Functional Test duration be less than four weeks, plus what is reasonably required to correct issues identified and time required for retest and back-check. Contractor shall coordinate the work of other disciplines so that commissioning test procedures are not interrupted as a result of work that needs to be performed inside or outside the building.
- H. Refer to owners commissioning requirements for additional requirements regarding Functional Tests.

END OF SECTION

# SECTION 23 09 95 EXHIBIT B - SAMPLE FUNCTIONAL TEST PROCEDURE (FTP) FOR HEATING COILS

Functional Test Plan

# Heating, Hot-Water System

Project: Tri City Medical Center USP 800 Upgrades

# 1. Objective:

Confirm satisfactory operation of heating, hot-water system.

# 2. Equipment:

	EQUIPMENT	MARK	MODEL
1.			

# 3. Participants

	NAME	COMPANY	FUNCTION	ROLE
1.				Party filling out this form
2.				Party operating equipment and executing the test
3.				Party witnessing / observing the test

# 4. Prerequisite Checklist:

	ITEM	$\checkmark$
	The following have been started up and startup reports and prefunctional checklists submitted and approved ready for functional testing:	
1.	Heating, Hot-water coils	
2.	All control system functions for this and all interlocking systems are programmed and operable per contract documents, including final setpoints and schedules and with debugging, loop tuning and sensor and device calibrations completed.	
4.	Piping system flushing complete and required report approved.	
5.	Occupants (if any) notified that testing in progress and zone temperatures will be significantly out of normal range	
6.	Water treatment system complete and operational.	
7.	Vibration control report approved (if required).	
8.	Test and balance (TAB) complete and approved for the hydronic system	

	ITEM	$\checkmark$
9.	All A/E punchlist items for this equipment corrected.	
10.	These functional test procedures reviewed and approved by installing contractor.	
11.	Safeties and operating ranges reviewed.	
12.	Sufficient clearance around equipment for servicing.	
14.	Parameters, setpoints and logic sequences appear to follow the specified written sequences. Attach sequence of operation to this test.	
15.	Record made of all values (i.e., Setpoints, Control Parameters, Limits, Delays, Lockouts, Schedules, etc.) changed to accommodate testing. Attach as necessary.	

# 5. Seasonal Testing Note:

Due to the building completion being during winter, this test will be completed in two stages. The first testing will occur during cold weather. The objective of this first stage test is to provide reasonable assurance that the boiler will function properly during higher load conditions. This will prepare the boiler for operation during the beginning of the cooling season (lower load). As many of the test procedures as possible will be executed during this first stage of testing, through the use of the methods of artificial loading or partial loading. Stage 2 tests for low load condition tests will not be executed until summer.

# END OF EXHIBIT

### SECTION 23 21 13

### HYDRONIC PIPING

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes pipe and fitting materials, joining methods, special-duty valves, and specialties for the following:
  - 1. Heating, hot-water piping.
- B. Related Sections include the following:
  - 1. Division 23 Section "Hydronic Pumps" for pumps, motors, and accessories for hydronic piping.

## 1.03 DEFINITIONS

- A. PTFE: Polytetrafluoroethylene.
- B. RTRF: Reinforced thermosetting resin (fiberglass) fittings.
- C. RTRP: Reinforced thermosetting resin (fiberglass) pipe.
- 1.04 PERFORMANCE REQUIREMENTS
  - A. Hydronic piping components and installation shall be capable of withstanding the following minimum working pressure and temperature:
    - 1. Heating, Hot-Water Piping: 125 psig at 200 deg F.
    - 2. Safety-Valve-Inlet and -Outlet Piping: Equal to the pressure of the piping system to which it is attached.

# 1.05 SUBMITTALS

- A. Product Data: For each type of the following:
  - 1. Valves. Include flow and pressure drop curves based on manufacturer's testing for calibrated-orifice balancing valves and automatic flow-control valves.
  - 2. Air control devices.
  - 3. Chemical treatment.
  - 4. Hydronic specialties.
- B. Shop Drawings: Detail, at 1/4 scale, the piping layout, fabrication of pipe anchors, hangers, supports for multiple pipes, alignment guides, expansion joints and loops, and attachments of the same to the building structure. Detail location of anchors, alignment guides, and expansion joints and loops.
- C. Welding certificates.

- D. Qualification Data: For Installer.
- E. Field quality-control test reports.
- F. Operation and Maintenance Data: For air control devices, hydronic specialties, and specialduty valves to include in emergency, operation, and maintenance manuals.

## 1.06 QUALITY ASSURANCE

- A. Installer Qualifications:
- B. Steel Support Welding: Qualify processes and operators according to AWS D1.1/D1.1M, "Structural Welding Code Steel."
- C. Welding: Qualify processes and operators according to ASME Boiler and Pressure Vessel Code: Section IX.
  - 1. Comply with provisions in ASME B31 Series, "Code for Pressure Piping."
  - 2. Certify that each welder has passed AWS qualification tests for welding processes involved and that certification is current.
- D. ASME Compliance: Comply with ASME B31.9, "Building Services Piping," for materials, products, and installation. Safety valves and pressure vessels shall bear the appropriate ASME label. Fabricate and stamp air separators and expansion tanks to comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 01.

# 1.07 EXTRA MATERIALS

A. Differential Pressure Meter: For each type of balancing valve and automatic flow control valve, include flowmeter, probes, hoses, flow charts, and carrying case.

# PART 2 PRODUCTS

- 2.01 COPPER TUBE AND FITTINGS
  - A. Drawn-Temper Copper Tubing: ASTM B 88, Type L.
  - B. Wrought-Copper Fittings: ASME B16.22.
- 2.02 STEEL PIPE AND FITTINGS
  - A. Steel Pipe: ASTM A 53/A 53M, black steel with plain ends; type, grade, and wall thickness as indicated in Part 3 "Piping Applications" Article.
  - B. Cast-Iron Threaded Fittings: ASME B16.4; Classes 125 and 250 as indicated in Part 3 "Piping Applications" Article.
  - C. Malleable-Iron Threaded Fittings: ASME B16.3, Classes 150 and 300 as indicated in Part 3 "Piping Applications" Article.
  - D. Malleable-Iron Unions: ASME B16.39; Classes 150, 250, and 300 as indicated in Part 3 "Piping Applications" Article.

- E. Cast-Iron Pipe Flanges and Flanged Fittings: ASME B16.1, Classes 25, 125, and 250; raised ground face, and bolt holes spot faced as indicated in Part 3 "Piping Applications" Article.
- F. Wrought-Steel Fittings: ASTM A 234/A 234M, wall thickness to match adjoining pipe.
- G. Wrought Cast- and Forged-Steel Flanges and Flanged Fittings: ASME B16.5, including bolts, nuts, and gaskets of the following material group, end connections, and facings:
  - 1. Material Group: 1.1.
  - 2. End Connections: Butt welding.
  - 3. Facings: Raised face.
- H. Steel Pipe Nipples: ASTM A 733, made of same materials and wall thicknesses as pipe in which they are installed.

#### 2.03 JOINING MATERIALS

- A. Pipe-Flange Gasket Materials: Suitable for chemical and thermal conditions of piping system contents.
  - 1. ASME B16.21, nonmetallic, flat, asbestos free, 1/8-inch maximum thickness unless thickness or specific material is indicated.
    - a. Full-Face Type: For flat-face, Class 125, cast-iron and cast-bronze flanges.
    - b. Narrow-Face Type: For raised-face, Class 250, cast-iron and steel flanges.
- B. Flange Bolts and Nuts: ASME B18.2.1, carbon steel, unless otherwise indicated.
- C. Solder Filler Metals: ASTM B 32, lead-free alloys. Include water-flushable flux according to ASTM B 813.
- D. Brazing Filler Metals: AWS A5.8, BCuP Series, copper-phosphorus alloys for joining copper with copper; or BAg-1, silver alloy for joining copper with bronze or steel.
- E. Welding Filler Metals: Comply with AWS D10.12/D10.12M for welding materials appropriate for wall thickness and chemical analysis of steel pipe being welded.
- F. Gasket Material: Thickness, material, and type suitable for fluid to be handled and working temperatures and pressures.

# 2.04 DIELECTRIC FITTINGS

- A. Description: Combination fitting of copper-alloy and ferrous materials with threaded, solderjoint, plain, or weld-neck end connections that match piping system materials.
- B. Insulating Material: Suitable for system fluid, pressure, and temperature.
- C. Dielectric Unions:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Capitol Manufacturing Company.
    - b. Central Plastics Company.
    - c. Hart Industries International, Inc.
    - d. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
    - e. Zurn Plumbing Products Group; AquaSpec Commercial Products Division.
  - 2. Factory-fabricated union assembly, for 250-psig minimum working pressure at 180 deg F.

- D. Dielectric Flanges:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Capitol Manufacturing Company.
    - b. Central Plastics Company.
    - c. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - 2. Factory-fabricated companion-flange assembly, for 150- or 300-psig minimum working pressure as required to suit system pressures.
- E. Dielectric-Flange Kits:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Advance Products & Systems, Inc.
    - b. Calpico, Inc.
    - c. Central Plastics Company.
    - d. Pipeline Seal and Insulator, Inc.
  - 2. Companion-flange assembly for field assembly. Include flanges, full-face- or ring-type neoprene or phenolic gasket, phenolic or polyethylene bolt sleeves, phenolic washers, and steel backing washers.
  - 3. Separate companion flanges and steel bolts and nuts shall have 150- or 300-psig minimum working pressure where required to suit system pressures.
- F. Dielectric Couplings:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Calpico, Inc.
    - b. Lochinvar Corporation.
  - 3. Galvanized-steel coupling with inert and noncorrosive thermoplastic lining; threaded ends; and 300-psig minimum working pressure at 225 deg F.
- G. Dielectric Nipples:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Perfection Corporation; a subsidiary of American Meter Company.
    - b. Precision Plumbing Products, Inc.
    - c. Sioux Chief Manufacturing Company, Inc.
    - d. Victaulic Company of America.
  - 2. Electroplated steel nipple with inert and noncorrosive, thermoplastic lining; plain or threaded,; and 300-psig minimum working pressure at 225 deg F.

## 2.05 VALVES

- A. Gate, Globe, Check, Ball, and Butterfly Valves: Comply with requirements specified in Division 23 Section "General-Duty Valves for HVAC Piping."
- B. Automatic Temperature-Control Valves, Actuators, and Sensors: Comply with requirements specified in Division 23 Section "Instrumentation and Control for HVAC."
- C. Bronze, Calibrated-Orifice, Balancing Valves:

- 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - a. Armstrong Pumps, Inc.
  - b. Bell & Gossett Domestic Pump; a division of ITT Industries.
  - c. Flow Design Inc.
  - d. Taco.
- 2. Body: Bronze, ball or plug type with calibrated orifice or venturi.
- 3. Ball: Brass or stainless steel.
- 4. Plug: Resin.
- 5. Seat: PTFE.
- 6. End Connections: Threaded or socket.
- 7. Pressure Gage Connections: Integral seals for portable differential pressure meter.
- 8. Handle Style: Lever, with memory stop to retain set position.
- 9. CWP Rating: Minimum 125 psig.
- 10. Maximum Operating Temperature: 250 deg F.
- D. Cast-Iron or Steel, Calibrated-Orifice, Balancing Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Armstrong Pumps, Inc.
    - b. Bell & Gossett Domestic Pump; a division of ITT Industries.
    - c. Flow Design Inc.
    - d. Gerand Engineering Co.
    - e. Griswold Controls.
    - f. Taco.
    - g. Tour & Andersson; available through Victaulic Company of America.
  - 2. Body: Cast-iron or steel body, ball, plug, or globe pattern with calibrated orifice or venturi.
  - 3. Ball: Brass or stainless steel.
  - 4. Stem Seals: EPDM O-rings.
  - 5. Disc: Glass and carbon-filled PTFE.
  - 6. Seat: PTFE.
  - 7. End Connections: Flanged
  - 8. Pressure Gage Connections: Integral seals for portable differential pressure meter.
  - 9. Handle Style: Lever, with memory stop to retain set position.
  - 10. CWP Rating: Minimum 125 psig.
  - 11. Maximum Operating Temperature: 250 deg F.
- E. Diaphragm-Operated Safety Valves:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Amtrol, Inc.
    - b. Armstrong Pumps, Inc.
    - c. Bell & Gossett Domestic Pump; a division of ITT Industries.
    - d. Conbraco Industries, Inc.
    - e. Spence Engineering Company, Inc.
    - f. Watts Regulator Co.; a division of Watts Water Technologies, Inc.
  - 2. Body: Bronze or brass.
  - 3. Disc: Glass and carbon-filled PTFE.
  - 4. Seat: Brass.
  - 5. Stem Seals: EPDM O-rings.
  - 6. Diaphragm: EPT.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 7. Wetted, Internal Work Parts: Brass and rubber.
- 8. Inlet Strainer: brass, removable without system shutdown.
- 9. Valve Seat and Stem: Noncorrosive.
- 10. Valve Size, Capacity, and Operating Pressure: Comply with ASME Boiler and Pressure Vessel Code: Section IV, and selected to suit system in which installed, with operating pressure and capacity factory set and field adjustable.

## 2.06 AIR CONTROL DEVICES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Amtrol, Inc.
  - 2. Armstrong Pumps, Inc.
  - 3. Bell & Gossett Domestic Pump; a division of ITT Industries.
  - 4. Taco.
- B. Manual Air Vents:
  - 1. Body: Bronze.
  - 2. Internal Parts: Nonferrous.
  - 3. Operator: Screwdriver or thumbscrew.
  - 4. Inlet Connection: NPS 1/2.
  - 5. Discharge Connection: NPS 1/8.
  - 6. CWP Rating: 150 psig.
  - 7. Maximum Operating Temperature: 225 deg F.
- C. Automatic Air Vents:
  - 1. Body: Bronze or cast iron.
  - 2. Internal Parts: Nonferrous.
  - 3. Operator: Noncorrosive metal float.
  - 4. Inlet Connection: NPS 1/2.
  - 5. Discharge Connection: NPS 1/4.
  - 6. CWP Rating: 150 psig.
  - 7. Maximum Operating Temperature: 240 deg F.
- D. Coalescing Type Air Separators:
  - 1. Tank: Welded steel; ASME constructed and labeled for 125-psig minimum working pressure and 375 deg F maximum operating temperature.
  - 2. Air Collector Tube: Perforated stainless steel, constructed to direct released air into expansion tank.
  - 3. Inlet and Outlet Connections: Threaded for NPS 2 and smaller; flanged connections for NPS 2-1/2 and larger.
  - 4. Blowdown Connection: Threaded.
  - 5. Size: Match system flow capacity.

#### 2.07 HYDRONIC PIPING SPECIALTIES

- A. Y-Pattern Strainers:
  - 1. Body: ASTM A 126, Class B, cast iron with bolted cover and bottom drain connection.
  - 2. End Connections: Threaded ends for NPS 2 and smaller; flanged ends for NPS 2-1/2 and larger.
  - 3. Strainer Screen: 40-mesh startup strainer, and perforated stainless-steel basket with 50 percent free area.
  - 4. CWP Rating: 125 psig.

## PART 3 EXECUTION

# 3.01 PIPING APPLICATIONS

- A. Heating, hot-water piping, aboveground, NPS 2 and smaller, shall be any of the following:
  - 1. Type L, drawn-temper copper tubing, wrought-copper fittings, and brazed joints.
  - 2. Schedule 40 steel pipe; Class 150, malleable-iron fittings; cast-iron flanges and flange fittings; and threaded joints.
- B. Heating, hot-water piping, aboveground, NPS 2-1/2 and larger, shall be any of the following:
  - 1. Type L, drawn-temper copper tubing, wrought-copper fittings, and brazed joints.
  - 2. Schedule 40 steel pipe, wrought-steel fittings and wrought-cast or forged-steel flanges and flange fittings, and welded and flanged joints.

#### 3.02 VALVE APPLICATIONS

- A. Install shutoff-duty valves at each branch connection to supply mains, and at supply connection to each piece of equipment.
- B. Install check valves at each pump discharge and elsewhere as required to control flow direction.
- C. Install safety valves at hot-water generators and elsewhere as required by ASME Boiler and Pressure Vessel Code. Install drip-pan elbow on safety-valve outlet and pipe without valves to the outdoors; and pipe drain to nearest floor drain or as indicated on Drawings. Comply with ASME Boiler and Pressure Vessel Code: Section VIII, Division 1, for installation requirements.

### 3.03 PIPING INSTALLATIONS

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of piping systems. Indicate piping locations and arrangements if such were used to size pipe and calculate friction loss, expansion, pump sizing, and other design considerations. Install piping as indicated unless deviations to layout are approved on Coordination Drawings.
- B. Install piping in concealed locations, unless otherwise indicated and except in equipment rooms and service areas.
- C. Install piping indicated to be exposed and piping in equipment rooms and service areas at right angles or parallel to building walls. Diagonal runs are prohibited unless specifically indicated otherwise.
- D. Install piping above accessible ceilings to allow sufficient space for ceiling panel removal.
- E. Install piping to permit valve servicing.
- F. Install piping at indicated slopes.
- G. Install piping free of sags and bends.
- H. Install fittings for changes in direction and branch connections.
- I. Install piping to allow application of insulation.

- J. Select system components with pressure rating equal to or greater than system operating pressure.
- K. Install groups of pipes parallel to each other, spaced to permit applying insulation and servicing of valves.
- L. Install drains, consisting of a tee fitting, NPS 3/4 ball valve, and short NPS 3/4 threaded nipple with cap, at low points in piping system mains and elsewhere as required for system drainage.
- M. Install piping at a uniform grade of 0.2 percent upward in direction of flow.
- N. Reduce pipe sizes using eccentric reducer fitting installed with level side up.
- O. Install branch connections to mains using tee fittings in main pipe, with the branch connected to the bottom of the main pipe. For up-feed risers, connect the branch to the top of the main pipe.
- P. Install valves according to Division 23 Section "General-Duty Valves for HVAC Piping."
- Q. Install unions in piping, NPS 2 and smaller, adjacent to valves, at final connections of equipment, and elsewhere as indicated.
- R. Install flanges in piping, NPS 2-1/2 and larger, at final connections of equipment and elsewhere as indicated.
- S. Install strainers on inlet side of each control valve, pressure-reducing valve, solenoid valve, inline pump, and elsewhere as indicated. Install NPS 3/4 nipple and ball valve in blowdown connection of strainers NPS 2 and larger. Match size of strainer blowoff connection for strainers smaller than NPS 2.
- T. Install expansion loops, expansion joints, anchors, and pipe alignment guides as specified in Division 23 Section "Expansion Fittings and Loops for HVAC Piping."
- U. Identify piping as specified in Division 23 Section "Identification for HVAC Piping and Equipment."

#### 3.04 HANGERS AND SUPPORTS

- A. Hanger, support, and anchor devices are specified in Division 23 Section "Hangers and Supports for HVAC Piping and Equipment." Comply with the following requirements for maximum spacing of supports.
- B. Seismic restraints are specified in Division 23 Section "Vibration and Seismic Controls for HVAC Piping and Equipment."
- C. Install the following pipe attachments:
  - 1. Adjustable steel clevis hangers for individual horizontal piping less than 20 feet long.
  - 2. Adjustable roller hangers and spring hangers for individual horizontal piping 20 feet or longer.
  - 3. Pipe Roller: MSS SP-58, Type 44 for multiple horizontal piping 20 feet or longer, supported on a trapeze.
  - 4. Spring hangers to support vertical runs.
  - 5. Provide copper-clad hangers and supports for hangers and supports in direct contact with copper pipe.

- 6. On plastic pipe, install pads or cushions on bearing surfaces to prevent hanger from scratching pipe.
- D. Install hangers for steel piping with the following maximum spacing and minimum rod sizes:
  - 1. NPS 3/4: Maximum span, 7 feet; minimum rod size, 3/8 inch.
  - 2. NPS 1: Maximum span, 7 feet; minimum rod size, 3/8 inch.
  - 3. NPS 1-1/4: Maximum span, 7 feet; minimum rod size, 3/8 inch.
  - 4. NPS 1-1/2: Maximum span, 9 feet; minimum rod size, 3/8 inch.
  - 5. NPS 2: Maximum span, 10 feet; minimum rod size, 3/8 inch.
  - 6. NPS 2-1/2: Maximum span, 11 feet; minimum rod size, 1/2 inch.
  - 7. NPS 3: Maximum span, 12 feet; minimum rod size, 1/2 inch.
  - 8. NPS 3-1/2: Maximum span, 13 feet; minimum rod size, 1/2 inch.
  - 9. NPS 4: Maximum span, 14 feet; minimum rod size, 5/8 inch.
  - 10. NPS 5: Maximum span, 16 feet; minimum rod size, 5/8 inch.
  - 11. NPS 6: Maximum span, 17 feet; minimum rod size, 3/4 inch.
  - 12. NPS 8: Maximum span, 19 feet; minimum rod size, 3/4 inch.
  - 13. NPS 10: Maximum span, 22 feet; minimum rod size, 7/8 inch.
  - 14. NPS 12: Maximum span, 23 feet; minimum rod size, 7/8 inch.
- E. Install hangers for drawn-temper copper tubing with the following maximum spacing and minimum rod sizes:
  - 1. NPS 3/4: Maximum span, 5 feet; minimum rod size, 3/8 inch.
  - 2. NPS 1: Maximum span, 6 feet; minimum rod size, 3/8 inch.
  - 3. NPS 1-1/4: Maximum span, 7 feet; minimum rod size, 3/8 inch.
  - 4. NPS 1-1/2: Maximum span, 8 feet; minimum rod size, 3/8 inch.
  - 5. NPS 2: Maximum span, 8 feet; minimum rod size, 3/8 inch.
  - NPS 2-1/2: Maximum span, 9 feet; minimum rod size, 1/2 inch.
  - 7. NPS 3: Maximum span, 10 feet; minimum rod size, 1/2 inch.
- F. Support vertical runs at roof, at each floor, and at 10-foot intervals between floors.

#### 3.05 PIPE JOINT CONSTRUCTION

- A. Join pipe and fittings according to the following requirements and Division 23 Sections specifying piping systems.
- B. Ream ends of pipes and tubes and remove burrs. Bevel plain ends of steel pipe.
- C. Remove scale, slag, dirt, and debris from inside and outside of pipe and fittings before assembly.
- D. Brazed Joints: Construct joints according to AWS's "Brazing Handbook," "Pipe and Tube" Chapter, using copper-phosphorus brazing filler metal complying with AWS A5.8.
- E. Threaded Joints: Thread pipe with tapered pipe threads according to ASME B1.20.1. Cut threads full and clean using sharp dies. Ream threaded pipe ends to remove burrs and restore full ID. Join pipe fittings and valves as follows:
  - 1. Apply appropriate tape or thread compound to external pipe threads unless dry seal threading is specified.
  - 2. Damaged Threads: Do not use pipe or pipe fittings with threads that are corroded or damaged. Do not use pipe sections that have cracked or open welds.
- F. Welded Joints: Construct joints according to AWS D10.12/D10.12M, using qualified processes and welding operators according to Part 1 "Quality Assurance" Article.

G. Flanged Joints: Select appropriate gasket material, size, type, and thickness for service application. Install gasket concentrically positioned. Use suitable lubricants on bolt threads.

## 3.06 HYDRONIC SPECIALTIES INSTALLATION

- A. Install manual air vents at high points in piping, at heat-transfer coils, and elsewhere as required for system air venting.
- B. Install automatic air vents at high points of system piping in mechanical equipment rooms only. Manual vents at heat-transfer coils and elsewhere as required for air venting.
- C. Install piping from boiler air outlet, air separator, or air purger to expansion tank with a 2 percent upward slope toward tank.
- D. Install tangential air separator in pump suction. Install blowdown piping with gate or full-port ball valve; extend full size to nearest floor drain.
- E. Install bypass chemical feeders in each hydronic system where indicated, in upright position with top of funnel not more than 48 inches above the floor. Install feeder in minimum NPS 3/4 bypass line, from main with full-size, full-port, ball valve in the main between bypass connections. Install NPS 3/4 pipe from chemical feeder drain, to nearest equipment drain and include a full-size, full-port, ball valve.
- F. Install expansion tanks on the floor. Vent and purge air from hydronic system, and ensure tank is properly charged with air to suit system Project requirements.

#### 3.07 TERMINAL EQUIPMENT CONNECTIONS

- A. Sizes for supply and return piping connections shall be the same as or larger than equipment connections.
- B. Install control valves in accessible locations close to connected equipment.
- C. Install bypass piping with globe valve around control valve. If parallel control valves are installed, only one bypass is required.
- D. Install ports for pressure gages and thermometers at coil inlet and outlet connections according to Division 23 Section "Meters and Gages for HVAC Piping."

## 3.08 FIELD QUALITY CONTROL

- A. Prepare hydronic piping according to ASME B31.9 and as follows:
  - 1. Leave joints, including welds, uninsulated and exposed for examination during test.
  - 2. Provide temporary restraints for expansion joints that cannot sustain reactions due to test pressure. If temporary restraints are impractical, isolate expansion joints from testing.
  - 3. Flush hydronic piping systems with clean water; then remove and clean or replace strainer screens.
  - 4. Isolate equipment from piping. If a valve is used to isolate equipment, its closure shall be capable of sealing against test pressure without damage to valve. Install blinds in flanged joints to isolate equipment.
  - 5. Install safety valve, set at a pressure no more than one-third higher than test pressure, to protect against damage by expanding liquid or other source of overpressure during test.
- B. Perform the following tests on hydronic piping:

- 1. Use ambient temperature water as a testing medium unless there is risk of damage due to freezing. Another liquid that is safe for workers and compatible with piping may be used.
- 2. While filling system, use vents installed at high points of system to release air. Use drains installed at low points for complete draining of test liquid.
- 3. Isolate expansion tanks and determine that hydronic system is full of water.
- 4. Subject piping system to hydrostatic test pressure that is not less than 1.5 times the system's working pressure. Test pressure shall not exceed maximum pressure for any vessel, pump, valve, or other component in system under test. Verify that stress due to pressure at bottom of vertical runs does not exceed 90 percent of specified minimum yield strength or 1.7 times "SE" value in Appendix A in ASME B31.9, "Building Services Piping."
- 5. After hydrostatic test pressure has been applied for at least 10 minutes, examine piping, joints, and connections for leakage. Eliminate leaks by tightening, repairing, or replacing components, and repeat hydrostatic test until there are no leaks.
- 6. Prepare written report of testing.
- C. Perform the following before operating the system:
  - 1. Open manual valves fully.
  - 2. Inspect pumps for proper rotation.
  - 3. Set makeup pressure-reducing valves for required system pressure.
  - 4. Inspect air vents at high points of system and determine if all are installed and operating freely (automatic type), or bleed air completely (manual type).
  - 5. Set temperature controls so all coils are calling for full flow.
  - 6. Inspect and set operating temperatures of hydronic equipment, such as boilers, chillers, cooling towers, to specified values.
  - 7. Verify lubrication of motors and bearings.

END OF SECTION

## SECTION 23 31 13

## METAL DUCTS

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Single-wall rectangular ducts and fittings.
  - 2. Single-wall round and flat-oval ducts and fittings.
  - 3. Sheet metal materials.
  - 4. Sealants and gaskets.
  - 5. Hangers and supports.
  - 6. Seismic-restraint devices.
- B. Related Sections:
  - 1. Division 23 Section "Testing, Adjusting, and Balancing for HVAC" for testing, adjusting, and balancing requirements for metal ducts.
  - 2. Division 23 Section "Air Duct Accessories" for dampers, sound-control devices, ductmounting access doors and panels, turning vanes, and flexible ducts.

#### 1.03 PERFORMANCE REQUIREMENTS

- A. Delegated Duct Design: Duct construction, including sheet metal thicknesses, seam and joint construction, reinforcements, and hangers and supports, shall comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible" and performance requirements and design criteria indicated in "Duct Schedule" Article.
- B. Structural Performance: Duct hangers and supports and seismic restraints shall withstand the effects of gravity and seismic loads and stresses within limits and under conditions described in SMACNA's "HVAC Duct Construction Standards Metal and Flexible" and SMACNA's "Seismic Restraint Manual: Guidelines for Mechanical Systems."
- C. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.

## 1.04 SUBMITTALS

- A. Product Data: For each type of the following products:
  - 1. Sealants and gaskets.
  - 2. Seismic-restraint devices.
- B. Shop Drawings:
  - 1. Fabrication, assembly, and installation, including plans, elevations, sections, components, and attachments to other work.
  - 2. Factory- and shop-fabricated ducts and fittings.
  - 3. Duct layout indicating sizes, configuration, and static-pressure classes.
  - 4. Elevation of top of ducts.

- 5. Dimensions of main duct runs from building grid lines.
- 6. Fittings.
- 7. Reinforcement and spacing.
- 8. Seam and joint construction.
- 9. Penetrations through fire-rated and other partitions.
- 10. Equipment installation based on equipment being used on Project.
- 11. Locations for duct accessories, including dampers, turning vanes, and access doors and panels.
- 12. Hangers and supports, including methods for duct and building attachment, seismic restraints, and vibration isolation.
- C. Delegated-Design Submittal:
  - 1. Sheet metal thicknesses.
  - 2. Joint and seam construction and sealing.
  - 3. Reinforcement details and spacing.
  - 4. Materials, fabrication, assembly, and spacing of hangers and supports.
  - 5. Design Calculations: Calculations, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation for selecting hangers and supports and seismic restraints.
- D. Coordination Drawings: Plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
  - 1. Duct installation in congested spaces, indicating coordination with general construction, building components, and other building services. Indicate proposed changes to duct layout.
  - 2. Suspended ceiling components.
  - 3. Structural members to which duct will be attached.
  - 4. Size and location of initial access modules for acoustical tile.
  - 5. Penetrations of smoke barriers and fire-rated construction.
  - 6. Items penetrating finished ceiling including the following:
    - a. Lighting fixtures.
    - b. Air outlets and inlets.
    - c. Sprinklers.
    - d. Access panels.
- E. Welding certificates.
- F. Field quality-control reports.

# 1.05 QUALITY ASSURANCE

- A. Welding Qualifications: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code Steel," for hangers and supports.
- B. Welding Qualifications: Qualify procedures and personnel according to the following:
  1. AWS D1.1/D1.1M, "Structural Welding Code Steel," for hangers and supports.
- C. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 5 "Systems and Equipment" and Section 7 "Construction and System Start-Up."
- D. ASHRAE/IESNA Compliance: Applicable requirements in ASHRAE/IESNA 90.1, Section 6.4.4 "HVAC System Construction and Insulation."

## PART 2 PRODUCTS

#### 2.01 SINGLE-WALL RECTANGULAR DUCTS AND FITTINGS

- A. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible" based on indicated static-pressure class unless otherwise indicated.
- B. Transverse Joints: Select joint types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 2-1, "Rectangular Duct/Transverse Joints," for static-pressure class, applicable sealing requirements, materials involved, ductsupport intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards -Metal and Flexible."
- C. Longitudinal Seams: Select seam types and fabricate according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 2-2, "Rectangular Duct/Longitudinal Seams," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards Metal and Flexible."
- D. Elbows, Transitions, Offsets, Branch Connections, and Other Duct Construction: Select types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Chapter 4, "Fittings and Other Construction," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."

#### 2.02 SINGLE-WALL ROUND AND FLAT-OVAL DUCTS AND FITTINGS

- A. General Fabrication Requirements: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Chapter 3, "Round, Oval, and Flexible Duct," based on indicated static-pressure class unless otherwise indicated.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. McGill AirFlow LLC.
    - b. SEMCO Incorporated.
    - c. Sheet Metal Connectors, Inc.
- B. Flat-Oval Ducts: Indicated dimensions are the duct width (major dimension) and diameter of the round sides connecting the flat portions of the duct (minor dimension).
- C. Transverse Joints: Select joint types and fabricate according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 3-1, "Round Duct Transverse Joints," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards Metal and Flexible."
  - 1. Transverse Joints in Ducts Larger Than 60 Inches in Diameter: Flanged.
- D. Longitudinal Seams: Select seam types and fabricate according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible," Figure 3-2, "Round Duct Longitudinal Seams," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
  - 1. Fabricate round ducts larger than 90 inches in diameter with butt-welded longitudinal seams.

- 2. Fabricate flat-oval ducts larger than 72 inches in width (major dimension) with buttwelded longitudinal seams.
- E. Tees and Laterals: Select types and fabricate according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 3-5, "90 Degree Tees and Laterals," and Figure 3-6, "Conical Tees," for static-pressure class, applicable sealing requirements, materials involved, duct-support intervals, and other provisions in SMACNA's "HVAC Duct Construction Standards Metal and Flexible."

## 2.03 SHEET METAL MATERIALS

- A. General Material Requirements: Comply with SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.
- B. Galvanized Sheet Steel: Comply with ASTM A 653/A 653M.
  - 1. Galvanized Coating Designation: G90.
  - 2. Finishes for Surfaces Exposed to View: Mill phosphatized.
- C. Tie Rods: Galvanized steel, 1/4-inch minimum diameter for lengths 36 inches or less; 3/8-inch minimum diameter for lengths longer than 36 inches.

#### 2.04 SEALANT AND GASKETS

- A. General Sealant and Gasket Requirements: Surface-burning characteristics for sealants and gaskets shall be a maximum flame-spread index of 25 and a maximum smoke-developed index of 50 when tested according to UL 723; certified by an NRTL.
- B. Two-Part Tape Sealing System:
  - 1. Tape: Woven cotton fiber impregnated with mineral gypsum and modified acrylic/silicone activator to react exothermically with tape to form hard, durable, airtight seal.
  - 2. Tape Width: 4 inches.
  - 3. Sealant: Modified styrene acrylic.
  - 4. Water resistant.
  - 5. Mold and mildew resistant.
  - 6. Maximum Static-Pressure Class: 10-inch wg, positive and negative.
  - 7. Service: Indoor and outdoor.
  - 8. Service Temperature: Minus 40 to plus 200 deg F.
  - 9. Substrate: Compatible with galvanized sheet steel (both PVC coated and bare), stainless steel, or aluminum.
  - 10. For indoor applications, use sealant that has a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 11. Sealant shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- C. Water-Based Joint and Seam Sealant:
  - 1. Application Method: Brush on.
  - 2. Solids Content: Minimum 65 percent.
  - 3. Shore A Hardness: Minimum 20.
  - 4. Water resistant.
  - 5. Mold and mildew resistant.
  - 6. VOC: Maximum 75 g/L (less water).
  - 7. Maximum Static-Pressure Class: 10-inch wg, positive and negative.
- 8. Service: Indoor or outdoor.
- 9. Substrate: Compatible with galvanized sheet steel (both PVC coated and bare), stainless steel, or aluminum sheets.
- D. Solvent-Based Joint and Seam Sealant:
  - 1. Application Method: Brush on.
  - 2. Base: Synthetic rubber resin.
  - 3. Solvent: Toluene and heptane.
  - 4. Solids Content: Minimum 60 percent.
  - 5. Shore A Hardness: Minimum 60.
  - 6. Water resistant.
  - 7. Mold and mildew resistant.
  - 8. For indoor applications, use sealant that has a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 9. VOC: Maximum 395 g/L.
  - 10. Sealant shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
  - 11. Maximum Static-Pressure Class: 10-inch wg, positive or negative.
  - 12. Service: Indoor or outdoor.
  - 13. Substrate: Compatible with galvanized sheet steel (both PVC coated and bare), stainless steel, or aluminum sheets.
- E. Flanged Joint Sealant: Comply with ASTM C 920.
  - 1. General: Single-component, acid-curing, silicone, elastomeric.
  - 2. Type: S.
  - 3. Grade: NS.
  - 4. Class: 25.
  - 5. Use: O.
  - 6. For indoor applications, use sealant that has a VOC content of 250 g/L or less when calculated according to 40 CFR 59, Subpart D (EPA Method 24).
  - 7. Sealant shall comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- F. Flange Gaskets: Butyl rubber, neoprene, or EPDM polymer with polyisobutylene plasticizer.

### 2.05 HANGERS AND SUPPORTS

- A. Hanger Rods for Noncorrosive Environments: Cadmium-plated steel rods and nuts.
- B. Strap and Rod Sizes: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Table 5-1, "Rectangular Duct Hangers Minimum Size," and Table 5-2, "Minimum Hanger Sizes for Round Duct."
- C. Steel Cables for Galvanized-Steel Ducts: Galvanized steel complying with ASTM A 603.
- D. Steel Cable End Connections: Cadmium-plated steel assemblies with brackets, swivel, and bolts designed for duct hanger service; with an automatic-locking and clamping device.
- E. Duct Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.
- F. Trapeze and Riser Supports:
  - 1. Supports for Galvanized-Steel Ducts: Galvanized-steel shapes and plates.

- 2. Supports for Stainless-Steel Ducts: Stainless-steel shapes and plates.
- 3. Supports for Aluminum Ducts: Aluminum or galvanized steel coated with zinc chromate.

## 2.06 SEISMIC-RESTRAINT DEVICES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. B-Line, an Eaton Business
  - 2. Kinetics Noise Control.
  - 3. Mason Industries.
  - 4. Unistrut; part of Atkore International.
- B. General Requirements for Restraint Components: Rated strengths, features, and applications shall be as defined in reports by an agency acceptable to authorities having jurisdiction.
  - 1. Structural Safety Factor: Allowable strength in tension, shear, and pullout force of components shall be at least four times the maximum seismic forces to which they will be subjected.
- C. Channel Support System: Shop- or field-fabricated support assembly made of slotted steel channels rated in tension, compression, and torsion forces and with accessories for attachment to braced component at one end and to building structure at the other end. Include matching components and corrosion-resistant coating.
- D. Restraint Cables: ASTM A 603, galvanized -steel cables with end connections made of cadmium-plated steel assemblies with brackets, swivel, and bolts designed for restraining cable service; and with an automatic-locking and clamping device or double-cable clips.
- E. Hanger Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections or reinforcing steel angle clamped to hanger rod.
- F. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

## PART 3 EXECUTION

### 3.01 DUCT INSTALLATION

- A. Drawing plans, schematics, and diagrams indicate general location and arrangement of duct system. Indicated duct locations, configurations, and arrangements were used to size ducts and calculate friction loss for air-handling equipment sizing and for other design considerations. Install duct systems as indicated unless deviations to layout are approved on Shop Drawings and Coordination Drawings.
- B. Install ducts according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible" unless otherwise indicated.
- C. Install round and flat-oval ducts in maximum practical lengths.
- D. Install ducts with fewest possible joints.
- E. Install factory- or shop-fabricated fittings for changes in direction, size, and shape and for branch connections.

- F. Unless otherwise indicated, install ducts vertically and horizontally, and parallel and perpendicular to building lines.
- G. Install ducts close to walls, overhead construction, columns, and other structural and permanent enclosure elements of building.
- H. Install ducts with a clearance of 1 inch, plus allowance for insulation thickness.
- I. Route ducts to avoid passing through transformer vaults and electrical equipment rooms and enclosures.
- J. Where ducts pass through non-fire-rated interior partitions and exterior walls and are exposed to view, cover the opening between the partition and duct or duct insulation with sheet metal flanges of same metal thickness as the duct. Overlap openings on four sides by at least 1-1/2 inches.
- K. Where ducts pass through fire-rated interior partitions and exterior walls, install fire dampers. Comply with requirements in Division 23 Section "Air Duct Accessories" for fire and smoke dampers.
- L. Protect duct interiors from moisture, construction debris and dust, and other foreign materials. Comply with SMACNA's "IAQ Guidelines for Occupied Buildings Under Construction," Appendix G, "Duct Cleanliness for New Construction Guidelines."

## 3.02 INSTALLATION OF EXPOSED DUCTWORK

- A. Protect ducts exposed in finished spaces from being dented, scratched, or damaged.
- B. Trim duct sealants flush with metal. Create a smooth and uniform exposed bead. Do not use two-part tape sealing system.
- C. Grind welds to provide smooth surface free of burrs, sharp edges, and weld splatter. When welding stainless steel with a No. 3 or 4 finish, grind the welds flush, polish the exposed welds, and treat the welds to remove discoloration caused by welding.
- D. Maintain consistency, symmetry, and uniformity in the arrangement and fabrication of fittings, hangers and supports, duct accessories, and air outlets.
- E. Repair or replace damaged sections and finished work that does not comply with these requirements.

### 3.03 DUCT SEALING

- A. Seal ducts for duct static-pressure, seal classes, and leakage classes specified in "Duct Schedule" Article according to SMACNA's "HVAC Duct Construction Standards - Metal and Flexible."
- B. Seal ducts to the following seal classes according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible":
  - 1. Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible."
  - 2. Outdoor, Supply-Air Ducts: Seal Class A.
  - 3. Outdoor, Return-Air Ducts: Seal Class C.
  - 4. Unconditioned Space, Supply-Air Ducts in Pressure Classes 2-Inch wg and Lower: Seal Class B.

- 5. Unconditioned Space, Supply-Air Ducts in Pressure Classes Higher Than 2-Inch wg: Seal Class A.
- 6. Unconditioned Space, Exhaust Ducts: Seal Class C.
- 7. Unconditioned Space, Return-Air Ducts: Seal Class B.
- 8. Conditioned Space, Supply-Air Ducts in Pressure Classes 2-Inch wg and Lower: Seal Class C.
- 9. Conditioned Space, Supply-Air Ducts in Pressure Classes Higher Than 2-Inch wg: Seal Class B.
- 10. Conditioned Space, Exhaust Ducts: Seal Class B.
- 11. Conditioned Space, Return-Air Ducts: Seal Class C.
- 3.04 HANGER AND SUPPORT INSTALLATION
  - A. Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Chapter 5, "Hangers and Supports."
  - B. Building Attachments: Concrete inserts, powder-actuated fasteners, or structural-steel fasteners appropriate for construction materials to which hangers are being attached.
    - 1. Where practical, install concrete inserts before placing concrete.
    - 2. Install powder-actuated concrete fasteners after concrete is placed and completely cured.
    - 3. Use powder-actuated concrete fasteners for standard-weight aggregate concretes or for slabs more than 4 inches thick.
    - 4. Do not use powder-actuated concrete fasteners for lightweight-aggregate concretes or for slabs less than 4 inches thick.
    - 5. Do not use powder-actuated concrete fasteners for seismic restraints.
  - C. Hanger Spacing: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Table 5-1, "Rectangular Duct Hangers Minimum Size," and Table 5-2, "Minimum Hanger Sizes for Round Duct," for maximum hanger spacing; install hangers and supports within 24 inches of each elbow and within 48 inches of each branch intersection.
  - D. Hangers Exposed to View: Threaded rod and angle or channel supports.
  - E. Support vertical ducts with steel angles or channel secured to the sides of the duct with welds, bolts, sheet metal screws, or blind rivets; support at each floor and at a maximum intervals of 16 feet.
  - F. Install upper attachments to structures. Select and size upper attachments with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

## 3.05 SEISMIC-RESTRAINT-DEVICE INSTALLATION

- A. Install ducts with hangers and braces designed to support the duct and to restrain against seismic forces required by applicable building codes. Comply with SMACNA's "Seismic Restraint Manual: Guidelines for Mechanical Systems."
  - 1. Space lateral supports a maximum of 40 feet o.c., and longitudinal supports a maximum of 80 feet o.c.
  - 2. Brace a change of direction longer than 12 feet.
- B. Select seismic-restraint devices with capacities adequate to carry present and future static and seismic loads.
- C. Install cables so they do not bend across edges of adjacent equipment or building structure.

- D. Install cable restraints on ducts that are suspended with vibration isolators.
- E. Install seismic-restraint devices using methods approved by an agency acceptable to authorities having jurisdiction.
- F. Attachment to Structure: If specific attachment is not indicated, anchor bracing and restraints to structure, to flanges of beams, to upper truss chords of bar joists, or to concrete members.
- G. Drilling for and Setting Anchors:
  - Identify position of reinforcing steel and other embedded items prior to drilling holes for anchors. Do not damage existing reinforcement or embedded items during drilling. Notify the Architect if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.
  - 2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
  - 3. Wedge Anchors: Protect threads from damage during anchor installation. Heavy-duty sleeve anchors shall be installed with sleeve fully engaged in the structural element to which anchor is to be fastened.
  - 4. Set anchors to manufacturer's recommended torque, using a torque wrench.
  - 5. Install zinc-coated steel anchors for interior applications and stainless-steel anchors for applications exposed to weather.

## 3.06 CONNECTIONS

- A. Make connections to equipment with flexible connectors complying with Division 23 Section "Air Duct Accessories."
- B. Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible" for branch, outlet and inlet, and terminal unit connections.

## 3.07 PAINTING

A. Paint interior of metal ducts that are visible through registers and grilles and that do not have duct liner. Apply one coat of flat, black, latex paint over a compatible galvanized-steel primer. Paint materials and application requirements are specified in Division 09 painting Sections.

### 3.08 FIELD QUALITY CONTROL

- A. Perform tests and inspections.
- B. Leakage Tests:
  - 1. Comply with SMACNA's "HVAC Air Duct Leakage Test Manual." Submit a test report for each test.
  - 2. Test the following systems:
    - a. Ducts with a Pressure Class Higher Than 3-Inch wg: Test representative duct sections, selected by Architect from sections installed, totaling no less than 25 percent of total installed duct area for each designated pressure class.
    - b. Supply Ducts with a Pressure Class of 3-Inch wg or Higher: Test representative duct sections, selected by Architect from sections installed, totaling no less than 50 percent of total installed duct area for each designated pressure class.
    - c. Return Ducts with a Pressure Class of 2-Inch wg or Higher: Test representative duct sections, selected by Architect from sections installed, totaling no less than 50 percent of total installed duct area for each designated pressure class.

- d. Exhaust Ducts with a Pressure Class of 2-Inch wg 3-Inch wg 4-Inch wg or Higher: Test representative duct sections, selected by Architect from sections installed, totaling no less than 50 percent of total installed duct area for each designated pressure class.
- e. Outdoor Air Ducts with a Pressure Class of 3-Inch wg or Higher: Test representative duct sections, selected by Architect from sections installed, totaling no less than 100 percent of total installed duct area for each designated pressure class.
- 3. Disassemble, reassemble, and seal segments of systems to accommodate leakage testing and for compliance with test requirements.
- 4. Test for leaks before applying external insulation.
- 5. Conduct tests at static pressures equal to maximum design pressure of system or section being tested. If static-pressure classes are not indicated, test system at maximum system design pressure. Do not pressurize systems above maximum design operating pressure.
- 6. Give seven days' advance notice for testing.
- C. Duct System Cleanliness Tests:
  - 1. Visually inspect duct system to ensure that no visible contaminants are present.
  - Test sections of metal duct system, chosen randomly by Owner, for cleanliness according to "Vacuum Test" in NADCA ACR, "Assessment, Cleaning and Restoration of HVAC Systems."
    - a. Acceptable Cleanliness Level: Net weight of debris collected on the filter media shall not exceed 0.75 mg/100 sq. cm.
- D. Duct system will be considered defective if it does not pass tests and inspections.
- E. Prepare test and inspection reports.

## 3.09 DUCT CLEANING

- A. Clean new duct system(s) before testing, adjusting, and balancing.
- B. Use service openings for entry and inspection.
  - 1. Create new openings and install access panels appropriate for duct static-pressure class if required for cleaning access. Provide insulated panels for insulated or lined duct. Patch insulation as recommended by manufacturer. Comply with Division 23 Section "Air Duct Accessories" for access panels and doors.
  - 2. Disconnect and reconnect flexible ducts as needed for cleaning and inspection.
  - 3. Remove and reinstall ceiling to gain access during the cleaning process.
- C. Particulate Collection and Odor Control:
  - 1. When venting vacuuming system inside the building, use HEPA filtration with 99.97 percent collection efficiency for 0.3-micron-size (or larger) particles.
  - 2. When venting vacuuming system to outdoors, use filter to collect debris removed from HVAC system, and locate exhaust downwind and away from air intakes and other points of entry into building.
- D. Clean the following components by removing surface contaminants and deposits:
  - 1. Air outlets and inlets (registers, grilles, and diffusers).
  - 2. Supply, return, and exhaust fans including fan housings, plenums (except ceiling supply and return plenums), scrolls, blades or vanes, shafts, baffles, dampers, and drive assemblies.

- 3. Air-handling unit internal surfaces and components including mixing box, coil section, air wash systems, spray eliminators, condensate drain pans, filters and filter sections, and condensate collectors and drains.
- 4. Coils and related components.
- 5. Return-air ducts, dampers, actuators, and turning vanes except in ceiling plenums and mechanical equipment rooms.
- 6. Supply-air ducts, dampers, actuators, and turning vanes.
- 7. Dedicated exhaust and ventilation components and makeup air systems.
- E. Mechanical Cleaning Methodology:
  - 1. Clean metal duct systems using mechanical cleaning methods that extract contaminants from within duct systems and remove contaminants from building.
  - 2. Use vacuum-collection devices that are operated continuously during cleaning. Connect vacuum device to downstream end of duct sections so areas being cleaned are under negative pressure.
  - 3. Use mechanical agitation to dislodge debris adhered to interior duct surfaces without damaging integrity of metal ducts, or duct accessories.
  - 4. Clean coils and coil drain pans according to NADCA 1992. Keep drain pan operational. Rinse coils with clean water to remove latent residues and cleaning materials; comb and straighten fins.
  - 5. Provide drainage and cleanup for wash-down procedures.
  - 6. Antimicrobial Agents and Coatings: Apply EPA-registered antimicrobial agents if fungus is present. Apply antimicrobial agents according to manufacturer's written instructions after removal of surface deposits and debris.

# 3.10 START UP

A. Air Balance: Comply with requirements in Division 23 Section "Testing, Adjusting, and Balancing for HVAC."

## 3.11 DUCT SCHEDULE

- A. Supply Ducts:
  - 1. Ducts Connected to Air Handling Units and Terminal Units:
    - a. Pressure Class: Positive 2-inch wg.
    - b. Minimum SMACNA Seal Class: A.
    - c. SMACNA Leakage Class for Rectangular: 12.
    - d. SMACNA Leakage Class for Round and Flat Oval: 12.
  - 2. Ducts Connected to Variable-Air-Volume Air-Handling Units:
    - a. Pressure Class: Positive 4-inch wg.
    - b. Minimum SMACNA Seal Class: A.
    - c. SMACNA Leakage Class for Rectangular: 3.
    - d. SMACNA Leakage Class for Round and Flat Oval: 3.
  - 3. Ducts Connected to Equipment Not Listed Above:
    - a. Pressure Class: Positive 2-inch wg.
    - b. Minimum SMACNA Seal Class: A.
    - c. SMACNA Leakage Class for Rectangular: 3.
    - d. SMACNA Leakage Class for Round and Flat Oval: 3.
- B. Return Ducts:
  - 1. Ducts Connected to Air-Handling Units:
    - a. Pressure Class: Positive or negative 3-inch wg.
    - b. Minimum SMACNA Seal Class: A.
    - c. SMACNA Leakage Class for Rectangular: 6.
    - d. SMACNA Leakage Class for Round and Flat Oval: 6.

- C. Exhaust Ducts:
  - 1. Ducts Connected to Fans Exhausting (ASHRAE 62.1, Class 1 and 2) Air:
    - a. Pressure Class: Negative 2-inch wg.
    - b. Minimum SMACNA Seal Class: A if negative pressure, and A if positive pressure.
    - c. SMACNA Leakage Class for Rectangular: 12.
    - d. SMACNA Leakage Class for Round and Flat Oval: 6.
- D. Intermediate Reinforcement:
  - 1. Galvanized-Steel Ducts: Galvanized steel.
- E. Elbow Configuration:
  - 1. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 4-2, "Rectangular Elbows."
    - a. Velocity 1000 fpm or Lower:
      - 1) Radius Type RE 1 with minimum 0.5 radius-to-diameter ratio.
    - b. Velocity 1000 fpm or Higher:
      - 1) Radius Type RE 3 with minimum 1.0 radius-to-diameter ratio and two vanes.
  - 2. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 4-2, "Rectangular Elbows."
    - a. Radius Type RE 3 with minimum 1.0 radius-to-diameter ratio and two vanes.
  - 3. Round Duct: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 3-4, "Round Duct Elbows."
    - a. Minimum Radius-to-Diameter Ratio and Elbow Segments: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Table 3-1, "Mitered Elbows." Elbows with less than 90-degree change of direction have proportionately fewer segments.
      - 1) Velocity 1500 fpm or Higher: 1.5 radius-to-diameter ratio and five segments for 90-degree elbow.
      - 2) Radius-to Diameter Ratio: 1.5.
    - b. Round Elbows, 12 Inches and Smaller in Diameter: Stamped or pleated.
    - c. Round Elbows, 14 Inches and Larger in Diameter: Welded.
- F. Branch Configuration:
  - 1. Rectangular Duct: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Figure 4-6, "Branch Connection."
    - a. Rectangular Main to Rectangular Branch: 45-degree entry.
    - b. Rectangular Main to Round Branch: Spin in.
  - Round and Flat Oval: Comply with SMACNA's "HVAC Duct Construction Standards -Metal and Flexible," Figure 3-5, "90 Degree Tees and Laterals," and Figure 3-6, "Conical Tees." Saddle taps are permitted in existing duct.
    - a. Velocity 1000 fpm or Lower: 90-degree tap.
    - b. Velocity 1000 to 1500 fpm: Conical tap.
    - c. Velocity 1500 fpm or Higher: 45-degree lateral.

END OF SECTION

### SECTION 23 33 00

### AIR DUCT ACCESSORIES

### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Backdraft and pressure relief dampers.
  - 2. Barometric relief dampers.
  - 3. Manual volume dampers.
  - 4. Combination fire and smoke dampers.
  - 5. Flange connectors.
  - 6. Turning vanes.
  - 7. Duct-mounted access doors.
  - 8. Flexible connectors.
  - 9. Flexible ducts.

# 1.03 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. For duct silencers, include pressure drop and dynamic insertion loss data. Include breakout noise calculations for high transmission loss casings.
- B. Shop Drawings: For duct accessories. Include plans, elevations, sections, details and attachments to other work.
  - 1. Detail duct accessories fabrication and installation in ducts and other construction. Include dimensions, weights, loads, and required clearances; and method of field assembly into duct systems and other construction. Include the following:
    - a. Special fittings.
    - b. Manual volume damper installations.
    - c. Control-damper installations.
    - d. Fire-damper, smoke-damper, combination fire- and smoke-damper, ceiling, and corridor damper installations, including sleeves; and duct-mounted access doors and remote damper operators.
    - e. Duct security bars.
    - f. Wiring Diagrams: For power, signal, and control wiring.

### 1.04 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which ceiling-mounted access panels and access doors required for access to duct accessories are shown and coordinated with each other, using input from Installers of the items involved.
- B. Source quality-control reports.

#### 1.05 CLOSEOUT SUBMITTALS

A. Operation and Maintenance Data: For air duct accessories to include in operation and maintenance manuals.

#### 1.06 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  - 1. Fusible Links: Furnish quantity equal to 10 percent of amount installed.

## PART 2 PRODUCTS

### 2.01 ASSEMBLY DESCRIPTION

- A. Comply with NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," and with NFPA 90B, "Installation of Warm Air Heating and Air Conditioning Systems."
- B. Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible" for acceptable materials, material thicknesses, and duct construction methods unless otherwise indicated. Sheet metal materials shall be free of pitting, seam marks, roller marks, stains, discolorations, and other imperfections.

### 2.02 MATERIALS

- A. Galvanized Sheet Steel: Comply with ASTM A 653/A 653M.
  - 1. Galvanized Coating Designation: G60.
  - 2. Exposed-Surface Finish: Mill phosphatized.
- B. Stainless-Steel Sheets: Comply with ASTM A 480/A 480M, Type 304, and having a No. 2 finish for concealed ducts and No. 2 finish for exposed ducts.
- C. Aluminum Sheets: Comply with ASTM B 209, Alloy 3003, Temper H14; with mill finish for concealed ducts and standard, 1-side bright finish for exposed ducts.
- D. Extruded Aluminum: Comply with ASTM B 221, Alloy 6063, Temper T6.
- E. Reinforcement Shapes and Plates: Galvanized-steel reinforcement where installed on galvanized sheet metal ducts; compatible materials for aluminum and stainless-steel ducts.
- F. Tie Rods: Galvanized steel, 1/4-inch minimum diameter for lengths 36 inches or less; 3/8-inch minimum diameter for lengths longer than 36 inches.

#### 2.03 BACKDRAFT AND PRESSURE RELIEF DAMPERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Air Balance Inc.; a division of Mestek, Inc.
  - 2. Greenheck Fan Corporation.
  - 3. Pottorff.
  - 4. Ruskin Company.
- B. Description: Gravity balanced.

- C. Maximum Air Velocity: 1000 fpm.
- D. Maximum System Pressure: 1-inch wg.
- E. Frame: Hat-shaped, 0.05-inch-thick, galvanized sheet steel, with welded corners or mechanically attached and mounting flange.
- F. Blades: Multiple single-piece blades, center pivoted, off-center pivoted, or end pivoted, maximum 6-inch width, 0.025-inch-thick, roll-formed aluminum with sealed edges.
- G. Blade Action: Parallel.
- H. Blade Seals: Felt Vinyl foam Extruded vinyl, mechanically locked or Neoprene, mechanically locked.
- I. Blade Axles:
  - 1. Material: Nonferrous metal, Galvanized steel, or Stainless steel.
  - 2. Diameter: 0.20 inch.
- J. Tie Bars and Brackets: Galvanized steel.
- K. Return Spring: Adjustable tension.
- L. Bearings: Steel ball.
- M. Accessories:
  - 1. Adjustment device to permit setting for varying differential static pressure.
  - 2. Counterweights and spring-assist kits for vertical airflow installations.
  - 3. Electric actuators.
  - 4. Chain pulls.
  - 5. Screen Mounting: Front mounted in sleeve.
    - a. Sleeve Thickness: 20 gage minimum.
    - b. Sleeve Length: 6 inches minimum.
  - 6. Screen Mounting: Rear mounted.
  - 7. Screen Material: Galvanized steel.
  - 8. Screen Type: Insect.
  - 9. 90-degree stops.

### 2.04 BAROMETRIC RELIEF DAMPERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Air Balance Inc.; a division of Mestek, Inc.
  - 2. American Warming and Ventilating; a division of Mestek, Inc.
  - 3. Greenheck Fan Corporation.
  - 4. Pottorff.
  - 5. Ruskin Company.
- B. Suitable for horizontal or vertical mounting.
- C. Maximum Air Velocity: 1000 fpm.
- D. Maximum System Pressure: 2-inch wg.

- E. Frame: Hat-shaped, 0.05-inch-thick, galvanized sheet steel, with welded corners or mechanically attached.
- F. Blades:
  - 1. Multiple, 0.025-inch-thick, roll-formed aluminum.
  - 2. Maximum Width: 6 inches.
  - 3. Action: Parallel.
  - 4. Balance: Gravity.
  - 5. Eccentrically pivoted.
- G. Blade Seals: Vinyl.
- H. Blade Axles: Galvanized steel.
- I. Tie Bars and Brackets:
  - 1. Material: Aluminum.
  - 2. Rattle free with 90-degree stop.
- J. Return Spring: Adjustable tension.
- K. Bearings: Synthetic.
- L. Accessories:
  - 1. Flange on intake.
  - 2. Adjustment device to permit setting for varying differential static pressures.

## 2.05 MANUAL VOLUME DAMPERS

- A. Standard, Steel, Manual Volume Dampers:
  - 1. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
    - a. Air Balance Inc.; a division of Mestek, Inc.
    - b. Flexmaster U.S.A., Inc.
    - c. Nailor Industries Inc.
    - d. Pottorff.
    - e. Ruskin Company.
  - 2. Standard leakage rating.
  - 3. Suitable for horizontal or vertical applications.
  - 4. Frames:
    - a. Frame: Hat-shaped, 0.094-inch-thick, galvanized sheet steel.
    - b. Mitered and welded corners.
    - c. Flanges for attaching to walls and flangeless frames for installing in ducts.
  - 5. Blades:
    - a. Multiple or single blade.
    - b. Parallel- or opposed-blade design.
    - c. Stiffen damper blades for stability.
    - d. Galvanized-steel, 0.064 inch thick.
  - 6. Blade Axles: Galvanized steel.
  - 7. Bearings:
    - a. Oil-impregnated bronze.
    - b. Dampers in ducts with pressure classes of 3-inch wg or less shall have axles full length of damper blades and bearings at both ends of operating shaft.
  - 8. Tie Bars and Brackets: Galvanized steel.

## 2.06 COMBINATION FIRE AND SMOKE DAMPERS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Greenheck Fan Corporation.
  - 2. Pottorff.
  - 3. Ruskin Company.
- B. Type: Dynamic; rated and labeled according to UL 555 and UL 555S by an NRTL.
- C. Closing rating in ducts up to 4-inch wg static pressure class and minimum 2000-fpm velocity.
- D. Fire Rating: 1-1/2 and 3 hours.
- E. Frame: Hat-shaped, 0.094-inch-thick, galvanized sheet steel, with welded corners.
- F. Heat-Responsive Device: Resettable, 165 deg F rated, fusible links.
- G. Heat-Responsive Device: Electric resettable link and switch package, factory installed, rated.
- H. Smoke Detector: Integral, factory wired for single-point connection.
- I. Blades: Roll-formed, horizontal, interlocking, 0.063-inch-0.034-inch-thick, galvanized sheet steel.
- J. Leakage: Class I.
- K. Rated pressure and velocity to exceed design airflow conditions.
- L. Mounting Sleeve: Factory-installed, 0.039-inch-thick, galvanized sheet steel; length to suit wall or floor application.
- M. Master control panel for use in dynamic smoke-management systems.
- N. Damper Motors: Modulating action.
- O. Comply with NEMA designation, temperature rating, service factor, enclosure type, and efficiency requirements for motors specified in Section 23 05 13 "Common Motor Requirements for HVAC Equipment."
  - 1. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.
  - Controllers, Electrical Devices, and Wiring: Comply with requirements for electrical devices and connections specified in Section 23 09 00 "Instrumentation and Control for HVAC."
  - 3. Permanent-Split-Capacitor or Shaded-Pole Motors: With oil-immersed and sealed gear trains.
  - 4. Spring-Return Motors: Equip with an integral spiral-spring mechanism where indicated. Enclose entire spring mechanism in a removable housing designed for service or adjustments. Size for running torque rating of 150 in. x lbf and breakaway torque rating of 150 in. x lbf.
  - 5. Outdoor Motors and Motors in Outdoor-Air Intakes: Equip with O-ring gaskets designed to make motors weatherproof. Equip motors with internal heaters to permit normal operation at minus 40 deg F.
  - 6. Nonspring-Return Motors: For dampers larger than 25 sq. ft., size motor for running torque rating of 150 in. x lbf and breakaway torque rating of 300 in. x lbf.

- 7. Electrical Connection: 115 V, single phase, 60 Hz.
- P. Accessories:
  - 1. Auxiliary switches for signaling or position indication.

## 2.07 TURNING VANES

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Ductmate Industries, Inc.
  - 2. Duro Dyne Inc.
  - 3. METALAIRE, Inc.
- B. Manufactured Turning Vanes for Metal Ducts: Curved blades of galvanized sheet steel; support with bars perpendicular to blades set; set into vane runners suitable for duct mounting.
  - 1. Acoustic Turning Vanes: Fabricate airfoil-shaped aluminum extrusions with perforated faces and fibrous-glass fill.
- C. General Requirements: Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible"; Figures 4-3, "Vanes and Vane Runners," and 4-4, "Vane Support in Elbows."
- D. Vane Construction: Double wall.

## 2.08 DUCT-MOUNTED ACCESS DOORS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Cesco Products; a division of Mestek, Inc.
  - 2. Ductmate Industries, Inc.
  - 3. Greenheck Fan Corporation.
  - 4. Nailor Industries Inc.
  - 5. Pottorff.
- B. Duct-Mounted Access Doors: Fabricate access panels according to SMACNA's "HVAC Duct Construction Standards Metal and Flexible"; Figures 7-2, "Duct Access Doors and Panels," and 7-3, "Access Doors Round Duct."
  - 1. Door:
    - a. Double wall, rectangular.
    - b. Galvanized sheet metal with insulation fill and thickness as indicated for duct pressure class.
    - c. Vision panel.
    - d. Hinges and Latches: 1-by-1-inchbutt or piano hinge and cam latches.
    - e. Fabricate doors airtight and suitable for duct pressure class.
    - Frame: Galvanized sheet steel, with bend-over tabs and foam gaskets.
  - 3. Number of Hinges and Locks:
    - a. Access Doors Less Than 12 Inches Square: No hinges and two sash locks.
    - b. Access Doors up to 18 Inches Square: Two hinges and two sash locks.
    - c. Access Doors up to 24 by 48 Inches: Three hinges and two compression latches with outside and inside handles.
    - d. Access Doors Larger Than 24 by 48 Inches: Four hinges and two compression latches with outside and inside handles.
- C. Pressure Relief Access Door:
  - 1. Door and Frame Material: Galvanized sheet steel.
  - 2. Door: Single wall with metal thickness applicable for duct pressure class.

2.

- 3. Operation: Open outward for positive-pressure ducts and inward for negative-pressure ducts.
- 4. Factory set at 3.0- to 8.0-inch wg.
- 5. Doors close when pressures are within set-point range.
- 6. Hinge: Continuous piano.
- 7. Latches: Cam.
- 8. Seal: Neoprene or foam rubber.
- 9. Insulation Fill: 1-inch-thick, fibrous-glass or polystyrene-foam board.

#### 2.09 FLEXIBLE CONNECTORS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. Ductmate Industries, Inc.
  - 2. Duro Dyne Inc.
  - 3. Ventfabrics, Inc.
- B. Materials: Flame-retardant or noncombustible fabrics.
- C. Coatings and Adhesives: Comply with UL 181, Class 1.
- D. Metal-Edged Connectors: Factory fabricated with a fabric strip 3-1/2 inches 5-3/4 inches wide attached to two strips of 2-3/4-inch-wide, 0.028-inch-thick, galvanized sheet steel or 0.032-inch-thick aluminum sheets. Provide metal compatible with connected ducts.
- E. Indoor System, Flexible Connector Fabric: Glass fabric double coated with neoprene.
  - 1. Minimum Weight: 26 oz./sq. yd..
  - 2. Tensile Strength: 480 lbf/inch in the warp and 360 lbf/inch in the filling.
  - 3. Service Temperature: Minus 40 to plus 200 deg F.
- F. Outdoor System, Flexible Connector Fabric: Glass fabric double coated with weatherproof, synthetic rubber resistant to UV rays and ozone.
  - 1. Minimum Weight: 24 oz./sq. yd..
  - 2. Tensile Strength: 530 lbf/inch in the warp and 440 lbf/inch in the filling.
  - 3. Service Temperature: Minus 50 to plus 250 deg F.
- G. High-Temperature System, Flexible Connectors: Glass fabric coated with silicone rubber.
  - 1. Minimum Weight: 16 oz./sq. yd..
  - 2. Tensile Strength: 285 lbf/inch in the warp and 185 lbf/inch in the filling.
  - 3. Service Temperature: Minus 67 to plus 500 deg F.
- H. High-Corrosive-Environment System, Flexible Connectors: Glass fabric with chemicalresistant coating.
  - 1. Minimum Weight: 14 oz./sq. yd..
  - 2. Tensile Strength: 450 lbf/inch in the warp and 340 lbf/inch in the filling.
  - 3. Service Temperature: Minus 67 to plus 500 deg F.
- I. Thrust Limits: Combination coil spring and elastomeric insert with spring and insert in compression, and with a load stop. Include rod and angle-iron brackets for attaching to fan discharge and duct.
  - 1. Frame: Steel, fabricated for connection to threaded rods and to allow for a maximum of 30 degrees of angular rod misalignment without binding or reducing isolation efficiency.
  - 2. Outdoor Spring Diameter: Not less than 80 percent of the compressed height of the spring at rated load.
  - 3. Minimum Additional Travel: 50 percent of the required deflection at rated load.

- 4. Lateral Stiffness: More than 80 percent of rated vertical stiffness.
- 5. Overload Capacity: Support 200 percent of rated load, fully compressed, without deformation or failure.
- 6. Elastomeric Element: Molded, oil-resistant rubber or neoprene.
- 7. Coil Spring: Factory set and field adjustable for a maximum of 1/4-inch movement at start and stop.

## 2.10 FLEXIBLE DUCTS

- A. Manufacturers: Subject to compliance with requirements, available manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
  - 1. CASCO
  - 2. Flexmaster U.S.A., Inc.
  - 3. McGill AirFlow LLC.
  - 4. Ward Industries, Inc.; a division of Hart & Cooley, Inc.
- B. Insulated, Flexible Duct: UL 181, Class 1, 2-ply vinyl film supported by helically wound, spring-steel wire; fibrous-glass insulation; polyethylene vapor-barrier film.
  - 1. Pressure Rating: 10-inch wg positive and 1.0-inch wg negative.
  - 2. Maximum Air Velocity: 4000 fpm.
  - 3. Temperature Range: Minus 10 to plus 160 deg F.
  - 4. Insulation R-value: Comply with ASHRAE/IESNA 90.1.
- C. Flexible Duct Connectors:
  - 1. Clamps: Stainless-steel band with cadmium-plated hex screw to tighten band with a worm-gear action in sizes 3 through 18 inches, to suit duct size.
  - 2. Non-Clamp Connectors: Adhesive.
- 2.11 DUCT ACCESSORY HARDWARE
  - A. Instrument Test Holes: Cast iron or cast aluminum to suit duct material, including screw cap and gasket. Size to allow insertion of pitot tube and other testing instruments and of length to suit duct-insulation thickness.
  - B. Adhesives: High strength, quick setting, neoprene based, waterproof, and resistant to gasoline and grease.

# PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Install duct accessories according to applicable details in SMACNA's "HVAC Duct Construction Standards Metal and Flexible" for metal ducts and in NAIMA AH116, "Fibrous Glass Duct Construction Standards," for fibrous-glass ducts.
  - B. Install duct accessories of materials suited to duct materials; use galvanized-steel accessories in galvanized-steel and fibrous-glass ducts, stainless-steel accessories in stainless-steel ducts, and aluminum accessories in aluminum ducts.
  - C. Install backdraft dampers at inlet of exhaust fans or exhaust ducts as close as possible to exhaust fan unless otherwise indicated.
  - D. Install volume dampers at points on supply, return, and exhaust systems where branches extend from larger ducts. All manual volume dampers shall be installed in accessible

locations. If manual volume dampers are installed above hard lid ceilings, where access is not attainable, flush mounted, keyed, cable type remote damper controllers shall be provided. Where dampers are installed in ducts having duct liner, install dampers with hat channels of same depth as liner, and terminate liner with nosing at hat channel.

- 1. Install steel volume dampers in all branch ducts.
- E. Set dampers to fully open position before testing, adjusting, and balancing.
- F. Install test holes at fan inlets and outlets and elsewhere as indicated.
- G. Install fire and smoke dampers according to UL listing.
- H. Connect ducts to duct silencers with flexible duct connectors.
- I. Install duct access doors on sides of ducts to allow for inspecting, adjusting, and maintaining accessories and equipment at the following locations:
  - 1. On both sides of duct coils.
  - 2. Upstream from duct filters.
  - 3. At outdoor-air intakes and mixed-air plenums.
  - 4. At drain pans and seals.
  - 5. Downstream from manual volume dampers, control dampers, backdraft dampers, and equipment.
  - 6. Adjacent to and close enough to fire or smoke dampers, to reset or reinstall fusible links. Access doors for access to fire or smoke dampers having fusible links shall be pressure relief access doors and shall be outward operation for access doors installed upstream from dampers and inward operation for access doors installed downstream from dampers.
  - 7. At each change in direction and at maximum 50-foot spacing.
  - 8. Upstream from turning vanes.
  - 9. Upstream or downstream from duct silencers.
  - 10. Control devices requiring inspection.
  - 11. Elsewhere as indicated.
- J. Install access doors with swing against duct static pressure.
- K. Access Door Sizes:
  - 1. One-Hand or Inspection Access: 8 by 5 inches.
  - 2. Two-Hand Access: 12 by 6 inches.
  - 3. Head and Hand Access: 18 by 10 inches.
  - 4. Head and Shoulders Access: 21 by 14 inches.
  - 5. Body Access: 25 by 14 inches.
  - 6. Body plus Ladder Access: 25 by 17 inches.
- L. Label access doors according to Section 23 05 53 "Identification for HVAC Piping and Equipment" to indicate the purpose of access door.
- M. Install flexible connectors to connect ducts to equipment.
- N. For fans developing static pressures of 5-inch wg and more, cover flexible connectors with loaded vinyl sheet held in place with metal straps.
- O. Connect terminal units to supply ducts directly or with maximum 12-inch lengths of flexible duct. Do not use flexible ducts to change directions.

- P. Connect diffusers or light troffer boots to ducts directly or with maximum 60-inch lengths of flexible duct clamped or strapped in place.
- Q. Connect flexible ducts to metal ducts with adhesive.
- R. Install duct test holes where required for testing and balancing purposes.
- S. Install thrust limits at centerline of thrust, symmetrical on both sides of equipment. Attach thrust limits at centerline of thrust and adjust to a maximum of 1/4-inch movement during start and stop of fans.

# 3.02 FIELD QUALITY CONTROL

- A. Tests and Inspections:
  - 1. Operate dampers to verify full range of movement.
  - 2. Inspect locations of access doors and verify that purpose of access door can be performed.
  - 3. Operate fire, smoke, and combination fire and smoke dampers to verify full range of movement and verify that proper heat-response device is installed.
  - 4. Inspect turning vanes for proper and secure installation.
  - 5. Operate remote damper operators to verify full range of movement of operator and damper.

END OF SECTION

### SECTION 23 36 00

#### **AIR TERMINAL UNITS**

### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section Includes:
  - 1. Shutoff, single-duct air terminal units.

## 1.03 PERFORMANCE REQUIREMENTS

- A. Structural Performance: Hangers and supports and seismic restraints shall withstand the effects of gravity and seismic loads and stresses within limits and under conditions described in SMACNA's "HVAC Duct Construction Standards - Metal and Flexible" SMACNA's "Seismic Restraint Manual: Guidelines for Mechanical Systems".
  - 1. Seismic Hazard Level A: Seismic force to weight ratio, 0.48.

## 1.04 SUBMITTALS

- A. Product Data: For each type of the following products, including rated capacities, furnished specialties, sound-power ratings, and accessories.
  - 1. Air terminal units.
- B. Shop Drawings: For air terminal units. Include plans, elevations, sections, details, and attachments to other work.
  - 1. Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 2. Wiring Diagrams: For power, signal, and control wiring.
  - 3. Hangers and supports, including methods for duct and building attachment, seismic restraints, and vibration isolation.
- C. Delegated-Design Submittal:
  - 1. Materials, fabrication, assembly, and spacing of hangers and supports.
  - 2. Design Calculations: Calculations, including analysis data signed and sealed by the qualified professional engineer responsible for their preparation for selecting hangers and supports and seismic restraints.
- D. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from Installers of the items involved:
  - 1. Ceiling suspension assembly members.
  - 2. Size and location of initial access modules for acoustic tile.
  - 3. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.
- E. Field quality-control reports.

- F. Operation and Maintenance Data: For air terminal units to include in emergency, operation, and maintenance manuals. In addition to items specified in Division 01 Section "Operation and Maintenance Data," include the following:
  - 1. Instructions for resetting minimum and maximum air volumes.
  - 2. Instructions for adjusting software set points.

## 1.05 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. ASHRAE Compliance: Applicable requirements in ASHRAE 62.1, Section 5 "Systems and Equipment" and Section 7 "Construction and System Start-Up."

# PART 2 PRODUCTS

- 2.01 SHUTOFF, SINGLE-DUCT AIR TERMINAL UNITS
  - A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - B. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
    - 1. Anemostat Products; a Mestek Company.
    - 2. Krueger.
    - 3. Price Industries.
    - 4. Titus.
  - C. Configuration: Volume-damper assembly inside unit casing with control components inside a protective metal shroud.
  - D. Casing: 0.034-inch steel, single wall.
    - Casing Lining: The air terminal shall be internally lined with (1/2")(1") thick foil-faced insulation, with an aluminum laminate facing. The aluminum laminate shall face the air stream to prevent erosion and airborne fibers. The edges of the insulation shall be sealed with aluminum tape, and the insulation shall meet NFPA 90A, UL181, ASTM C665, and shall be approved for use by the California Office of Statewide Health, Planning and Development (OSHPD)..
    - 2. Air Inlet: Round stub connection or S-slip and drive connections for duct attachment.
    - 3. Air Outlet: S-slip and drive connections.
    - 4. Access: Removable panels for access to parts requiring service, adjustment, or maintenance; with airtight gasket.
    - 5. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.
  - E. Volume Damper: Galvanized steel with peripheral gasket and self-lubricating bearings.
    - 1. Maximum Damper Leakage: ARI 880 rated, 3 percent of nominal airflow at 3-inch wg inlet static pressure.
    - 2. Damper Position: Normally open.
  - F. Attenuator Section: 0.034-inch steel sheet.
    - 1. Lining: Adhesive attached, 3/4-inch-thick, polyurethane foam insulation complying with UL 181 erosion requirements, and having a maximum flame-spread index of 25 and a maximum smoke-developed index of 50, for both insulation and adhesive, when tested

according to ASTM E 84 and shall be approved for use by the California Office of Statewide Health, Planning and Development (OSHPD)..

- 2. Airstream Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.
- G. Hydronic Coils: Copper tube, with mechanically bonded aluminum fins spaced no closer than 0.1 inch, and rated for a minimum working pressure of 200 psig and a maximum entering-water temperature of 220 deg F. Include manual air vent and drain valve.
- H. Electronic Controls: Bidirectional damper operator and microprocessor-based thermostat with integral airflow transducer and room sensor. Control devices shall be compatible with temperature controls specified in Division 23 Section "Instrumentation and Control for HVAC" and shall have the following features:
  - 1. Damper Actuator: 24 V, powered closed, spring return open.
  - 2. Provide damper position feedback sensor.
  - 3. Velocity Controller: Factory calibrated and field adjustable to minimum and maximum air volumes; shall maintain constant airflow dictated by thermostat within 5 percent of set point while compensating for inlet static-pressure variations up to 4-inch wg; and shall have a multipoint velocity sensor at air inlet.
- I. Direct Digital Controls: Single-package unitary controller and actuator specified in Division 23 Section "Instrumentation and Control for HVAC."
- J. Control Sequence:
  - 1. Suitable for operation with duct pressures between 0.25- and 3.0-inch wg inlet static pressure.
  - 2. System-powered, wall-mounted thermostat.

## 2.02 HANGERS AND SUPPORTS

- A. Hanger Rods for Noncorrosive Environments: Cadmium-plated steel rods and nuts.
- B. Hanger Rods for Corrosive Environments: Electrogalvanized, all-thread rods or galvanized rods with threads painted with zinc-chromate primer after installation.
- C. Steel Cables: Galvanized steel complying with ASTM A 603.
- D. Steel Cable End Connections: Cadmium-plated steel assemblies with brackets, swivel, and bolts designed for duct hanger service; with an automatic-locking and clamping device.
- E. Air Terminal Unit Attachments: Sheet metal screws, blind rivets, or self-tapping metal screws; compatible with duct materials.
- F. Trapeze and Riser Supports: Steel shapes and plates for units with steel casings; aluminum for units with aluminum casings.

### 2.03 SEISMIC-RESTRAINT DEVICES

- A. General Requirements for Restraint Components: Rated strengths, features, and applications shall be as defined in reports by an agency acceptable to authorities having jurisdiction.
  - 1. Structural Safety Factor: Allowable strength in tension, shear, and pullout force of components shall be at least four times the maximum seismic forces to which they will be subjected.

- B. Channel Support System: Shop- or field-fabricated support assembly made of slotted steel channels rated in tension, compression, and torsion forces and with accessories for attachment to braced component at one end and to building structure at the other end. Include matching components and corrosion-resistant coating.
- C. Restraint Cables: ASTM A 492, stainless-steel cables with end connections made of cadmium-plated steel assemblies with brackets, swivel, and bolts designed for restraining cable service; with an automatic-locking and clamping device or double-cable clips.
- D. Hanger Rod Stiffener: Steel tube or steel slotted-support-system sleeve with internally bolted connections or reinforcing steel angle clamped to hanger rod.
- E. Mechanical Anchor Bolts: Drilled-in and stud-wedge or female-wedge type. Select anchor bolts with strength required for anchor and as tested according to ASTM E 488.

## 2.04 SOURCE QUALITY CONTROL

- A. Factory Tests: Test assembled air terminal units according to ARI 880.
  - 1. Label each air terminal unit with plan number, nominal airflow, maximum and minimum factory-set airflows, coil type, and ARI certification seal.

## PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Install air terminal units according to NFPA 90A, "Standard for the Installation of Air Conditioning and Ventilating Systems."
  - B. Install air terminal units level and plumb. Maintain sufficient clearance for normal service and maintenance.
  - C. Install wall-mounted thermostats.

### 3.02 HANGER AND SUPPORT INSTALLATION

- A. Comply with SMACNA's "HVAC Duct Construction Standards Metal and Flexible," Chapter 5, "Hangers and Supports."
- B. Building Attachments: Concrete inserts, powder-actuated fasteners, or structural-steel fasteners appropriate for construction materials to which hangers are being attached.
  - 1. Where practical, install concrete inserts before placing concrete.
  - 2. Install powder-actuated concrete fasteners after concrete is placed and completely cured.
  - 3. Use powder-actuated concrete fasteners for standard-weight aggregate concretes and for slabs more than 4 inches thick.
  - 4. Do not use powder-actuated concrete fasteners for lightweight-aggregate concretes and for slabs less than 4 inches thick.
  - 5. Do not use powder-actuated concrete fasteners for seismic restraints.
- C. Hangers Exposed to View: Threaded rod and angle or channel supports.
- D. Install upper attachments to structures. Select and size upper attachments with pull-out, tension, and shear capacities appropriate for supported loads and building materials where used.

### 3.03 SEISMIC-RESTRAINT-DEVICE INSTALLATION

- A. Install hangers and braces designed to support the air terminal units and to restrain against seismic forces required by applicable building codes. Comply with SMACNA's "Seismic Restraint Manual: Guidelines for Mechanical Systems."
- B. Select seismic-restraint devices with capacities adequate to carry present and future static and seismic loads.
- C. Install cables so they do not bend across edges of adjacent equipment or building structure.
- D. Install cable restraints on air terminal units that are suspended with vibration isolators.
- E. Install seismic-restraint devices using methods approved by an agency acceptable to authorities having jurisdiction.
- F. Attachment to Structure: If specific attachment is not indicated, anchor bracing and restraints to structure, to flanges of beams, to upper truss chords of bar joists, or to concrete members.
- G. Drilling for and Setting Anchors:
  - Identify position of reinforcing steel and other embedded items before drilling holes for anchors. Do not damage existing reinforcement or embedded items during drilling. Notify the Architect if reinforcing steel or other embedded items are encountered during drilling. Locate and avoid prestressed tendons, electrical and telecommunications conduit, and gas lines.
  - 2. Do not drill holes in concrete or masonry until concrete, mortar, or grout has achieved full design strength.
  - 3. Wedge Anchors: Protect threads from damage during anchor installation. Install heavyduty sleeve anchors with sleeve fully engaged in the structural element to which anchor is to be fastened.
  - 4. Set anchors to manufacturer's recommended torque, using a torque wrench.
  - 5. Install zinc-coated steel anchors for interior applications and stainless-steel anchors for applications exposed to weather.

## 3.04 CONNECTIONS

- A. Install piping adjacent to air terminal unit to allow service and maintenance.
- B. Hot-Water Piping: In addition to requirements in Division 23 Section "Hydronic Piping," connect heating coils to supply with shutoff valve, strainer, control valve, and union or flange; and to return with balancing valve and union or flange.
- C. Connect ducts to air terminal units according to Division 23 Section "Metal Ducts."
- D. Make connections to air terminal units with flexible connectors complying with requirements in Division 23 Section "Air Duct Accessories."

## 3.05 IDENTIFICATION

A. Label each air terminal unit with plan number, nominal airflow, and maximum and minimum factory-set airflows. Comply with requirements in Division 23 Section "Identification for HVAC Piping and Equipment" for equipment labels and warning signs and labels.

### 3.06 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust components, assemblies, and equipment installations, including connections.
- C. Perform tests and inspections.
  - 1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
- D. Tests and Inspections:
  - 1. After installing air terminal units and after electrical circuitry has been energized, test for compliance with requirements.
  - 2. Leak Test: After installation, fill water coils and test for leaks. Repair leaks and retest until no leaks exist.
  - 3. Operational Test: After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.
  - 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- E. Air terminal unit will be considered defective if it does not pass tests and inspections.
- F. Prepare test and inspection reports.

## 3.07 STARTUP SERVICE

- A. Perform startup service.
  - 1. Complete installation and startup checks according to manufacturer's written instructions.
  - 2. Verify that inlet duct connections are as recommended by air terminal unit manufacturer to achieve proper performance.
  - 3. Verify that controls and control enclosure are accessible.
  - 4. Verify that control connections are complete.
  - 5. Verify that nameplate and identification tag are visible.
  - 6. Verify that controls respond to inputs as specified.

## 3.08 DEMONSTRATION

A. Train Owner's maintenance personnel to adjust, operate, and maintain air terminal units.

END OF SECTION

### SECTION 23 37 13

## DIFFUSERS, REGISTERS, AND GRILLES

### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. Section Includes:
  - 1. Modular core supply grilles.
  - 2. Fixed face registers and grilles.
- B. Related Sections:
  - 1. Division 08 Section "Louvers and Vents" for fixed and adjustable louvers and wall vents, whether or not they are connected to ducts.
  - 2. Division 23 Section "Air Duct Accessories" for fire and smoke dampers and volumecontrol dampers not integral to diffusers, registers, and grilles.

## 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated, include the following:
  - 1. Data Sheet: Indicate materials of construction, finish, and mounting details; and performance data including throw and drop, static-pressure drop, and noise ratings.
  - 2. Diffuser, Register, and Grille Schedule: Indicate drawing designation, room location, quantity, model number, size, and accessories furnished.
- B. Coordination Drawings: Reflected ceiling plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from Installers of the items involved:
  - 1. Ceiling suspension assembly members.
  - 2. Method of attaching hangers to building structure.
  - 3. Size and location of initial access modules for acoustical tile.
  - 4. Ceiling-mounted items including lighting fixtures, diffusers, grilles, speakers, sprinklers, access panels, and special moldings.
  - 5. Duct access panels.
- C. Source quality-control reports.

### PART 2 PRODUCTS

- 2.01 CEILING DIFFUSERS
  - A. Modular Core Supply Grilles:
    - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 2. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on drawings or a comparable product by one of the following:
      - a. Anemostat Products; a Mestek company.
      - b. Nailor Industries.

- c. Krueger.
- d. Price Industries.
- e. Titus.
- 3. Throw: Extended distance for airflow rates.
- 4. Material: Steel.
- 5. Grilles per Unit: Four.
- 6. Finish: White baked acrylic.
- 7. Border: 1-1/2-inch width with countersunk screw holes. And 24x24 filler panel.
- 8. Blades:
  - a. Set in modules.
- 9. Modules: Removable; rotatable.
- 10. Mounting: Surface and lay-in tee bar with filler panel.
- 11. Accessory: Opposed-blade steel damper.

## 2.02 REGISTERS AND GRILLES

- A. Fixed Face Register:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 2. Basis-of-Design Product: Subject to compliance with requirements, provide the product indicated on drawings or a comparable product by one of the following:
    - a. Anemostat Products; a Mestek company.
    - b. Nailor Industries
    - c. Krueger.
    - d. Price Industries.
    - e. Titus.
  - 3. Material: Steel or Aluminum.
  - 4. Finish: Baked enamel, white.
  - 5. Face Blade Arrangement: Horizontal spaced 3/4 inch apart.
  - 6. Core Construction: Integral.
  - 7. Frame: 1 inch wide.
  - 8. Mounting: Countersunk screw.
  - 9. Damper Type: Adjustable opposed blade.

### 2.03 SOURCE QUALITY CONTROL

A. Verification of Performance: Rate diffusers, registers, and grilles according to ASHRAE 70, "Method of Testing for Rating the Performance of Air Outlets and Inlets."

## PART 3 EXECUTION

### 3.01 EXAMINATION

- A. Examine areas where diffusers, registers, and grilles are to be installed for compliance with requirements for installation tolerances and other conditions affecting performance of equipment.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 INSTALLATION

A. Install diffusers, registers, and grilles level and plumb.

- B. Ceiling-Mounted Outlets and Inlets: Drawings indicate general arrangement of ducts, fittings, and accessories. Air outlet and inlet locations have been indicated to achieve design requirements for air volume, noise criteria, airflow pattern, throw, and pressure drop. Make final locations where indicated, as much as practical. For units installed in lay-in ceiling panels, locate units in the center of panel. Where architectural features or other items conflict with installation, notify Architect for a determination of final location.
- C. Install diffusers, registers, and grilles with airtight connections to ducts and to allow service and maintenance of dampers, air extractors, and fire dampers.

## 3.03 ADJUSTING

A. After installation, adjust diffusers, registers, and grilles to air patterns indicated, or as directed, before starting air balancing.

END OF SECTION

### **SECTION 234133**

### HIGH-EFFICIENCY PARTICULATE FILTRATION

## PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

## 1.02 SUMMARY

- A. Section Includes:
  - 1. HEPA filter fan modules.

### 1.03 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include dimensions; operating characteristics; required clearances and access; rated flow capacity, including initial and final pressure drop at rated airflow; efficiency and test method; fire classification; furnished specialties; and accessories for each model indicated.
- B. Shop Drawings: For air filters. Include plans, elevations, sections, details, and attachments to other work.
  - 1. Show assembly, dimensions, materials, and methods of assembly of components.
  - 2. Include setting drawings, templates, and requirements for installing anchor bolts and anchorages.
  - 3. Include diagrams for power, signal, and control wiring.

### 1.04 INFORMATIONAL SUBMITTALS

A. Field quality-control reports.

### 1.05 CLOSEOUT SUBMITTALS

A. Operation and Maintenance Data: For each type of filter and rack to include in emergency, operation, and maintenance manuals.

## PART 2 PRODUCTS

### 2.01 PERFORMANCE REQUIREMENTS

- A. ASHRAE Compliance:
  - 1. Finish of Interior Surfaces: Surfaces in contact with the airstream shall comply with requirements in ASHRAE 62.1.

- B. Comply with IEST-RP-CC001.5.
- C. Comply with UL 586.
- D. Comply with IEST-RP-CC007.2.
- E. Comply with NFPA 90A and NFPA 90B.
- F. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended use.

## 2.02 HEPA FILTER FAN MODULES

- A. Description: Factory-fabricated, HEPA filter ceiling module with fan.
  - 1. Envirco
  - 2. AAF International
  - 3. Camfil Farr
- B. Casing:
  - 1. Configuration: Ducted inlet.
  - 2. Module Material: Extruded aluminum, 16 gage with mill finish.

## C. Features:

- a. Universal Control Card
- b. Network Speed Control, MODBUS RTU
- c. Manual Speed Control, On-Board Potentiometer
- d. Analog Speed Control, Remote 0-10V
- e. Electronically Commutated (EC) brushless motor with internal microprocessor
- f. High Efficiency Particulate Air (HEPA) Filter: 99.99% efficient @ 0.3 micron
- g. 1.0 in. wg (200 Pa) of external static capability
- h. Backward-inclined centrifugal fan
- i. Walkable plenum (excluding prefilter), rated to 250 lbs.
- j. Washable pre-filter
- k. Manufactured to IEST recommended practices
- I. Available in 2x2, 2x3, 2x4 and 4x4 sizes
- m. cUL listed (115V, 208-240V, 277V) with standard UL 900 filter, file number E152685 (UL507).
- n. Mill finished aluminum exterior
- o. Room-side Replaceable Filter and Motor Assembly (RSRE)
- p. Infrared Speed Control: Room-side airflow adjustment with a hand-held remote control
- q. Ducted Inlet Connection (shipped loose).
- r. Direct connection to air conditioning supply
- s. Stainless steel housing
- t. 3/4" Knife Edge: Permits easy placement in gel track ceiling grid system (available on RSR and RSRE units only)
- 2. Electrical Characteristics:

a. See equipment schedule on drawings

# 2.03 CAPACITIES AND CHARACTERISTICS

A. See equipment schedule on drawings.

# PART 3 EXECUTION

## 3.01 INSTALLATION

- A. Equipment Mounting:
  - 1. Comply with requirements for vibration isolation and seismic-control devices specified in Section 230548 "Vibration and Seismic Controls for HVAC."
  - 2. Comply with requirements for vibration isolation devices specified in Section 230548.13 "Vibration Controls for HVAC."
- B. Position each filter unit with clearance for normal service and maintenance. Anchor filter holding frames to substrate.
- C. Install filters in position to prevent passage of unfiltered air.
- D. Install filter gage for each filter bank.
- E. Do not operate fan system until filters (temporary or permanent) are in place. Replace temporary filters that were used during construction and testing with new, clean filters.
- F. Install filter-gage static-pressure tips upstream and downstream from filters. Install filter gages on filter banks with separate static-pressure taps upstream and downstream from filters. Mount filter gages on outside of filter housing or filter plenum in an accessible position. Adjust and level inclined gages.
- G. Coordinate filter installations with duct and air-handling unit installations.

## 3.02 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect components, assemblies, and equipment installations, including connections.
- C. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
  - 1. Test for leakage of unfiltered air while system is operating.

- D. Air filter will be considered defective if it does not pass tests and inspections.
- E. Prepare test and inspection reports.

## 3.03 CLEANING

A. After completing system installation and testing, adjusting, and balancing air-handling and airdistribution systems, clean filter housings and install new filter media.

# 3.04 PROTECTION

A. Protect installed products and accessories from damage during construction.

END OF SECTION

#### SECTION 26 00 10

#### ELECTRICAL GENERAL PROVISIONS

### PART 1 GENERAL

### 1.01 SCOPE

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete, as shown on the drawings and/or specified herein. Work includes, but is not necessarily limited to, the following:
  - 1. Examine all other sections for work related to those other sections and required to be included as work under this section.
  - 2. General provisions and requirements for electrical work.
- B. Organization of the specifications into divisions, sections and articles, and arrangement of drawings shall not control the CONTRACTOR in dividing the contract work among subcontractors or in establishing the extent of work to be performed by any trade.

#### 1.02 GENERAL SUMMARY OF ELECTRICAL WORK

- A. The specifications and drawings are intended to cover a complete installation of systems. The omission of expressed reference to any item of labor or material for the proper execution of the work in accordance with present practice of the trade shall not relieve the CONTRACTOR from providing such additional labor and materials.
- B. Refer to the drawings and shop drawings of other trades for additional details, which affect the proper installation of this work. Diagrams and symbols showing electrical connections are diagrammatic only. Wiring diagrams do not necessarily show the exact physical arrangement of the equipment.
- C. Before submitting a bid, the CONTRACTOR shall become familiar with all features of the building drawings and site drawings, which may affect the execution of the work. No extra payment will be allowed for failure to obtain this information.
- D. If there are omissions or conflicts between the drawings and specifications, clarify these points with the OWNER'S REPRESENTATIVE before submitting bid.
- E. Provide work and material in conformance with the manufacturer's published recommendations for respective equipment and systems.

### 1.03 LOCATIONS OF EQUIPMENT

- A. The drawings indicate diagrammatically the desired locations or arrangements of conduit runs, outlets, equipment, etc., and are to be followed as closely as possible. Proper judgment must be exercised in executing the work so as to secure the best possible installation in the available space and to overcome local difficulties due to space limitations or interference of structure conditions encountered.
- B. Where outlets are placed on a wall, locate symmetrically with respect to each other and other features or finishes on the wall.

- C. In the event changes in the indicated locations or arrangements are necessary, due to developed conditions in the building construction or rearrangement of furnishings or equipment, such changes made without cost, providing the change is ordered before the conduit runs, etc., and work directly connected to same is installed and no extra materials are required.
- D. Lighting fixtures in mechanical spaces are shown in their approximate location only. Do not install light outlets or fixtures until mechanical piping and ductwork is installed; then install lights in a location to provide best lighting.
- E. Coordinate and cooperate in every way with other trades in order to avoid interference and assure a satisfactory job.
- F. The location of the existing utilities, building, equipment and conduit shown on the drawings is approximate. Verify exact locations and routing of existing systems by potholing all trench routes prior to digging the trench. Pothole at least 100 feet ahead of the actual trenching to allow space to alter the new conduit routing to accommodate existing conditions.
- G. Underground detection services existing utility structures
  - 1. Services shall be provided utilizing the latest detection equipment available. Services shall be performed by a company regularly engaged in the business of existing Underground Utility Structure Detection for the past five years.
  - 2. Prior to excavation the following work shall be performed:
    - a. Contractor to mark trenching locations and indicate width and depth.
    - b. Locate, by way of vertical and horizontal control dimensions, existing subgrade petroleum product pipes, process piping, conduits, sewer, water, gas, storm drain, electrical, telephone and irrigation lines in the affected areas of contract construction work.
    - c. Arrange and meet with the OWNER'S Representative to review existing underground conditions.
    - d. The proposed route of each excavation shall be continuously surveyed along the entire excavation path using ground-penetrating radar (GPR) operating from the surface grade. The GPR shall detect and map existing underground metal and non-metal private and public utility lines, pipes, conduits, conductors, etc. The GPR shall identify the horizontal and vertical location of existing underground conditions located at a depth of up to 3 meters below finish grade and located with a vertical and horizontal accuracy within ± 12" of actual condition.
  - 3. Exercise extreme caution in excavating and trenching on this site to avoid existing underground utilities, and to prevent hazard to personnel and/or damage to existing underground utilities or structures. These drawings and specifications do not include necessary components for construction safety, which is the responsibility of the CONTRACTOR.
  - 4. Repair/replace, without additional cost to the contract, and to the satisfaction of the OWNER any existing work damaged that was identified in the record drawings provided; Identified by the Owner's Representative; Identified by the Underground Detection Services performed; or any existing work damaged as a result of failure to comply with all the referenced requirements.
  - 5. The CONTRACTOR shall contact Underground Service Alert (USA) of Southern California, at least 48 hours prior to excavation, and shall not excavate until verification has been received from the USA and that public utilities serving the site have been located and marked.
- H. The locations of existing underground utilities, where shown on drawings, are shown diagrammatically and have not been independently verified by the OWNER, the OWNER'S REPRESENTATIVE. The OWNER, the OWNER'S REPRESENTATIVE, and the OWNER's
Consulting ENGINEER'S are not responsible for the location of underground utilities or structures, whether or not shown or detailed and installed under this or any other contracts. The CONTRACTOR shall identify each existing utility line prior to excavation and mark the locations on the ground of each existing utility line.

### 1.04 AIR CONDITIONING, HEATING, PLUMBING EQUIPMENT WIRING

A. Provide electrical work, materials, and control components required for proper operation of the air conditioning, heating and plumbing systems as indicated on the electrical, mechanical, and plumbing Contract Documents and specified herein.

### 1.05 POWER SERVICES

A. Within 30 calendar days of receipt of notice that the contract award has been made, the CONTRACTOR shall notify the New Business Departments of the District Office of the serving utility companies concerning the project contract and shall provide information as to the total lighting and power requirements of the contract. The CONTRACTOR shall furnish at the same time information as to the estimated completion date of job or the date when the respective utility company circuits, will be ready for installation, energizing and activation of the respective services.

### 1.06 PERMITS

A. Take out and pay for all required permits, inspections and examinations without additional cost to the OWNER.

## 1.07 QUALITY ASSURANCE

- A. Work and materials shall be in full accordance with the latest rules and regulations as follows. The following publications shall be included in the contract documents requirements. If a conflict occurs between the following publications and any other part of the contract documents, the requirements describing the more restrictive provisions shall become the applicable contract definition:
  - 1. California Code of Regulations Title 24.
  - 2. California Part 3 "California Electrical Code" CEC, Title 24 and Title 8 "Division of Industrial Safety".
  - 3. California Electrical Code-CEC.
  - 4. The National Life Safety Code.
  - 5. The Uniform Building Code-UBC.
  - 6. National Fire Protection Agency-NFPA.
  - 7. Underwriter's Laboratory-U.L.
  - 8. Other applicable State and Local Government Agencies laws and regulations.
  - 9. National Electrical Installation Standards
  - 10. ational Electrical Contractors Association (NECA) and National Electrical Installation Standards (NEIS):
    - a. NECA/NEIS-1: Standard of Practices for Good Workmanship in Electrical Contracting
    - b. NECA/NEIS-101: Standard for Installing Steel Conduit (Rigid, IMC, etc.)
    - c. NECA/NEIS-400: Recommended Practice for Installing and Maintaining Switchboards
    - d. NECA/NEIS-402: Recommended Practice for Installing and Maintaining Motor Control Centers
    - e. NEIS/NECA Recommended Practice for & EGSA-404: Installing Generator Sets
    - f. NEIS/NECA Recommended Practice for

& IESNA-500: Installing Indoor Commercial Lighting Systems

- g. NEIS/NECARecommended Practice for
  - & IESNA-501: Installing Exterior Lighting Systems
- h. NEIS & IESNA-502 Recommended Practice for Installing Industrial Lighting Systems
- B. All material and equipment shall be new and shall be delivered to the site in unbroken packages. All material and equipment shall be listed and labeled by Underwriters Laboratories or other recognized testing laboratories, where such listings are available. Comply with all installation requirements and restrictions pertaining to such listings.
- C. Work and material shown on the drawings and in the specifications is new and included in the contract unless specifically indicated as existing or N.I.C. (not in contract).
- D. Keep a copy of all applicable codes available at the job site at all times while performing work under this section. Nothing in plans or specifications shall be construed to permit work not conforming to the most stringent of codes.
- E. Where a conflict or variation occurs between applicable Codes, the provisions of the most restrictive code shall be the requirement of the Contract Documents. Where a conflict or variation occurs between applicable Codes and the Contract Documents, the requirements of the most restrictive provision(s) shall be the requirement of the Contract Document.

## 1.08 SUBMITTALS

- A. General
  - Review of CONTRACTOR'S submittals is for general conformance with the design concept of the project and general compliance with the information given in the contract documents. Any action shown is subject to the requirements of the plans and specifications. CONTRACTOR is responsible for quantities; dimensions which shall be confirmed and correlated at the job site; fabrication processes and techniques of construction; coordination of work with that of all other trades and satisfactory performance of their work.
  - 2. The CONTRACTOR shall review each submittal in detail for compliance with the requirements of the contract documents prior to submittal. The CONTRACTOR shall "Ink Stamp" and sign each item of the submittal with a statement "CERTIFYING THE SUBMITTAL HAS BEEN REVIEWED BY THE CONTRACTOR AND COMPLIES WITH ALL THE REQUIREMENTS OF THE CONTRACT DOCUMENTS". The CONTRACTOR shall clearly and specifically identify each individual proposed substitution or proposed deviation from the requirements of the contract documents with a statement "THIS ITEM IS A SUBSTITUTION".
  - 3. Departure from the submittal procedure will result in resubmittals and delays. Failure of the CONTRACTOR to comply with the submittal requirements shall render void any acceptance or any approval of the proposed variation. The CONTRACTOR shall then be required to provide the equipment or method without variation from the contract documents and without additional cost to the contract.
  - 4. The CONTRACTOR at no additional cost or delays to the contract shall remove any work, material and correct any deficiencies resulting from deviations from the requirements of the contract documents not approved in advance by the OWNER prior to commencement of work.
  - 5. Shop drawings submitted by the CONTRACTOR, which are not specifically required for submittal by the Contract Documents, or CONTRACTOR shop drawings previously reviewed and resubmitted without a written resubmittal request to the CONTRACTOR, will not be reviewed, considered, or commented on. The respective shop drawing submittal/resubmittal will not be returned to the CONTRACTOR and will be destroyed

without comment or response to the CONTRACTOR. The respective submittal shall be considered null and void as being not in compliance with the requirements of the Contract Documents.

- B. Material Lists and Shop Drawings:
  - 1. Submit material list and equipment manufacturers for review within 35 days of award of contract. Give name of manufacturer and where applicable, brand name, type and/or catalog number of each item. Listing of more than one manufacturer for any one item of equipment, or listing items "as specified", without both make and model or type designation, is not acceptable. Shop drawings shall not be submitted before review completion of manufacturers list. The right is reserved to require submission of samples of any material whether or not particularly mentioned herein.
  - 2. After completion of review of the material and equipment manufacturers list, submit shop drawings for review. Shop drawings shall be submitted in completed bound groups of materials (i.e., all lighting fixtures or all switchgear, etc.). The CONTRACTOR shall verify dimensions of equipment and be satisfied as to fit and that they comply with all code requirements relating to clear working space about electrical equipment prior to submitting shop drawings for review. Submittals, which are intended to be reviewed as substitution or departure from the contract documents, must be specifically noted as such or the requirements of the contract documents will prevail regardless of the acceptance of the submittal.
  - 3. Shop drawings shall include catalog data sheets, instruction manuals, dimensioned plans, elevations, details, wiring diagrams and descriptive literature of component parts where applicable. Structural calculations and mounting details, signed by a Structural ENGINEER registered by the State of California, shall be submitted for all equipment weighing over four hundred pounds, and shall be in compliance with Title 21 of the California Code of Regulations.
  - 4. Each shop drawing item shall be identified with the specification section and paragraph numbers, lighting fixture types and drawing sheet numbers; the specific shop drawing is intended to represent. Shop drawings 11" x 17" or smaller in size shall be bound in 3-ring binders. Divider tabs shall be provided in the 3-ring binders identifying and separating each separate shop drawing submittal item. Shop drawings larger than 11" x 17", shop drawing pages/sheets submittals shall be sequentially numbered with unique alphanumeric numbering system to facilitate correspondence referencing identification of individual sheets.
  - 5. The time required to review and comment on the CONTRACTOR'S submittals will not be less than 14 calendar days, [or more than 21 calendar days] after receipt of the submittals at the office of Donn C. Gilmore & Associates. The review of CONTRACTOR submittals and return to CONTRACTOR of submittals with review comments will occur in a timely manner conditioned upon the CONTRACTOR complying with all of the following:
    - a. The submittals contain complete and accurate information, complying with the requirements of the Contract Documents.
    - b. CONTRACTOR'S submittals are each marked with CONTRACTOR'S approval "stamp", and with CONTRACTOR signatures.
    - c. The submittals are received in accordance with a written, shop drawing submittal schedule for each submittal. The CONTRACTOR distributes the schedule not less than 35-day calendar days in advance of the Shop Drawing Submittals, and the schedule identifies the calendar dates, the CONTRACTOR will deliver the various submittals for review.
  - 6. Shop drawings shall include the manufacturers projected days for shipment from the factory of completed equipment, after the CONTRACTOR releases the equipment for production. It shall be the responsibility of the CONTRACTOR to insure that all material and equipment is ordered in time to provide an orderly progression of the

work. The CONTRACTOR shall notify the OWNER'S Representative of any changes in delivery, which would affect the project completion date.

- 7. Submittal Identification
  - a. Each submittal shall be dated: with submittal transmission date; sequentially numbered and titled with submittal contents identification and applicable specification/drawing references (*i.e. Submittal dated: 5/12/98 Submittal #4 Contents: Branch circuit panelboards Sheet #E5.1 and transformers Specification Section 16050 Paragraph 2.11, etc.*).
  - b. Each resubmittal shall be dated: with original submittal date and resubmittal transmission dates; sequentially numbered with original submittal number and sequential resubmittal revision number and titled with submittal contents identification and applicable specifications/drawing references (*i.e. Original Submittal Date: 5/12/98 Resubmittal Date: 10/9/98 Original Submittal #4 resubmittal Revision R2 Contents: Transformer resubmittal Specification Section 16050 Paragraph 2.11, etc.*)
- C. The CONTRACTOR shall be responsible for incidental, direct and indirect costs resulting from the CONTRACTOR'S substitution of; or changes to; the specified contract materials and work.
- D. The CONTRACTOR shall pay, upon request by the OWNER'S Representative, \$125.00 per hour for the OWNER'S Representative time involved in the review of substitution submittals and design changes resulting from the CONTRACTOR'S requested substitutions.
- E. Maintenance and Operating Manuals
  - 1. The CONTRACTOR shall furnish three copies of typewritten maintenance and operating manuals for all electrical equipment, fire alarm equipment, nurse call system equipment, etc., to the OWNER.
  - 2. Instruct OWNER'S personnel in correct operation of all equipment at completion of project. Provide the quantity and duration of instruction class as specified; but in no case less than two (2) four (4) hour duration separate instruction classes for each individual equipment group furnished as part of the contract. Instruction classes shall be presented by Manufacturer's authorized field service ENGINEER at the project site. Instruction class size shall be at the OWNER'S discretion, not less than one (1) or more than fifteen (15) students shall attend each instruction session. Submit 15-written outline copies of the proposed instruction class curriculum, 14 days prior to the class scheduled dates.
  - 3. Maintenance and operating manuals shall be bound in three-ring, hard-cover, plastic binders with table of contents. Manuals shall be delivered to the OWNER's Representative, with an itemized receipt.
- F. Portable or Detachable Parts: The CONTRACTOR shall retain in his possession, and shall be responsible for all portable and detachable parts or portions of the installation such as fuses, keys, locks, adapters, locking clips, and inserts until final completion of contract work. These parts shall then be delivered to the OWNER's Representative with an itemized receipt.
- G. Record Drawings
  - 1. Provide and maintain in good order a complete set of electrical contract "record" prints. Changes to the contract to be clearly recorded on this set of prints. At the end of the project, transfer all changes to one set of transparencies to be delivered unfolded to the OWNER'S Representative.
  - 2. The actual location and elevation of all buried lines, boxes, monuments, vaults, stubouts and other provisions for future connections shall be referenced to the building lines or other clearly established base lines and to approved bench marks. If any necessary dimensions are omitted from the record drawings, the CONTRACTOR shall, at his own

expense, do all excavation required to expose the buried work and to establish the correct locations.

3. The CONTRACTOR shall keep the "record" prints up to date and current with all work performed.

### 1.09 CLEANING EQUIPMENT, MATERIALS, PREMISES

A. All parts of the equipment shall be thoroughly cleaned of dirt, rust, cement, plaster, etc., and all cracks and corners scraped out clean. Surfaces to be painted shall be carefully cleaned of grease and oil spots and left smooth, clean and in proper condition to receive paint finish.

### 1.10 JOB CONDITIONS - PROTECTION

A. Protect all work, materials and equipment from damage from any cause whatever and provide adequate and proper storage facilities during the progress of the work. Provide for the safety and good condition of all the work until final acceptance of the work by the OWNER and replace all damaged or defective work, materials and equipment before requesting final acceptance.

### 1.11 EXCAVATION, CUTTING, BACKFILL AND PATCHING ADDITIONAL REQUIREMENTS.

- A. General
  - 1. Perform excavation, cutting, backfill, core drilling, directional boring, and patching of the construction work required for the proper installation of the electrical work.
  - 2. Patching shall be of the same material, thickness, workmanship and finish as existing and accurately match surrounding work to the satisfaction of the OWNER'S Representative.
- B. Excavation Temporary cover
  - 1. Excavations for contract work occurring in streets, vehicular drive areas, parking lots, sidewalks or any paved surface; provide temporary steel plating and shoring support for the plates, to completely cover the excavations under one or more of the following conditions:
    - a. Excavation shall not remain "open" for more than four (4) calendar days; provide temporary plating.
    - b. Excavation shall not be "open" over weekends (Saturday, Sunday) or Holidays, provide temporary plating.
  - 2. The temporary plating shall be a minimum of 0.75-inch thickness steel, but in no case shall the thickness be less than required to support AASHO-H20 traffic loading.
  - 3. Provide a minimum of two (2) [one (1)] 100% open lane(s) (10 ft. width) for vehicular traffic at all times during construction, for vehicle access to all areas.

# 1.12 IDENTIFICATION

- A. Equipment Nameplates
  - 1. Panelboards, terminal cabinets, circuit breakers, disconnect switches, starters, relays, time switches, contactors, push-button control stations, and other apparatus used for the operation or control of feeders, circuits, appliances, or equipment shall be properly identified by means of descriptive nameplates or tags permanently attached to the apparatus and wiring.
  - 2. Nameplates shall be engraved laminated phenolic. Shop drawings with dimensions and format shall be submitted before installation. Attachment to equipment shall be with escutcheon pins, rivets, self-tapping screws or machine screws. Self-adhering or adhesive backed nameplates shall not be used.

- 3. Provide black-on-white laminated plastic nameplates engraved in minimum 1/4" high letters to correspond with the designations on the drawings. Provide other or additional information on nameplates where indicated.
- B. Plates: All cover and device plates shall be furnished with engraved or etched designations under any one of the following conditions (minimum character size not less than 0.188 inch. Engraving shall indicate circuits and equipment controlled or connected):
  - 1. More than two devices under a common coverplate.
  - 2. Lock switches.
  - 3. Pilot switches.
  - 4. Switches in locations from which the equipment or circuits controlled cannot be readily seen.
  - 5. Manual motor starting switches.
  - 6. Where so indicated on the drawings.
  - 7. As required on all control circuit switches, such as heater controls, motor controls, etc.
  - 8. Receptacles other than standard 15 ampere 120 volt duplex receptacles; shall indicate circuit voltage, ampere, phase and source circuit number.
  - 9. Where outlets or switches are connected to emergency power circuit; provide panelboard and circuit number engraved on plate.
- C. For equipment and access doors or gates to equipment containing or operating on circuits of more than 240 volts nominal, provide red-on-white laminated warning signs engraved in 1/2" high letters to read: "DANGER 480 (or applicable voltage) VOLTS KEEP OUT AUTHORIZED PERSONNEL ONLY".
- D. Wire and Cable Identification
  - 1. Provide identification on individual wire and cable including signal systems, fire alarm, electrical power systems (each individual phase, neutral and ground), empty conduit pull ropes, and controls circuit.
  - 2. Permanent identification shall be provided at each termination location, splice location, pullbox, junction box and equipment enclosure.
    - a. Individual wire and cable larger than #6 AWG or 0.25 inch diameter, shall be provided with polypropylene identification tag holders, with yellow polypropylene tags interchangeable black alpha/numeric characters, character height 0.25 inch. Attach identification tags with plastic "tie" wraps, minimum of two for each tag. As manufactured by Almetek Industries-"EZTAG" series; or TECH Products "EVERLAST" series.
    - b. Individual wire and cable #6 AWG and smaller or smaller than 0.25 inch diameter, shall be provided with water and oil resistant, flexible, pressure sensitive machine embossed plastic tags that wrap a minimum of 360 degrees around the wire/cable diameter. The entire tag shall then be covered with a clear flexible waterproof plastic cover wrapped a minimum of 540 degrees around the wire/cable diameter and completely covering the identification.
    - c. Each identification tag location shall indicate the following information: circuit number, circuit phase, source termination and destination termination equipment name (or outlet number as applicable).
  - 3. Install permanent identification after installation/pulling of wire/cable is complete, to prevent loss or damage to the identification.
- E. Cardholders and cards shall be provided for circuit identification in panelboards. Cardholders shall consist of a metal frame retaining a clear plastic cover permanently attached to the inside of panel door. List of circuits shall be typewritten on card. Circuit description shall include name or number of circuit, area, and connected load.

F. Junction and pull boxes shall have covers stenciled with box number when shown on the drawings, or circuit numbers according to panel schedule. Data shall be lettered in a conspicuous manner with a color contrasting to finish.

# 1.13 TESTING

- A. The CONTRACTOR shall obtain an independent testing laboratory that will provide all instrumentation and tests on the electrical system and equipment as hereinafter described and further directed by the OWNER's Representative. The test shall be performed after the completion of all electrical systems included in the Contract Scope of Work. All tests shall be recorded and documented and submitted to the OWNER'S Representative for review.
  - 1. Test for Phase to Ground and Neutral Condition:
    - a. Open main service disconnects.
    - b. Isolate the system neutral from ground by removing the neutral disconnects link located in the service switchboard.
    - c. Close all submain disconnects.
    - d. Close all branch feeder circuit breakers.
    - e. Turn all switches to "on" position, unplug all portable equipment from outlet receptacles.
    - f. Measure the resistance of each phase to ground and phase to neutral. A properly calibrated "megger" type test instrument shall be used. The test voltage shall be a nominal 500 volts.
    - g. Record all readings after one minute duration and document into a complete report.
  - 2. Isolating Grounds: In the event that low resistance ground neutral connections are found in the system, they shall be isolated and located by testing each circuit individually as outlined above. Make proper corrections to restore the resistance values to an acceptable value.
- B. Method of obtaining ground resistance shall be in accordance with the latest edition of the James G. Biddle (Plymouth Meeting, Pennsylvania) manual published on this subject.
  - 1. Perform "fall-of-potential" 3-point tests on the main grounding electrode of system per IEEE Standard No. 81, Section 8.2.1.5. when suitable locations for test rods are not available, a low resistance dead earth or reference ground shall be utilized.
  - 2. Perform the two-point method test per IEEE Standard No. 81, Section 8.2.1.1, to determine the ground resistance between the main grounding system and all major electrical equipment frames, system neutral, and/or derived neutral points.
  - 3. Where the existing surface or subsurface conditions prevent the installation of auxiliary test "driven" ground rods (electric potential test probes), the ground test "driven" ground rods may substitute a "lazy-spike" test alternative. The test instrumentation shall be designed and approved by the test instrument manufacturer to use portable test electrodes instead of temporary "driven" test electrodes (ground rods). The portable test electrodes shall be "coiled" metal chains of flexible metalized grounding mat (lazy-spike) which may lay on the surface on existing undisturbed grade.
- C. All equipment and personnel required for testing shall be furnished by the CONTRACTOR.
- D. Ampere and voltage measurements:
  - 1. Take and record ampere and line voltage measurements under full load on all panel feeders, switchboard and switchgear feeders, motor control centers and motor circuits provided in the contract. Record measurements at the equipment tested and submit to the OWNER's Representative for review.
  - 2. Ampere voltage readings shall be:
    - a. Phase A-B, A-C and B-C.

- b. Phase A-Neutral, B-Neutral and C-Neutral.
- 3. The ampere and voltage readings shall be not less than 20 minutes duration for each test. Record and submit the measured minimum, maximum and 20 minute average for each ampere and voltage value and test location. Voltage and ampere measurements shall occur at the connected load end of each respective feeder, not at the source of supply end of each feeder.
- 4. Test equipment shall be accurate within plus or minus 1-percent.
- 5. Branch circuit devices 40 ampere or less and motor loads 10 horsepower or smaller are excluded from ampere and voltage testing requirement.
- 6. If, in the opinion of the OWNER'S Representative, the voltages and regulations are not met within acceptable limits, make arrangements with the serving utility for proper electrical service. Retest feeder line voltages, and submit to OWNER'S Representative for review, after the utility company has completed corrective actions. Reset "voltage taps" on transformers provided or modified as part of the contract work, to adjust line voltages to within acceptable values, as directed by the OWNER'S Representative.
- E. The Contractor shall complete the following work before any electrical equipment is energized:
  - 1. All equipment shall be permanently anchored.
  - 2. All bus connections shall be tightened per manufacturer's instructions and witnessed by the OWNER'S Representative.
  - 3. All ground connections shall be completed and identified. Perform and successfully complete all required megger and ground resistance tests.
  - 4. All feeders shall be connected and identified.
  - 5. The interiors of all electrical enclosures including busbars and wiring terminals shall be cleaned of all loose material and debris, paint, plaster, cleaners or other abrasive's overspray removed and equipment vacuumed clean. The OWNER'S Representative shall observe all interiors before covers are installed.
  - 6. All dry wall work and painting shall be completed within areas containing electrical equipment prior to installation of equipment.
  - 7. All doors to electrical equipment rooms shall be provided with locks in order to restrict access to energized equipment.
  - 8. Electrical rooms shall not be used as a storage rooms after power is energized.
  - 9. The electrical system coordination study shall be complete for circuit breakers, ground relays sets, and circuit relay sets, fuses; tested and calibrated accordingly.

# 1.14 POWER OUTAGES

- A. All electrical services in all occupied facilities of the contract work are to remain operational during the entire contract period. Any interruption of the electrical services for the performance of this work shall be at the convenience of the OWNER and performed only after consultation with the OWNER'S Representative. Work involving circuit outages shall be only at such a time and of such a duration as approved in writing. Work involving circuit outages for the work required to connect new equipment and disconnect existing equipment shall be performed at the convenience of the OWNER.
- B. Contract work involving outages or disruption of normal function in electrical power systems, telephone/communication systems, fire alarms, shall be performed during the following time periods. The contract work shall be phased to limit outages in the respective systems to the stated periods:
  - 1. 11:30 p.m. Friday to 11:30 p.m. Sunday of the same weekend. Work shall occur on multiple weekend periods if a single weekend is not sufficient time to complete the work.
  - 2. The contract work involving outages shall be phased in multiple work time units, to comply with the permitted outage limitations.

- C. Work involving system outages to the building fire alarm system shall be performed only after consultation with the OWNER and shall be only at such a time and of such duration as approved in writing.
- D. Provide overtime work; double shift work; night time work; Saturday, Sunday, and holiday work to meet outages schedule.
- E. Provide temporary electrical power to meet the requirements of this Article.
- F. Any added costs to CONTRACTOR due to necessity of complying with this Article shall be included in the Contract Scope of Work.
- G. When electrical work involving power disruptions to existing areas is initiated, the work shall proceed on a continuous basis without stopping until electric power is restored to the affected areas.
- H. The CONTRACTOR shall request in writing to the OWNER'S Representative a minimum of three weeks in advance, for any proposed electrical outage.
- 1.15 ASBESTOS, POLYCHLORINATED BIPHENYL (PCB) OR HAZARDOUS WASTE
  - A. It is understood and agreed that this contract does not contemplate the handling of asbestos, PCB or any hazardous waste material. If asbestos, PCB or any hazardous waste material is encountered, notify the OWNER'S Representative immediately. Do not disturb, handle or attempt to remove.
- 1.16 SERIES RATED EQUIPMENT
  - A. Circuit protective Devices identified as "Series Rated" or "Current Limiting" (i.e. CLCB current limiting circuit breaker; CLF current limiting fuse, etc.) shall be series rated and tested (UL 489 & CSA5) by the manufacturer with all equipment and circuit protective devices installed down stream of the identified series rated or current limiting device. Provide nameplates on all equipment located down stream, including the CLCB and CLF devices, to comply with N.E.C. paragraphs 110-22 and 240-83 "CAUTION SERIES RATED SYSTEM NEW DEVICE INSTALLATIONS AND REPLACEMENTS SHALL BE THE SAME MANUFACTURER AND MODELS".
- 1.17 INDEPENDENT TESTING LABORATORY
  - A. The Testing Laboratory shall meet Federal OSHA criteria for accreditation of Testing Laboratories Title 29 Part 1907.
  - B. Membership in the National Electrical Testing Association shall constitute proof of meeting said criteria, for testing of electrical systems.

### 1.19 EQUIPMENT SEISMIC REQUIREMENTS

- A. Equipment supports and anchorage's provided as part of the contract shall be designed, constructed and installed in accordance with the earthquake regulations of the California Code, Title 24, Section 2312, and the Uniform Building Code (UBC).
- B. Mounting recommendations shall be provided by the manufacturer based upon approved shake table tests used to verify the seismic design of that type of equipment.

- C. The equipment manufacturer shall certify that the equipment can withstand, and function following the seismic event, including both vertical and lateral required response spectra as specified in California Title 24 and the UBC. Alternatively, the manufacturer's certification may be based on an approved detailed structural analysis of the assembly, as specified in California Title 24 and the UBC.
- D. The equipment manufacturer shall document the details necessary for proper seismic mounting, anchorage, and bracing of the equipment for back installation location.
- E. Seismic qualification shall be considered achieved when the capability of the provided equipment, as described by the test response spectra, meets or exceeds the required response spectra as specified in California Title 24 and the UBC, for all equipment natural frequencies up to 35 HZ.
- F. The seismic requirements are typical for each equipment item exceeding 100 pounds, including but not limited to the following:
  - 1. Panels
  - 2. Conduits with ceiling or wall support suspension attachments.
  - 3. Lighting equipment

# 1.20 ELECTRICAL WORK CLOSEOUT

- A. Prepare the following items and submit to the OWNER'S REPRESENTATIVE before final acceptance.
  - 1. Two copies of all test results as required under this section.
  - 2. Two copies of local and/or state code enforcing authorities final inspection certificates.
  - 3. Copies of record drawings as required under the General Conditions, pertinent Division One Sections and Electrical General Provisions.
  - 4. Two copies of all receipts transferring portable or detachable parts to the OWNER'S Representative when requested.
  - 5. Notify the OWNER's Representative in writing when installation is complete and that a final inspection of this work can be performed. In the event any defect or deficiencies are found during this final inspection they shall be corrected to the satisfaction of the OWNER's Representative before final acceptance can be issued.
  - 6. List of spare fuses and locations identified by equipment name and building designation.
  - 7. Prior to energizing, retighten to the proper torque, each circuit conductor lug landing, each bus bar (phases, neutral and ground) and circuit protection device threaded connections in all switchboards, switchgear, motor control centers, transformers, busways, disconnect switches, motor starters, motor terminals and panelboards, after the equipment is installed/connected and prior to energizing the equipment. The torque values shall comply with manufacturer's recommendations.

# END OF SECTION

### SECTION 26 05 00

### COMMON WORK RESULTS FOR ELECTRICAL

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Electrical equipment coordination and installation.
  - 2. Sleeves for raceways and cables.
  - 3. Sleeve seals.
  - 4. Grout.
  - 5. Common electrical installation requirements.

#### 1.03 DEFINITIONS

- A. EPDM: Ethylene-propylene-diene terpolymer rubber.
- B. NBR: Acrylonitrile-butadiene rubber.
- 1.04 SUBMITTALS
  - A. Product Data: For sleeve seals.

#### 1.05 COORDINATION

- A. Coordinate arrangement, mounting, and support of electrical equipment:
  - 1. To allow maximum possible headroom unless specific mounting heights that reduce headroom are indicated.
  - 2. To provide for ease of disconnecting the equipment with minimum interference to other installations.
  - 3. To allow right of way for piping and conduit installed at required slope.
  - 4. To connecting raceways, cables, wireways, cable trays, and busways will be clear of obstructions and of the working and access space of other equipment.
- B. Coordinate installation of required supporting devices and set sleeves in cast-in-place concrete, masonry walls, and other structural components as they are constructed.
- C. Coordinate sleeve selection and application with selection and application of firestopping specified in Division 07 Section "Penetration Firestopping.

### PART 2 PRODUCTS

- 2.01 SLEEVES FOR RACEWAYS AND CABLES
  - A. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, galvanized steel, plain ends.

- B. Cast-Iron Pipe Sleeves: Cast or fabricated "wall pipe," equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.
- C. Sleeves for Rectangular Openings: Galvanized sheet steel.
  - 1. Minimum Metal Thickness:
    - a. For sleeve cross-section rectangle perimeter less than 50 inches and no side more than 16 inches, thickness shall be 0.052 inch.
    - b. For sleeve cross-section rectangle perimeter equal to, or more than, 50 inches and 1 or more sides equal to, or more than, 16 inches, thickness shall be 0.138 inch.

# 2.02 SLEEVE SEALS

- A. Description: Modular sealing device, designed for field assembly, to fill annular space between sleeve and raceway or cable.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Advance Products & Systems, Inc.
    - b. Calpico, Inc.
    - c. Metraflex Co.
    - d. Pipeline Seal and Insulator, Inc.
  - 2. Sealing Elements: EPDM interlocking links shaped to fit surface of cable or conduit. Include type and number required for material and size of raceway or cable.
  - 3. Pressure Plates: Plastic. Include two for each sealing element.
  - 4. Connecting Bolts and Nuts: Carbon steel with corrosion-resistant coating of length required to secure pressure plates to sealing elements. Include one for each sealing element.
- 2.03 GROUT
  - A. Nonmetallic, Shrinkage-Resistant Grout: ASTM C 1107, factory-packaged, nonmetallic aggregate grout, noncorrosive, nonstaining, mixed with water to consistency suitable for application and a 30-minute working time.

# PART 3 EXECUTION

- 3.01 COMMON REQUIREMENTS FOR ELECTRICAL INSTALLATION
  - A. Comply with NECA 1.
  - B. Measure indicated mounting heights to bottom of unit for suspended items and to center of unit for wall-mounting items.
  - C. Headroom Maintenance: If mounting heights or other location criteria are not indicated, arrange and install components and equipment to provide maximum possible headroom consistent with these requirements.
  - D. Equipment: Install to facilitate service, maintenance, and repair or replacement of components of both electrical equipment and other nearby installations. Connect in such a way as to facilitate future disconnecting with minimum interference with other items in the vicinity.
  - E. Right of Way: Give to piping systems installed at a required slope.

### 3.02 SLEEVE INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Electrical penetrations occur when raceways, cables, wireways, cable trays, or busways penetrate concrete slabs, concrete or masonry walls, or fire-rated floor and wall assemblies.
- B. Concrete Slabs and Walls: Install sleeves for penetrations unless core-drilled holes or formed openings are used. Install sleeves during erection of slabs and walls.
- C. Use pipe sleeves unless penetration arrangement requires rectangular sleeved opening.
- D. Fire-Rated Assemblies: Install sleeves for penetrations of fire-rated floor and wall assemblies unless openings compatible with firestop system used are fabricated during construction of floor or wall.
- E. Cut sleeves to length for mounting flush with both surfaces of walls.
- F. Extend sleeves installed in floors 2 inches above finished floor level.
- G. Size pipe sleeves to provide 1/4-inch annular clear space between sleeve and raceway or cable, unless indicated otherwise.
- H. Seal space outside of sleeves with grout for penetrations of concrete and masonry
  - 1. Promptly pack grout solidly between sleeve and wall so no voids remain. Tool exposed surfaces smooth; protect grout while curing.
- I. Interior Penetrations of Non-Fire-Rated Walls and Floors: Seal annular space between sleeve and raceway or cable, using joint sealant appropriate for size, depth, and location of joint. Comply with requirements in Division 07 Section "Joint Sealants.".
- J. Fire-Rated-Assembly Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at raceway and cable penetrations. Install sleeves and seal raceway and cable penetration sleeves with firestop materials. Comply with requirements in Division 07 Section "Penetration Firestopping."
- K. Roof-Penetration Sleeves: Seal penetration of individual raceways and cables with flexible boot-type flashing units applied in coordination with roofing work.
- L. Aboveground, Exterior-Wall Penetrations: Seal penetrations using steel pipe sleeves and mechanical sleeve seals. Select sleeve size to allow for 1-inch annular clear space between pipe and sleeve for installing mechanical sleeve seals.
- M. Underground, Exterior-Wall Penetrations: Install cast-iron pipe sleeves. Size sleeves to allow for 1-inch annular clear space between raceway or cable and sleeve for installing mechanical sleeve seals.

### 3.03 SLEEVE-SEAL INSTALLATION

- A. Install to seal exterior wall penetrations.
- B. Use type and number of sealing elements recommended by manufacturer for raceway or cable material and size. Position raceway or cable in center of sleeve. Assemble mechanical sleeve seals and install in annular space between raceway or cable and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.

# 3.04 FIRESTOPPING

A. Apply firestopping to penetrations of fire-rated floor and wall assemblies for electrical installations to restore original fire-resistance rating of assembly. Firestopping materials and installation requirements are specified in Division 07 Section "Penetration Firestopping."

END OF SECTION

### SECTION 26 05 19

### LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Building wires and cables rated 600 V and less.
  - 2. Connectors, splices, and terminations rated 600 V and less.

### 1.03 DEFINITIONS

- A. EPDM: Ethylene-propylene-diene terpolymer rubber.
- B. NBR: Acrylonitrile-butadiene rubber.

# 1.04 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Qualification Data: For testing agency.
- C. Field quality-control test reports.

#### 1.05 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

### PART 2 PRODUCTS

## 2.01 CONDUCTORS AND CABLES

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Alcan Products Corporation; Alcan Cable Division.
  - 2. American Insulated Wire Corp.; a Leviton Company.
  - 3. General Cable Corporation.
  - 4. Senator Wire & Cable Company.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 5. Southwire Company.
- C. Copper Conductors: Comply with NEMA WC 70.
- D. Conductor Insulation: Comply with NEMA WC 70 for Types THHN-THWN and SO.

# 2.02 CONNECTORS AND SPLICES

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. AFC Cable Systems, Inc.
  - 2. Hubbell Power Systems, Inc.
  - 3. O-Z/Gedney; EGS Electrical Group LLC.
  - 4. 3M; Electrical Products Division.
  - 5. Tyco Electronics Corp.
- B. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.

# PART 3 EXECUTION

- 3.01 CONDUCTOR MATERIAL APPLICATIONS
  - A. Feeders: Copper. Solid for No. 10 AWG and smaller; stranded for No. 8 AWG and larger.
  - B. Branch Circuits: Copper. Solid for No. 10 AWG and smaller; stranded for No. 8 AWG and larger.
- 3.02 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS
  - A. Feeders Concealed in Ceilings, Walls, Partitions, and Crawlspaces: Type THHN-THWN, single conductors in raceway.
  - B. Branch Circuits Concealed in Ceilings, Walls, and Partitions: Type THHN-THWN, single conductors in raceway.

# 3.03 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors, unless otherwise indicated.
- B. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- C. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips, that will not damage cables or raceway.
- D. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.
- E. Support cables according to Division 26 Section "Hangers and Supports for Electrical Systems."

F. Identify and color-code conductors and cables according to Division 26 Section "Identification for Electrical Systems."

# 3.04 CONNECTIONS

- A. Tighten electrical connectors and terminals according to manufacturer's published torquetightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A and UL 486B.
- B. Make splices and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
  1. Use oxide inhibitor in each splice and tap conductor for aluminum conductors.
- C. Wiring at Outlets: Install conductor at each outlet, with at least 6 inches of slack.

# 3.05 FIELD QUALITY CONTROL

- A. Perform tests and inspections and prepare test reports.
- B. Tests and Inspections:
  - 1. After installing conductors and cables and before electrical circuitry has been energized, test service entrance and feeder conductors, and conductors feeding the following critical equipment and services for compliance with requirements.
  - 2. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
- C. Test Reports: Prepare a written report to record the following:
  - 1. Test procedures used.
  - 2. Test results that comply with requirements.
  - 3. Test results that do not comply with requirements and corrective action taken to achieve compliance with requirements.
- D. Remove and replace malfunctioning units and retest as specified above.

END OF SECTION

### SECTION 26 05 26

#### **GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS**

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

A. This Section includes methods and materials for grounding systems and equipment.

#### 1.03 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Field quality-control test reports.

#### 1.04 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with UL 467 for grounding and bonding materials and equipment.

### PART 2 PRODUCTS

### 2.01 CONDUCTORS

- A. Insulated Conductors: Copper wire or cable insulated for 600 V unless otherwise required by applicable Code or authorities having jurisdiction.
- B. Bare Copper Conductors:
  - 1. Solid Conductors: ASTM B 3.
  - 2. Stranded Conductors: ASTM B 8.
  - 3. Tinned Conductors: ASTM B 33.
  - 4. Bonding Cable: 28 kcmil, 14 strands of No. 17 AWG conductor, 1/4 inch in diameter.
  - 5. Bonding Conductor: No. 4 or No. 6 AWG, stranded conductor.
  - 6. Bonding Jumper: Copper tape, braided conductors, terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.
  - 7. Tinned Bonding Jumper: Tinned-copper tape, braided conductors, terminated with copper ferrules; 1-5/8 inches wide and 1/16 inch thick.

### 2.02 CONNECTORS

A. Listed and labeled by a nationally recognized testing laboratory acceptable to authorities having jurisdiction for applications in which used, and for specific types, sizes, and combinations of conductors and other items connected.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- B. Bolted Connectors for Conductors and Pipes: Copper or copper alloy, bolted pressure-type, with at least two bolts.
  - 1. Pipe Connectors: Clamp type, sized for pipe.
- C. Welded Connectors: Exothermic-welding kits of types recommended by kit manufacturer for materials being joined and installation conditions.

# PART 3 EXECUTION

- 3.01 APPLICATIONS
  - A. Conductors: Install solid conductor for No. 8 AWG and smaller, and stranded conductors for No. 6 AWG and larger, unless otherwise indicated.
  - B. Conductor Terminations and Connections:
    - 1. Pipe and Equipment Grounding Conductor Terminations: Bolted connectors.
    - 2. Underground Connections: Welded connectors, except at test wells and as otherwise indicated.
    - 3. Connections to Ground Rods at Test Wells: Bolted connectors.
    - 4. Connections to Structural Steel: Welded connectors.

### 3.02 CONDUIT GROUNDING

- A. Install insulated equipment grounding conductors with all feeders and branch circuits.
- B. Where nonmetallic conduit is used in the distribution system, the CONTRACTOR shall install the proper sized copper ground wire in the conduit with the feeder for use as an equipment ground. The electrical metallic raceway system shall be grounded to this ground wire.
- C. The maximum ground/bond resistance to the grounding electrode shall not exceed 1 ohms from any location in the electrical system. The maximum ground resistance of the grounding electrode to earth shall not exceed 5 ohms.
- D. Ground/Bond Conductors
  - 1. Provide an additional, dedicated, green insulation equipment ground/bond wire inside each conduit type as follows. The metal conduit shall not be permitted to serve (function) as the only (exclusive) electrical ground return path:
    - a. All types of nonmetallic conduit raceways including but not limited to: RNMC Rigid Nonmetallic Conduit.
    - b. FMC Flexible Metal Conduit.
    - c. LTFMC Liquid Tight Flexible Metal Conduit.
    - d. RMC Rigid Metal Conduit.
    - e. EMT Electrical Metal Tubing.
  - 2. The equipment ground/bond wire shall be continuous from the electrical circuit source point of origin to the electrical circuit end termination utilization point as follows:
    - a. Every conduit path containing any length of the above identified conduits.
    - b. Every conduit path connected to any length of the above-identified conduits.
  - 3. The equipment ground/bond wire shall be sized as follows, but in no case smaller than indicated on the drawings. Install equipment ground/bond wire in each conduit/raceway, with the respective phase conductors:

a.	Feeder, Subfeeders & Branch	Minimum Equipment
	Circuit Protection	Ground Wire Size
	15 Amp	#12
	20 Amp	#12

30 to 60 Amp	#10
70 to 100 Amp	#8
101 to 200 Amp	#6
201 to 400 Amp	#2
401 to 600 Amp	#1
801 to 1000 Amp	2/0
1001 to 1200 Amp	3/0
1201 to 1600 Amp	4/0
1601 to 2000 Amp	250 MCM
2001 to 2500 Amp	350 MCM
2501 to 4000 Amp	500 MCM

- 4. Isolated grounds Raceways containing branch circuit or feeder phase conductors connected to panelboards equipment, or receptacles with isolated grounds or isolated ground bus shall contain a dedicated insulated ground conductor connected to the isolated ground system only. The isolated ground conductor shall be continuous the length of the raceways and connected only to the isolated ground terminals in addition to and independent of the equipment bonding/ ground conductor. The isolated ground conductor shall be sized as indicated above, for equipment ground/bond wire.
- 5. Splices in ground/bond wires shall be permitted only at the following locations:
  - a. Ground buses with listed and approved ground lugs.
  - b. Where exothermic welded ground/bond wire splices are provided.
- 6. Provide ground/bond wire jumpers for conduit fittings with ground lugs, expansion and deflection conduit fittings at conduit fittings connecting between metallic and non-metallic raceways and to bond metal enclosures to conduit fittings with ground lugs.
- E. Where conductors are run in parallel in multiple raceways, the grounding conductor shall be run in parallel. Each parallel equipment-grounding conductor shall be sized on the basis of the ampere rating of the overcurrent device protecting the circuit conductors in the raceway. When conductors are adjusted in size to compensate for voltage drop, grounding conductors, where required, shall be adjusted proportionately in size.
- F. Ground conductors for branch circuit wiring shall be attached at each outlet to the back of the box using drilled and tapped holes and washer head screws, 6-32 or larger.
- G. Each panelboard, switchboard, pull box or any other enclosure in which several ground wires are terminated shall be equipped with a ground bus secured to the interior of the enclosure. The bus shall have a separate lug for each ground conductor. No more than one conductor shall be installed per lug.
- H. Provide a separate ground/bond insulated grounding electrode conductor, copper wire from the main electrical service ground bus to each of the following locations. The ground/bond conductor shall be sized to comply with applicable codes and as indicated on the drawings, but in no case smaller than the following:
  - 1. Each transformer (size as indicated and to comply with applicable codes).
  - 2. Generator 1.5 inch conduit with 1#4/0.

### 3.03 EQUIPMENT GROUNDING

- A. Install insulated equipment grounding conductors with all feeders and branch circuits.
- B. Install insulated equipment grounding conductors with the following items, in addition to those required by NFPA 70:
  - 1. Feeders and branch circuits.
  - 2. Lighting circuits.
  - 3. Receptacle circuits.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 4. Single-phase motor and appliance branch circuits.
- 5. Three-phase motor and appliance branch circuits.
- 6. Flexible raceway runs.
- 7. Armored and metal-clad cable runs.
- C. Signal and Communication Equipment: For telephone, alarm, voice and data, and other communication equipment, provide No. 4 AWG minimum insulated grounding conductor in raceway from grounding electrode system to each service location, terminal cabinet, wiring closet, and central equipment location.
  - 1. Service and Central Equipment Locations and Wiring Closets: Terminate grounding conductor on a 1/4-by-2-by-12-inch grounding bus.
  - 2. Terminal Cabinets: Terminate grounding conductor on cabinet grounding terminal.

### 3.04 INSTALLATION

- A. Grounding Conductors: Route along shortest and straightest paths possible, unless otherwise indicated or required by Code. Avoid obstructing access or placing conductors where they may be subjected to strain, impact, or damage.
- B. Bonding Straps and Jumpers: Install in locations accessible for inspection and maintenance, except where routed through short lengths of conduit.
  - 1. Bonding to Structure: Bond straps directly to basic structure, taking care not to penetrate any adjacent parts.
  - 2. Bonding to Equipment Mounted on Vibration Isolation Hangers and Supports: Install so vibration is not transmitted to rigidly mounted equipment.
  - 3. Use exothermic-welded connectors for outdoor locations, but if a disconnect-type connection is required, use a bolted clamp.
- C. Grounding and Bonding for Piping:
  - 1. Metal Water Service Pipe: Install insulated copper grounding conductors, in conduit, from building's main service equipment, or grounding bus, to main metal water service entrances to building. Connect grounding conductors to main metal water service pipes, using a bolted clamp connector or by bolting a lug-type connector to a pipe flange, using one of the lug bolts of the flange. Where a dielectric main water fitting is installed, connect grounding conductor on street side of fitting. Bond metal grounding conductor conduit or sleeve to conductor at each end.
  - 2. Water Meter Piping: Use braided-type bonding jumpers to electrically bypass water meters. Connect to pipe with a bolted connector.
  - 3. Bond each aboveground portion of gas piping system downstream from equipment shutoff valve.
- D. Bonding Interior Metal Ducts: Bond metal air ducts to equipment grounding conductors of associated fans, blowers, electric heaters, and air cleaners. Install bonding jumper to bond across flexible duct connections to achieve continuity.
- E. Grounding for Steel Building Structure: Install a driven ground rod at base of each corner column and at intermediate exterior columns at distances not more than 60 feet apart.

### 3.05 FIELD QUALITY CONTROL

- A. Perform the following tests and inspections and prepare test reports:
  - 1. After installing grounding system but before permanent electrical circuits have been energized, test for compliance with requirements.

- 2. Test completed grounding system at each location where a maximum groundresistance level is specified, at service disconnect enclosure grounding terminal, at ground test wells. Make tests at ground rods before any conductors are connected.
  - a. Measure ground resistance not less than two full days after last trace of precipitation and without soil being moistened by any means other than natural drainage or seepage and without chemical treatment or other artificial means of reducing natural ground resistance.
  - b. Perform tests by fall-of-potential method according to IEEE 81.
- B. Report measured ground resistances that exceed the following values:
  - 1. Power and Lighting Equipment or System with Capacity 500 kVA and Less: 10 ohms.
- C. Excessive Ground Resistance: If resistance to ground exceeds specified values, notify Architect promptly and include recommendations to reduce ground resistance.

END OF SECTION

### SECTION 26 05 29

#### HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Hangers and supports for electrical equipment and systems.
  - 2. Construction requirements for concrete bases.

#### 1.03 DEFINITIONS

- A. EMT: Electrical metallic tubing.
- B. IMC: Intermediate metal conduit.
- C. RMC: Rigid metal conduit.

### 1.04 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Design supports for multiple raceways, including comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- B. Design supports for multiple raceways capable of supporting combined weight of supported systems and its contents.
- C. Design equipment supports capable of supporting combined operating weight of supported equipment and connected systems and components.
- D. Rated Strength: Adequate in tension, shear, and pullout force to resist maximum loads calculated or imposed for this Project, with a minimum structural safety factor of five times the applied force.

## 1.05 SUBMITTALS

- A. Product Data: For the following:
  - 1. Steel slotted support systems.
- B. Shop Drawings: Signed and sealed by a qualified professional engineer. Show fabrication and installation details and include calculations for the following:
  - 1. Trapeze hangers. Include Product Data for components.
  - 2. Steel slotted channel systems. Include Product Data for components.
  - 3. Nonmetallic slotted channel systems. Include Product Data for components.
  - 4. Equipment supports.
- C. Welding certificates.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

### 1.06 QUALITY ASSURANCE

- A. Welding: Qualify procedures and personnel according to AWS D1.1/D1.1M, "Structural Welding Code Steel."
- B. Comply with NFPA 70.

## 1.07 COORDINATION

A. Coordinate size and location of concrete bases. Cast anchor-bolt inserts into bases. Concrete, reinforcement, and formwork requirements are specified in Division 03.

# PART 2 PRODUCTS

### 2.01 SUPPORT, ANCHORAGE, AND ATTACHMENT COMPONENTS

- A. Steel Slotted Support Systems: Comply with MFMA-4, factory-fabricated components for field assembly.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Allied Tube & Conduit.
    - b. Cooper B-Line, Inc.; a division of Cooper Industries.
    - c. ERICO International Corporation.
    - d. GS Metals Corp.
    - e. Thomas & Betts Corporation.
    - f. Unistrut; Tyco International, Ltd.
    - g. Wesanco, Inc.
  - 2. Metallic Coatings: Hot-dip galvanized after fabrication and applied according to MFMA-4.
  - 3. Nonmetallic Coatings: Manufacturer's standard PVC, polyurethane, or polyester coating applied according to MFMA-4.
  - 4. Painted Coatings: Manufacturer's standard painted coating applied according to MFMA-4.
  - 5. Channel Dimensions: Selected for applicable load criteria.
- B. Raceway and Cable Supports: As described in NECA 1 and NECA 101.
- C. Conduit and Cable Support Devices: Steel hangers, clamps, and associated fittings, designed for types and sizes of raceway or cable to be supported.
- D. Structural Steel for Fabricated Supports and Restraints: ASTM A 36/A 36M, steel plates, shapes, and bars; black and galvanized.
- E. Mounting, Anchoring, and Attachment Components: Items for fastening electrical items or their supports to building surfaces include the following:
  - 1. Powder-Actuated Fasteners: Threaded-steel stud, for use in hardened portland cement concrete, steel, or wood, with tension, shear, and pullout capacities appropriate for supported loads and building materials where used.
    - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
      - 1) Hilti Inc.
      - 2) ITW Ramset/Red Head; a division of Illinois Tool Works, Inc.
      - 3) MKT Fastening, LLC.
      - 4) Simpson Strong-Tie Co., Inc.; Masterset Fastening Systems Unit.

- 2. Mechanical-Expansion Anchors: Insert-wedge-type, zinc-coated steel, for use in hardened portland cement concrete with tension, shear, and pullout capacities appropriate for supported loads and building materials in which used.
  - a. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - 1) Cooper B-Line, Inc.; a division of Cooper Industries.
    - 2) Empire Tool and Manufacturing Co., Inc.
    - 3) Hilti Inc.
    - 4) ITW Ramset/Red Head; a division of Illinois Tool Works, Inc.
    - 5) MKT Fastening, LLC.
- 3. Concrete Inserts: Steel or malleable-iron, slotted support system units similar to MSS Type 18; complying with MFMA-4 or MSS SP-58.
- 4. Clamps for Attachment to Steel Structural Elements: MSS SP-58, type suitable for attached structural element.
- 5. Through Bolts: Structural type, hex head, and high strength. Comply with ASTM A 325.
- 6. Toggle Bolts: All-steel springhead type.
- 7. Hanger Rods: Threaded steel.

# 2.02 FABRICATED METAL EQUIPMENT SUPPORT ASSEMBLIES

- A. Description: Welded or bolted, structural-steel shapes, shop or field fabricated to fit dimensions of supported equipment.
- B. Materials: Comply with requirements in Division 05 Section "Metal Fabrications" for steel shapes and plates.

# PART 3 EXECUTION

# 3.01 APPLICATION

- A. Comply with NECA 1 and NECA 101 for application of hangers and supports for electrical equipment and systems except if requirements in this Section are stricter.
- B. Maximum Support Spacing and Minimum Hanger Rod Size for Raceway: Space supports for EMT, IMC, and RMC as required by NFPA 70. Minimum rod size shall be 1/4 inch in diameter.
- C. Multiple Raceways or Cables: Install trapeze-type supports fabricated with steel slottedsupport system, sized so capacity can be increased by at least 25 percent in future without exceeding specified design load limits.
  - 1. Secure raceways and cables to these supports with two-bolt conduit clamps.
- D. Spring-steel clamps designed for supporting single conduits without bolts may be used for 1-1/2-inch and smaller raceways serving branch circuits and communication systems above suspended ceilings and for fastening raceways to trapeze supports.

# 3.02 SUPPORT INSTALLATION

- A. Comply with NECA 1 and NECA 101 for installation requirements except as specified in this Article.
- B. Raceway Support Methods: In addition to methods described in NECA 1, EMT, IMC, and RMC may be supported by openings through structure members, as permitted in NFPA 70.

- C. Strength of Support Assemblies: Where not indicated, select sizes of components so strength will be adequate to carry present and future static loads within specified loading limits. Minimum static design load used for strength determination shall be weight of supported components plus 200 lb.
- D. Mounting and Anchorage of Surface-Mounted Equipment and Components: Anchor and fasten electrical items and their supports to building structural elements by the following methods unless otherwise indicated by code:
  - 1. To Wood: Fasten with lag screws or through bolts.
  - 2. To New Concrete: Bolt to concrete inserts.
  - 3. To Masonry: Approved toggle-type bolts on hollow masonry units and expansion anchor fasteners on solid masonry units.
  - 4. To Existing Concrete: Expansion anchor fasteners.
  - 5. Instead of expansion anchors, powder-actuated driven threaded studs provided with lock washers and nuts may be used in existing standard-weight concrete 4 inches thick or greater. Do not use for anchorage to lightweight-aggregate concrete or for slabs less than 4 inches thick.
  - 6. To Steel: Beam clamps (MSS Type 19, 21, 23, 25, or 27) complying with MSS SP-69.
  - 7. To Light Steel: Sheet metal screws.
  - 8. Items Mounted on Hollow Walls and Nonstructural Building Surfaces: Mount cabinets, panelboards, disconnect switches, control enclosures, pull and junction boxes, transformers, and other devices on slotted-channel racks attached to substrate by means that meet seismic-restraint strength and anchorage requirements.
- E. Drill holes for expansion anchors in concrete at locations and to depths that avoid reinforcing bars.

# 3.03 INSTALLATION OF FABRICATED METAL SUPPORTS

- A. Comply with installation requirements in Division 05 Section "Metal Fabrications" for sitefabricated metal supports.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor electrical materials and equipment.
- C. Field Welding: Comply with AWS D1.1/D1.1M.

# 3.04 PAINTING

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
   1. Apply paint by brush or spray to provide minimum dry film thickness of 2.0 mils.
- B. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A 780.

# END OF SECTION

### SECTION 26 05 33

### RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS

### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

A. This Section includes raceways, fittings, boxes, enclosures, wireway, and cabinets for electrical wiring.

# 1.03 DEFINITIONS

- A. RMC: Rigid metal conduit
- B. EMT: Electrical metallic tubing.
- C. FMC: Flexible metal conduit.
- D. LTFMC: Liquid Tight Flexible metal conduit.
- E. RNMC: Rigid nonmetallic conduit.

## 1.04 SCOPE

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other sections for work related to those other sections and required to be included as work under this section.
  - 2. General provisions and requirements for electrical work.

### 1.05 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For the following raceway components. Include plans, elevations, sections, details, and attachments to other work.
  - 1. Custom enclosures and cabinets.
- C. Coordination Drawings: Conduit routing plans, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:
  - 1. Structural members in the paths of conduit groups with common supports.
  - 2. HVAC and plumbing items and architectural features in the paths of conduit groups with common supports.

- D. Manufacturer Seismic Qualification Certification: Submit certification that enclosures and cabinets and their mounting provisions, including those for internal components, will withstand seismic forces defined in Division 26 Section "Vibration and Seismic Controls for Electrical Systems." Include the following:
  - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
    - a. The term "withstand" means "the cabinet or enclosure will remain in place without separation of any parts when subjected to the seismic forces specified and the unit will retain its enclosure characteristics, including its interior accessibility, after the seismic event."
  - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
  - 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- E. Qualification Data: For professional engineer and testing agency.
- F. Source quality-control test reports.
- G. Submit material list for outlet boxes, conduit and conduit fittings.
- H. Submit details and structural engineering calculations for conduit support systems.

# 1.06 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- B. Comply with NFPA 70.

# PART 2 PRODUCTS

- 2.01 METAL CONDUIT AND TUBING
  - A. General
    - 1. The interior surfaces of conduits and fittings shall be continuous and smooth, with a constant interior diameter. Conduits and conduit fittings shall provide conductor raceways of fully enclosed circular cross section. The interior surfaces of conduits and fittings shall be without ridges, burrs irregularities or obstructions. Conduits and fittings of the same type shall be of the same uniform weight and thickness.
    - 2. Type of conduit, type of conduit fittings and conduit supports shall be suitable for the conditions of use and the conditions of location of installation, based on the manufacturer's recommendations and based on applicable codes.
    - 3. All fittings for metal conduit shall be suitable for use as a grounding means, pursuant to the applicable code requirements. All metal conduit and metal conduit fittings shall provide 3 second duration ground fault current carrying ratings, when installed and connected to the respective conduit, as follows:
      - a. RMC and EMT conduit fittings.
        - 1) 0.5 inch through 1.5 inch conduit/fitting size 10,000 ampere RMS.
        - 2) 2.0 inch and larger conduit/fitting size 20,000 ampere RMS.
      - b. RMC and EMT conduit fittings.
        - 1) 0.5 inch through 1.25 inch conduit/fitting size-1,000 ampere RMS (without external bonding jumper).

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 2) 1.5 inch through 4.0 inch fitting size-10,000 ampere RMS with bonding jumper.
- 4. Protective corrosion resistant finish for metal conduit fabricated from steel and metal conduit fittings fabricated from steel, shall be as follows:
  - a. Clean all metal surfaces (including metal threads) with acid bath "pickle" prior to coating, to remove dirt, oil and prepare surfaces for galvanizing.
  - b. Hot-dip galvanized zinc coating on all interior and exterior steel surfaces. Minimum finish zinc coating thickness shall not be less than 0.002 inches.
  - c. Threads shall be hot-dip zinc coated after machine fabrication.
  - d. Exterior metal surfaces shall be finished with clear organic polymer topcoat layer, after galvanizing.
  - e. The inner metal surfaces of conduit fittings shall be finished with a lubricating topcoat after galvanizing, to facilitate conductor pulling through the conduit/fitting.
- 5. Threads for metal conduit and metal conduit fittings shall be taper-pipe-thread, National Pipe Standards(NPS) and shall comply with ANSI-B1.20.1.
- 6. Metal conduit termination connector fittings shall be provided with a manufacturer installed, insulating throat bushing inside the fitting. The bushing shall protect the wire conductor insulation from cutting, nicks and abrasion during conductor installation and electrical load "cycling" after installation is complete. The bushing shall comply with UL 94V-0 flammability.
- 7. Provide conduit bonding/grounding jumper from metal enclosures with "concentric ring" knockouts, to positively ground/bond each respective conduit(s) to the metal enclosure.
- 8. Metal conduit fittings connecting to PVC coated metal conduit shall be PVC coated to match the conduit.
- B. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Appleton
  - 2. Erickson
  - 3. O-Z Gedney; a unit of General Signal
  - 4. Thomas & Betts
- C. RMC: ANSI C80.3.
  - 1. Rigid metal, round tubing, machine threaded at both ends.
    - a. Clean all metal surfaces (including metal threads) with acid bath "pickle" prior to coating, to remove dirt, oil and prepare surfaces for galvanizing.
    - b. The conduit shall be watertight and airtight without cracks and pinholes.
  - 2. RMC raceway types shall be as follows
    - Rigid galvanized steel conduit (RGS), minimum yield strength shall be 35,000 PSI. Shall comply with NEMA standard 5-19 (latest revision); ANSI C80.1 and ANSI-C80.4 (latest revision); U.L. 514-B and UL 6 (latest revisions); National Pipe Standard Specification (latest revision).
    - b. Intermediate steel conduit (IMC). Shall comply with NEMA Standard 5-19 (latest revision) ANSI-C80.6 (latest revision); UL 2142 (latest revision).
  - 3. RMC Fittings
    - a. Fittings shall be compatible with RGS and IMC.
    - b. Fittings shall be rated "liquid tight".
    - c. Fittings imbedded in concrete shall be rated "liquid tight" and "concrete tight".
    - d. Connectors and couplings for terminating, connecting and coupling to RMC conduit shall be threaded metal.
    - e. Fittings shall comply with ANSI C80.4 and ANSI C33-84 (latest revision); NEMA FB1 (latest revision); UL 514 (latest revision).
    - f. Conduit Seal Fittings

- 1) Conduit seals shall prevent the passage of gasses, liquids and vapors past the location of the seal installation in the conduit.
- 2) Conduit seals shall be suitable for installation in both vertical and horizontal conduit locations.
- 3) Conduit seals shall be visible and accessible for inspection after installation is complete.
- 4) Conduit seals shall be rated for the following locations:
  - a) Wet locations
  - b) Classified hazardous location materials NEC Class 1 Division 1.
  - c) Temperature ranges from 0 [minus 20] degrees centigrade through 90 degrees centigrade.
- 5) Conduit seals, sealing compound and sealing compound dam shall be the products of the same manufacturer.
- 4. RMC Fittings as manufactured by:
  - a. For threaded enclosure, termination connection.
    - 1) Thomas & Betts 106 Series bonding locknut, 5302 series sealing ring with stainless steel retainer.
  - b. For non-threaded enclosure, termination connector.
    - Thomas & Betts 370 Series watertight threaded sealing hub, 106 series threaded bonding lock nut, Sta-Con Series enclosure bonding jumper and 3870 Series threaded ground bushing.
    - 2) OZ/Gedney-CHMT/CHT watertight threaded hub with bonding locknut and GH50G Series enclosure bonding jumper.
  - c. For RMC to RMC conduit-to-conduit coupling
    - 1) Erickson 674 (threaded) Series
    - 2) OZ/Gedney Type 4 (threaded) Series
    - 3) Threaded RMC conduit couplings, product of the same manufacturer as the RMC conduit.
  - d. For RMC Conduit Seals
    - 1) OZ/Gedney-EYA and EYAM (threaded) Series
    - 2) Appleton-EYF and EYM (threaded) Series
- D. EMT: ANSI C80.3.

1.

- Rigid metal round tubing, "thin wall" steel construction, with non-threaded ends.
  - a. The conduit and conduit fittings shall comply with the requirements for a equipment grounding conductor pursuant to applicable codes.
- b. The conduit shall be watertight and airtight without cracks and pinholes.
- 2. EMT shall be allowed for conduit size ranges from 0.5 inch through 4.0 inch.
- 3. Comply with ANSI C80.3, C80.4, and ANSI C33.98 (latest revisions); UL 594 and UL 797 (latest revisions); CEC Section 12500 (latest revision).
- 4. EMT Fittings

a.

- a. Connectors and couplings for terminating, connecting and coupling to EMT conduit shall be non-threaded steel fabrication.
- b. EMT termination connector fittings shall be as follows:
  - 1) Set screw type "concrete tight" when installed in dry interior locations.
  - 2) Compression types "raintight" and "concrete tight" when installed in wet or damp locations, outdoors and in concrete or masonry construction.
- c. Fittings shall comply with ANSI C33.84 (latest revision); UL 514 (latest revision); NEMA FB-1.
- 5. EMT Fittings as manufactured by:
  - For threaded and non threaded enclosure, termination connector
  - 1) Thomas & Betts-TC5031 (set screw type) Series (with locknuts).
  - 2) OZ/Gedney-4000ST (set screw type) Series.
  - 3) Thomas & Betts-5123 (compression type) Series (with 2 locknuts).
  - 4) OZ/Gedney-7000ST (compression type) Series (with locknut).

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00 RACEWAY AND BOXES FOR ELECTRICAL SYSTEMS 26 05 33 - 4

- 5) Thomas & Betts-4240 (compression type) Series (90 degree angle with locknut).
- 6) OZ/Gedney-8000WT (compression type) Series (90 degree angle with locknut).
- b. For EMT to EMT conduit-to-conduit coupling:
  - 1) Thomas & Betts-TK121 (set screw type) Series (with locknut).
  - 2) OZ/Gedney-5000 (set screw type) Series (with locknut).
  - 3) Thomas & Betts-5120 (compression type) Series
  - 4) OZ/Gedney-6000S (compression type) Series.
- c. For EMT to RMC conduit to conduit combination coupling:
  - 1) Thomas & Betts-HT221 (set screw type) Series
  - 2) OZ/Gedney-ESR (set screw type) Series.
  - 3) Thomas & Betts-530 (compression type) Series
  - 4) OZ/Gedney-ETR (compression type) Series.
- E. FMC: Zinc-coated steel.
  - 1. Round flexible conduit, fabricated from a single continuous steel strip. The steel shall be factory formed into continuous interlocking convolutions to form a complete lock between steel strips and provide raceway flexibility.
  - 2. Metal to metal grounding contact shall be maintained throughout the length of the FMC conduit.
  - 3. FMC shall be allowed for conduit size ranges from 0.5 inch through 0.75 inch.
  - 4. FMC shall comply with ANSI-C.33.84 and ANSI C33.92; NEMA FB-1; CEC 12-1100.
  - 5. FMC Fittings
    - a. FMC fittings shall be malleable iron construction or steel construction.
    - b. Fitting shall automatically cause the FMC raceway throat opening to be centered with respect to the fitting throat opening.
    - c. Straight and angled connector termination fittings shall be threaded on one end and shall include a threaded locknut, suitable for connection to threaded and unthreaded enclosures.
    - d. The attachment of the fittings to FMC shall be angled saddle type, to engage and interlock with the FMC spiral groove, and shall be unaffected by vibration. Direct bearing screw type fittings shall not be used.
    - e. Direct FMC conduit-to-FMC conduit coupling of FMC shall not be permitted.
    - f. Shall comply with ANSI C33.9, and ANSI C33.92 (latest revision); NEMA FB1 (latest revision); U.L. 514.
  - 6. FMC Fittings as manufactured by:
    - a. Straight Termination 45 & 90 Degree Connectors Angle Connectors
      - 1) Thomas & Betts-Thomas & Betts-3110 Series 3130 Series
    - b. FMC to EMT conduit combination coupling:
      - 1) Thomas & Betts 503TB Series.
- F. LTFMC:
  - 1. The metal conduit core of LTFMC shall comply with the same requirements as FMC conduit, with the addition of a thermoplastic exterior flexible jacket over the metal core.
  - 2. The exterior jacket shall be positively locked to the metal core to prevent jacket "sleeving".
  - 3. The LTFMC shall be rated for installation and operating service temperatures of between 0 [minus 20] degrees centigrade through plus 90 degrees centigrade.
  - 4. The LTFMC jacket shall be suitable for continuous exposure to sunlight, rainwater, water vapor, mineral oils and liquid solvents, without penetrating into the conduit and without deteriorating the jacket.
  - 5. LTFMC sizes from 0.5 inch through 1.25 inches shall include an additional internal ground conductor, fabricated by the manufacturer, as a integral part of the conduit core.
  - 6. Direct LTFMC conduit-to-LTFMC conduit coupling of LTFMC shall not be permitted.

- 7. LTFMC shall be allowed for conduit size ranges from 0.5 inch through 4.0 inches.
- In addition to the requirements for FMC conduit, LTFMC shall also comply with ANSI C-33.84 (latest revision): NEMA-FB1 (latest revision): CEC 12-1400 (latest revision).
- 9. LTFMC fittings

а.

b.

- a. Fittings shall include an external mechanical ground/bond wire connector.
- b. The attachment of the fitting to LTFMC shall be threaded compression type onto the conduit core with locknut and liquid tight jacket compression seal. The fitting shall automatically prevent "sleeving" of the jacket.
- c. Straight and angled termination connector fittings shall be threaded on one end and shall include locknut suitable for connection to threaded and unthreaded enclosures.
- 10. LTFMC Fittings as manufactured by:
  - Termination connector fittings Straight 45 and 90 Degree Angle Connectors
    - 1) Thomas & Betts-5331Thomas & Betts-GR Series. 5341GR and 5351GR Series.
    - Appleton-STB Series; Appleton-STB-L STN-L Series for use Series; STN-L Series with preformed Series for use "knockouts". with preformed "knockouts".
    - 3) OZ/Gedney-4QLT Series. OZ/Gedney-4QLT Series
  - For EMT to EMT conduit-to-conduit coupling:
    - 1) Thomas & Betts-5271 GR Series.
      - 2) OZ/Gedney-4QFML Series
- G. Fittings for Conduit (Including all Types and Flexible and Liquidtight), EMT, and Cable: NEMA FB 1; listed for type and size raceway with which used, and for application and environment in which installed.
  - 1. Conduit Fittings for Hazardous (Classified) Locations: Comply with UL 886.
  - 2. Conduit Fittings for Hazardous (Classified) Locations: Comply with UL 886.
  - 3. Fittings for EMT: Steel type.
  - 4. Coating for Fittings for PVC-Coated Conduit: Minimum thickness, 0.040 inch, with overlapping sleeves protecting threaded joints.
- H. Joint Compound for Rigid Steel Conduit or IMC: Listed for use in cable connector assemblies, and compounded for use to lubricate and protect threaded raceway joints from corrosion and enhance their conductivity.

### 2.02 EXPANSION JOINT, DEFLECTION JOINT AND SEISMIC JOINT CONDUIT FITTINGS

- A. Expansion Conduit Fitting Fitting shall provide for a minimum of two (2) inches straight line movement between two connecting conduits in each direction (total four (4) inches conduit expansion and contraction) parallel to the respective conduit lengths. Fitting shall be watertight.
- B. Deflection Conduit Fitting Fitting shall provide for a minimum of 30 degrees angular deflection movement ("Shear" deflection) between two connecting conduits, in any direction perpendicular to the length of the respective conduits. Fitting shall be watertight.
- C. Combination Expansion/Deflection Conduit Fitting Fitting shall provide the combined "expansion" and "deflection" movement capacity between two connecting conduits as described for separate "expansion" and "deflection" conduit fittings. Fitting shall be approved for installation concealed in both masonry/concrete construction and exposed nonmasonry/concrete construction. Fitting shall be watertight.
- D. Fittings shall comply with U.L.

- E. Fittings as manufactured by:
- F. Conduit expansion fittings exposed or concealed locations as manufactured by:
  - 1. OZ/Gedney AX8 Series for RMC conduit.
  - 2. OZ/Gedney TX Series for EMT conduit
  - 3. Appleton XJ8 Series for RMC conduit and EMT conduits. Provide RMC to EMT combination conduit coupling fittings for each end of the expansion fitting.
    - a. Combination expansion/deflection conduit fittings exposed or concealed conduit locations as manufactured by:
      - 1) OZ/Gedney AXDX Series for RMC conduit.
      - OZ/Gedney AXDX Series for EMT conduit. Provide RMC to EMT combination conduit coupling fittings for each end of the expansion/deflection fitting.
    - b. Conduit expansion/deflection fittings for FMC and LTFMC conduit.
      - 1) Provide a minimum of 12 inches of "slack" LTFMC in each FMC or LTFMC conduit at building and structure seismic or expansion joint conduit crossings.
      - Note: Each FMC "slack" expansion/deflection location, shall be considered as not less than a 90 degree conduit bend location, for compliance with the maximum quantity of conduit bends allowed in a raceway.
  - 4. Conduit Fitting Bonding Jumper
    - a. The grounding/bonding path of metal conduit shall be maintained by the fitting.
    - b. Provide a bonding jumper at each expansion, deflection and combination expansion deflection conduit fitting.
    - c. The jumper shall be a bare flexible copper "braid". The copper braid electrical current carrying capacity shall be equal to the metal conduit.
    - d. Provide a factory terminated ground clamp on each end of the braid with adjusting steel conduit grounding clamps and connect to each respective conduit end.
    - e. The jumper braid length shall be eight (8) inches longer than the respective conduit fitting.
    - f. Bonding jumper for FMC and EMT fittings as manufactured by:
      - 1) OZ/Gedney BJ Series
      - 2) Appleton XJB Series

# 2.03 CONDUIT BODIES CONDUIT FITTING

- A. Conduit bodies shall provide conductor access with a removable conduit body cover and wiring area enclosed in metal housing. The conduit body shall facilitate pulling conductors.
- B. In-line form "C" conduit bodies shall be prohibited.
- C. The interior space "length" of 90 degree "elbow" conduit bodies shall not be less than 6 times the diameter size of the largest conduit connecting to the conduit body.
- D. Conduit body covers shall be removable, gasketed; watertight "domed" metal covers with threaded screw attachment to the conduit body.
- E. Lubricated, reusable, wire roller guards inside the conduit body shall protect wire from insulation damage during wire "pulling".
- F. Conduit body fittings shall comply with UL 514.
  - 1. For RMC Conduit
    - a. OZ/Gedney LB 6X/Mogul (90 degree elbow) Series threaded body.
    - b. Appleton LB/Mogul (90 degree elbow) Series threaded body.

- 2. For EMT Conduit
  - a. Same as for RMC conduit. Provide EMT to RMC conduit combination coupling fitting for each outlet body connection.

## 2.04 METAL WIREWAYS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Cooper B-Line, Inc.
  - 2. Hoffman.
  - 3. Square D; Schneider Electric.
- B. Description: Sheet metal sized and shaped as indicated, NEMA 250, Type 1, unless otherwise indicated.
- C. Fittings and Accessories: Include couplings, offsets, elbows, expansion joints, adapters, hold-down straps, end caps, and other fittings to match and mate with wireways as required for complete system.
- D. Minimum cross section size 4 inches X 4 inches.
- E. Suitable for mounting in any position orientation.
- F. Finish
  - 1. Indoor non-raintight, rust inhibitor phosphatizing base coating and baked enamel finish, manufacturer's standard color.
  - 2. Raintight or outdoor-galvanized metal, with corrosion resistant phosphate primer and baked enamel finish, manufacturer's standard color, NEMA 3R construction.
  - 3. All hardware shall be plated to prevent corrosion.
- G. Construction
  - 1. Minimum metal gauge shall not be less than 14 gauge.
  - 2. Cover shall be hinged entire length of cover. Cover shall be held in the closed position with bolts and nuts.
  - 3. Provide spring nuts on all hardware fastener penetrations into the interior of the wireway to protect against wire insulation damage.
  - 4. The inside of 90-degree corners in the wireway shall be a 45-degree level.
  - 5. Grounding continuity between wireway sections and fittings shall be continuous the entire length of the wireway.

# 2.05 SURFACE RACEWAYS

- A. Surface Metal Raceways: Galvanized steel with snap-on covers. Prime coating, ready for field painting.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Thomas & Betts Corporation.
    - b. Walker Systems, Inc.; Wiremold Company (The).
    - c. Wiremold Company (The); Electrical Sales Division.

### 2.06 BOXES, ENCLOSURES, AND CABINETS

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - 1. Cooper Crouse-Hinds; Div. of Cooper Industries, Inc.
- 2. EGS/Appleton Electric.
- 3. Hubbell Incorporated; Killark Electric Manufacturing Co. Division.
- 4. O-Z/Gedney; a unit of General Signal.
- 5. Thomas & Betts Corporation.
- 6. Walker Systems, Inc.; Wiremold Company (The).
- B. Flush or concealed outlet and junction boxes: Pressed steel, hot-dip galvanized, knockout type with conduit entrances sized to match.
- C. General Requirements for Boxes, Enclosures, and Cabinets: Boxes, enclosures, and cabinets installed in wet locations shall be listed for use in wet locations.
- D. Sheet Metal Outlet and Device Boxes: NEMA OS 1.
- E. Cast-Metal Outlet and Device Boxes: NEMA FB 1, ferrous alloy, Type FD, with gasketed cover.
- F. Nonmetallic Outlet and Device Boxes: NEMA OS 2.
- G. Metal Floor Boxes: Cast metal, rectangular.
- H. Small Sheet Metal Pull and Junction Boxes: NEMA OS 1.
- I. Cast-Metal Access, Pull, and Junction Boxes: NEMA FB 1, cast aluminum with gasketed cover.
- J. Hinged-Cover Enclosures: NEMA 250, Type 1, with continuous-hinge cover with flush latch, unless otherwise indicated.
  - 1. Metal Enclosures: Steel, finished inside and out with manufacturer's standard enamel.
  - 2. Nonmetallic Enclosures: Plastic.
- K. Cabinets:
  - 1. NEMA 250, Type 1, galvanized-steel box with removable interior panel and removable front, finished inside and out with manufacturer's standard enamel.
  - 2. Hinged door in front cover with flush latch and concealed hinge.
  - 3. Key latch to match panelboards.
  - 4. Metal barriers to separate wiring of different systems and voltage.
  - 5. Accessory feet where required for freestanding equipment.
- L. Luminaire Outlet Boxes: Nonadjustable, designed for attachment of luminaire weighing 50 lb. Outlet boxes designed for attachment of luminaires weighing more than 50 lb shall be listed and marked for the maximum allowable weight.
- M. Box extension rings used to accommodate new building finishes shall be of same material as recessed box.
- N. Provide boxes of proper code size for the number of wires or conduits passing through or terminating therein, but in no case shall box be less than 4 inches square by 2 1/8 inch deep, unless specified elsewhere or noted otherwise on the drawings.
- O. Gangable boxes are allowed.
- P. Boxes installed concrete shall be U.L. approved for installation in concrete, and shall allow the placing of conduit without displacing reinforcing bars.

- Q. Provide fixture-supporting device in outlet boxes for surface mounted fixtures as required.
- R. Provide solid gang boxes for three or more switches, for mounting behind a common device plate. Provide barriers for all 277-volt devices where more than one device is installed in an outlet box.
- S. Individual audio/visual telephone, computer or data outlets: 4-11/16" square by 2-1/2" deep minimum with single gang extension ring on flush boxes.
- T. Combination telephone/data or computer outlets: 4-11/16" square by 2-1/2" deep minimum with single gang extension ring on flush boxes.
- U. Surface Outlet Boxes
  - 1. Surface mounted outlet boxes, cast iron Type FS or FD, with threaded hubs as required. Provide plugs in all unused openings. Provide weatherproof gaskets for all exterior boxes.

## 2.07 PULLBOXES AND BOXES

- A. Sizes as indicated on the drawings and in no case of less or material thickness than required by the governing code. Exercise care in locating underground pull boxes to avoid installation in drain water flow areas.
  - 1. General purpose sheet steel pull boxes: Install only in dry protected locations with removable screw covers. Manufacturer's standard baked enamel finish.
  - 2. Weatherproof sheet steel pull boxes: Fabricate of code gauge, hot-dip galvanized steel with gasketed weathertight cover of same material. Manufacturer's standard baked exterior enamel finish.
  - 3. Concrete pull boxes: Furnish complete with pulling irons, hot-dip galvanized traffic cover with hot-dip galvanized frame and 4 galvanized cable racks with porcelain blocks. The box to be set on a pea gravel base 12" thick and as large as the bottom. Install a 3/4" by 10' copper clad ground rod for grounding all metal parts. After cables have been pulled and inspected, seal box between cover and frame with a mastic compound similar to Parmagum or Dukseal. Construction equal to prefabricated pull boxes as manufactured by Quikset or Brooks Products. Refer to drawings for size. Provide bead weld on cover to pull box to indicate services within pull box (i.e. "480/277-VOLT, 3-PHASE, 4-WIRE ELECTRICAL" OR "SIGNAL/TEL/P.A./CLOCK/FIRE ALARM").

## PART 3 EXECUTION

### 3.01 RACEWAY APPLICATION

- A. Comply with the following indoor applications, unless otherwise indicated:
  - 1. Exposed, Not Subject to Physical Damage: EMT.
  - 2. Exposed, Not Subject to Severe Physical Damage: EMT.
  - 3. Exposed and Subject to Severe Physical Damage: Rigid steel conduit. Includes raceways in the following locations:
    - a. Loading dock.
    - b. Corridors used for traffic of mechanized carts, forklifts, and pallet-handling units.
    - c. Mechanical rooms.
  - 4. Concealed in Ceilings and Interior Walls and Partitions: EMT.
  - 5. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): FMC, except use LFMC in damp or wet locations.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 6. Damp or Wet Locations: Rigid steel conduit.
- 7. Raceways for Optical Fiber or Communications Cable in Spaces Used for Environmental Air: Plenum-type, optical fiber/communications cable raceway.
- 8. Raceways for Optical Fiber or Communications Cable Risers in Vertical Shafts: Risertype, optical fiber/communications cable raceway.
- 9. Raceways for Concealed General Purpose Distribution of Optical Fiber or Communications Cable: General-use, optical fiber/communications cable raceway.
- 10. Boxes and Enclosures: NEMA 250, Type 1, except use NEMA 250, Type 4, stainless steel in damp or wet locations.
- B. Conduit installation
  - 1. General
    - a. The sizes of the conduits for the various circuits shall be as indicated on the drawings, but not less than the conduit size required by code for the size and quantity of conductors to be installed in the conduit.
    - b. Conduits shall be installed concealed from view. Install conduits concealed in walls, concealed in/below floors and concealed above ceilings, except as specifically noted otherwise.
    - c. The following systems shall be considered as circuits 100 volts and less, all other circuits shall be considered to be over 100 volts (power circuits) unless specifically noted otherwise: Fire alarm, energy management control, telephone, public address, data, computer, television, intercom, intrusion alarm and nurse call.
    - d. Conduits shall be provided complete with conduit bends, conduit fittings, outlet boxes, pullboxes, junction boxes, conduit anchors/supports, grounding/bonding for a complete and operating conductor/wire raceway system.
    - e. Metal and nonmetal conduits shall be provided mechanically continuous between termination connection points. Metal conduit shall be provided electrically continuous between termination connection points.
    - f. Individual conduit paths and home runs shown on the drawings shall be maintained as separate individual conduits for each homerun and path.
    - g. Conduits, conduit fittings and installation work occurring in classified hazardous materials locations shall comply with applicable code Class 1 Division 1 requirements, unless specifically noted otherwise.
    - h. Transitions between conduits constructed of different materials and occurring in above grade locations shall be allowed only at outlet boxes, junction boxes, pull boxes and equipment enclosures unless specifically indicated otherwise. Provide outlet boxes and junction boxes.
    - i. Metal conduit terminating to nonmetal enclosures; terminating into metal enclosures with "concentric.ring" knockouts; terminating into metal enclosures with knockout reducing washers, including but not limited to equipment housings, outlet boxes, junction boxes, pull boxes, cable trenches, manholes, shall be provided with a ground/bonding lug integrated with the conduit termination conductor fitting construction, by the fitting manufacturer. The lug shall provide for connection of a grounding/bonding conductor (insulated or uninsulated). The grounding lug shall be located on the fitting, inside the termination enclosure.
    - j. The type of conduit, type of conduit fittings, and type of conduit supports and method of conduit installation shall be suitable for the conditions of use and conditions of location of installation based on the manufacturer's recommendations; based on the applicable codes and based on the requirements of the contract documents.
- C. Minimum Raceway Size: 3/4-inch trade size.
- D. Raceway Fittings: Compatible with raceways and suitable for use and location.

- 1. Rigid and Intermediate Steel Conduit: Use threaded rigid steel conduit fittings, unless otherwise indicated.
- 2. PVC Externally Coated, Rigid Steel Conduits: Use only fittings listed for use with that material. Patch and seal all joints, nicks, and scrapes in PVC coating after installing conduits and fittings. Use sealant recommended by fitting manufacturer.
- E. Install nonferrous conduit or tubing for circuits operating above 60 Hz. Where aluminum raceways are installed for such circuits and pass through concrete, install in nonmetallic sleeve.
- F. Do not install aluminum conduits in contact with concrete.

# 3.02 INSTALLATION

- A. General
  - 1. The sizes of the conduits for the various circuits shall be as indicated on the drawings, but not less than the conduit size required by code for the size and quantity of conductors to be installed in the conduit
  - 2. Conduits shall be installed concealed from view. Install conduits concealed in walls, concealed in/below floors and concealed above ceilings, except as specifically noted otherwise.
  - 3. The following systems shall be considered as circuits 100 volts and less, all other circuits shall be considered to be over 100 volts (power circuits) unless specifically noted otherwise: Fire alarm, energy management control, telephone, public address, data, computer, television, intercom, intrusion alarm and nurse call.
  - 4. Conduits shall be provided complete with conduit bends, conduit fittings, outlet boxes, pullboxes, junction boxes, conduit anchors/supports, grounding/bonding for a complete and operating conductor/wire raceway system.
  - 5. Metal and nonmetal conduits shall be provided mechanically continuous between termination connection points. Metal conduit shall be provided electrically continuous between termination connection points.
  - 6. Individual conduit paths and home runs shown on the drawings shall be maintained as separate individual conduits for each homerun and path
  - 7. Conduits, conduit fittings and installation work occurring in classified hazardous materials locations shall comply with applicable code Class 1 Division 1 requirements, unless specifically noted otherwise.
  - 8. Transitions between conduits constructed of different materials and occurring in above grade locations shall be allowed only at outlet boxes, junction boxes, pull boxes and equipment enclosures unless specifically indicated otherwise. Provide outlet boxes and junction boxes.
  - 9. Metal conduit terminating to nonmetal enclosures; terminating into metal enclosures with "concentric.ring" knockouts; terminating into metal enclosures with knockout reducing washers, including but not limited to equipment housings, outlet boxes, junction boxes, pull boxes, cable trenches, manholes, shall be provided with a ground/bonding lug integrated with the conduit termination conductor fitting construction, by the fitting manufacturer. The lug shall provide for connection of a grounding/bonding conductor (insulated or uninsulated). The grounding lug shall be located on the fitting, inside the termination enclosure.
  - 10. The type of conduit, type of conduit fittings, and type of conduit supports and method of conduit installation shall be suitable for the conditions of use and conditions of location of installation based on the manufacturer's recommendations; based on the applicable codes and based on the requirements of the contract documents.
- B. RMC Installation Locations

- C. RGS, IMC conduits and RGS, IMC fittings shall be installed in the following locations:
  - 1. Embedded in floors, walls, ceilings, roofs, foundations, and footings constructed with concrete.
  - 2. Embedded in walls and foundations constructed with brick and masonry.
  - 3. Interior of buildings, within nine feet of finish floor lines for exposed conduit locations.
  - 4. Exterior of building for exposed conduit locations.
  - 5. Damp or wet locations, exposed or concealed locations.
  - 6. Exposed on roofs.
  - 7. In hazardous materials areas and locations; below hazardous materials areas and locations; above hazardous materials areas and locations.
  - 8. Exposed on utility service poles, for pole risers less than 9 feet above finish grade.
  - 9. RMC conduit and RMC fittings may be installed in any location where EMT and FMC conduit is permitted to be installed.
- D. EMT Installation Locations
- E. EMT conduit and EMT fittings may be installed in the following locations, for circuit conductors operating below 600 volts to ground; locations containing only "non-hazardous materials"; only dry locations:
  - 1. Concealed in hollow non masonry, metal stud frame and wood stud frame walls.
  - 2. Concealed above ceilings.
  - 3. Exposed inside interior enclosed crawl spaces.
  - 4. Exposed interior locations placed 9 ft. or higher above finished floors.
  - 5. Exposed in the following dedicated function areas, interior enclosed room locations:
    - a. Indoor enclosed electrical equipment rooms and closets.
      - b. Indoor enclosed data and telecommunication terminal rooms and closets.
      - c. Indoor enclosed HVAC equipment rooms and closets.
  - 6. Any location where FMC is described to be installed, except as the final connection to rotating or vibrating equipment.
- F. FMC Installation Locations
- G. FMC conduit and FMC fittings may be installed in the following locations normal branch for circuit conductors operating below 600 volts to ground; locations containing only "non-hazardous materials"; only dry, interior locations. FMC conduit and FMC fittings are not allowed for emergency branch circuits, including life safety critical or equipment branch circuits and feeders.
  - 1. Concealed in hollow non-masonry metal stud frame and wood stud frame fully enclosed walls.
  - 2. Concealed above fully enclosed ceiling spaces.
  - 3. FMC conduit shall be installed in continuous lengths between termination points. FMC shall not be "spliced" or coupled directly to FMC or any other conduit type under any circumstance.
  - 4. The maximum continuous length of FMC that shall be installed between termination end points is 6 feet. Circuits requiring continuous conduit lengths exceeding 6 feet between termination end points shall be installed using either RMC or EMT conduits. FMC lengths shorter than 16 inches are prohibited.
  - 5. The minimum size FMC conduit shall be as shown on the drawings but not be less than the following:
    - a. FMC lengths of six feet or less, minimum FMC conduit size shall be 0.50 inches.
- H. LTFMC Installation Locations

- I. LTFMC conduit and LTFMC fittings shall be installed in the following locations for circuit conductors operating below 600 volts to ground; locations containing only "non-hazardous materials":
  - 1. Final electrical connection to vibrating or rotating equipment; control and monitoring devices mounted on vibrating and rotating equipment including the following. Minimum conduit length shall not be less than 24 inches:
    - a. Motor, engines, boilers, solenoids, and valves.
    - b. Fixed mounted.
    - c. Fixed mounted food preparation equipment and "kitchen" equipment.
  - 2. All locations where exposed flexible conduit connections are required, both indoor and outdoor.
  - 3. Final connection to indoors electrical transformers. Minimum conduit length shall not be less than 24 inches, maximum conduit length shall not exceed 72 inches.
  - 4. Do not install LTFMC located in environmental air plenums.
- J. Comply with NECA 1 for installation requirements applicable to products specified in Part 2 except where requirements on Drawings or in this Article are stricter.
- K. Keep raceways at least 6 inches away from parallel runs of flues and steam or hot-water pipes. Install horizontal raceway runs above water and steam piping.
- L. Complete raceway installation before starting conductor installation.
- M. Support raceways as specified in Division 26 Section "Hangers and Supports for Electrical Systems."
- N. Install no more than the equivalent of three 90-degree bends in any conduit run except for communications conduits, for which fewer bends are allowed.
- O. Conceal conduit and EMT within finished walls, ceilings, and floors, unless otherwise indicated.
- P. Threaded Conduit Joints, Exposed to Wet, Damp, Corrosive, or Outdoor Conditions: Apply listed compound to threads of raceway and fittings before making up joints. Follow compound manufacturer's written instructions.
- Q. Raceway Terminations at Locations Subject to Moisture or Vibration: Use insulating bushings to protect conductors, including conductors smaller than No. 4 AWG.
- R. Install pull wires in empty raceways. Use polypropylene or monofilament plastic line with not less than 200-lb tensile strength. Leave at least 12 inches of slack at each end of pull wire.
- S. Flexible Conduit Connections: Use maximum of 72 inches of flexible conduit for recessed and semirecessed lighting fixtures, equipment subject to vibration, noise transmission, or movement; and for transformers and motors.
  - 1. Use LFMC in damp or wet locations subject to severe physical damage.

## 3.03 PROTECTION

- A. Provide final protection and maintain conditions that ensure coatings, finishes, and cabinets are without damage or deterioration at time of Substantial Completion.
  - 1. Repair damage to galvanized finishes with zinc-rich paint recommended by manufacturer.
  - 2. Repair damage to PVC or paint finishes with matching touchup coating recommended by manufacturer.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

## 3.04 INSTALLATION OF OUTLET AND JUNCTION BOXES

- A. Accurately place boxes and securely fasten to structural members. Where outlets are shown at same location but at different mounting heights, install outlets in one vertical line. Where outlets are shown at same location and mounting height, mount outlets as close together in a horizontal row as possible. Where the outlet boxes for switches and receptacles are shown at the same location and mounting height, mount in common outlet box with barriers between devices. Provide single piece multigang cover plate for close mounted outlet boxes. Where switches are shown on wall adjacent to hinge side of doors, box shall be installed to clear door when door is fully opened.
- B. Mount boxes at heights indicated on Drawings. If mounting heights of boxes are not individually indicated, give priority to ADA requirements. Install boxes with height measured to bottom of box unless otherwise indicated.
- C. Flush mounted boxes shall be attached to two studs or structural member by means of metal supports.
- D. Boxes above accessible ceilings shall be attached to structural members. Where boxes are suspended, they shall be supported independently of conduit system by means of hanger rods and/or preformed steel channels. Boxes shall be supported independently of all piping, ductwork, equipment, ceiling hanger wires and suspended ceiling grid system.
- E. Recessed Boxes in Masonry Walls: Saw-cut opening for box in center of cell of masonry block, and install box flush with surface of wall. Prepare block surfaces to provide a flat surface for a raintight connection between box and cover plate or supported equipment and box.
- F. Surface mounted outlets shall be attached to concrete or masonry walls by means of expansion shields.
- G. Horizontally separate boxes mounted on opposite sides of walls so they are not in the same vertical channel.
- H. Locate boxes so that cover or plate will not span different building finishes.
- I. Support boxes of three gangs or more from more than one side by spanning two framing members or mounting on brackets specifically designed for the purpose.
- J. Fasten junction and pull boxes to or support from building structure. Do not support boxes by conduits.
- K. Set metal floor boxes level and flush with finished floor surface and within adjustable limits of floor ring. Where outlets are shown at same location or adjacent location, use multigang boxes.
- L. Outlet box horizontal and vertical separation unless noted otherwise. Outlet boxes and device outlet rings installed flush in walls shall be horizontally and vertically separated by not less than 24 inches (edge of box to edge of box) from device outlet boxes and rings in common wall surfaces located on the opposite (back) side of the same wall.
  - Where the separation cannot be maintained, provide a solid backing behind the outlet box. The backing shall extend the width of the wall cavity (i.e. between "studs" or masonry cells) behind the box and 12 inches above and below the outlet box centerline. The backing shall consist of 5/8-inch thick gypsum board anchored in place for "stud"

wall construction and solid "mortar" to completely fill the outlet box "cell" in masonry construction.

- 2. In fire rated walls where the separation cannot be maintained, provide fire rated "boxwrap" around each outlet box inside the wall, to maintain the fire rating of wall with the installed outlet boxes.
- M. Set nonmetallic floor boxes level. Trim after installation to fit flush with finished floor surface.

## 3.05 WIREWAY INSALLATION

A. Wireway hangers shall provide clamp type, hanger rod type, direct bolted bracket type from ceiling or walls as indicated on the drawings and required for field installation locations. Supports shall be installed a minimum of 5 ft. on center.

## 3.06 GROUNDING (ADDITIONAL REQUIREMENTS)

- A. Grounding shall be executed in accordance with all applicable codes and regulations, both of the State of California and local authorities having jurisdiction.
- B. The neutral of each transformer shall be grounded by individual separate ground conductors in individual conduits as follows:
  - 1. Conductor and conduit shall be grounded to building main ground bus.
  - 2. Conductor and conduit shall be grounded to nearest available effectively grounded building structural steel member or grounded metal cold water pipe.
- C. The transformer neutral ground conductors for secondary side of the transformers shall be copper and shall be sized according to the following table:
  - 1. Secondary Total Equivalent
  - 2. Size Copper
  - 3. #2 or smaller
  - 4. 1 or 1/0
  - 5. 2/0 or 3/0
  - 6. 4/0 thru 350 MCM
  - 7. Over 350 MCM thru 600 MCM
  - 8. Over 600 MCM thru 1100 MCM
  - 9. Over 1100 MCM

- Neutral Ground Wire Size Copper
- #6-1" conduit #4-1" conduit #2-1 1/4" conduit
- #1-1 1/4" conduit 2/0-1 1/2" conduit
  - 3/0-1 1/2" conduit
    - 4/0-2" conduit
- D. Each pull box or any other enclosure in which several ground wires are terminated shall be equipped with a ground bus secured to the interior of the enclosure. The bus shall have a separate lug for each ground conductor. No more than one conductor shall be installed per lug.
- E. The maximum resistance to ground shall not exceed 5 ohms.

#### SECTION 26 05 53

#### **IDENTIFICATION FOR ELECTRICAL SYSTEMS**

#### PART 1 GENERAL

### 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.02 SUMMARY

- A. Section Includes:
  - 1. Identification for raceways.
  - 2. Identification of power and control cables.
  - 3. Identification for conductors.
  - 4. Warning labels and signs.
  - 5. Instruction signs.
  - 6. Equipment identification labels.
  - 7. Miscellaneous identification products.

#### 1.03 SUBMITTALS

- A. Product Data: For each electrical identification product indicated.
- B. Samples: For each type of label and sign to illustrate size, colors, lettering style, mounting provisions, and graphic features of identification products.
- C. Identification Schedule: An index of nomenclature of electrical equipment and system components used in identification signs and labels.

### 1.04 QUALITY ASSURANCE

- A. Comply with ANSI A13.1.
- B. Comply with NFPA 70.
- C. Comply with 29 CFR 1910.144 and 29 CFR 1910.145.
- D. Comply with ANSI Z535.4 for safety signs and labels.
- E. Adhesive-attached labeling materials, including label stocks, laminating adhesives, and inks used by label printers, shall comply with UL 969.

#### 1.05 COORDINATION

A. Coordinate identification names, abbreviations, colors, and other features with requirements in other Sections requiring identification applications, Drawings, Shop Drawings, manufacturer's wiring diagrams, and the Operation and Maintenance Manual; and with those required by codes, standards, and 29 CFR 1910.145. Use consistent designations throughout Project.

- B. Coordinate installation of identifying devices with completion of covering and painting of surfaces where devices are to be applied.
- C. Coordinate installation of identifying devices with location of access panels and doors.
- D. Install identifying devices before installing acoustical ceilings and similar concealment.

## PART 2 PRODUCTS

## 2.01 POWER RACEWAY IDENTIFICATION MATERIALS

- A. Comply with ANSI A13.1 for minimum size of letters for legend and for minimum length of color field for each raceway size.
- B. Colors for Raceways Carrying Circuits at 600 V or Less:
  - 1. Black letters on an orange field.
  - 2. Legend: Indicate voltage and system or service type.
- C. Self-Adhesive Vinyl Labels for Raceways Carrying Circuits at 600 V or Less: Preprinted, flexible label laminated with a clear, weather- and chemical-resistant coating and matching wraparound adhesive tape for securing ends of legend label.

## 2.02 POWER AND CONTROL CABLE IDENTIFICATION MATERIALS

- A. Comply with ANSI A13.1 for minimum size of letters for legend and for minimum length of color field for each raceway and cable size.
- B. Self-Adhesive Vinyl Labels: Preprinted, flexible label laminated with a clear, weather- and chemical-resistant coating and matching wraparound adhesive tape for securing ends of legend label.

### 2.03 CONDUCTOR IDENTIFICATION MATERIALS

- A. Color-Coding Conductor Tape: Colored, self-adhesive vinyl tape not less than 3 mils thick by 1 to 2 inches wide.
- B. Self-Adhesive Vinyl Labels: Preprinted, flexible label laminated with a clear, weather- and chemical-resistant coating and matching wraparound adhesive tape for securing ends of legend label.
- C. Marker Tapes: Vinyl or vinyl-cloth, self-adhesive wraparound type, with circuit identification legend machine printed by thermal transfer or equivalent process.

### 2.04 WARNING LABELS AND SIGNS

- A. Comply with NFPA 70 and 29 CFR 1910.145.
- B. Self-Adhesive Warning Labels: Factory-printed, multicolor, pressure-sensitive adhesive labels, configured for display on front cover, door, or other access to equipment unless otherwise indicated.
- C. Warning label and sign shall include, but are not limited to, the following legends:
  - 1. Multiple Power Source Warning: "DANGER ELECTRICAL SHOCK HAZARD EQUIPMENT HAS MULTIPLE POWER SOURCES."

### 2.05 INSTRUCTION SIGNS

- A. Engraved, laminated acrylic or melamine plastic, minimum 1/16 inch thick for signs up to 20 sq. inches and 1/8 inch thick for larger sizes.
  - 1. Engraved legend with black letters on white face.
  - 2. Punched or drilled for mechanical fasteners.
  - 3. Framed with mitered acrylic molding and arranged for attachment at applicable equipment.
- B. Adhesive Film Label: Machine printed, in black, by thermal transfer or equivalent process. Minimum letter height shall be 3/8 inch.

### 2.06 EQUIPMENT IDENTIFICATION LABELS

- A. Engraved, Laminated Acrylic or Melamine Label: Punched or drilled for screw mounting. White letters on a dark-gray background. Minimum letter height shall be 3/8 inch.
- 2.07 CABLE TIES
  - A. General-Purpose Cable Ties: Fungus inert, self extinguishing, one piece, self locking, Type 6/6 nylon.
    - 1. Minimum Width: 3/16 inch.
    - 2. Tensile Strength at 73 deg F, According to ASTM D 638: 12,000 psi.
    - 3. Temperature Range: Minus 40 to plus 185 deg F.
    - 4. Color: Black except where used for color-coding.
  - B. Plenum-Rated Cable Ties: Self extinguishing, UV stabilized, one piece, self locking.
    1. Minimum Width: 3/16 inch.
    - 2. Tensile Strength at 73 deg F, According to ASTM D 638: 7000 psi.
    - 3. UL 94 Flame Rating: 94V-0.
    - 4. Temperature Range: Minus 50 to plus 284 deg F.
    - 5. Color: Black.
- 2.08 MISCELLANEOUS IDENTIFICATION PRODUCTS
  - A. Paint: Comply with requirements in Division 09 painting Sections for paint materials and application requirements. Select paint system applicable for surface material and location (exterior or interior).
  - B. Fasteners for Labels and Signs: Self-tapping, stainless-steel screws or stainless-steel machine screws with nuts and flat and lock washers.

### PART 3 EXECUTION

- 3.01 INSTALLATION
  - A. Verify identity of each item before installing identification products.
  - B. Location: Install identification materials and devices at locations for most convenient viewing without interference with operation and maintenance of equipment.
  - C. Apply identification devices to surfaces that require finish after completing finish work.

- D. Self-Adhesive Identification Products: Clean surfaces before application, using materials and methods recommended by manufacturer of identification device.
- E. Cable Ties: For attaching tags. Use general-purpose type, except as listed below:
  1. In Spaces Handling Environmental Air: Plenum rated.

## 3.02 IDENTIFICATION SCHEDULE

- A. Accessible Raceways 600 V or Less, for Service, Feeder, and Branch Circuits More Than 30 A, and 120 V to ground: Identify with self-adhesive vinyl label. Install labels at 10-foot maximum intervals.
- B. Accessible Raceways and Cables within Buildings: Identify the covers of each junction and pull box of the following systems with self-adhesive vinyl labels with the wiring system legend and system voltage. System legends shall be as follows:
  - 1. Emergency Power.
  - 2. Normal Power.
  - 3. UPS.
- C. Power-Circuit Conductor Identification, 600 V or Less: For conductors in vaults, pull and junction boxes, manholes, and handholes, use color-coding conductor tape to identify the phase.
  - 1. Color-Coding for Phase and Voltage Level Identification, 600 V or Less: Use colors listed below for ungrounded feeder and branch-circuit conductors.
    - a. Color shall be factory applied or field applied for sizes larger than No. 8 AWG, if authorities having jurisdiction permit.
    - b. Colors for 208/120-V Circuits:
      - 1) Phase A: Black.
      - 2) Phase B: Red.
      - 3) Phase C: Blue.
    - c. Colors for 480/277-V Circuits:
      - 1) Phase A: Brown.
      - 2) Phase B: Orange.
      - 3) Phase C: Yellow.
    - d. Field-Applied, Color-Coding Conductor Tape: Apply in half-lapped turns for a minimum distance of 6 inches from terminal points and in boxes where splices or taps are made. Apply last two turns of tape with no tension to prevent possible unwinding. Locate bands to avoid obscuring factory cable markings.
- D. Install instructional sign including the color-code for grounded and ungrounded conductors using adhesive-film-type labels.
- E. Conductors to Be Extended in the Future: Attach marker tape to conductors and list source.
- F. Auxiliary Electrical Systems Conductor Identification: Identify field-installed alarm, control, and signal connections.
  - 1. Identify conductors, cables, and terminals in enclosures and at junctions, terminals, and pull points. Identify by system and circuit designation.
  - 2. Coordinate identification with Project Drawings, manufacturer's wiring diagrams, and the Operation and Maintenance Manual.
- G. Warning Labels for Indoor Cabinets, Boxes, and Enclosures for Power and Lighting: Selfadhesive warning labels.
  - 1. Comply with 29 CFR 1910.145.
  - 2. Identify system voltage with black letters on an orange background.

- 3. Apply to exterior of door, cover, or other access.
- 4. For equipment with multiple power or control sources, apply to door or cover of equipment including, but not limited to, the following:
  - a. Power transfer switches.
  - b. Controls with external control power connections.
- H. Operating Instruction Signs: Install instruction signs to facilitate proper operation and maintenance of electrical systems and items to which they connect. Install instruction signs with approved legend where instructions are needed for system or equipment operation.
- I. Emergency Operating Instruction Signs: Install instruction signs with white legend on a red background with minimum 3/8-inch-high letters for emergency instructions at equipment used for power transfer.
- J. Equipment Identification Labels: On each unit of equipment, install unique designation label that is consistent with wiring diagrams, schedules, and the Operation and Maintenance Manual. Apply labels to disconnect switches and protection equipment, central or master units, control panels, control stations, terminal cabinets, and racks of each system. Systems include power, lighting, control, communication, signal, monitoring, and alarm systems unless equipment is provided with its own identification.
  - 1. Labeling Instructions:
    - a. Indoor Equipment: Engraved, laminated acrylic or melamine label. Unless otherwise indicated, provide a single line of text with 1/2-inch-high letters on 1-1/2-inch-high label; where two lines of text are required, use labels 2 inches high.
    - b. Outdoor Equipment: Engraved, laminated acrylic or melamine label.
    - c. Elevated Components: Increase sizes of labels and letters to those appropriate for viewing from the floor.
    - d. Unless provided with self-adhesive means of attachment, fasten labels with appropriate mechanical fasteners that do not change the NEMA or NRTL rating of the enclosure.
  - 2. Equipment to Be Labeled:
    - a. Panelboards: Typewritten directory of circuits in the location provided by panelboard manufacturer. Panelboard identification shall be engraved, laminated acrylic or melamine label.
    - b. Enclosures and electrical cabinets.
    - c. Access doors and panels for concealed electrical items.
    - d. Switchgear.
    - e. Switchboards.
    - f. Transformers: Label that includes tag designation shown on Drawings for the transformer, feeder, and panelboards or equipment supplied by the secondary.
    - g. Substations.
    - h. Emergency system boxes and enclosures.
    - i. Motor-control centers.
    - j. Enclosed switches.
    - k. Enclosed circuit breakers.
    - I. Enclosed controllers.
    - m. Variable-speed controllers.
    - n. Push-button stations.
    - o. Power transfer equipment.
    - p. Contactors.
    - q. Remote-controlled switches, dimmer modules, and control devices.
    - r. Battery-inverter units.
    - s. Battery racks.
    - t. Power-generating units.
    - u. Monitoring and control equipment.

v. UPS equipment.

END OF SECTION

### SECTION 26 27 26

### WIRING DEVICES

### PART 1 GENERAL

## 1.01 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Receptacles, receptacles with integral GFCI, and associated device plates.
  - 2. Twist-locking receptacles.
  - 3. Wall-box motion sensors.
  - 4. Hospital-grade receptacles.
  - 5. Snap switches and wall-box dimmers.

### 1.03 DEFINITIONS

- A. EMI: Electromagnetic interference.
- B. GFCI: Ground-fault circuit interrupter.
- C. Pigtail: Short lead used to connect a device to a branch-circuit conductor.
- D. RFI: Radio-frequency interference.
- E. TVSS: Transient voltage surge suppressor.

### 1.04 SCOPE

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, delivery and installation of the work of this Section, complete as shown on the drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other sections for work related to those other sections and required to be included as work under this section.
  - 2. General provisions and requirements for electrical work.

### 1.05 SUBMITTALS

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: List of legends and description of materials and process used for premarking wall plates.
- C. Field quality-control test reports.

D. Operation and Maintenance Data: For wiring devices to include in all manufacturers' packing label warnings and instruction manuals that include labeling conditions.

### 1.06 QUALITY ASSURANCE

- A. Source Limitations: Obtain each type of wiring device and associated wall plate through one source from a single manufacturer. Insofar as they are available, obtain all wiring devices and associated wall plates from a single manufacturer and one source.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with NFPA 70.

## 1.07 COORDINATION

- A. Receptacles for Owner-Furnished Equipment: Match plug configurations.
  - 1. Cord and Plug Sets: Match equipment requirements.

### PART 2 PRODUCTS

## 2.01 MANUFACTURERS

- A. Manufacturers' Names: Shortened versions (shown in parentheses) of the following manufacturers' names are used in other Part 2 articles:
  - 1. Cooper Wiring Devices; a division of Cooper Industries, Inc. (Cooper).
  - 2. Hubbell Incorporated; Wiring Device-Kellems (Hubbell).
  - 3. Leviton Mfg. Company Inc. (Leviton).
  - 4. Pass & Seymour/Legrand; Wiring Devices & Accessories (Pass & Seymour).

### 2.02 STRAIGHT BLADE RECEPTACLES (SHALL BE UL LISTED HOSPITAL GRADE)

- A. All receptacles in flush type outlet boxes shall be installed with bonding jumper to connect to box to the receptacles ground terminal. Grounding through the receptacle mounting straps is not acceptable. The bonding jumper shall be sized in accordance with the branch circuit protective device as tabulated herein under "Grounding". Bonding jumper shall be attached at each outlet to the back of the box using drilled and tapped holes and washer head screws 6-32 or larger (except isolated ground receptacles). For receptacles in surface mounted outlet boxes direct metal-to-metal contact between receptacle mounting strap (if it is connected to the grounding contacts) and outlet box may be used. Receptacles connected to normal circuits shall be ivory, white or gray as selected by ARCHITECT. Receptacles connected to emergency (ESSENTIAL) power circuits shall be red.
- B. Hospital-Grade, Duplex Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 configuration 5-20R, and UL 498 Supplement SD.
  - Products: Subject to compliance with requirements, provide one of the following:
    - a. Cooper; 8300 (duplex).
    - b. Hubbell; HBL8310 (single), HBL8300H (duplex).
    - c. Leviton; 8310 (single), 8300 (duplex).
    - d. Pass & Seymour; 9301-HG (single), 9300-HG (duplex).
- C. Isolated-Ground, Duplex Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 configuration 5-20R, and UL 498.

1

- 1. Products: Subject to compliance with requirements, provide one of the following:
  - a. Hubbell; CR 5253IG.
  - b. Leviton; 5362-IG.
  - c. Pass & Seymour; IG6300.
- 2. Description: Straight blade; equipment grounding contacts shall be connected only to the green grounding screw terminal of the device and with inherent electrical isolation from mounting strap. Isolation shall be integral to receptacle construction and not dependent on removable parts.
- 2.03 GFCI RECEPTACLES (SHALL BE UL LISTED HOSPITAL GRADE)
  - A. General Description: Straight blade, feed-through type. Comply with NEMA WD 1, NEMA WD 6, UL 498, and UL 943, Class A, and include indicator light that is lighted when device is tripped.
  - B. Hospital-Grade, Duplex GFCI Convenience Receptacles, 125 V, 20 A: Comply with UL 498 Supplement SD.
    - 1. Products: Subject to compliance with requirements, provide one of the following:
      - a. Cooper; HGF20.
      - b. Hubbell; HGF8300.
      - c. Leviton; 6898-HG.
      - d. Pass & Seymour; 2091-SHG.
- 2.04 TWIST-LOCKING RECEPTACLES
  - A. Single Convenience Receptacles, 125 V, 20 A: Comply with NEMA WD 1, NEMA WD 6 configuration L5-20R, and UL 498.
    - 1. Products: Subject to compliance with requirements, provide one of the following:
      - a. Cooper; L520R.
      - b. Hubbell; HBL2310.
      - c. Leviton; 2310.
      - d. Pass & Seymour; L520-R.
  - B. Isolated-Ground, Single Convenience Receptacles, 125 V, 20 A:
    - Products: Subject to compliance with requirements, provide one of the following:
      - a. Hubbell; IG2310.
    - b. Leviton; 2310-IG.
    - 2. Description: Comply with NEMA WD 1, NEMA WD 6 configuration L5-20R, and UL 498. Equipment grounding contacts shall be connected only to the green grounding screw terminal of the device and with inherent electrical isolation from mounting strap. Isolation shall be integral to receptacle construction and not dependent on removable parts.

### 2.05 CORD AND PLUG SETS

1

- A. Description: Match voltage and current ratings and number of conductors to requirements of equipment being connected.
  - 1. Cord: Rubber-insulated, stranded-copper conductors, with Type SOW-A jacket; with green-insulated grounding conductor and equipment-rating ampacity plus a minimum of 30 percent.
  - 2. Plug: Nylon body and integral cable-clamping jaws. Match cord and receptacle type for connection.

### 2.06 SNAP SWITCHES

- A. Comply with NEMA WD 1 and UL 20.
- B. Provide circuit switches totally enclosed, Bakelite or composition base, toggle type with 277 volt A.C. rating for full capacity or contacts for incandescent or fluorescent lamp loads. Switch raitings shall be 20 ampere only. Switches controlling normal circuits shall be ivory, white or gray as selected by ARCHITECT. Switches controlling circuits connected to emergency (ESSENTIAL) power shall be red.
- C. Where switches are mounted in multiple gang assembly and are operating at 277 volts and/or 277 volts and 120 volts mounted in same outlet box, there shall be a barrier installed between each switch.
- D. Switches, 120/277 V, 20 A:
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Cooper; 2221 (single pole), 2222 (two pole), 2223 (three way), 2224 (four way).
    - b. Hubbell; CS1221 (single pole), CS1222 (two pole), CS1223 (three way), CS1224 (four way).
    - c. Leviton; 1221-2 (single pole), 1222-2 (two pole), 1223-2 (three way), 1224-2 (four way).
    - d. Pass & Seymour; 20AC1 (single pole), 20AC2 (two pole), 20AC3 (three way), 20AC4 (four way).
- E. Pilot Light Switches, 20 A:
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Cooper; 2221PL for 120 V and 277 V.
    - b. Hubbell; HPL1221PL for 120 V and 277 V.
    - c. Leviton; 1221-PLR for 120 V, 1221-7PLR for 277 V.
    - d. Pass & Seymour; PS20AC1-PLR for 120 V.
  - 2. Description: Single pole, with neon-lighted handle, illuminated when switch is "ON."

## 2.07 OCCUPANCY SENSORS

- A. Wall-Switch Sensors:
  - 1. Products: Subject to compliance with requirements, provide one of the following: a. Hubbell; AT120 for 120 V, AT277 for 277 V.
    - b. Leviton; ODS 15-ID.
  - 2. Description: Adaptive-technology type, 120/277 V, adjustable time delay up to 20 minutes, 180-degree field of view, with a minimum coverage area of 900 sq. ft..
  - 3. Description: Passive-infrared type, 120/277 V, adjustable time delay up to 30 minutes, 110-degree field of view, with a minimum coverage area of 1200 sq. ft..
- B. Long-Range Wall-Switch Sensors:
  - 1. Products: Subject to compliance with requirements, provide one of the following:
    - a. Hubbell; ATD1600WRP.
    - b. Leviton; ODW12-MRW.
    - c. Watt Stopper (The); DT-200.
  - 2. Description: Dual technology, with both passive-infrared- and ultrasonic-type sensing, 120/277 V, adjustable time delay up to 30 minutes, 110-degree field of view, and a minimum coverage area of 1200 sq. ft.

### 2.08 WALL PLATES

- Α. Provide plates for every normal power switch, normal power receptacle, telephone, computer, television and other device outlets. All plates shall be Pass & Seymour Type "SRP" thermoset plastic color shall be ivory, white or gray as selected by ARCHITECT. Refer to Section 26 "Identification for Electrical Systems" and Section 26 "Medical Facilities" for engraving requirements.
- Β. Provide plates for every emergency (ESSENTIAL) power switch, emergency (ESSENTIAL) power receptacle, and other emergency (ESSENTIAL) power device outlets. All plates shall be Pass & Seymour Type "SRP" thermoset plastic color shall be red for emergency (ESSENTIAL) power device outlets. Refer to Section 26 "Identification for Electrical Systems" and Section 26 "Medical Facilities" for engraving requirements.
- C. Single and combination types to match corresponding wiring devices.
  - Plate-Securing Screws: Metal with head color to match plate finish. 1.
  - Material for Finished Spaces: Smooth, high-impact thermoplastic. 2.
  - Material for Unfinished Spaces: Smooth, high-impact thermoplastic. 3.
  - 4. Material for Damp Locations: with spring-loaded lift cover, and listed and labeled for use in "wet locations."
  - 5. Color: Refer to Architectural plans and specifications.
- D. Wet-Location, Weatherproof Cover Plates: NEMA 250, complying with type 3R weatherresistant thermoplastic with lockable cover.

## 2.09 MULTIOUTLET ASSEMBLIES

- Manufacturers: Subject to compliance with requirements, provide products by one of the Α. followina:
  - Hubbell Incorporated: Wiring Device-Kellems. 1.
  - 2. Wiremold Company (The).
- Β. Components of Assemblies: Products from a single manufacturer designed for use as a complete, matching assembly of raceways and receptacles.
- C. Raceway Material: Metal, with manufacturer's standard finish.
- D. Wire: No. 12 AWG.

### 2.10 FINISHES

- Α. Color: Wiring device catalog numbers in Section Text do not designate device color.
  - 1. Wiring Devices Connected to Normal Power System: ivory, white or gray as selected by Architect, unless otherwise indicated or required by NFPA 70 or device listing. 2.
    - Wiring Devices Connected to Emergency (ESSENTIAL) Power System: Red.
  - TVSS Devices: Blue. 3.
  - Isolated-Ground Receptacles: Orange. 4.
- 2.11 IDENTIFICATION (ADDITIONAL REQUIREMENTS)
  - The front face device cover plates for switches and outlets shall be engraved with the circuit Α. number and connection source equipment name with 1/4" letters, (i.e. "PNL-A #1"; "PNL-AC #42"; etc.) Additionally device cover plates shall also be engraved 1/8" letters with the circuit ampacity and voltage for circuit exceeding 20 ampere or 120 volts. (i.e. PNL-A #6, 8 - 20

AMP 208V 1 Phase; PNL-2B #10 - 30 AMP 120V 1 Phase; etc.) Lettering for normal circuits shall be black lettering for emergency (essential) circuits shall be black.

### PART 3 EXECUTION

#### 3.01 INSTALLATION

- A. Comply with NECA 1, including the mounting heights listed in that standard, unless otherwise noted.
- B. Conductors:
  - 1. Do not strip insulation from conductors until just before they are spliced or terminated on devices.
  - 2. Strip insulation evenly around the conductor using tools designed for the purpose. Avoid scoring or nicking of solid wire or cutting strands from stranded wire.
  - 3. The length of free conductors at outlets for devices shall meet provisions of NFPA 70, Article 300, without pigtails.
  - 4. Existing Conductors:
    - a. Cut back and pigtail, or replace all damaged conductors.
    - b. Straighten conductors that remain and remove corrosion and foreign matter.
    - c. Pigtailing existing conductors is permitted provided the outlet box is large enough.
- C. Device Installation:
  - 1. Replace all devices that have been in temporary use during construction or that show signs that they were installed before building finishing operations were complete.
  - 2. Keep each wiring device in its package or otherwise protected until it is time to connect conductors.
  - 3. Do not remove surface protection, such as plastic film and smudge covers, until the last possible moment.
  - 4. Connect devices to branch circuits using pigtails that are not less than 6 inches in length.
  - 5. When there is a choice, use side wiring with binding-head screw terminals. Wrap solid conductor tightly clockwise, 2/3 to 3/4 of the way around terminal screw.
  - 6. Use a torque screwdriver when a torque is recommended or required by the manufacturer.
  - 7. When conductors larger than No. 12 AWG are installed on 15- or 20-A circuits, splice No. 12 AWG pigtails for device connections.
  - 8. Tighten unused terminal screws on the device.
  - 9. When mounting into metal boxes, remove the fiber or plastic washers used to hold device mounting screws in yokes, allowing metal-to-metal contact.
- D. Receptacle Orientation:
  - 1. Install ground pin of vertically mounted receptacles up, and on horizontally mounted receptacles to the right.
  - 2. Install hospital-grade receptacles in patient-care areas with the ground pin or neutral blade at the top.
- E. Device Plates: Do not use oversized or extra-deep plates. Repair wall finishes and remount outlet boxes when standard device plates do not fit flush or do not cover rough wall opening.
- F. Dimmers:
  - 1. Install dimmers within terms of their listing.
  - 2. Verify that dimmers used for fan speed control are listed for that application.

- 3. Install unshared neutral conductors on line and load side of dimmers according to manufacturers' device listing conditions in the written instructions.
- 4. Do not break off dimmer cooling fans.
- G. Arrangement of Devices: Unless otherwise indicated, mount flush, with long dimension vertical and with grounding terminal of receptacles on top. Group adjacent switches under single, multigang wall plates.
- H. Occupancy Sensor Light Switches
  - 1. Install dimmers within terms of their listing. Installation and location of occupancy sensors shall be in accordance with manufacturers recommendations.
  - 2. Adjust sensitivity control as required for proper operation and to limit coverage to room controlled. Adjust sensitivity so that persons passing by an open door to the room controlled will not activate the lights and for minimal motion within the room by the occupant will maintain the lights on.
  - 3. Adjust time delay off for 15 minutes.

## 3.02 IDENTIFICATION

- A. Comply with Division 26 Section "Medical Facilities."
  - 1. Receptacles: Identify panelboard and circuit number from which served. Use hot, stamped or engraved machine printing with black-filled lettering on face of plate, and durable wire markers or tags inside outlet boxes.

## 3.03 FIELD QUALITY CONTROL

- A. Perform tests and inspections and prepare test reports.
  - 1. In healthcare facilities, prepare reports that comply with recommendations in NFPA 99.
  - 2. Test Instruments: Use instruments that comply with UL 1436.
  - 3. Test Instrument for Convenience Receptacles: Digital wiring analyzer with digital readout or illuminated LED indicators of measurement.
- B. Tests for Convenience Receptacles:
  - 1. Line Voltage: Acceptable range is 105 to 132 V.
  - 2. Percent Voltage Drop under 15-A Load: A value of 6 percent or higher is not acceptable.
  - 3. Ground Impedance: Values of up to 2 ohms are acceptable.
  - 4. GFCI Trip: Test for tripping values specified in UL 1436 and UL 943.
  - 5. Using the test plug, verify that the device and its outlet box are securely mounted.
  - 6. The tests shall be diagnostic, indicating damaged conductors, high resistance at the circuit breaker, poor connections, inadequate fault current path, defective devices, or similar problems. Correct circuit conditions, remove malfunctioning units and replace with new ones, and retest as specified above.
- C. Test straight blade convenience outlets in patient-care areas for the retention force of the grounding blade according to NFPA 99. Retention force shall be not less than 4 oz..

## END OF SECTION

### **SECTION 26 51 00**

## INTERIOR LIGHTING FIXTURES

## PART 1 - GENERAL

### 1.01 SECTIONS INCLUDED

- A. LED Chips on PCB Boards
- B. Drivers
- C. New & Retrofit Fixtures

### 1.02 DESCRIPTION

- A. Provide all lighting fixtures as described on the electrical narrative, and for certain fixtures specified in detail herein. Provide complete with all light sources, completely wired, controlled, and securely attached to supports. Support shall comply with local Codes and ordinances for securing against seismic forces.
- B. Where both catalog number and narrative and/or pictorial description are indicated, the requirements of the description shall take precedence and prevail.
- C. General Contractor shall provide electrical Contractor with entire lighting specification (including fixture catalog cuts and sketches); Electrical Contractor shall provide each specified manufacturer with complete information about the fixtures they will supply.
- D. Type of fixtures shall be as indicated alphanumerically and as specified.
- E. Fixture details shown may be modified by the manufacturer provided all of the following conditions have been met:
  - 1. Fixture performance is equal or improved;
  - 2. Structural, mechanical, electrical, safety and maintenance characteristics are equal or improved;
  - 3. Cost to the Owner is unchanged or reduced;
  - 4. Modifications have been reviewed by the Contractor's Engineer and have been approved by the Project Manager in writing.
- F. Blemished, damaged or unsatisfactory fixtures shall be replaced in a satisfactory manner.

## 1.03 RELATED DOCUMENTS

A. Drawings and General Provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

### 1.04 REFERENCE STANDARDS

- A. National Energy Policy Act of 2005, Public Law No. 109-58.
- B. IESNA LM-63 ANSI Approved Standard File Format for Electronic Transfer of Photometric Data and Related Information; 2002.
- C. NFPA 70 National Electrical Code; National Fire Protection Association; latest version.

- D. IESNA LM-79-08 IESNA Approved Method for Electrical and Photometric Measurements of Solid-State Lighting Products; 2008
- E. IESNA LM-80-08 IESNA Approved Method for Measuring Lumen Maintenance of LED Light Sources
- F. IESNA LM-84 Approved method for measurement of luminous flux and color maintenance of LED lamps, integrated; LED lamps, non-integrated; LED light engines, and LED luminaires.
- G. IESNA TM-21-2011 Projecting Long Term Lumen Maintenance of LED Light Sources
- H. IESNA TM-28 Approved standard method for projecting the measured data over longer lifetimes UL 8750 Light Emitting Diode (LED) Equipment for Use in Lighting Products
- I. UL 8750 Light Emitting Diode (LED) Equipment for Use in Lighting Products
- J. UL 924 Standard for Emergency Lighting and Power Equipment
- K. IEC/EN/UL/CSA 60950 Safety of information technology equipment
- L. OSHA 29CFR1910.7 luminaires shall be listed by national recognized testing laboratory approved by United Stated Department of Labor, Occupational Safety and Health Administration (OSHA)
- M. EXECUTIVE ORDER 13693, (Net Zero Federal Mandates) Planning for Federal Sustainability in the Next Decade, issued March 19, 2015

### 1.05 DEFINITIONS

- A. Correlated Color Temperature (CCT) The temperature in units of kelvin of a blackbody whose chromaticity most nearly resembles that of the light source in question.
- B. Candela (cd) SI Unit of luminous intensity, equal to 1 lumen per steradian (lm/sr)
- C. Chromacity The property of color of light defined by the dominant or complementary wavelength and purity aspects of the color taken together
- D. Color Rendering Index (CRI) measure of the degree of color shift of reference objects when illuminated by the light source as compared to a reference source of comparable color temperature LER: Luminaire Efficacy Rating (delivered lumens/watt).
- E. Delivered Lumens Delivered lumens refers to the total light output from the fixture, whereas nominal lumens is a measure of the total light output of just the light engine or LED chip without consideration for loss from other factors such as drivers, circuit boards, lenses, or other losses that reduce the total fixture output
- F. Efficacy Luminous efficacy is a measure of how well a light source produces visible light. It is the ratio of luminous flux to power.
- G. Foot Candle (fc) Unit of illuminance, equal to 1 lm/ft2
- H. L70 The extrapolated life in hours of the luminaire when the luminous output depreciates from initial values.

- I. LED Light Emitting Diode
- J. LER Luminaire Efficacy Rating (delivered lumens/watt)
- K. Lumen Measured output of luminaire (Only Delivered Lumens of the fixture shall be provided)
- L. Luminaire Complete lighting fixture as an assembly, including LED chip and associated circuit boards, LED driver(s), lens, and integrated sensors and controls, if specified.
- M. MacAdam Shape on the CIE chromaticity diagram that illustrates how much one can "stray" from the target before perceiving a difference from the target color
- N. 4-Step MacAdam Color consistency refers to the average amount of variation in chromaticity among a batch of supposedly identical lamp samples. SDCM is an acronym, which stands for Standard Deviation Color Matching- sometimes known as a "MacAdam ellipse". A MacAdam ellipse refers to an elliptical region centered at a target Color on a chromaticity diagram. The size of the MacAdam ellipse defines the threshold at which color difference becomes perceivable to the average human eye (between any color contained within the ellipse and the color at the center of the ellipse). The 4-Step MacAdams specification reflects a minimal color variation in color spectrum for the LED chips being specified
- O. NEMA National Electrical Manufacturers Association
- P. NRTL Nationally Recognized Testing Laboratory
- Q. NVLAP National Voluntary Laboratory Accreditation Program A program under the US DOE to accredit independent testing laboratories to qualify
- R. Power Factor (PF) Power Factor The ratio of the real power component to the total (complex) power component.
- S. Rated Power Power consumption that the luminaire was designed and tested to achieve at specified temperatures.
- T. RoHS Compliance to restrict certain dangerous substances commonly used in electronic equipment, including Lead, Cadmium, Mercury and others.
- U. Surge Protection Device (SPD) Surge Protection Device A subsystem or component(s) that can protect the unit against short duration voltage and current surges
- V. Solid State Lighting (SSL)
- W. Total Harmonic Distortion (THD) The amount of higher frequency power on the power line

### 1.06 SUBMITTALS

- A. Product Data: For each type of new and retrofit fixture, arranged in order of fixture designation. Include data on features, accessories, finishes, and the following:
- 1. Physical description of lighting fixture including dimensions.
- 2. Energy-efficiency data including Fixture Efficacy (lumens/watt) of luminaire.
- 3. LM79 and LM 80 reports
- 4. Life, output (delivered lumens of fixture, CCT, and CRI), and energy-efficiency data for LEDs.
- 5. Testing Agency Certified Data: Photometric data shall be certified by a qualified independent testing agency.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- 6. Manufacturer Certified Data: Photometric data shall be certified by a manufacturer's laboratory with a current accreditation requirements of National Voluntary Laboratory Accreditation Program (NVLAP) for Energy Efficient Lighting Products and compliance with ISO/IEC 17025.
- 7. Evidence of Fixtures Listed with DesignLights Consortium (DLC).
- 8. Evidence of Fixtures Listed with Lighting Facts Labels available.
- 9. Shop Drawings: For nonstandard or custom lighting fixtures. Include plans, elevations, sections, details, and attachments to other work.
- 10. Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
- 11. Wiring Diagrams: For power, signal, control, Ethernet and other required wiring.
- 12. Installation instructions.

### 1.07 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified agencies providing photometric data for lighting fixtures.
- B. Warranty: Sample of warranty.

## 1.08 QUALITY ASSURANCE

- A. Luminaire Photometric Data Testing Laboratory Qualifications: Provided by an independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910, complying with the IESNA Lighting Measurements Testing & Calculation Guides.
- B. New and/or Retrofit Fixture, Electrical Components, Devices, Accessories and Sensors & Controls and associated components: Listed and UL labeled and marked for intended location and application.
- C. Comply with NFPA 70.
- 1.09 GENERAL LIGHTING REQUIREMENTS
  - A. Verify ceiling materials employed and coordinate fixtures to mount to the ceiling system used.
  - B. Provide support materials of all types necessary to secure lighting fixtures to the building structure.

### 1.010 FIXTURES

- A. Fixtures shall be rated as suitable for both dry and damp locations.
- B. LED Driver and power module, if needed, shall have poke-in wire trap connectors and quick release plug to disconnect fixture from line power.
- C. LED Boards shall be provided to allow for ease of replacement.
- D. LED Boards shall be manufactured and warrantied by fixture manufacturer.

## 1.011 FIXTURE SUPPORT AND INSTALLATION

- A. Recessed fixtures:
  - 1. Equip recessed fixtures with approved attachments to junction boxes unless noted otherwise in the fixture list.

- 2. Provide plaster frames, and other mounting material compatible with the ceiling and wall systems employed.
- Support recessed fixtures separately from ceiling system where ceiling members are not structurally capable of supporting lighting fixtures, or where required by Code. Interconnect fixture bodies and ceiling system members to prevent independent movement where required by Code.
- B. Supplemental support:
  - 1. Include any supplemental support and framing material and fastenings necessary to support lighting fixtures in the locations indicated. Attach this material onto the building structural members. All such materials and installations shall comply with code requirements.
  - 2. Include any foundations required for the support of base mounted lighting fixtures. If the pedestals, poles, or standards supporting such fixtures exceed 10 feet in height, and no foundation details are included on the Contract Documents, provide details of proposed foundations for review by the Structural Engineer. If required by code, proposed foundation designs must be signed by a registered Structural Engineer.

## 1.012 BIDDING PROCEDURE FOR SUBSTITUTIONS

- A. Bidders' attention is called to the following procedure to be followed in submitting their bids for the Lighting section of the Electrical Work:
- B. Bidders wishing to obtain approval on selected brands shall submit their requests not later than fourteen (14) days before the bid opening. Approval will be in the form of an addendum to the specifications issued to all prospective bidders indicating that the additional brand or brands are approved as equal to those described as far as the requirements of the project are concerned. If the bidders do not elect to obtain prior approval during the time so specified, the owner has no obligation to review or consider any such article after the contract award.
- C. If the bidder wishes to substitute fixtures from alternate manufacturers, refer to this section of the specifications. Note that the dimensions of visible parts of many fixtures are binding to the bidder and cannot be changed without prior approval by the Project Manager.
- D. Request for approval shall be accompanied with the name and location of at least one completed project where each proposed substitute has been in operation for a period of at least six (6) months, as well as the names and addresses of the Owner, the Project Manager and the Engineer of record.

## 1.013 DELIVERY, STORAGE, AND HANDLING

- A. Store, protect, and handle products to site under provisions of Division 1 and 26.
- B. Store in a clean, dry space. Maintain factory wrapping or provide an additional heavy canvas or heavy plastic cover to protect units from dirt, water, construction debris, and traffic.
- C. Handle in accordance with manufacturer's written instructions.

### 1.014 WARRANTY

A. LEDs and drivers for LED fixtures shall be covered by a limited five-year warranty against defects in workmanship or material. Warranty shall not define any limitations or percentage of acceptable failure for any component thereby allowing the failure or any component to not be covered under the warranty. Any failure of any component(s) and/or sub-components shall be

deemed a failure and subject to replacement of the failed component(s) and/or subcomponents under the warranty.

- B. Warranty shall be for the entire fixture and it associated components and shall not refer warranty of components to other manufacturers of components that make up the fixture.
- C. Warranty shall not require labor or installation costs.

# PART 2 - PRODUCTS

## 2.01 MANUFACTURERS

- A. Approved Manufacturers: Provide products of firms engaged in the manufacture of LED lighting fixtures of types and ratings required, whose products have been in satisfactory use in similar service with Warranty. The manufacturer of the lighting fixtures shall comply with the provisions of the appropriate codes and standards. All fixtures shall be pre-tested before shipping.
- B. Conformance: Fixtures shall be manufactured in strict accordance with the Contract Drawings and Specifications.
- C. Codes: Materials and installation shall be in accordance with the latest revision of the National Electrical Code and any applicable Federal, State, and local codes and regulations.
- D. UL & Equivalent Listing: All fixtures shall be manufactured in strict accordance with the appropriate and current requirements of the "Standards for Safety" for UL 924 for Emergency Lighting, UL 1598/CSA C22.2, UL 8750 or others as they may be applicable. A listing shall be provided for each fixture type, and the appropriate label or labels shall be affixed to each fixture in a position concealing it from normal view.
- E. Luminaire shall be DLC Certified (Design Lights Consortium).
- F. Specifications and scale drawings are intended to convey the salient features, function and character of the fixtures only, and do not undertake to illustrate or set forth every item or detail necessary for the work.
- G. Base Bid Manufacturers: Are listed on fixture schedule and specification. Manufacturers listed without accompanying catalog numbers are responsible for meeting the quality standards and photometric distribution (delivered lumens and/or average foot candles) set by the specified product.
- H. Alternate Manufacturers: Identification by means of manufacturers names and catalog numbers is to establish basic features, quality and performance standards. Any substitutions must meet or exceed these standards

## 2.02 LUMINAIRES

- A. Each luminaire shall consist of an assembly that utilizes LEDs as the light source. In addition, a complete luminaire shall consist of a housing, LED array, and electronic driver (power supply) and if specified integral sensors and controls per this specification.
- B. Each luminaire shall be designed to operate at an average operating temperature of 25°C.
- C. The operating temperature range shall be 0°C to +50°C.
- D. Each luminaire shall meet all parameters of this specification throughout the minimum operational life of 50,000 hours when operated at the average operating temperature.
- E. Luminaire Construction:
  - 1. Luminaire housing to have no visible welding, screws, springs, hooks, rivets, bare LED's or plastic supports.

- 2. The luminaire shall be a single one-piece, self-contained device, not requiring on-site assembly of exposed luminaire components for installation. The power supply and circuit board for the luminaire shall be integral to the unit and covered per code, but readily accessible.
- 3. Luminaires shall be fabricated from post assembly, powder coated aluminum.
- 4. Finish: Polyester powder coat painted with high-reflective paint, painted after fabrication of metal components.
- 5. The assembly and manufacturing process for the luminaire shall be designed to assure all internal components are adequately supported to withstand mechanical shock and vibration.

## 2.03 LED Sources

- A. LED's shall be manufactured by, Nichia, Samsung, LG or Osram or approved equal.
- B. Lumen Output minimum initial lumen output of the luminaire shall be as measured by IESNA Standard LM-79-08 in an accredited lab.
- C. Lumen output shall not decrease by more than 8% over the minimum operational life of 50,000 hours.
- D. LED Boards shall be suitable for field maintenance or service
- E. Light Color / Quality-
  - 1. Correlated Color temperature (CCT) range as per specification shall be 4000k correlated to chromaticity as defined by the absolute (X,Y) coordinates on the 2-D CIE chromaticity chart.
  - 2. The LED chips shall be within a 4-Step MacAdam Ellipse for color consistency.
  - 3. The color rendering index (CRI) shall be 84 or greater.
  - 4. Color shift over 6,000 hours shall be <0.007 change in u' v' as demonstrated in IES LM80 report.

### 2.04 LED DRIVER

- A. LED Driver shall be suitable for full-range dimming. The luminaire shall be capable of continuous dimming without perceivable flicker over a range of 100% to 10% of rated lumen output with a smooth shut off function.
- B. Driver disconnect shall be provided with a quick disconnect plug to line power.
- C. The LED Driver enclosure shall be internal to the luminaire and be easily accessible.
- D. Models shall be capable of operating across the full range from 90V through 305VAC.
- E. Operating Temperature shall be within -40 +70C.
- F. Shall comply with requirements of FCC (Federal Communications Commission rules and regulations and Title 47 CFR Part 18, Non Consumer (Class A) for EMI/RFI (conducted and radiated). CE listing with related FCC test requirements included in CE certification shall be acceptable.
- G. Power factor shall be greater than 0.90 at full light output.

### 2.05 ELECTRICAL

- A. Power Consumption: Maximum power consumption, +/- 5% when operating between 120 277V shall be as defined on LM-79 reports for each fixture configuration.
- B. Operation Voltage The luminaire shall operate from a 50 or 60 HZ ±3 HZ AC line over a voltage ranging from 120 VAC to 277 VAC. The fluctuations of line voltage shall have no visible effect on the luminous output. The standard operating voltages are 120 VAC, 277 VAC.
- C. Power Factor: The luminaire shall have a power factor of 90% or greater at all standard operating voltages and full luminaire output.
- D. THD: Total harmonic distortion (current and voltage) induced into an AC power line by a luminaire shall not exceed 20 percent at any standard input voltage.
- E. Surge Suppression: The luminaire shall include surge protection to withstand high repetition noise and other interference.
- F. RF Interference: The luminaire and associated on-board circuitry must meet Class A emission limits referred in Federal Communications Commission (FCC) Title 47, Subpart B, Section 15 Non-Consumer requirements for EMI/RFI emissions.
- G. All electrical components shall be RoHS compliant.

### 2.06 EMERGENCY BATTERY PACK

A. Shall be factory installed and provide 1400 lm of light output for 90 minutes.

## 2.07 PHOTOMETRIC REQUIREMENTS

- A. Luminaire performance shall be tested as described herein.
  - 1. Luminaire performance shall be judged against the specified minimum illuminance in the specified pattern for a particular application.
  - 2. Luminaire lighting performance shall be adjusted (depreciated) for the minimum life expectancy.
  - 3. The performance shall be adjusted (depreciated) by using the LED manufacturer's data or the data from the IESNA Standard TM-21 test report, whichever one results in a higher level of lumen depreciation.
  - 4. The luminaire may be determined to be compliant photometrically, if:
    - a. The initial minimum illuminance level is achieved in 100% of the area of the specified lighting pattern
  - 5. The measurements shall be calibrated to standard photopic calibrations.
  - 6. Add specific project requirements.

### 2.08 THERMAL MANAGEMENT

- A. The thermal management (of the heat generated by the LEDs) shall be of sufficient capacity to assure proper operation of the luminaire over the expected useful life.
- B. The LED manufacturer's maximum junction temperature for the expected life shall not be exceeded at the average operating ambient.
- C. The LED manufacturer's maximum junction temperature for the catastrophic failure shall not be exceeded at the maximum operating ambient.
- D. The luminaire shall have an UL IC rating.

E. The Driver manufacturer's maximum case temperature shall not be exceeded at the maximum operating ambient. Thermal management shall be passive by design. The use of fans or other mechanical devices shall not be allowed.

## 2.09 OPTICS

A. The optical assembly shall provide distribution to provide uniform illumination in the space and increased luminance on vertical surfaces.

### 2.010 DIGITAL CONTROLS

A. Not applicable

### 2.011 LUMINAIRE IDENTIFICATION

- A. Each luminaire shall have the manufacturer's name, trademark, model number, serial number, date of manufacture (month-year), and lot number as identification permanently marked inside the each unit.
- B. The following operating characteristics shall be permanently marked inside each unit: rated voltage and rated power in Watts and Volt-Ampere.

### 2.012 QUALITY ASSURANCE

- A. The luminaires shall be manufactured in accordance with a manufacturer quality assurance (QA) program. The QA program shall include two types of quality assurance: (1) design quality assurance and (2) production quality assurance. The production quality assurance shall include statistically controlled routine tests to ensure minimum performance levels of the modules built to meet this specification.
- B. QA process and test results documentation shall be kept on file for a minimum period of five years.
- C. LED luminaire designs not satisfying design qualification testing and the production quality assurance testing performance requirements described below shall not be labeled, advertised, or sold as conforming to this specification.

## 2.013 DESIGN QUALIFICATION TESTING

- A. Design Qualification Testing shall be performed by a National Voluntary Laboratory Accreditation Program (NVLAP) testing facility. Such testing may be performed by the manufacturer or an independent testing lab hired by the manufacturer on new luminaire designs, and when a major design change has been implemented on an existing design. A major design change is defined as a design change (electrical or physical) which changes any of the performance characteristics of the luminaire, results in a different circuit configuration for the power supply, or changes the layout of the individual LED's in the module.
- B. A quantity of two units for each design shall be submitted for Design Qualification Testing.
- C. Product submittals shall be accompanied by product specification sheets or other documentation that includes the designed parameters as detailed in this specification. These parameters include (but not limited to):
- D. Maximum power in Watts

- E. L80 in hours, when extrapolated for the worse case operating temperature. TM21 report shall be submitted to demonstrate this requirement.
- F. Product submittals shall be accompanied by performance data that is derived in accordance with appropriate IESNA testing standards and tested in a laboratory that is NVLAP accredited for Energy Efficient Lighting Products.
- G. Luminaire shall be tested per IESNA LM 79-08.

## **PART 3 - EXECUTION**

### 3.01 EXAMINATION

- A. Examine substrate and supports for luminaires.
- B. Examine each luminaire to determine suitability for locations specified, mounting requirements and seismic support requirements.

## 3.02 INSTALLATION:

- A. Electrical installation shall conform to requirements of NFPA 70, NEC, state and local codes, and to requirements specified herein.
- B. Provide a lighting fixture for each lighting location as indicated.
- C. Provide complete fixtures, including diffusers, lenses, fitters, canopies, LEDs, reflectors, drivers, wiring, hangers and any accessories necessary to complete each fixture installation.
- D. Provide spacers where required for surface-mounted fixtures mounted to low-density cellulose or similar ceiling materials.
- E. Provide accessories as required for ceiling construction type indicated on Finish Schedule. Fixture catalog numbers do not necessarily denote specific mounting accessories for type of ceiling in which a fixture may be installed.
- F. Provide details showing adequate and sturdy support for each lighting fixture. Identify weight and mounting method of all fixtures and furnish and install suitable supports. Fixture mounting assemblies shall comply with all local seismic requirements, codes and regulations.
- G. Install rows of fixtures accurately on straight lines unless otherwise specified. Coordinate with mechanical work.
- H. Install fixtures with vent holes free of air blocking obstacles.
- I. Mask the trims and bottoms of all lighting fixtures if necessary to protect the fixture during construction.
- J. All lighting fixtures recessed in a ceiling, which has a fire resistive rating of one hour or more shall be enclosed in a box which has a fire rating equal to that of the ceiling. The space from the fixture to the enclosure shall be a minimum of one inch.

- K. At the completion of construction clean the bottoms, the trim, the reflecting surfaces, lenses, baffles, louvers and reflector cones of all lighting fixtures so as to render them free of any material, substance or film foreign to the fixture.
- L. Ascertain and ensure that all LED boards are exactly as specified for each fixture type and location.
- M. Provide labor and materials for final targeting of all adjustable fixtures under the Engineer's supervision. Targeting shall take place immediately before building is turned over to the owner, after regular working hours if required.
- N. Replace all burned-out or inoperative LED modules and inoperative drivers in all fixtures before the project is accepted by the owner so that all lighting fixtures will be in operating condition.

## 3.03 FIXTURE LOCATIONS

- A. Reflected Ceiling Plans, Fixture Schedule and other reference data shall be approved by the project Manager prior to ordering of fixtures.
  - 1. Notify Project Manager about field conditions at variance with Contract Documents before placing order for lighting and/or controls and again prior to commencing installation.
  - 2. Coordinate space conditions with other trades before ordering of fixtures.
  - 3. Coordinate length of continuous-run fixtures with adjacent walls, partitions, coffers and other Architectural elements as required.
- B. Prior to installing fixture outlets, examine the plans of other trades in order to conform to all of the following conditions:
  - 1. Fixtures shall not conflict with the installation of doors, etc.
  - 2. Locate fixtures symmetrical with tile and wall material patterns and room dimensions.
  - 3. Fixture outlets shall be accessible and fixtures shall hang clear of ducts and piping. Verify exposed duct and piping locations prior to rough-in of electrical outlets. Adjust outlet locations to coordinate with ducts and piping.
  - 4. Follow indicated mounting heights. Obtain missing heights, if any, from the Engineer.

### 3.04 EXPANSION SHIELD ANCHORS

- A. Expansion shields may be used for supporting lighting fixtures instead of concrete inserts under the following conditions:
  - 1. Fastenings and expansion shield anchors shall be one trade size larger than Specification requirements for fastenings used with concrete inserts.
  - 2. Holes for expansion shield anchors, cinch anchors, etc., shall be self-drilled or drilled with carbide tipped, rotary type concrete drills. Do not drill holes with pneumatic or impact tools. Do not install fasteners in concrete by powder-actuated methods.
  - 3. Drill holes for expansion shields carefully in a workmanlike manner. Drill to the full depth of the expansion shield anchor and in a manner that will develop the full strength of the fastening.
  - 4. Do not drill into post or pre-tension slabs.

### 3.05 INTERFACE WITH OTHER PRODUCTS

A. Interface with air handling accessories furnished and installed under other sections.

## 3.06 CLEANING

A. Clean Work under provisions of Division 1.

TCMC USP 800 Tri-City Medical Center SA Project No. 01667.00

- B. Clean electrical parts to remove conductive and deleterious materials.
- C. Remove dirt and debris from enclosure.
- D. Clean photometric control surfaces as recommended by manufacturer.
- E. Clean finishes and touch up damage.

## 3.07 FIELD QUALITY CONTROL

- A. Provide systems demonstration under provisions of Division 1.
- B. Operate each luminaire after installation and connection. Inspect for proper connection and operation.

# END OF SECTION 265100

#### SECTION 26 57 00

#### MEDICAL FACILITIES

### PART 1 GENERAL

#### 1.01 SCOPE

- A. Work Included: All labor, materials, appliances, tools, equipment, facilities, transportation and services necessary for and incidental to performing all operations in connection with furnishing, deliver and installation of the work of this Section, complete as shown on the drawings and/or specified herein. Work includes, but is not necessarily limited to the following:
  - 1. Examine all other sections for work related to those other sections and required to be included as work under this section.
  - 2. General provisions and requirements for electrical work.

### 1.02 SUBMITTALS (ADDITIONAL REQUIREMENTS)

A. Submit product data sheets for all outlet boxes, wiring devices, device plates.

### PART 2 PRODUCTS

### 2.01 RECEPTACLES (ADDITIONAL REQUIREMENTS)

- A. Receptacles shall be Underwriters Laboratories listed hospital grade.
  - Duplex convenience receptacles shall be heavy duty grounding type 120 volt 15 ampere with two current carrying contacts and one grounding contact which is internally connected to the frame. Outlets shall accommodate standard parallel blade cap and be side wired. Receptacles on normal circuits shall be ivory, white or gray as selected by Architect. Receptacles on emergency (essential) circuit shall be red.
     a. Hubbell #8200
  - Duplex 20 ampere convenience outlets same as 15 ampere except ampacity shall be used where duplex receptacles is supplied by separate 20-ampere circuit:
     a. Hubbell #8300
  - 3. Ground fault convenience receptacles provide separate ground fault receptacle at each location indicated on drawings.
    - a. Hubbell #GF8300
- B. Special outlets hospital grade capacities and types shall be as indicated on the drawings.

#### 2.02 IDENTIFICATION (ADDITIONAL REQUIREMENTS)

A. The front face device cover plates for switches and outlets shall be engraved with the circuit number and connection source equipment name with 1/4" letters, (i.e. "PNL-A #1"; "PNL-AC #42"; etc.) Additionally device cover plates shall also be engraved 1/8" letters with the circuit ampacity and voltage for circuit exceeding 20 ampere or 120 volts. (i.e. PNL-A #6, 8 - 20 AMP 208V 1 Phase; PNL-2B #10 - 30 AMP 120V 1 Phase; etc.) Lettering for normal circuits shall be black lettering for emergency (essential) circuits shall be red.

#### **PART 3 EXECUTION**

## 3.01 GROUNDING (ADDITIONAL REQUIREMENTS)

- A. General
  - 1. The drawings do not show all the bonding connection points or conductors runs. Provide all material and work required for a complete system.
  - 2. All conductor raceways both metallic and non-metallic shall have a separate green equipment ground conductor installed in the raceway with the circuit conductors except as described otherwise for isolated power systems. The raceway shall not be used as the only ground return path. The ground conductor in each raceway shall sized as follows:
    - a. Signal circuit conduits one inch and smaller 1#14 AWG.
    - b. Signal circuit conduits larger then one inch. 1#10 AWG.
    - c. Power circuit raceways.

d.	Feeders, Subfeeders & Branch Circuit Protection Size 15 Amp 20 Amp 30 to 60 Amp 70 to 100 Amp 101 to 200 Amp 201 to 400 Amp 401 to 600 Amp 601 to 800 Amp	Minimum Ground Wire Size in each Raceway #12 #12 #10 #8 #6 #3 #1 1/0
	101 to 200 Amp	#6
	201 to 400 Amp	#3
	401 to 600 Amp	#1
	601 to 800 Amp	1/0
	801 to 1000 Amp	2/0
	1001 to 1200 Amp	3/0
	1201 to 1600 Amp	4/0
	1601 to 2000 Amp	250 MCM
	2001 t0 2500 Amp	350 MCM
	2501 to 4000 Amp	500 MCM

- B. Grounding in General Patient Care Locations
  - 1. Grounding in general patient care areas supplied from non-power isolated systems shall be prepared as follows. General patient care areas include but are not limited to:
    - a. Non-critical patient care areas
    - b. Non-emergency examination rooms
    - c. Non-emergency x-ray rooms
    - d. general nursing area patient rooms
    - e. non-emergency treatment rooms
  - 2. Provide ground conductor in same raceway as respective branch circuit phase conductors, back to respective panelboard.

# END OF SECTION
#### SECTION 31 23 33

#### TRENCHING AND BACKFILLING

#### PART 1 GENERAL

#### 1.01 SUMMARY

- A. Section Includes:
  - 1. Trench excavation, backfill and compaction for new underslab sanitary waste line extension for sink drain.
- B. Related Requirements:
  - 1. Cutting and Removing Concrete Floor Slab: Section 02 41 19.16 Selective Interior Demolition.
  - 2. Underslab Vapor Retarder: Section 07 26 16 Below-Grade Vapor Retarders.
  - 3. Sanitary Waste Piping Installation and Encasement: Section 22 13 16 Sanitary Waste and Vent Piping.

#### 1.02 REFERENCES

- A. Reference Standards: Comply with the following except as otherwise specified in this Project Manual.
  - 1. Soil Compaction Standard: ASTM D698-12e2 Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft<sup>3</sup> (600 kN-m/m<sup>3</sup>))

#### 1.03 EXISTING CONDITIONS

A. The Contractor's attention is directed to the possible existence of pipe and other underground improvements that may or may not be shown on the Drawings. All reasonable precautions shall be taken to preserve and protect any such improvements whether shown on the Drawings or not. Where it is necessary to remove and replace or to relocate such improvements in order to prosecute the work, they shall be removed, maintained in operation and permanently replaced by the Contractor at its expense.

#### PART 2 PRODUCTS

#### 2.01 BACKFILL MATERIAL

- A. Use of Excavated Material as Backfill: The Contractor may backfill with the excavated material provided that such material consists of loam, clay, sand, gravel or other materials that, in the opinion of the Architect, are suitable for backfilling.
- B. Imported Backfill Materials: Whenever the excavated material is not suitable for backfill, the Contractor shall arrange for and furnish suitable imported backfill material which is capable of attaining the required density at its own expense. Contractor shall legally dispose of the excess trench excavation material off Owner's property.
- C. Crushed Rock or Gravel for Pipe Bedding: Where crushed rock or gravel is specified in the bedding detail on the Drawings, the material shall have the following gradations:

<u>Sieve Sizes</u>	No. 3 Rock & Passing (%)	No. 4 Rock & Passing (%)	ASTM No. 67 & Passing (%)	<u>Squeegee (%)</u>
1-1/2"	100			
1"	90-100		100	
3/4"	60-80	100	90-100	
3/8"	0-15	90-100	29-55	100
No. 4	0-5	0-5	0-5	70-80
No. 8				10-25
No.16				0-10
No.200				0-2

Unless otherwise specified, No. 3 rock shall be used for pipes with inside diameters of 27 inches and larger and No. 4 rock shall be used for pipes with inside diameters of 24 inches and less.

D. Sand Backfill: The sand shall be natural bank sand, graded from fine to coarse, not lumpy or frozen and free from slag, cinders, ashes, rubbish or other objectionable or deleterious material. The sand shall not contain a total of more than 10 percent, by weight, of loam or clay and all material must be capable of being passed through a 3/4-inch sieve. Not more than 5 percent shall remain on a No. 4 sieve.

#### PART 3 EXECUTION

- 3.01 PREPARATION
  - A. Structure Protection: Temporary support, adequate protection and maintenance of all existing underground and surface structures, drains, sewers, and other obstructions encountered in the progress of the work shall be furnished by the Contractor at its expense. Any structure that has been disturbed shall be restored upon completion of the Work.

#### 3.02 EXCAVATION SUPPORT

- A. Regulatory Requirements: All excavations shall be properly supported in the manner as required by OSHA Federal Register Vol. 37, No. 243, Sub-part P, Section 1926.652 or as required by state laws and municipal ordinances and as may be necessary to protect life, property, or the Work.
  - 1. Contractor's Responsible Person, as defined in 29 CFR, part 1926, shall evaluate the soil exposed in the excavations.
- B. Excavations shall be so braced, sheeted and supported that they will be safe and the floor alongside the excavation will not slide or settle, and all existing construction will be fully protected from damage. If any damage does result to existing construction, the Contractor, at its own expense, shall make the necessary repairs or reconstruction required as directed by the Architect.
- C. Care shall be exercised in the drawing or removing of sheeting, shoring, bracing and timbering to prevent the caving or collapsing of the excavation faces which are being supported.

#### 3.03 DEWATERING

A. The Contractor shall provide and maintain, at all times during construction, ample means and devices with which to promptly remove and properly dispose of all water from any source entering

the excavations or other parts of the work. Dewatering shall be accomplished by methods that will ensure a dry excavation and preservation of the final lines and grades of the bottoms of excavations.

B. The Contractor shall dispose of the water from the work in a suitable manner without damage to existing construction. No water shall be drained into work built or under construction. Water shall be disposed in such a manner as not to be a menace to the public health.

#### 3.04 TRENCH EXCAVATION

- A. General: Excavation for pipelines, fittings and appurtenances shall be open trench to the depth and in the direction necessary for the proper installation of the same as shown on the Contract Drawings or as otherwise approved by the Architect.
- B. Trench Width: The overall trench width shall not be more than 16 inches nor less than 12 inches wider than the largest outside diameter of the pipe to be laid therein, measured at a point 12 inches above the top of the pipe, exclusive of branches. Excavating and trenching shall be true to line so that a clear space of not more than 8 inches or less than 6 inches in width is provided on each side of the largest outside diameter of the pipe in place. For the purpose of this section, the largest outside diameter shall be the outside diameter of the bell, on bell and spigot pipe.
- C. Excavation to Grade and Ductile Iron Water Pipe:
  - 1. The trench shall be excavated to the depth required so as to provide a uniform and continuous bearing and support for the pipe on solid and undisturbed ground at every point between bell holes. The finished subgrade shall be prepared accurately by means of hand tools.
  - 2. The subgrade beneath the centerline of the pipe shall be finished to within 0.03 feet of a straight line between pipe joints and all tolerances shall be above the specified grade.
- D. Trenching by Hand: Hand methods for excavation shall be employed in interior locations.

#### 3.05 PIPE FOUNDATION AND SUBGRADE PREPARATION

- A. Trench Bottom for Pipe: The trench bottom shall be graded to provide a smooth, firm and stable foundation at every point throughout the length of the pipe. Should large gravel and cobbles be encountered at the trench bottom or pipe subgrade, they shall be removed from beneath the pipe and replaced with clean imported sand that shall be compacted to provide uniform support and a firm foundation all at the Contractor's expense.
- B. Foundation in Poor Soil: If excessively wet, soft, spongy, unstable or similarly unsuitable material is encountered at the surface upon which the bedding material is to be placed, the unsuitable material shall be removed to a depth exposing stable subgrade.

#### 3.06 PIPE BEDDING

- A. General:
  - 1. The pipe shall be carefully bedded as shown on the Drawings. The Contractor shall be responsible for accurately shaping the pipe subgrade to fit the bottom of the pipe for the width shown on the bedding details.
  - 2. Each joint shall be recessed in undisturbed soil or bedding material as required by the bedding detail in such a manner as to relieve the bell of the pipe of all load and to ensure continuous bearing along the pipe barrel upon the pipe subgrade.
  - 3. The pipe bedding, using either selected material, clean, imported sand or crushed rock or gravel, shall be compacted by approved methods to Standard Proctor of 95 percent. When the bedding material is selected material or imported sand, the pipe bedding backfill shall be

brought to optimum moisture content and shall be placed by hand in layers not exceeding 3 inches in thickness to the centerline (springline) of the pipe and each layer shall be solidly tamped with the proper tools so as not to injure, damage or disturb the pipe. Backfilling shall be carried on simultaneously on each side of the pipe to ensure proper protection of the pipe.

B. Sand for Pipe Bedding: Where the trench excavation and pipe foundation and/or subgrade consist of granular soil, the pipe may be bedded in the material found in the trench as hereinafter provided. Clean imported sand shall be used when the trench excavation material and pipe foundation is not granular soil that is suitable for adequate bedding. In all cases, the material to be used for pipe bedding shall be subject to the approval of the Architect.

#### 3.07 BACKFILLING

- A. General:
  - 1. All trenches shall be backfilled after pipe, fittings and appurtenances have been installed, inspected and approved by the Engineer. Whenever a relative compaction requirement value is specified herein, the optimum moisture content and relative density shall be determined in accordance with Standard Proctor Density AASHTO T-99 or ASTM D698.
  - 2. All wood and waste material shall be removed from excavation preparatory to backfilling. Backfill material shall be free of trash, wood, large rock or other objectionable debris. Backfilling shall include the refilling and compacting of the fill in trenches of excavations up to the bottom elevation of the floor slab, or, where indicated on the Drawings, to the bottom elevation of the underslab gravel layer with the underslab vapor retarder. Coordinate with Section 07 26 16.
- B. Procedure at Pipe Zone: Selected backfill material consisting of loose earth or sand free from stones, clods or other deleterious material shall be placed in the trench simultaneously on each side of the pipe for the full width of the trench in layers of about 6 inches in depth. Each layer shall be thoroughly compacted to a Standard Proctor of 95 percent by tamping. Particular attention is to be given to the underside of the pipe and fittings to provide a firm bedding support along the full length of the pipe. Care shall be exercised in backfilling to avoid damage to the pipe. The pipe zone shall be considered to extend 12 inches above the top of the outside diameter of the pipe bell.
- C. Procedure Above Pipe Zone: The remaining portion of the trench shall be backfilled, compacted and/or consolidated by approved methods to obtain a Standard Proctor of 95 percent.
- D. Compaction: Compaction shall be done by use of vibratory equipment, tamping rollers, or other mechanical tampers of the type and size approved by the Architect. The backfill shall be placed in horizontal layers of such depths as are considered proper for the type of compacting equipment being used in relation to the backfill material being placed. Each layer shall be evenly spread, properly moistened and compacted to 90 percent of its standard dry density, ASTM 698 0. Any damage to the pipe as a result of Contractor's operation shall be repaired and/or replaced at the Contractor's expense.

#### 3.08 SITE QUALITY CONTROL

- A. General: See Section 01 45 20.
  - 1. Field Testing: Soil testing during construction will be conducted by acceptable testing laboratory.
- B. Density and Moisture Content Testing: The density and moisture content of each layer of compacted backfill will be determined by the testing agency in accordance with ASTM D1556 or D6938.

- C. Non-Conforming Work:
  - 1. Any material found not to comply with the minimum specified density shall be recompacted until the required density is obtained.
  - 2. If, because of unsatisfactory test results it is necessary to retest after corrective works, cost of tests other than initial tests shall be paid by Contractor.

#### 3.09 CLEANING AND WASTE MANAGEMENT

- A. Waste Management: The Contractor shall make the necessary arrangements for and shall remove and legally dispose of all excess excavated material off Owner's property.
- B. Cleaning: After backfill has been completed, sweep floor area around the backfilled trench, leaving interior space clean and ready for installation of concrete floor patch.

#### END OF SECTION

DELTA 3 OSHPD COMMENTS 12/11/2017

DELTA 3 OSHPD COMMENTS 12/11/2017



MODEL NUMBER	<b>SG404</b>	SG504	SG604
Nominal Size	4'	5'	6'
Interior Dimension (w x d x h)	46" x 24 <sup>9</sup> / <sub>16</sub> " x 27 <sup>7</sup> / <sub>16</sub> "	58" x 24 <sup>9</sup> / <sub>16</sub> " x 27 <sup>7</sup> / <sub>16</sub> "	70" x 24 <sup>9</sup> / <sub>16</sub> " x 27 <sup>7</sup> / <sub>16</sub> "
Usable Workspace (w x d)	44" x 19 ⁵/ <sub>8</sub> "	56" x 19 ⁵/8"	68" x 19 <sup>5</sup> / <sub>8</sub> "
Exterior Dimensions (w x d x h)	53 <sup>3</sup> /4" x 30 <sup>11</sup> /16" x 61 <sup>3</sup> /4"	65 <sup>3</sup> / <sub>4</sub> " x 30 <sup>11</sup> / <sub>16</sub> " x 61 <sup>3</sup> / <sub>4</sub> "	77 <sup>7</sup> /8" x 30 <sup>11</sup> / <sub>16</sub> " x 61 <sup>3</sup> /4"
Cabinet Weight (lbs)	582	714	771
Shipping Weight (lbs)	785	940	1,020
Opening Max.	20"	20"	20"
Working Access Opening Height (8" standard	) 8" / 10" / 12"	8" / 10″ / 12"	8" / 10" / 12"
Operating Amperage <sup>+</sup>			
Normal Operating Mode (Amps)	3.6 / 4.0 / 4.2	4.1 / 4.7 / 5.2	5.6 / 6.8 / 8.1
ReadySAFE <sup>™</sup> Mode (Amps)	1.8	1.9	2.1
Power Consumption <sup>++</sup>			
Normal Operating Mode (Watts)	414 / 460 / 483	472 / 541 / 598	644 / 782 / 932
ReadySAFE <sup>™</sup> Mode (Watts)	207	219	242
Heat Generation <sup>‡</sup>			
Normal Operating Mode (BTU/hr)	1,413 / 1,570 / 1,649	1,612 / 1,847 / 2,042	2,198 / 2,670 / 3,182
ReadySAFE™ Mode (BTU/hr)	706	747	826
Electrical Service Requirements**	115V AC, 20 A, 60 Hz	115V AC, 20 A, 60 Hz	115 V AC, 20 A, 60 Hz
Noise (dBa)	61 / 62 / 65	64 / 65 / 66	65 / 67 / 67

<sup>†</sup>Amperage for new cabinet with clean filters <sup>††</sup>Power consumption at 120V <sup>‡</sup>Calculated maximum based on operating amperage <sup>‡†</sup> Also available in 100V (50/60 Hz) and 220V (50/60 Hz) configurations. CE compliant at 220V.

EXHAUST AND STATIC PRESSURE REQUIREMENTS (with FlexAIR <sup>®</sup> Canopy Exhaust Connection)					
	SG404	SG504	SG604		
8" Working Access Opening Height					
Concurrent Balance Value (CFM min/max)	290 / 663	360 / 750	460 / 845		
8" Exhaust Duct Diameter (" W.G. min/max)	-0.10 / -0.32	-0.10 / -0.55	-0.15 / -0.74		
10" Exhaust Duct Diameter (" W.G. min/max)	-0.04 / -0.17	-0.05 / -0.18	-0.07 / -0.18		
12" Exhaust Duct Diameter (" W.G. min/max)	-0.03 / -0.08	-0.03 / -0.19	-0.06 / -0.13		
10" Working Access Opening Height					
Concurrent Balance Value (CFM min/max)	360 / 701	450 / 820	550 / 945		
8" Exhaust Duct Diameter (" W.G. min/max)	-0.15 / -0.62	-0.18 / -0.60	-0.20 / -0.78		
10" Exhaust Duct Diameter (" W.G. min/max)	-0.05 / -0.18	-0.09 / -0.35	-0.11 / -0.24		
12" Exhaust Duct Diameter (" W.G. min/max)	-0.04 / -0.10	-0.05 / -0.19	-0.09 / -0.16		
12" Working Access Opening Height					
Concurrent Balance Value (CFM min/max)	415 / 871	550 / 925	644 / 1,114		
8" Exhaust Duct Diameter (" W.G. min/max)	-0.17 / -0.75	-0.26 / -0.77	-0.30 / -0.79		
10" Exhaust Duct Diameter (" W.G. min/max)	-0.07 / -0.30	-0.14 / -0.45	-0.14 / -0.36		
12" Exhaust Duct Diameter (" W.G. min/max)	-0.05 / -0.25	-0.06 / -0.23	-0.11 / -0.30		

Equipment #

#### SterilGARD® e3 Class II, Type A2 Biological Safety Cabinet, Vertical Flow, 115 V, 60 Hz Model

#### PERFORMANCE

- Manufacturer shall provide a certified copy of the personnel, product, and crosscontamination (biological) tests, equivalent to or more demanding than as specified in NSF International Standard 49, performed on the unit selected from the corresponding statistical sample. Tests may be witnessed by a representative of the purchaser.
- Cabinet shall have momentum air curtain downflow velocity profile - a higher velocity of downflow behind the viewscreen relative to downflow velocity over the work surface - for added personnel and product protection.
- High-velocity return air slots shall be located at each end of the front access opening. These slots help to prevent contaminated air from being drawn into the work area along the edges of the side wall and from escaping the work area to the ambient environment.
- High-velocity return air slots shall also be located behind the viewscreen on the top edge for enhanced containment and product protection.
- Cabinet shall be capable of automatically handling a 300% minimum increase in filter loading without reducing total air delivery by more than 10%. Test data to verify these capabilities shall be available upon request.
- Intake velocity through the front access opening shall be minimum of 105 FPM. Standard opening for all models is 8"; 10" and 12" openings are also available for all models.
- Each unit, before shipping, shall have a complete physical test to assure cabinet meets Class II requirements. A copy of this test will be provided with the operator's manual shipped with the unit.
- The unit shall have standard HEPA filters for a protection effectiveness of 99.99% on 0.3 micron size particles by DOP test. Filters shall be serviceable from front of cabinet.
- 9. The cabinet shall have a low flow mode (ReadySAFE™), which is active when the viewscreen is closed. This mode of operation shall reduce energy consumption by at least 50% and still meet the product and personnel protection testing requirements of NSF/ ANSI 49. Particle testing while the cabinet is in this mode shall exceed the requirements for ISO Class 5 conditions for 0.3 micron particles. A connection shall be provided for indicating the ReadySAFE™ status to the facility building management system.

#### CONSTRUCTION

- The vertical sliding viewscreen shall be slanted at an angle of 10° from vertical, capable of moving to a fully closed position during shutdown periods.
- Viewscreen shall be constructed of ¼" UV-resistant laminated safety plate glass, with a maximum opening of 20" for equipment loading.
- All biologically contaminated ducts, plenums, and work area side walls shall be permanent metal construction and maintained under negative pressure or enclosed within a negative-pressure zone.
- 4. Interior work area shall be 27<sup>7</sup>/16" high.
- Cabinet shall have Baker's exclusive UniPressure™ Preflow Plenum, designed to provide more uniform airflow to the supply filter.
- 6. Supply and exhaust filters shall be frontloading.
- A telescoping plenum assembly shall be provided to allow the filters to be directly clamped to the plenum against a closedcell neoprene gasket. Plenum applies force to full perimeter of filters, rather than point force.
- 8. Unit shall have an audible alarm and a flashing LED to indicate when the sliding viewscreen is in an unsafe position. An alarm mute switch shall be provided on the front-mounted cabinet control panel to allow the operator to mute the alarm tone for brief adjustments. The alarm shall automatically reactivate after 5 minutes if the viewscreen remains in an unsafe position. Cabinet shall have capability of indicating a power loss at the panel with visual and audible alarms.
- Cabinet exterior construction: seal panels and dress panels of 16-gauge cold-rolled steel, powder coated finish, painted PermaWhite.<sup>™</sup>
- Cabinet interior (work area) construction: one-piece, 16-gauge, Type 304 stainless steel, with a smooth, 7/16" radius between rear and side walls, and easily cleanable, radiused corners on the work surface tray.
- Work area side walls and rear wall to be one-piece construction. A straight back wall shall be provided to maximize work area and easily accommodate laboratory equipment.
- Cabinet shall be double-wall construction with negative-pressure airflow between the walls, from drain pan to top, surrounding the sides and back of work area and cable port.
- Bottom of access opening shall be aerodynamic airflow design directing airflow into the front grille to improve access opening containment capability and bypass armrest.

- Cabinet shall have a unitized drain pan with <sup>7</sup>/16" radius on all sides and a fully removable work surface and work surface supports to facilitate cleaning.
- 15. Cabinet shall be equipped with a stainless steel ball valve to allow safe and effective draining of spills.
- Stainless steel air diffuser and filter protector provided in work area. Filter protector on top of cabinet is cold-rolled steel with powder coat finish.
- 17. Externally adjustable internal damper shall be provided to compensate for changing resistance of exhaust and supply filters during certification.
- One petcock and one plugged penetration are provided as standard on the right side wall. Left side wall is prepunched for optional/additional plumbing connections.
- 19. All external plumbing connections to the petcocks shall be made through the bottom or back of the cabinet and not the sides, allowing zero clearance between the unit and the building walls or equipment to its right and left.
- 20. The unit has 3 optional stands available, including one with telescoping legs that allow the work surface height to be set from 26<sup>1</sup>/<sub>8</sub>" to 38<sup>5</sup>/<sub>8</sub>", a stand with casters, or a stand with an electric hydraulic lift.
- 21. Viewscreen guide design shall be a counterweighted pulley system allowing ease of movement up and down.

ELECTRICAL

- 1. Complete unit shall be listed as certified by Underwriters Laboratory (cULus) for electrical, fire, and personal safety.
- Cabinet shall have a microprocessor-based control system with an easy-to-clean membrane control panel mounted on the front of the cabinet.
- Cabinet shall have adjustable timers for fluorescent lights, outlets and optional UV lights. Timers operate in 15-minute intervals.
- Work area shall be provided with two GFCI-protected duplex outlets, with dripproof covers and shall be protected by a self-resetting circuit breaker.
- A single 14' power cord and plug (NEMA 5-20P) shall be provided for electrical power source.
- If equipped with optional UV light, includes a shutoff safety feature when the viewscreen is raised.
- The unit shall have electronic ballasts for UV and fluorescent lighting to provide longer life and lower heat output.
- Cabinet shall have an externally mounted fluorescent light fixture with electronic ballasts producing an average of 100 footcandles illumination at work surface.

# THE BAKER COMPANY

Available in Console, and Space-Saver Models. Exceeds ISO-14644 ISO Class 5 (Class 100) Requirements.

# **EdgeGARD**<sup>®</sup>



EdgeGARD<sup>®</sup> Console Model

#### Featuring Unique High Velocity Return Air Slots

EdgeGARD<sup>®</sup> is a horizontal laminar flow clean bench which provides a HEPA-filtered airflow across the work area, and a particulate-free work surface. Because only HEPA-filtered air crosses the work surface, the cabinet is ideal for a range of life science and industrial laboratory and process applications where clean air and product protection are essential.

#### **Applications**

Equipment #

008

Equipment #

009

- IV admixture preparation
- Drug compounding
- Plant cell culture
- Media preparation
- Pharmaceutical procedures
- Electronic assembly
- · Limited experimental research

Note: Protects product only; does not contain aerosols generated in the work area, and does not protect personnel or the environment.

#### **Features**

Each EdgeGARD<sup>®</sup> cabinet receives I3 separate performance tests prior to shipment, including complete filter leak tests. A test report accompanies each EdgeGARD<sup>®</sup> upon delivery.

• High velocity return air slots maximize product protection and ensure ISO Class 5 (Class 100) cleanliness.

• All models feature non-glare, all stainless steel work surfaces and side walls.

• A high performance airflow system provides laminar airflow across the work surface.

• HEPA supply filter with 99.99% minimum efficiency in capturing 0.3 micrometer particulates.



#### High Velocity Return Air Slots Capture Backwash Air

Cleanliness and product protection are accomplished with precise control of airflow volumes and velocities. A unique feature in the Baker cabinet design, the high velocity return air slots, have been proven to maximize the clean bench protective capabilities.

• High velocity return air slots are located along the front edge and side walls of the work area.

• Location of the return air slots protects from backwash of dirty air into the work area created when instruments, labware or the user's hands and arms are placed within the air stream on the work surface.

• Air is drawn into these slots at high velocity, ensuring that no unfiltered air enters the work area.

• Recovered air is HEPA-filtered before being passed through the work area.

• Because recirculated air reduces the percentage of dirty air passed through the filter, overall filter life is extended.

#### HEPA Supply Filter With Prefilter

Because filters remove microorganisms and airborne particulates (generally called aerosols) from the air, the quality, performance and useful life of HEPA filters are critical considerations in the clean bench environment.

• Each Baker clean bench filter is scan tested for leaks and tested for overall efficiency by the manufacturer, then individually scan tested by Baker after installation to assure leak-free performance with increased trapping efficiency.



#### **Airflow Characteristics**

**EdaeGARD®** 

Console Model

EdgeGARD® employs a laminar airflow across the work surface. • Clean air is drawn through a

prefilter into the base of the console by a blower/motor.

• The prefilter traps dust and larger particles.

• The air is then pushed up the back wall plenum and through a HEPA filter at an average velocity of 100 FPM.

• HEPA-filtered air is directed horizontally across the work surface toward the opening.



3

6



• Minimum filter efficiency is 99.99% for particulates 0.3 micrometers, increased efficiency for particulates greater and smaller than 0.3 micrometers.

• A removable protective screen is located in front of the HEPA filter. The screen protects the filter and is easily removed for cleaning or service.

• The rigid angle steel filter frame is concealed to permit only the filter media to be exposed to the work area, eliminating turbulence created by the frame effect on the rear wall.

• All air is passed through a washable, reusable Scottfoam<sup>®</sup> prefilter which keeps the HEPA filter free of dust and larger particles, and extends HEPA filter life.

#### Blower/Motor System Helps Extend Filter Life

Baker has selected an optimum blower/motor combination to assure performance and to extend filter life. The Baker blower/motor provides a volume of air despite increases in resistance due to filter loading, resulting in extremely long filter life as verified by simulated filter loading tests.

Extended filter life minimizes filter replacement costs. The more filter resistance the blower/motor system can overcome, the longer between filter changes.

• As particulates fill the filter media, resistance to airflow increases.

• The Baker blower/motor is a direct drive permanent split capacitor motor designed to deliver the maximum amount of filter life for each cabinet.

• The blower/motor automatically compensates for loading until the filter is fully loaded and motor capacity is reached. • The filter need not be changed until the blower/motor system cannot deliver adequate air volume to maintain the average velocity of IO0 FPM.



#### StediVOLT<sup>®</sup> Motor Speed Controller Maintains Optimum Performance

The Baker exclusive StediVOLT<sup>®</sup> motor speed controller reduces the risk of performance degradation and possible product loss due to typical line voltage fluctuations.

• StediVOLT<sup>®</sup> minimizes changes in cabinet performance due to routine voltage fluctuations.

• StediVOLT<sup>®</sup> reads incoming voltage, automatically compensates for low and high voltage, and maintains proper blower speed to prevent periods of unbalanced airflow which may contribute to loss of cleanliness or product protection.

#### Spacious Work Area With Comfortable Lighting

• The 22" work area depth provides ample space for safe, efficient operation; heights vary from 28%" to 34%", depending on model.

• Each EdgeGARD<sup>®</sup> clean bench includes fluorescent lamps which provide up to 200 foot-candle lighting at the work surface.

• The warm, natural illumination exhibits better color fidelity.

• Adjustable leg risers (optional) permit work surface heights of 36" and 38".

#### **Electrical System Offers Safety and Convenience**

The EdgeGARD<sup>®</sup> electrical system is designed for safety and convenience.

• An exterior GFCI duplex outlet is provided to accommodate most commonly used instruments and equipment.

• The outlet is provided with a

5 amp self-resetting circuit breaker.

• The outlets are on a separate circuit from the cabinet lights and blower/motor so that an overload caused by equipment will not affect cabinet function.

• For safety reasons, the EdgeGARD<sup>®</sup> utilizes a single power cord and plug (or junction box) arrangement. This assures that a second power source is not left on if maintenance functions are necessary.

• EdgeGARD<sup>®</sup> is UL and CSA Listed for electrical safety and integrity.



The EdgeGARD<sup>®</sup> Model EGBIV22 Space Saver is a two-foot clean bench for applications where space is at a premium. Only 28" wide overall, it is typically used for IV and nursing stations, satellite pharmacies, intensive care units and other small volume clinical or industrial situations.

#### **Cabinet Construction Enhances Performance, Minimizes Downtime**

Baker cabinet designs represent many years of experience in stainless steel fabrication and craftsmanship.

- EdgeGARD<sup>®</sup> cabinets include a corrosion-resistant Type 304 stainless steel work surface and work area side walls.
- A hinged panel located directly below the high velocity return air slots on the leading edge of the work surface provides easy access for cleaning.
- A ½" lip at the rear of the stainless steel work surface prevents spills from entering the HEPA filter.
- The satin finish work surface diminishes harsh light reflection.
- The 18-gauge cold-rolled steel exterior cabinet is protected with a white baked enamel finish.

#### Caution

A clean bench is not designed to protect personnel or the environment from potentially harmful agents. The adequacy of this product for the user's personal safety, as with any clean bench, should be determined by an industrial hygienist or safety officer.

Site preparation information, architectural drawings, detailed dimensions and purchase specifications are available. Equipment # Equipment #

#### **Options and Accessories**

For convenience, most options, accessories and modifications are factory installed and should be specified when ordering. Commonly requested options are listed below. For detailed information on accessories and modi/3`

- fications, contact The Baker Company.
- Adjustable leg risers (for work
- surface height of 36" to 38")
- Service petcocks (in right or left side wall)
- Stainless steel IV bar (removable)
- Plastic storage bins (below work surface)
- Casters (optional)\*
- Additional duplex outlet
- Isolated/Microbalanced
- blower/motor (for lowest vibration)
- Germicidal UV light—(optional)\*
- Seismic restraints

#### **To Order**

For ordering information, terms and conditions of sale, contact The Baker Company or visit the Baker Web site at www.bakerco.com for the name of your authorized Baker Company representative.





#### EdgeGARD<sup>®</sup> Clean Bench

**Site Preparation** 

Console Model Numbers: EG3252, EG4252, EG4320, EG5252, EG6252, EG6320, EG8252

Space Saver Model Number: EGBIV22

Cabinet Type: Laminar Flow Clean Bench

 $\left\{ \left\{ \right\} \right\}$ 

()

#### **Filtration System**

• Supply filter, zero-probed HEPA filter, 99.99% efficient on all particles 0.3 micron by DOP test.

• Prefilter, washable Scottfoam®

• Dust count, leak test and particle count by single particle monitor or cold DOP photometer which conforms to requirements of FS290b and U.S.A.F. T.O. 00-25-203.

#### Illumination

• Console and bench models, 200 foot-candles at work surface.

• Space-Saver model, 75 foot-candles at work surface.

					Console	Models				
	Model No.	Electrical	Amps	Required	A Exterior	B Interior	C Interior	D Exterior	Net Weight/	Filter Size
$\sim$	2			Breaker	Width	Width	Height	Height*	Ship Weight	
Equipment #	<b>D</b> G3252	115V, AC	11.8	15 amps	38"	34½"	28 <sup>1</sup> //"	64"	360/485 lbs	36"x 30"x 6"
	<b>)</b> G4252	115V, AC	14.2	20 amps	<mark>50"</mark>	<b>46½</b> "	28 <sup>1</sup> / <sub>8</sub> "	64"	440/590 lbs	48"x 30"x 6"
Equipment	EG4320	115V, AC	14.2	20 amps	50"	46½"	<b>34</b> <sup>1</sup> ⁄′′′	70"	460/610 lbs	48"x 36"x 6"
	ÉG5252	115V, AC	15.5	20 amps	62"	<b>58½</b> "	281/2"	64"	520/695 lbs	60"x 30"x 6"
<b>(</b> 009	<b>EG6252</b>	115V, AC	18.5	jct box	74"	<b>70</b> ½"	28 <sup>1</sup> / <sub>8</sub> "	64"	680/880 lbs	72"x 30"x 6"
	<b>E</b> G6320	115V, AC	18.5	jct box	74"	70½"	341⁄8''	70"	720/920 lbs	72"x 36"x 6"
	EG8252	115V, AC	23.4	jct box	<b>98</b> ½"	95"	28 <sup>1</sup> /8"	64"	800/1050 lbs	48"x 30"x 6" (2)

Note: Models EG4252, EG4320 and EG5252 include 11-foot line cord with 3-prong plug (7-foot cord on Model EG3252). Models EG6252, EG6320 and EG8252 require a hard wire connection to junction box located in the lower inside right hand corner of the cabinet.

\*Exterior heights are listed as minimum dimensions, for maximum height add 2 inches.



		Space S	Saver Mode	el	
Model No.	Electrical	Amps	Required Breaker	Net Weight/ Ship Weight	Filter Size
EGBIV22	115V, AC	11.2	15 amps	200/325 lbs	24"x 24"x 6"

Note: This model includes a 9-foot line cord with 3-prong plug.

#### Purchase Specification EdgeGARD<sup>®</sup> Horizontal Laminar Flow Clean Bench

 High velocity return air slots to be located at the leading edges of work surface and side walls. Return air slots protect against backwash of dirty air entering the work area when items are placed within the air stream on the work surface.
 Unit shall be all steel construction, 18- gauge, cold-rolled steel, with a white baked enamel finish and stainless steel work surface and stainless steel inner work area side walls.

3. Unit shall be provided with permanent split capacitor type motor and special blower which automatically compensates for increasing pressure drop across filter in excess of that which is required by existing standards.

4. Complete unit shall be listed as certified by Canadian Standards Association (CSA) and Underwriters Laboratory (UL) for electrical, fire and personal safety.

5. All joints and seams offering a possible path of contaminated air from outside to the inside of the work area shall be sealed.

6. Framing for the filter seal shall be of rigid angle steel construction and only the filter media shall be exposed to the work area opening, to eliminate picture frame effect.

7. Unit shall have washable reusable Scottfoam<sup>®</sup> prefilters.

8. Each unit, before shipping, shall have a complete test to assure hood meets all requirements of ISO-I4644. A copy of this test will be provided with the unit.

9. The unit manufacturer must be able to provide evidence that this unit has been tested by an independent laboratory or research organization.10. Speed controller shall automatically compensate for voltage change to maintain constant voltage to motor while allowing for manual adjustments during filter loading.

II. Unit work surface shall feature ½" lip at rear to prevent accidental spillage into HEPA filter area.
12. The unit shall have standard HEPA filters for a protection effectiveness of 99.99% when f iltering particles of 0.3 micron size.

13. A removable HEPA filter protective screen shall be provided.

Equipment #/

008

~Equipment/#

009

14. Work area shall be provided with externally mounted GFCI protected duplex outlet with circuit breaker.

#### Warranty

The Baker Company, Inc., expressly represents and warrants all goods (a) to be as specified (and described) in The Baker Company catalogs and literature, and (b) to be free under normal use, service and testing (all as described in The Baker Company catalogs and literature) from defects in material and workmanship for a period of thirty-six months from the invoice date.

The exclusive remedy for any breach or violation of this warranty is as follows: The Baker Company, Inc., will F.O.B. Sanford, Maine, furnish without charge repairs to or replacement of the parts or equipment which proved defective in material or workmanship. No claim may be made for any incidental or consequential damages.

THIS WARRANTY IS EXPRESSLY IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE UNLESS OTHERWISE AGREED IN WRITING SIGNED BY THE BAKER COMPANY. (THE BAKER COMPANY SHALL NOT BE RESPONSIBLE FOR ANY IMPROPER USE, INSTALLATION, SERVICE OR TESTING OF THE GOODS.)



P.O. Drawer E, Sanford, Maine 04073 (207) 324-8773 I-800-992-2537 FAX (207) 324-3869 www.bakerco.com

©2006 The Baker Company



# **Compounding Isolator with** Integrated VHP Generator





#### **TWO GLOVE / INTEGRATED** VHP GENERATOR











#### Equipment #

- 032
- SteriSafe Model
- USP 797 Compliant
- Two or Four Glove C.A.I.
- Positive pressure Aseptic Isolator
- Single pass, unidirection al airflow, exhaust type

# C.A.C.I.

- ChemoSafe Model
- USP 797 / USP 800 Compliant
- Two or Four Glove C.A.C.I
- Negative pressure Aseptic Containment Isolator
- Single pass, unidirectional airflow, exhaust type

### FEATURES

- Welded high grade PVC and Stainless Steel construction
- Polished acrylic front panel
- Sloped back approx. 10° for operator comfort
- Glove system with sleeve/cuff/glove assembly
- Aseptic glove change
- Dual door, Product entry airlock with VHP Decon capability
- Product exit airlock chamber
- Integrated Air Management System with alarms

## **SPECIFICATION**

- ISO 5 environment according to ISO 14644-1
- HEPA filters, H14 grade (99.995%) per ISO 1822-1
- Noise level: < 65 dBA.</li>
- Electrical: 115 VAC, 15 Amps, 50/60 hz., single phase

## **OPTIONS**

- Motorized height adjustment system for optimum ergonomics
- Waste material RTP port with disposable beta bag (solid and sharps waste)
- Material transfer RTP port system available in multiple sizes
- Compatible with industry standard prescription management systems
- Viable particulate matter (PM) monitoring system
- Non-viable particulate matter (PM) monitoring system
- Yearly maintenance plan
- Glove integrity tester

### DOCUMENTATION

- Operator and maintenance manual
- Validation support documentation



# Two-Glove CACL Isolator 032



#### **OVERALL SYSTEM**



WASTE PORT (EXTERNAL)



## C.A.C.I.

- ChemoSafe CACI (Compounding Aseptic Containment Isolator)
- Meets the new USP 800 regulation
- Two glove/Negative pressure/Aseptic
- Single pass, unidirectional airflow

- Single chamber system
- Access front panel with two aloves
- Integrated air handling system
- Transfer airlock chamber
- 160mm RTP port for waste removal
- Ready for use upon • receipt from factory

#### DIMENSIONS

- Outside dims (LxWxH): 51" x 28" x 85"
- Internal dims (LxWxH): 34" x 25" x 30"
- Transfer chamber: 16" x 16"

#### **ISOLATOR CHAMBER CONSTRUCTION**

- Rigid white PVC, welded not bonded
- Work surface: 316L Stainless steel
- Polished acrylic sloped front panel
- Excellent appearance / visibility
- Good stability to light and heat
- Compatible with all cleaning agents

#### **AIRLOCK CHAMBER**

- **Rigid white welded PVC**
- Internal pressure control management
- Inner door and outer door control

#### RTP TRANSFER SYSTEM FOR WASTE REMOVAL

- 160mm RTP port
- 160mm RTC container flange with attached bag

#### **GLOVE SYSTEM**

- Oval shaped gloveports, size 10" x 14"
- PVC sleeve / PVC cuff ring / Non-Latex gloves

#### **VENTILATION / FILTRATION SYSTEM**

- HEPA filtered AHU mounted above chamber
- Unidirectional laminar airflow top to bottom
- Pre-filter located on each HEPA filter
- HEPA filtered exhaust system

#### FEATURES INCLUDED WITH EACH ISOLATOR

- LED based lighting system
- Comfort support frame with lockable casters
- Stainless steel IV bar provided along the top Electrical outlets inside the chamber

#### **DOCUMENTATION**

- Operating and Maintenance manual
- Validation support documents •

# MAC 10° LEDC Fan Filter Unit Standard, RSR, & RSRE Models OPERATION & MAINTENANCE MANUAL



#### **ENVIRCO** Innovators in clean air technology

#### Installation & Service Manual

# Table of Contents

Critical Operations of the MAC 10 <sup>®</sup>	3
Part numbers	3
Warnings	4
Installation	5
Unit Control Box	6
Universal Control Card Set Up	7
Troubleshooting 1	2
Infrared Speed Control 1	3
Cleaning (foam) 1	4
Cleaning (pleated) 1	4
Service: Removal and Replacement of Standard Filters 1	5
Service: Removal and Replacement of RSR/E Filters 1	6
Service: Standard and RSR Motor Removal and Installation1	7
Service: RSRE Motor Removal and Installation 1	8
Technical Note: TN1004 Changing Motors in the Field 1	9
Technical Note: TN1002 Design with VAV Boxes	21
MAC 10 LEDC Wiring Diagrams 2	22
MAC 10 LEDC Replacement Parts List 2	<u>2</u> 4
Drawing - MAC 10 Standard Filter 2	25
Drawing - MAC 10 RSR Filter 2	26
Limited Warranty 2	27
Testing 2	27
For MAC 10 4x4, please see manual form #267278.	

For freight damage inquiries, call 800-884-0002 with model and job number available.



#### Installation & Service Manual

#### Critical Operation Conditions of the MAC 10

- Touching the HEPA filter will damage it and void the warranty on the filter. The screen is only to protect against an
  accidental 'touch' of the filter. Never place a hand or tool on the filter. Never lie filter face flat down on a surface always
  have filter on its side to protect from damage.
- 2. Prior to powering the unit, verify the voltage on the label and that the unit has been wired to the correct voltage. The serial number label on the top of the Mac 10 unit has the required voltage.
- 3. To ensure you order the proper replacement parts or complete MAC 10 unit, record the part number and serial number. This information is located on the serial number label, located adjacent to the electrical box. If you can't locate the Sales Order Number, please contact ENVIRCO for this information. Once obtained, record the information for reference.



 11203-XXX
 MAC 10 LEDC 2x3<sup>1/2</sup>
 (600x1057mm) Standard Filter

 11204-XXX
 MAC 10 LEDC 2x3
 (600x905mm) Standard Filter

 11205-XXX
 MAC 10 LEDC 2x2
 (600x600mm) Standard Filter

 11206-XXX
 MAC 10 LEDC 2x4
 (600x1010mm) RSR/E Filter

 11207-XXX
 MAC 10 LEDC 2x3<sup>1/2</sup>
 (600x1057mm) RSR/E Filter

 11208-XXX
 MAC 10 LEDC 2x3<sup>1/2</sup>
 (600x905mm) RSR/E Filter

 11209-XXX
 MAC 10 LEDC 2x3
 (600x905mm) RSR/E Filter

	MPO	<u>RTAN</u>	Τ
YOUR FAN OPERATION INSTALLER JNSURE CO THE MODES	FILTER UNIT I. IT IS YOUR TO SET THE NTACT YOU CONTROLS S ARE SET B SW	THAS THREE RESPONSIBI MODE AS RE R PROJECT M S COMPANY. Y SETTING TH ITCH.	MODES OF LITY AS THE QUIRED. IF IANAGER OR IE 2 PIN DIP
MANUAL MODE 1 OFF 2 OFF	ANALOG MODE 1 ON 2 OFF	NETWORK MODE 1 OFF 2 ON	NETWORK MODE 1 ON 2 ON

Units come set in manual mode from the factory. Please review installation requirements and set up with your end user (See page 8 for complete set up instructions).

û⊠ □ 1 2 1 2

Note: CON4 Univeral Control Card is also referenced as model # ENV1028.

#### Fan Filter Unit

#### Installation & Service Manual

ENVIRCO

#### Warning

TO REDUCE THE RISK OF FIRE, ELECTRICAL SHOCK, OR INJURY TO PERSONS, OBSERVE THE FOLLOWING:

- A. Installation work and electrical wiring must be done by qualified person(s) in accordance with all applicable codes and standards, including fire-rated construction.
- B. When cutting or drilling into wall or ceiling, do not damage electrical wiring and other hidden utilities.
- C. If this unit is to be installed over an area using liquid, such as water or chemical cleaning solutions, it must be marked as appropriate for the application.
- D. Use this unit only in the manner intended by the manufacturer. If you have any questions, contact the manufacturer.
- E. Before servicing or cleaning the unit, switch power off at unit service panel and lock service panel to prevent power from being switched on accidentally.

#### **ENVIRCO USA**

101 McNeill Road Sanford, NC 27330 Tel: (919) 775-2201 Tel: (800) 884-0002 Fax: (800) 458-2379 Email: info@envirco.com

#### **ENVIRCO Europe**

Ruskin Air Mangement South Street, Whitstable Kent, CT5 3DU, UK Tel: +44 (0) 1227.276100 Fax: +44 (0) 1227.264262 Email: sales@envirco.co.uk

#### **ENVIRCO Asia**

Johnson Controls Hong Kong Limited 12/F., Octa Tower 8 Lam Chak Street Kowloon Bay, Hong Kong Tel: +852.2590.0012 Fax: +852.2516.5648



#### Installation & Service Manual

#### Installation

Note: The MAC 10 LEDC Fan Filter Unit is completely assembled at the factory with the exception of the optional ¼" (0.64 cm)-20 eyebolts that are used when hanging the unit from an engineered support system (eyebolts not included and need to be ordered separately, p/n 222449-001) and installation of the HEPA/ULPA filters for RSR/E units only.

**Step 1.** Carefully remove the unit from the shipping carton and inspect for any damage that may have occurred during transportation (See Figure 1).

Recommendation: Review mode settings at this time as specified for installation (see page 7 for controls).



Note: When ordering RSR and RSRE units, the HEPA filters may be shipped separately to be installed into units after the fan box has been installed.



**Step 2.** If using rigidly supported grid (usually 2" (50 mm) or wider), raise unit through ceiling and lower onto the gasketed grid. If using a flexible grid (typically supported with wires), the unit must be secured to an engineered support system with s-hooks and chain. Screw the four eyebolts into the nutserts on the lid assembly before lifting into an overhead position (see Figure 2). **Note:** Confirm fan dimensions to match T-grid dimensions.



#### Figure 2: Hanger Supports

Step 2.1. If using a support grid, continue...

**Step 3.** Raise the unit and secure it into place using the chosen support system method suspended from a structural support bracing.

**Step 4.** Have an electrician wire the unit to the appropriate voltage, according to the wiring diagram (page 17), and all national and local electrical codes. All units are equipped with a three position terminal block for field connection. Verify correct single-phase power, before energizing units.

**Step 5.** Turn on the power using the rocker switch (ON/OFF) located on the electrical box. For RSR/E units, let the unit run for a few hours to purge off particulate (if filters are shipped loose) that may be adhered to the inside of the unit before installing the filters. Do not run fan at full speed as this may cause overload condition.

Note: Your fan filter may have been shipped separately. Controls have been shipped separately.

Fan Filter Unit

#### Installation & Service Manual

ENVIRCO Innovators in clean air technology

#### Unit Control Box

#### 2.1. ON/OFF Switch - Speed/Airflow Adjustment

All MAC 10 LEDC units are equipped with a two-position rocker switch (ON/OFF), which is located on the front side of the electrical box, on top of the unit. All units are furnished with a Universal Control Card to enable adjustment of airflow or be set to your means of communication. (see Page 7 for Universal Card Card Set Up).



Note: The CAT5e/RJ45 network ports are non-directional (i.e. in or out). Be sure to examine your cabling to insure that there is no cross-over wired cables.



#### Installation & Service Manual

#### Universal Control Card (ENV1028) Set Up

#### **CON4 UNIVERSAL CONTROL CARD - PRODUCT OVERVIEW**

ENVIRCO's ENV1028 Universal Control Card provides MODBUS network and analog control capabilities to an ENVIRCO Fan Filter Unit equipped with an electrically commutated motor. Three different control modes provide installation versatility by allowing the FFU to be controlled via MODBUS RTU network, analog 0-10 VDC control signal, or by adjusting the onboard potentiometer. The ENV1028 Universal Control Card is fully compatible with all of ENVIRCO's plug & play System Control Consoles using MODBUS RTU. Additional details of the controls modes are provided on page 8.

#### **FEATURES**

- Networkable Via MODBUS RTU
- 0-10 VDC Analog Control
- Manual Control Via Onboard Potentiometer
- Simple Connections
  - RJ45 For Networking Connection
  - Screw Terminals For Analog Control
  - Test Probe Jacks For DC mV Signal Output Of The Following...
    - RPM
    - Motor Control Set Point
- LED Diagnostics
  - Support for external LED (10mA) remote status notification via 2 Pin MTA connector
  - Onboard green LED for Board Status notification
  - Onboard red LED for Network Traffic
- Powered from Network or Local Supply



Note: CON4 Univeral Control Card is also referenced as model # ENV1028.

Fan Filter Unit

#### Installation & Service Manual

"(ENVIRC)

Innovators in clean air technology

#### **CONTROL MODES**

The ENV1028 operates in one of three selectable modes. The Mode is selected using DIP Switch S1.

- MANUAL control, on-board potentiometer
- ANALOG control, Remote 0-10 VDC
- NETWORK control, MODBUS RTU

Manual Mode = 1 OFF 2 OFF



Analog Mode = 1 ON 2 OFF





Network Mode = 1 OFF 2 ON



Network Mode = 1 ON 2 ON



Note: Network mode can be configured using either DIP switch setting shown above. DIP switch pictorials are for reference and may be labeled differently by the manufacturer.



#### Installation & Service Manual

#### Manual Control Mode:

In Manual control mode, the motor speed is set using the onboard potentiometer. Onboard potentiometer rotation is clockwise to increase the motor output.

#### Analog Control Mode:

In ANALOG control mode, the motor output is set using an external 0-10 VDC demand signal.

#### **Network Control Mode:**

In NETWORK control mode, the motor output is set using MODBUS Register 2. Motor output is specified as a value from 0 to 100 representing a percentage of motor torque output. Each ENV1028 in a MODBUS network must be set to a unique address. The address value is <u>set in binary format using the eight DIP switches of switch bank (S2)</u>. A maximum of 200 ENV1028 devices are recommended per local area network(LAN). If an ENVIRCO ACC Control Console is the MODBUS master, then addresses should be assigned within the address range supported by the Control Console. Address zero should not be used as it is reserved for global commands. Address switch settings are only checked by the ENV1028 at power-up. Power must be cycled (OFF/ON) before any changes take effect.



Note: Network mode can be configured using either DIP switch setting shown above. DIP switch pictorials are for reference and may be labeled differently by the manufacturer.

Registers relevant to this mode (see chart on page 11):

- Register 1 "Start/Stop" (R/W)
  - To enable motor, write a value of 1; To disable motor, write a value of 0
- Register 2 "Motor Set Speed" (R/W)
  - Motor Target speed value. Values may be written from 0 to 100
- Register 6 "RPM" (R)
  - Motor RPM. Read from the motor
- Register 12 "Actual Motor Speed Instruction" (R)
   Speed control signal applied to the motor by the ENV1028.

(R/W) = Read/Write, (R) = Read Only













Example of binary S2 switch settings







Fan Filter Unit

#### ENVIRCO Innovators in clean air technol

#### Installation & Service Manual

#### **ELECTRICAL SPECIFICATIONS**

Control and Interface Signals:

- 1. External Speed 0-10V Input
  - Input impedance 20k Ohms.
  - MIN ON-to-OFF threshold: 190mV
  - MAX OFF-to-ON threshold: 240mV
  - ON (~215mV) to 9.89V linearly scales 1 to 99% speed.
  - 9.89V or more deadbands to 100% speed.
- 2. External LED Output
  - 10mA regulated
  - LED forward voltages up to 5V
- 3. RPM Signal
  - Signal Value: mVDC = RPM
  - Ex: 900mV = 900RPM
  - RPM Output Range: ~ 0, 5 to 2000 RPM (0, 5mV to 2000 mV DC)
  - RPM Output Resolution: 5RPM (Zero, 400 steps from 5 to 2000 RPM inclusive)

#### Electrical and Environmental Specifications:

Specification	Min	Typical	Мах	Units
Input Voltage	22	24	42	VAC
Supply Frequency	50	50/60	60	Hz
Input Power Consumption	na	na	0.5	VA
Ambient Operating Temperature	0	25	50	С

#### Test Probe JacksPoints:

The test probe jacks may be used to measure the motor rpm or the PWM signal that is being output to the motor.

- In Manual or Analog Control Mode with a S2 #1 address setting of 1 or greater, the test probe jacks output 0-2000 mVDC representing motor RPM. By changing the address S2 #1 switch to 0, the test probe jacks will output 0-1000 mVDC representing 0-100% demand signal to the motor. The address may be changed without interrupting power to the control card.
- In Network Control Mode, 0-2000 mVDC always represents RPM.

#### LED Indicators:

Onboard Status LED:

The Onboard Status LED is software controlled by the unit microcontroller. The Status LED is solid ON when RPM reported by the motor is greater than zero and OFF when RPM reported by the motor is zero.

• External Status LED:

Support for an external Status LED (10mA current-controlled driver), via a 2-pin MTA connector, for remote system status notification. The external Status LED operates in the same manner as the Onboard Status LED. Onboard Net LED:

The Onboard Net LED is driven directly by the receive data signal. The NET LED shows all network traffic on a 2-wire network. The NET LED is intended to confirm low-level network connectivity, independent of microcontroller or firmware functionality. If A/B network wires are swapped, the NET LED will be normally on, providing quick diagnostics of this common condition.

Net LED Status Definition				
LED OFF	Power Lost or No Communications			
LED Flickering	Network Data Traffic In Progress			
LED ON	A/B network wires are swapped			



Red Network LED

✓ Green Status LED

#### **RJ45 Network Cable Connections:**

1	2	3	4	5	6	7	8
Bus Power	0V (GND)		RS-	0V (GND)	Bus Power		
Pass Through		+	NC	NC	-		Pass Through



#### Fan Filter Unit

#### Installation & Service Manual

#### **COMMUNICATION SPECIFICATIONS**

#### **Overview:**

- MODBUS RTU protocol over RS485 (serial)
- 9600 baud rate, word length is 8, parity is none(n), stop bits=1
- 255 unique address values selectable by S2 switch settings
- (recommended network node capacity 200 nodes)
- · Slew rate limited transceivers for improved network performance MODBUS Register Summary Table

#### • DO NOT USE CROSSOVER CABLES. THIS MAY DAMAGE THE CONTROL CARD OR RENDER IT NON-OPERATIONAL.

#### **MODBUS Register Specifications:**

Register	Name	R/W	Values & Defaults	Units	Origin	Comments
1	RUN/STOP	RW	0,1	1	RAM	power up from REG 14
2	DEMAND	RW	0-100	%	RAM	power up from REG 10
6	SPEED	R	0,5-2000	RPM	LIVE	
7	ANA1	R	0-1000	-	LIVE	Onboard Pot 0-1000=0-100%
9	STATUS	R	see detail	-	LIVE	
10	DEFAULT SPEED	RW	0-100	50	EEPROM	applies to network only
12	CURRENT SPEED	R	0-100	-	LIVE	
14	DEFAULT RUN/STOP	RW	0,1	1	EEPROM	applies in network mode only
24	ANA2	R	0-1000	-	LIVE	0-10V input 0-1000=0-10VDC

To reset non-volatile registers to factory default values, write 170 (AA hex) to Register 14, and then cycle power.

Note: Register 24 may be read in network mode to determine the value of 0-10VDC signal that *may* be connected. For example, a pressure transducer may be connected to indicate unit interal static pressure.

#### Fan Filter Unit

#### Installation & Service Manual

ENVIR

#### Troubleshooting

#### Mode Choice:

Verify mode setting choice to DIP switch S1 (Control Mode), which is manual mode and then retry.

Net LED Status Definition				
Green LED OFF	Power Lost or No Communications			
Green LED Flickering	Network Data Traffic In Progress			
Green LED ON	A/B network wires are swapped			



#### Motor Issues in Manual Mode:

(If you are in a network or analog mode, contact your controls contractor for troubleshooting assistance; if you continue to need assistance, contact the factory.)

#### Unit is not adjustable:

Step 1. Check incoming power supply for proper voltage (120,208-240,277/24).

**Step 2.** Verify that rotation of the manual speed potentiometer does not change the RPM. If rotating does nothing, remove the electrical box cover, then remove the 4-pin motor connector from the control board and reinstall 180 degrees rotated. Also insure that the 4-pin connection wires are pushed down securely onto connector pins. Again adjust the knob to verify proper fan operation. Note: The 4 pin connector is on the 1/8" white cable from motor.

#### Low Air Velocity:

Step 1. Check incoming power supply for proper voltage (120,208-240,277/24).

- Step 2. Check to be sure that the manual speed potentiometer is set correctly.
- Step 3. Examine the HEPA filter.

#### **High Air Velocity:**

**Step 1.** Check incoming power supply for proper voltage (120,208-240,277/24). **Step 2.** Check to be sure that the air flow settings are correct.

#### Filter Issues:

#### Non-Laminar Flow and/or Excessive Contamination:

- Step 1. Insure that no large obstructions are upstream of airflow pattern.
- Step 2. Determine that no other air-moving devices are operating in or around clean room which disrupt room's airflow pattern.
- Step 3. Check air velocity and if low, conduct the "Low Air Velocity" procedure outlined above.

#### If failure continues, contact ENVIRCO Technical Support at 800-884-0002.



#### Installation & Service Manual

#### Infrared Speed Control (Optional)

The Flow-Set is a handheld infrared remote control configured to adjust the ENVIRCO Mac 10 LE-DC unit.

An EVO/ECM-IRC control sends the motors a FLOW INDEX and a GO signal. The motor sends back a status signal that is connected to a red lamp. The control includes an infrared remote receiver.

The Flow-Set handheld remote sends infrared remote commands to the EVO/ECM-IRC control, allowing remote adjustment of the Motor. (See Figure 10). Using the Flow-Set, you can turn the motor on/off, adjust the flow index from 1-100 and read the current settings.

Point the Flow-Set at the Flow-Set target (red lamp if the motor is on) on the equipment. Operate the **on/off** button or any of the four  $\uparrow\downarrow$  buttons. The green lamp near the Flow-Set target lights, indicating you are in an adjustment session. Continue to operate the **on/off** button or any of the four  $\uparrow\downarrow$  buttons to achieve the desired settings.

Press the **Enter** button to save your new settings and exit the adjustment session. Press the **Clear** button to delete your new settings, revert to the IQ settings and exit the adjustment session. If you enter an adjustment session and do not make any adjustments for 15 minutes, the adjustment session automatically clears.

Use the **Clear** button to read the current settings. Point the Flow-Set at the Flow-Set target and press the **Clear** button. A green lamp begins to flash indicating the signal was received. The flash sequence indicates the current flow index. The sequence occurs in two sets. The tens (1<sup>st</sup>) set uses long flashes to indicate the tens digit. The units (2<sup>nd</sup>) set uses short flashes to indicate the units digit. An extra long flash in the tens set or the units set indicates the value of the corresponding digit is zero.

- A flow index of 24 flashes two longs, then 4 shorts.
- A flow index of 89 flashes 8 longs, then 9 shorts.
- A flow index of 30 flashes 3 longs, then an extra long.
- A flow index of 04 flashes an extra long, then 4 short.
- A flow index of 100 flashes 10 longs, then an extra long.

Use the **On/Off** button to turn the motor on or off. Point the Flow-Set at the Flow-Set target on the equipment and press the **on/off** button. If you press **Enter** while the motor is off, the motor stays off, even through a power on/off cycle.

Adjust the flow index using the  $\uparrow\downarrow$  buttons. The  $\uparrow\downarrow$  button pair on the left adjusts the index  $\uparrow\downarrow$  10. The  $\uparrow\downarrow$  button pair on the right adjusts the flow index  $\uparrow\downarrow$ 1. Using the  $\uparrow\downarrow$ 10 pair, you can quickly move the index up and down. Using the  $\uparrow\downarrow$ 1 pair, you can precisely set the index to achieve the desired flow. During an adjustment session, the green lamp blinks each time you make a valid entry. If the flow index is already 100, and you try to increase the flow index, the green lamp does not blink, and the increase does not occur. If the flow index is at 91 and you press the  $\uparrow\downarrow$ 10 buttons, the green lamp does not blink and the increase does not occur because your entry would take the index above 100. When the flow index is greater than 90, use the  $\uparrow\downarrow$ 1 button to increase the index. The  $\uparrow\downarrow$ 1 and  $\uparrow\downarrow$ 10 keys respond in a like manner when you try to set the flow index below 1. (Zero is not a valid flow index).

#### **Batteries**

Two AA batteries power the EVO/IRC-Handheld Controller. (See Figure 10). Remove the sliding door on the back of the unit to expose the battery compartment. Remove the old batteries. Insert the new batteries in the position indicated by the battery pictures

molded into the bottom of the battery compartment. The battery spring clips are difficult, so you may need to use a small screwdriver to "shoehorn" the batteries into place.

For maximum battery life, store the EVO/IRC- Handheld Controller so the buttons are not pressed. While current drain is minimum when the unit is not sending infrared signals, some battery current is drawn to sense the pressed key.



Fan Filter Unit

#### Installation & Service Manual

#### Cleaning the LEDC Pre-filter (foam)

Tools Required: None.

Note: To keep the filter in top operating condition, washing the foam prefilter is recommended every three to six months.

**Step 1.** To gain access to the prefilter, remove the ceiling panel next to the unit, if applicable.

Step 2. Switch the ON-OFF switch to the off position.

**Step 3.** Remove the 20"x20" prefilter from the snap-in frame. (See Figure X)

Step 4. Clean the prefilter by hand washing in water with a mild detergent or by using a vacuum cleaner. Allow prefilter to dry completely before replacing.

Step 5. Reassemble by reversing the above steps.



Changing the LEDC Pre-filter (pleated)

Tools Required: None.

Note: To keep the filter in top operating condition replacing the pleated prefilter is recommended every twelve months or sooner.

Step 1. To gain access to the prefilter, remove the ceiling panel next to the unit, if applicable.

Step 2. Switch the ON-OFF switch to the off position.

**Step 3.** Remove the prefilter from the snap-in frame. The beverage frame has slots that have to be depressed to release the filter from the prefilter housing (See figure below)

**Step 4.** After removing the new G4 pleated prefilter from the box, remove the die cut slots from the beverage board frame and install on prefilter bracket.

Step 5. Reassemble by reversing the above steps.



WARNING DISCONNECT THE UNIT FROM THE ELECTRICAL POWER SOURCE BEFORE ATTEMPTING ANY SERVICE

ENVIRCO



Fan Filter Unit

#### Installation & Service Manual

#### Service: Removal and Replacement of Standard HEPA/ULPA Filters

WARNING DISCONNECT THE UNIT FROM THE ELECTRICAL POWER SOURCE BEFORE ATTEMPTING ANY SERVICE WARNING THE STANDARD FILTER IS PROTECTED WITH AN EXPANDED METAL FACE SCREEN. THIS IS NEVER TO BE USED TO HANDLE THE FILTER. IT IS ONLY FOR PROTECTION AGAINST AN ACCIDENTAL TOUCH OF THE FILTER. ONLY HANDLE THE FILTER BY THE FRAME.

Note: All filters should be visually inspected for freight damage before installation. It is necessary to use two workers when removing the filter and for installation to avoid twisting or separation of the media seals. Handle the filter only by the frame and never place anything on the upstream filter side of the filter. Additionally, it is important to keep the filter level to prevent any shearing force on the media itself.

#### For Standard Filters:

Tools Required: Phillips Head Driver, Battery Operated Drill with 5/32 drill bit, Rivet Hand Tool, Ø5/32 aluminum rivet grip range .126-.187

Step 1. Remove unit from ceiling.

Step 2. Remove the 10 screws holding the HEPA/ULPA filter to the lid assembly.

**Step 3.** Lift the lid assembly off the HEPA/ULPA filter (see Figure). Remove Filter deflectors using 5/32 drill bit. Keep filter deflectors to install in new filter. Discard the used filter as per requirements of the applicable regulations. Carefully install the filter deflectors into the new filter using the 5/32 rivets. Do not touch or place the filter deflectors on the HEPA/ULPA media pack. This could cause tears in the filter pack.

**Step 4.** Before replacing with the new filter, carefully inspect the new filter for any visible damage. Also inspect the gasket and the T-Bar to insure a tight seal. Replace if necessary.

**Step 5.** To replace filter, raise the filter and rotate into position in the ceiling grid (with power off), then lower the plenum housing into place. Reconnect wiring and hardware from previous steps that have been removed.

Step 6. Restore power and verify proper operation of FFU.



#### **Standard Filter Change**

Fan Filter Unit

#### Installation & Service Manual

#### Service: Removal and Replacement of RSR/E Filters

WARNING DISCONNECT THE UNIT FROM THE ELECTRICAL POWER SOURCE BEFORE ATTEMPTING ANY SERVICE WARNING THE STANDARD FILTER IS PROTECTED WITH AN EXPANDED METAL FACE SCREEN. THIS IS NEVER TO BE USED TO HANDLE THE FILTER. IT IS ONLY FOR PROTECTION AGAINST AN ACCIDENTAL TOUCH OF THE FILTER. ONLY HANDLE THE FILTER BY THE FRAME.

ENVIRCO

Note: All filters should be visually inspected for freight damage before installation. It is necessary to use two workers when removing the filter and for installation to avoid twisting or separation of the media seals. Handle the filter only by the frame and never place anything on the upstream filter side of the filter. Additionally, it is important to keep the filter level to prevent any shearing force on the media itself.

#### For RSR/E Filters:

Tools Required: Phillips Head Driver, Battery Operated Drill, 3/16" hex head ball driver (2ea)

**Step 1.** With the power off, remove the diffuser screen by removing the 6 each 10-32x1/2 screws, then carefully place in a safe location.

**Step 2.** Loosen the six 1/4x12 socket head screws far enough to rotate the eight filter clips 90°. The filter may be loose enough to drop during this operation. If not, slowly pull the filter away from the knife-edge seal, taking care not to touch the filter face during this operation. It is important to pull the filter slowly away from the seal, so that the gel remains in the filter gel track.

Step 3. Carefully clean plenum assembly knife edge surface of residual gel material.

Step 4. Inspect filter for visible damage, if damaged set aside for replacement or repair.

**Step 5.** Inspect the gel seal, if reinstalling the removed filter. Determine if the gel has lost its ability to seal (i.e. the gel should reform to cover the track without voids or openings), if so repair the gel material or consider replacement of filter.

**Step 6.** Place the filter evenly against the filter-sealing surface of the RSR unit. Reposition filter clips and screws. The clips should be rotated and angled into place. It is recommended that workers work on each corner of the filter simultaneously, holding the filter seated into the track. Hand tighten clips from opposite corners evenly until all clamps are tightened. **Step 7.** Reinstall diffuser screen by hand-tightening the screws.

**Step 8.** Determine if recertification or testing of replacement is required.

Step 9: Restore power to FFU and verify proper operation of FFU.



Innovators in Clean Air Technology | www.envirco.com | Operation & Maintenance


Fan Filter Unit

#### Installation & Service Manual

### Service: Standard and RSR Motor Removal and Installation

WARNING DISCONNECT THE UNIT FROM THE ELECTRICAL POWER SOURCE BEFORE ATTEMPTING ANY SERVICE WARNING ELECTRICAL SERVICE SHOULD ONLY BE PERFORMED BY A LICENSED OR QUALIFIED ELECTRICIAN.

Tools Required: Phillips Head Driver, Battery Operated Drill, (2) 8" adjustable wrenches, 10 mm hex head wrench, #2 screwdriver, and slip joint pliers

Step 1. To gain access to the motor, remove the ceiling panel next to the unit, if applicable.

Step 2. Switch the ON-OFF switch to the off position.

Step 3. Loosen the electrical box cover screws (2), and slide/lift off cover.

Step 4. Make note of all wire routing and locations for later reinstallation.

Step 5. Disconnect motor wire harnesses from the electrical box housing and remove the tubing for test port, if installed.

**Step 6.** Remove the eight mounting screws to free the motor/blower assembly from the lid assembly. If using power drivers, set the unit to a low torque setting to avoid stripping the sheet metal screws. Carefully remove housing assembly, paying attention to wire routing.

Step 7. Using an adjustable wrench loosen the two set screws that attach the blower wheel to the motor shaft.

**Step 8.** Mark the location of the motor support bracket (belly band), then loosen the bolt just enough to allow the motor support bracket to slid off the motor.

Step 9. Using the removed motor, mark the new motor with the location of the motor support bracket.

**Step 10.** Replace with the new motor and reassemble by reversing the above steps 1-8. Set the spacing at 0.25" (6.35 mm) clearance between the blower and the upper motor plate/prefilter frame. This will give a 0.11" overlap between the venturi ring and the blower.



Fan Filter Unit

## ENVIRCO Innovators in clean air technology

#### Installation & Service Manual

## Service: RSR/E Motor Removal and Installation

WARNING DISCONNECT THE UNIT FROM THE ELECTRICAL POWER SOURCE BEFORE ATTEMPTING ANY SERVICE WARNING ELECTRICAL SERVICE SHOULD ONLY BE PERFORMED BY A LICENSED OR QUALIFIED ELECTRICIAN.

#### Note: Minimum 2 person project.

Tools Required: 3/16 Ball Driver, Phillips screw bit, Head Driver, Battery Operated Drill, (2) 8" adjustable wrenches, 10 mm hex head wrench, #2 standard screwdriver, and slip joint pliers

Step 1. To gain access to the motor, remove the gel seal filter.

**Step 2.** Prior to removing motor/blower assembly, remove blower wheel to expose motor connectors on motor. Using an adjustable wrench loosen the two set screws that attach the blower wheel to the motor shaft. Disconnect both cable pin connectors from the motor.

**Step 3.** While supporting the motor blower assembly from below, remove the six screws on the underside of the venturi ring and lower the assembly. (See Figure 7). Note the baffle does not have to be removed to remove the motor/blower assembly. **Step 4.** Before removal of the motor mount bracket, measure the precise location of the bracket on the motor. Remove the bracket.

**Step 5.** Replace with the new motor and reassemble by reversing the above steps. Set the location of the motor mount bracket as measured (see above Step 6). Set the spacing at 0.25" (6.35 mm) clearance between the blower and the upper motor plate/prefilter frame creating a 0.11" (2.80 mm) overlap between the wheel and the venturi ring. When reinstalling the assembly, align the plate to insure that the leads will reach the electrical box.



## ENVIRCO Innovators in clean air technology

# MAC 10<sup>®</sup> LEDC

Fan Filter Unit

#### Installation & Service Manual

**TN1004** Changing from GE to Nidec Motors in the Field

#### TECHNICAL NOTE

• Changing out from GE 2.3 to Nidec PerfectSpeed DC Motors in the field The ENVIRCO DC family of Fan Filter Units has previously used the GE 2.3 motor that was purchased by Regal Beloit. The older models have GE 2.3 motors that have become obsolete and are replaced with the new Regal Beloit model EON. The EON motor is currently being evaluated and you will be receiving a new manufactured motor named Nidec PerfectSpeed.

When you order a replacement motor they will be a form and fit replacement, except for the cable that connects to the control board and the motor. The new Nidec motor will require you to replace the cable. The old cable was a sixteen pin connector while the new motor cable will have a four pin connector as shown in the photo to the right.

Please use the new cable with the new four pin connector to connect your new motor. The cable number will be determined by the build style of your unit.

New Cable Style

Nidec Part References 18 in Standard Build

18 in Standard Build	63751-015
12 in RSRE Build	63751-016
15 ft Whip	63751-017

#### Old Cable References

The power cable, has remained the same for the new motor and will be reused. The rest of the fit and function will be a direct replacement. Follow the procedure in the IOM for motor swap for your particular FFU.

#### Contact Us

Contact ENVIRCO sales or technical team for any assistance needed.





Fan Filter Unit

#### Installation & Service Manual

ENVIRCO Innovators in clean air technology

# **TN1004**

Changing from GE to Nidec Motors in the Field

#### TECHNICAL NOTES

#### MAC 10 Motor Cable Configurations





Fan Filter Unit

#### Installation & Service Manual

TN1002 MAC10<sup>®</sup> Design with VAV Boxes

#### TECHNICAL NOTE

MAC 10 designs with Duct Collar, VAV or constant air box and fan coils For applications requiring powered fan filter units and a ducted connection our recommendations would be to use the MAC10 LEDC (ECM motor) or Mac10 Original (PSC motor)

- Feature
- » MAC10 LEDC
- Power conservation and high airflow
- » MAC10 Original
- Lower unit cost
- Caution
- » MAC10 IQ is not recommend for the above design

For applications when you use a VAV box or Constant Airflow Terminal, Duct Collars or Fan coils. The design engineer must advise the contractor or air balancer that the air supply needs to be balanced. If you do not balance the air supply properly you have the potential to starve or over feed the fan with air causing the motor to stall which can damage the fan motor. This also can be minimized by notifying ENVIRCO beforehand for assistance. The ECM motors used in the IQ design are a Microprocessor controlled motor and are designed to maintain a constant air volume. When two controllers are compensating the air volume at the same time, the motor microprocessor is unable to stabilize the airflow and will shut itself down if it cannot find a stable operating point.

In addition to properly balancing the airflow to the Fan: you should prepare a sequence of operations turning on FFU's prior to energizing the Air Handler to prevent potential backward rotation of the blower wheel which can prevent motor rotating in the proper direction and will reduce airflow and cause eventual shutdown. The drive components inside the ECM motors are self-testing and sized for the motor being used inside the unit they can't compete with the airflows from a duct blower motor.



#### Installation & Service Manual

**ENVIRCO** Innovators in clean air technology

## Wiring Diagrams



**Universal Card Wiring Diagram** 



Fan Filter Unit

## Installation & Service Manual

## Wiring Diagrams



**Infrared Control** 



## **ENVIRCO** Innovators in clean air technology

## Installation & Service Manual

# Replacement Parts List

Model	Part Number	Description			
	24397-003	Motor - ECM 1/3 HP (Program Installed) 120V / 220V			
MAC 10 LEDC 2X2 1/3HP	24397-004	Motor - ECM 1/3 HP (Program Installed) 277V			
	24397-012	Motor - ECM 1/3 HP (Program Installed) 120V / 220V			
MAC 10 LEDC 2X4 1/3HP	24397-013	Motor - ECM 1/3 HP (Program Installed) 277V			
	24504-001	Motor Blower 2X4 120V			
	24504-001	Motor Blower 2X4 220V			
	24504-001	Motor Blower 2X4 - CE 220V			
	24504-002	Motor Blower 2X4 277V			
	24397-012	Motor 2X4 120/240			
	24397-013	Motor 2X4 277V			
	24397-003	Motor 2X2 120/240V			
	24397-004	Motor 2X2 277V			
	63720	Choke 3.0AMPS 120V			
	63667	Transformer 120V			
	63666	Transformer 220V - CE 24VAC			
	63666	Transformer 208-240V			
	63665	Transformer 277V 24VAC			
	38511-001	Motor Mount Clip			
MAC TO LEDG STD	62964	Venturi Ring			
	64015	Blower Wheel			
	63751-015	Motor Harness, 18" (Standard build)			
	63751-016	Motor Harness, 12" (RSRE only )			
	63751-017	Motor Harness, 15 FT			
	63759-001	IR Sensor Harness			
	63758	IR Sensor Harness without Sensor			
	63951-002	Visual Control Unit - EVO			
	62981-038	Foam Prefilter 20 X 20 X .5 - MERV 4			
	64125-001	30/30 Prefilter 20 X 20 X 20 - MERV 8			
	63970	MODBUS Card 1004/4			
	63970-003	MODBUS Card 1014.1.32 REV			
	63415-003	Pressure Switch			
	265888	Universal Card CON4			
	S266587-007	2x4 Motor Asm 120/240V - Nidec			
	S266587-008	2x4 Motor Asm 277V - Nidec			
	S266587-009	2x3 Motor Asm 120/240V - Nidec			
MAC 10 LEDC / NIDEC	S266587-010	2x3 Motor Asm 277V - Nidec			
MAC TO LEDC / NIDEC	S266587-017	2x4 RSRE Motor Asm 120/240V - Nidec			
	S266587-018	2x4 RSRE Motor Asm 277V - Nidec			
	S266587-019	2x3 RSRE Motor Asm 120/240V - Nidec			
	S266587-020	2x3 RSRE Motor Asm 277V - Nidec			
	63739-002	Switch, Rocker Dpst Wht/Wht			
	63752-001	IQ Motor Harness, 5-pin 120v 15" LONG (W/ YEL JUMPER), STD, RSR			
	38532-001	Deflector - Filter, 2x4			
MAC 10 IQ	62968	Gasket, Neop .125x.5			
	63388	Grommet 5/8 ld 1 1/8 Od			
	94800-001	Carton, MAC10			
	94801-014	Insert, Cardboard			



Fan Filter Unit









#### Installation & Service Manual





Fan Filter Unit

#### Installation & Service Manual

#### Limted Warranty

LIMITED WARRANTY: Unless otherwise expressly stated in ENVIRCO's published specifications for the Goods, ENVIRCO warrants that Goods are free from defects in material and workmanship, except for services which are warranted to be performed in a competent and diligent manner in accordance with any mutually agreed specifications. The foregoing warranty shall apply for eighteen (18) months from the date of shipment from ENVIRCO's facility, except for services for which the warranty shall apply for ninety (90) days from the date of performance (the "Warranty Period"). Provided Buyer informs ENVIRCO in writing of any breach of warranty prior to the expiration of the applicable Warranty Period, ENVIRCO shall, as its sole obligation and Buyer's sole and exclusive remedy for any breach of this warranty, repair or replace/re-perform the Goods which gave rise to the breach or, at ENVIRCO' option, refund the amounts paid by Buyer for the Goods which gave rise to the breach. Any repair, replacement or re-performance by ENVIRCO hereunder shall not extend the applicable Warranty Period. The parties shall mutually agree on the specifications of any test to determine the presence of a defect. Unless otherwise agreed upon by ENVIRCO in writing, Buyer shall bear the costs of access, de-installation, re-installation and transportation of Goods to ENVIRCO and back to Buyer. These warranties and remedies are conditioned upon (a) the proper storage. installation, operation, and maintenance of the Goods and conformance with the proper operation instruction manuals provided by ENVIRCO or its suppliers or subcontractors, (b) Buyer keeping proper records of operation and maintenance during the applicable Warranty Period and providing ENVIRCO access to those records, and (c) modification or repair of the Goods only as authorized by ENVIRCO. ENVIRCO does not warrant the Goods or any repaired or replacement parts against normal wear and tear or damage caused by misuse, accident, or use against the instructions of ENVIRCO. Any modification or repair of any of the Goods not authorized by ENVIRCO shall render the warranty null and void. EXCEPT AS EXPRESSLY SET FORTH HEREIN, ENVIRCO MAKES NO OTHER WARRANTIES. EXPRESS OR IMPLIED. INCLUDING. BUT NOT LIMITED TO. ANY IMPLIED WARRANTIES OF MERCHANTABILITY, NON-INFRINGEMENT OR FITNESS FOR A PARTICULAR PURPOSE WHICH ARE HEREBY DISCLAIMED TO THE EXTENT PERMITTED BY APPLICABLE I AW.

#### Testing

Each MAC 10 LEDC filter unit is thoroughly tested at the factory before shipment. However, because of the "rigors" of shipping, ENVIRCO encourages its re-test after installation.

ENVIRCO recommends that the customer contact an independent organization, with technicians trained and experienced in performance evaluation and maintenance of clean air equipment.

HEPA filters (Type J) are tested to IEST-RP-00034. ULPA filters are tested to (Type F) IEST-RP-00034. All filters are UL 900 recognized. Your filters may have special requirements, please see original engineering specifications for you specific project.

All units that are airflow tested at ENVIRCO are tested using a Shortridge Airdata Multimeter 870 with a Velgrid head. The recommended method of reading is to place one corner of the Velgrid head 1-1/4" from the corner of the filter face and then take four reading evenly spaced along the four foot side, then repeat these reads three additional times. This gives a total of 8 reading to test the unit. All advertised data is based on using the Velgrid with 8 readings (128 velocity points). ENVIRCO recognized the using 8 reading during a cleanroom start-up may be time consuming and recommends using 4 Velgrid readings taken on each 2x2 filter section will approximate the same as 8 readings.

Additional independent testing on the ENVIRCO Mac 10 2x4, 2x2, 2x3, and 2x3<sup>1</sup>/<sub>2</sub> shows that using one-2x4 or two-2x2 hoods simultaneously give airflow data (cfm) with 5 percent of a duct traverse using 10 diameters of straight duct upstream of the fan intake.

# Clean air solutions built for you. MORE INFORMATION AVAILABLE AT WWW.ENVIRCO.COM

#### Industrial

#### **Cleanroom Products**

- » MAC 10<sup>®</sup> Original
- » MAC 10<sup>®</sup> IQ™
- » MAC 10<sup>®</sup> IQ<sup>™</sup> LAF
- » MAC 10<sup>®</sup> LEAC<sup>™</sup>
- » MAC 10<sup>®</sup> LEAC2™
- » MAC 10<sup>®</sup> LEDC™
- » Ducted Ceiling Module: DCM & RSR
- » AC or DC Control Systems
- » MAC-T Ceiling Grid System

**Hospital & Healthcare Hospital & Healthcare** 

- » IsoClean<sup>®</sup> and IsoClean with Ultraviolet Light
- » AirCeil®
- » Hospi-Gard<sup>®</sup> Room **Pressure Monitor**
- **Enviramedic Products**
- » HOR Horizontal Flow Enclosure
- **HCF Horizontal Flow** Surgery Room
- » VOR Vertical Flow Surgery Isolator

#### **Pharmaceutical Pharmaceutical & Medical Device**

- » Unimodule M2 Vertical Laminar Flow Workstation
- » METD 100% Exhausted Vertical Flow Workstation
- » Laminar Downflow Module

## Laboratory & Research Laboratory & Research

- » 100-Plus Horizontal or Vertical Flow Clean Bench
- » Unidirectional Flow
- Horizontal Flow Bench (LF)
- TT Table Top Horizontal
- Flow Clean Bench
- EnviraLab Sterility Module: ESM

**ENVIRCO**<sup>®</sup> Innovators in clean air technology

101 McNeill Road | Sanford, NC 27330, USA tel: 919.775.2201 | toll free: 800.884.0002 | fax: 800.458.2379 www.envirco.com | email: info@envirco.com

## **ENVIRCO®**

# MECHANICAL FAUCETS 201-AGN8AE35-319AB

# Manual Faucets

#### **Product Type**

Deck Mounted 8" Fixed Centers Concealed Hot and Cold Water Sink Faucet

#### **Features & Specifications**

- 8" Fixed Centers
- 8" Rigid / Swing Gooseneck Spout
- 1.5 GPM (5.7 L/min) Aerator
- 6" Elbow Blade Handle
- Quaturn Compression Operating Cartridge

• 1/2" NPSM Supply Inlets and Coupling Nut for 3/8" or 1/2" Flexible Riser

- ECAST® design provides durable construction with total lead content
- equal to or less than 0.25% by weighted average
- CFNow! Item Ships in 3 Days

#### **Performance Specification**

- Rated Operating Pressure: 20-125 PSI
- Rated Operating Temperature: 40-140°F

#### Warranty

- Lifetime Limited Faucet Warranty
- 5-Year Limited Cartridge Warranty
- 1-Year Limited Finish Warranty

#### **Codes & Standards**

- ASME A112.18.1/CSA B125.1
- · Certified to NSF/ANSI 61, Section 9 by CSA
- California Health and Safety Code 116875 (AB1953-2006)
- Vermont Bill S.152
- NSF/ANSI 372 Low Lead Content
- ADA ANSI/ICC A117.1
- CALGreen







ECAST products are intended for installation where state laws and local codes mandate lead content levels or in any location where lead content is a concern.

2100 South Clearwater Drive Des Plaines, IL P: 847/803-5000 F: 847/803-5454 Technical: 800/TEC-TRUE www.chicagofaucets.com





a Geberit company

# 201-AGN8AE35-319AB Manual Faucets



a Geberit company

#### **Architect/Engineer Specification**

Chicago Faucets No. 201-AGN8AE35-319AB, Sink Faucet for hot and cold water, concealed deck-mount with 8" fixed centers, chrome plated. Rigid/swing gooseneck spout, 8" center-to-center. 1.5 GPM (5.7 L/min) pressure compensating Softflo aerator. 6" metal elbow blade handles with sixteen-point, tapered broach and secured blue and red index buttons. Quaturn<sup>™</sup> rebuildable compression cartridge, opens and closes 90°, closes with water pressure, features square, tapered stem. 1/2" NPSM supply inlets and coupling nut for 3/8" or 1/2" flexible riser. Mounting hardware included. ECAST® construction with less than 0.25% lead content by weighted average. CALGreen compliant. This product meets ADA ANSI/ICC A117.1 requirements and is tested and certified to industry standards: ASME A112.18.1/CSA B125.1, Certified to NSF/ANSI 61, Section 9 by CSA, California Health and Safety Code 116875 (AB1953-2006), Vermont Bill S.152, NSF/ANSI 372 Low Lead Content, and California Green Building Standards Code (CALGreen).



#### **Operation and Maintenance**

Installation should be in accordance with local plumbing codes. Flush all pipes thoroughly before installation. After installation, remove spout outlet or flow control and flush faucet thoroughly to clear any debris. Care should be taken when cleaning the product. Do not use abrasive cleaners, chemicals or solvents as they can result in surface damage. Use mild soap and warm water for cleaning and protecting the life of Chicago Faucet products. For specific operation and maintenance refer to the installation instructions and repair parts documents that are located at <a href="https://www.chicagofaucets.com">www.chicagofaucets.com</a>.

Chicago Faucets, member of the Geberit Group, is the leading brand of commercial faucets and fittings in the United States, offering a complete range of products for schools, laboratories, hospitals, office buildings, food service, airports and sport facilities. Call 1.800.TECTRUE or 1.847.803.5000 Option 1 for installation or other technical assistance.



2100 South Clearwater Drive Des Plaines, IL P: 847/803-5000 F: 847/803-5454 Technical: 800/TEC-TRUE www.chicagofaucets.com



#### PRODUCT DATA SHEET

# USP 797 Introduction

#### A Second Generation FFU

While ENVIRCO<sup>®</sup> has introduced a variety of proprietary products, one of its most successful continues to be the MAC 10<sup>®</sup> family of fan filter units (FFUs). We add to this industry's leading line of products a second generation FFU, the MAC 10<sup>®</sup> LEDC, which features the most control options and the most versatile control system available on the market today.

#### **A Green Product Solution**

The MAC 10<sup>®</sup> LEDC FFU helps provide opportunities to earn LEED\* with its energy-saving features. *Note: LEED (Leadership in Energy and Environmental Design) is the rating system of US Green Building Council which building designs are certified.* 



By taking advantage of a unique combination of EC motor technology coupled with ENVIRCO's proprietary baffling system and backward inclined fan, the LEDC leads the industry in energy-efficiency. Its electronically commutated (EC) motor with internal microprocessor offers high performance and delivers long motor life with energy consumption rates as low as 90W @ 90 fpm.

Utilizing ENVIRCO's experience in FFU development, the LEDC also features low sound levels of 52 dBA, which are a MAC 10<sup>®</sup> family benchmark.

ENVIRCO<sup>®</sup> MAC 10<sup>®</sup> FFUs are used worldwide for a variety of critical clean air applications. Learn more about how you can benefit from the LEDC in your next critical room application. Contact your local ENVIRCO<sup>®</sup> representative or visit us on the web at www.envirco.com.

#### Standard Features

- » New Universal Control Card
  - Network Speed Control, MODBUS RTU
  - Manual Speed Control, On-Board Potentiometer
  - Analog Speed Control, Remote 0-10V
- » Electronically Commutated (EC) brushless motor with internal microprocessor
- » High Efficiency Particulate Air (HEPA) Filter: 99.99% efficient
   @ 0.3 micron
- » 1.0 in. wg (200 Pa) of external static capability
- » Backward-inclined centrifugal fan
- » Walkable plenum (excluding prefilter), rated to 250 lbs.
- » Washable pre-filter
- » Manufactured to IEST recommended practices
- » Available in 2 x 2, 2 x 3, 2 x 4 and 4 x 4 sizes
- » cUL listed (115V, 208-240V, 277V) with standard UL 900 filter, File number E152685 (UL507)
- » Mill finished aluminum exterior

#### Optional Features

- » Room-side Replaceable Filter (RSR)
- » Room-side Replaceable Filter and Motor Assembly (RSRE)
- » Infrared Speed Control: Room-side airflow adjustment with a hand-held remote control
- » Ducted Inlet Connection (shipped loose)
  - 10" (254 mm)
  - 12" (305 mm)
  - 14" (356 mm)
- » Direct connection to air conditioning supply
- » Flow-through light fixture provides illumination with minimal airflow disruption
- » Powder coat white paint or stainless steel housing
- » Room-side 3/8" Challenge Ports: Convenient aerosol challenge and HEPA filter testing. Standard on RSE and RSRE units
- » CE certified on 230V units
- » ULPA 99.9995% at 0.12 micron PTFE and low boron.
- » 3/4" Knife Edge: Permits easy placement in gel track ceiling grid system (available on RSR and RSRE units only)
- » Pleated MERV 8 pre-filter available



#### PRODUCT DATA SHEET

#### Dimensions





#### Performance MAC 10<sup>®</sup> LEDC

Nominal Unit Size	Active Filter Face Area (Sq. Ft.)	Max. CFM	Watts @ Max. CFM	CFM @ 90 FPM	Watts @ 90 FPM	Sound dBA @ 90 FPM	Unit Weight	Dimensions AxBxC (in)
2x4 LEDC	7.2	950	250	650	90	52	66	23.63 x 47.63 x 14.32 (600 x 1210 x 364)
2x3 LEDC	5.3	650	150	470	65	47	52	23.63 x 35.63 x 14.32 (600 x 905 x 364)
2x2 LEDC*	3.5	410	145	315	85	46	41	23.63 x 23.63 x 14.32 (600 x 600 x 364)
2x4 LEDC RSR/RSRE	5.3	850	240	477	65	47	71	23.63 x 47.63 x 16.43 (600 x 1210 x 417)
2x3 LEDC RSR/RSRE	3.8	650	150	340	45	43	54	23.63 x 35.63 x 16.43 (600 x 905 x 417)
2x2* LEDC RSR/RSRE	2.3	350	130	210	50	46	44	23.63 x 23.63 x 16.43 (600 x 600 x 364)

\* All 2 x 2 units will be built with a forward curve fan utilizing the same technology as the MAC10<sup>®</sup> IQ sold today. Weights above are for aluminum units. For RSRE units, add 5 lbs. For stainless steel units, add 10 lbs.

#### Notes:

Performance tested in accordance with the (ANSI/AMCA 210-07), (ANSI/ASHRAE 51-07) test standards for Certified Aerodynamic Performance Rating. Max CFM rating based on free air volumes @ high speed motor setting. 90 fpm values based on active filter face area. BTU = Watts x 3.413.

#### MAC 10® LEDC:

MAC 10<sup>®</sup> LEDC 115V, 50/60HZ 1 Phase = 2.75 F.L.A., 208-240V 50/60HZ 1 Phase = 1.75 F.L.A., 277V 60 HZ 1 Phase = 1.35 F.L.A. MAC 10<sup>®</sup> LEDC 2x2 115V-5.0 F.L.A. 2x2 208-240V 33.0 FL.A. 277V 2.5 F.L.A

ENVIRCO USA | 101 McNeill Road | Sanford, NC 27330 | Tel: 919.775.2201 | Toll Free: 800.884.0002 | Fax: 800.458.2379 | www.envirco.com | info@envirco.com

© 2017 ENVIRCO<sup>®</sup>. ENVIRCO<sup>®</sup> is a registered trademark of Air System Components, Inc. Air System Components, Inc. is a subsidiary of Johnson Controls Inc. All product specifications reflect available information at the printing of this brochure. ENVIRCO<sup>®</sup> reserves the right to revise or modify products and/or specifications without notice.



# AXION<sup>®</sup> MSR Sink Mount Eye/Face Wash

## FEATURES & BENEFITS

#### VALVE

Units pull-down to activate design produces a full continuous flow of water and provides an easy start to the irrigation process.

#### SAFETY

8" x 10-3/4" (20.3 x 27.3 cm) universal emergency sign make the unit easily detected in an emergency. Test card to record weekly checks helps maintain the unit's best working quality.

#### MOUNTING

Unit mounts at the back of sink, or on a wall so when the unit is not in use, it is as far out of the way as possible.

#### **EYE/FACE WASH**

AXION® MSR eye/face wash head (patent pending) uses an inverted directional laminar flow to sweep contaminants away from the vulnerable nasal cavity.

#### **OPTIONS**

- Test Tag: SP170 is a green waterproof test card with space for date and initials of inspector. Used to record weekly testing of emergency equipment.
- Emergency Alarm System : Model 9001.5, 1/2" 120 VAC emergency alarm and light system. Buzzer and flashing light are activated by a 1/2" IPS double pole, double throw flow switch.
- □ Thermostatic Mixing Valve: Model 9201EFE AXION® Emergency Tempering Valve thermostatically mixes hot and cold water to provide a safe fluid supply for a single emergency eye/face wash, with a flow rate of 12 gpm (38.8 L).
- □ Thermostatic Mixing Valve: Model 9201EW AXION® Emergency Tempering Valve thermostatically mixes hot and cold water to provide a safe fluid supply for a single emergency eye/face wash, with a flow rate of 10 gpm (38.8 L).

For more information, visit www.hawsco.com or call (888) 640-4297.



## **SPECIFICATIONS**

Model 7610 barrier-free sink/counter top or wall mount eye/face wash with AXION® MSR eye/face wash head with inverted directional laminar flow for Zero Vertical Velocity™ supplied by an integral 4.2 gpm flow control. Also included; polished chrome brass single action pull-down valve body, wheelchair accessibility, universal sign, and 1/2" O.D. (1.3 cm) slip joint inlet.

## **APPLICATIONS**

Where safety is of the utmost importance and the eyes of any person may be exposed to injurious or corrosive materials, suitable facilities for quick flushing and cleansing of the eyes must be provided within the work area for immediate emergency use. When installed properly, the stable construction, counter top design of the 7610 is space efficient with its rear mounting location, and can accommodate barrier-free access.Model is certified by CSA to meet the ANSI Z358.1 Standard for Emergency Eyewash and Shower Equipment.





©2016 Haws Corporation - All Rights Reserved. HAWS<sup>®</sup> and other trademarks used in these materials are the exclusive property of Haws Corporation.





## **NOTES:**

- 1. WHEN INSTALLING THIS UNIT, LOCAL, STATE, OR FEDERAL CODES SHOULD BE ADHERED TO FOR INSTALLATION DIMENSIONS (LOCATIONS), WASTE AND SUPPLY REQUIREMENTS OTHER THAN SHOWN.
- 2. THE ANSI Z358.1-2009 STANDARD SPECIFIES EYEWASH NOZZLE HEIGHTS TO BE 83.8cm (33 IN.) TO 114.3cm (45 IN.) ABOVE THE FLOOR AND 15.3cm (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.
- 3 DRILL ONE Ø7/8" [22mm] HOLE AND ONE Ø3/32" HOLE WHERE UNIT IS TO BE INSTALLED. REFER TO MOUNTING HOLE DETAIL.
- 4. THESE DIMENSIONS MAY VARY ±1/2" [6.4mm].

5 ASSEMBLE EYE/FACE WASH TO ARM, ORIENT TAB ON ASSEMBLY AWAY FROM USER.



DRAWING TYPE

INSTALLATION

2 OF

©2016 Haws Corporation - All Rights Reserved. HAWS<sup>®</sup> and other trademarks used in these materials are the exclusive property of Haws Corporation.

**NOTES:** 

# 7610 DECK MOUNTED CONFIGURATION

(SEE SHEET 1 FOR 7610 DECK MOUNTED CONFIGURATION) (SEE SHEET 2 FOR 7610 WALL MOUNTED CONFIGURATION)



©2016 Haws Corporation - All Rights Reserved. HAWS® and other trademarks used in these materials are the exclusive property of Haws Corporation.



6.07 Gallon Capacity\* \*CAPACITY MATTERS Max I.D. sizing with straight sided, non-tapered bowl confiuration. Tight corner radius design. Capacitybased on 6-1/2" bowl depth.

Seamless die-drawn construction of 18 gauge type 304 stainless steel. Interior and top surfaces satin blended No. 4 finish. Fully coated under-side insulates for sound and reduces condensation. Straight sided compartment with 1-3/4" radius corners provides greater capacity. Self-rimming top mount with Grip-Rim Plus with stainless steel mounting channels. DIntegra Drain integral drain system.



Integra Drain - seamlessly welded to sink creates integral drain in sink, without additional parts or rings. Reduces installation issues and leak potential. Includes basket strainer and tailpiece. Flat grid available in place of basket, specify I-SSF option.

CUTOUT DIMENSIONS				
Model Number	Front-to-Back	Left-to-Right		
SLN-ADA-2019-A-GR 19-1/4 18-1/4				
Cutout dimensions shown (Front-to-Back) x (Left-to-Right) - corners may be				

square or up to 1/2" radius.

APPROVED FOR MANUFACTURING MODEL NO.: SLN-ADA-2019-A-GR QTY:	<sup>1</sup> <u>DISPOSER SINKS DISCLAIMER NOTE:</u> Just Integra Drain sinks are designed for compatible disposers manufactured by InSinkErator® which utilizes the Quick Lock® mounting system. Use of other disposers may void the Just warranty. InSinkErator® and Quick Lock® are trademarks of Emerson Electric Co.
JOB NAME: TAG/ITEM:	
CUSTOMER:SIGNATURE:	JUST MFG. COMPANY CONTINUES TO MAKE QUALITY AND FUNCTIONALITY A MARK OF THE JUST PRODUCT LINE. WE RESERVE THE RIGHT TO CHANGE PRODUCT INFORMATION WITHOUT NOTICE. DIMENSIONS MAY CHANGE AND MAY BE SUBJECT TO CHANGE WITHOUT NOTICE. NO RESPONSIBILITY IS A SSUMED FOR USE OF SUPERCEDED OR VOIDED DATA. JUST MFG. CO. SINKS ARE MADE IN THE USA & A JONG WITH FEATURES AND DIMENSIONS
JUST MANUFACTURING COMPANY PH: 847-678-5150 FAX: 847-678-6817	9233 KING STREET . FRANKLIN PARK . ILLINOIS . 60131-2111 E-MAIL: custserv@justmfg.com . www.justmfg.com

## ADA COMPLIANT INTEGRA DRAIN - SINGLE BOWL LEDGE TYPE - 18 GA.

SLN-ADA-2019-A-GR





Faucot					
I aucei	Hole Punchin				
(1) Hole	Centered				
(2) Holes on 4" centers					
(3) Holes on 4 "centers(illustrated)					
Alternate Punching: Faucet Model:			Punching requir	red:	
DEPTH - MUST BE SPECIFIED:					
4-1/2" DEEP	5" DEEP	5-1/2" DEEP	6" DEEP	6-1/2" DEEP	
	(1) Hole (2) Hole (3) Hole Alternato Faucet N PTH - I 4-1/2" DEEP	(1) Hole Centered (2) Holes on 4" centers (3) Holes on 4 "centers(ill Alternate Punching: Faucet Model: PTH - MUST BE SPEC 4-1/2" 5" DEEP DEEP P	(1) Hole Centered (2) Holes on 4" centers (3) Holes on 4 "centers(illustrated) Alternate Punching: Faucet Model: PTH - MUST BE SPECIFIED: 4-1/2" 5" 5-1/2" DEEP DEEP Product Opt	(1) Hole Centered         (2) Holes on 4" centers         (3) Holes on 4 "centers(illustrated)         Alternate Punching: Faucet Model:         PTH - MUST BE SPECIFIED:         4-1/2"       5"         5-1/2"       6"         DEEP       DEEP         Product Options	

I-SSF Integra St. Stl. Flat Grid -GB Garbage disposal outlet<sup>1</sup>

C 2014-2016-JUST MFG CO